

## Attachment 1 (Derivation of ACE NITS Charge)

**ATLANTIC CITY ELECTRIC**  
Proposed Transmission Rate Design  
Formula Rate Effective September 1, 2022

Line

1	Transmission Service Annual Revenue Requirement	\$	210,153,068
2	Less Total Schedule 12 TEC Included in Line (1)	\$	(10,897,285)
3	ACE Customer Share of Schedule 12 TEC included in Line 2	\$	6,052,840
4	Total Transmission Costs Borne by ACE Customers	<u>\$</u>	<u>205,308,623</u>
5	2022 ACE Network Service Peak		2,631
6	2022 Network Integration Transmission Service Rate (per MW Per Year)	<u>\$</u>	<u>78,034.44</u>

**PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for ACE Projects**

	<b>Required Transmission Enhancement per PJM website</b>	<b>PJM Upgrade ID per PJM spreadsheet</b>	<b>June 2022 - May 2023 Annual Revenue Requirement per PJM website</b>	<b>ACE Zone Share per PJM Open Access Transmission Tariff</b>	<b>ACE Zone Charges</b>
7	Upgrade AE portion of Delco Tap	b0265	\$ 443,066	89.87%	\$ 398,183
8	Replace Monroe 230/69 kV TXfms	b0276	\$ 678,062	91.28%	\$ 618,935
9	Reconductor Union - Corson 138 kV	b0211	\$ 1,153,534	65.23%	\$ 752,450
10	New 500/230 Kv Sub on Salem-East Windsor (>500 kV portion)	b0210.A	\$ 1,153,776	1.67%	\$ 19,268
11	New 500/230 Kv Sub on Salem-East Windsor (>500 kV portion)	b0210.A_dfax	\$ 1,153,776	78.34%	\$ 903,868
12	New 500/230kV Sub on Salem-East Windsor (< 500kV) portion <sup>2</sup>	b0210.B	\$ 1,645,369	65.23%	\$ 1,073,274
13	Reconductor the existing Mickleton - Goucestr 230 kV circuit (AE portion)	b1398.5	\$ 419,717	0.00%	\$ -
14	Build second 230kV parallel from Mickleton to Gloucester	b1398.3.1	\$ 1,307,433	0.00%	\$ -
15	Upgrade to Mill T2 138/69 kV transformer	b1600	\$ 1,556,923	88.83%	\$ 1,383,015
16	Orchard-Cumberland Install 2nd 230 kV line	b0210.1	\$ 1,379,652	65.23%	\$ 899,947
17	Corson Upgrade 138kV Line trap	b0212	\$ 5,978	65.23%	\$ 3,899
<b>Total</b>			<b>\$10,897,285</b>		<b>\$6,052,840</b>

Attachment 2A – Atlantic City Electric Company Tariff Sheets

Attachment 2B – Public Service Electric and Gas Company Tariff Sheets

Attachment 2C – Jersey Central Power & Light Company Tariff Sheets

Attachment 2D – Rockland Electric Company Tariff Sheets

Attachment 2A – Atlantic City Electric Company Tariff Sheets

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 5****RATE SCHEDULE RS  
(Residential Service)****AVAILABILITY**

Available for full domestic service to individually metered residential customers, including rural domestic customers, engaged principally in agricultural pursuits.

	<b>SUMMER</b> June Through September	<b>WINTER</b> October Through May
<b>Delivery Service Charges:</b>		
Customer Charge (\$/Month)	\$6.25	\$6.25
<b>Distribution Rates (\$/kWh)</b>		
First Block (Summer <= 750 kWh; Winter <= 500kWh)	\$0.072624	\$0.066071
Excess kWh	\$0.085307	\$0.066071
<b>Non-Utility Generation Charge (NGC) (\$/kWh)</b>	See Rider NGC	
<b>Societal Benefits Charge (\$/kWh)</b>		
Clean Energy Program	See Rider SBC	
Universal Service Fund	See Rider SBC	
Lifeline	See Rider SBC	
Uncollectible Accounts	See Rider SBC	
<b>Transition Bond Charge (TBC) (\$/kWh)</b>	See Rider SEC	
<b>Market Transition Charge Tax (MTC-Tax) (\$/kWh)</b>	See Rider SEC	
<b>Transmission Service Charges (\$/kWh):</b>		
Transmission Rate	\$0.032305	\$0.032305
Reliability Must Run Transmission Surcharge	\$0.000000	
Transmission Enhancement Charge (\$/kWh)	See Rider BGS	
<b>Basic Generation Service Charge (\$/kWh)</b>	See Rider BGS	
<b>Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)</b>	See Rider RGGI	
<b>Infrastructure Investment Program Charge</b>	See Rider IIP	
<b>Conservation Incentive Program Recovery Charge</b>	See Rider CIP	

**CORPORATE BUSINESS TAX (CBT)**

Charges under this rate schedule include a component for Corporate Business Taxes as set forth in Rider CBT.

**NEW JERSEY SALES AND USE TAX (SUT)**

Charges under this rate schedule include a component for New Jersey Sales and Use Tax as set forth in Rider SUT.

Date of Issue:

Effective Date:

Issued by:

**ATLANTIC CITY ELECTRIC COMPANY**

**BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 11**

**RATE SCHEDULE MGS-SECONDARY  
(Monthly General Service)**

**AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer delivered at one point and metered at or compensated to the voltage of delivery. This schedule is not available to residential customers.

	<b>SUMMER</b> June Through September	<b>WINTER</b> October Through May
<b>Delivery Service Charges:</b>		
Customer Charge		
Single Phase	\$11.90	\$11.90
Three Phase	\$13.84	\$13.84
<b>Distribution Demand Charge (per kW)</b>	\$3.26	\$2.67
<b>Reactive Demand Charge</b> (For each kvar over one-third of kW demand)	\$0.64	\$0.64
<b>Distribution Rates (\$/kWh)</b>	\$0.061959	\$0.054818
<b>Non-Utility Generation Charge (NGC) (\$/kWh)</b>	See Rider NGC	
<b>Societal Benefits Charge (\$/kWh)</b>		
Clean Energy Program	See Rider SBC	
Universal Service Fund	See Rider SBC	
Lifeline	See Rider SBC	
Uncollectible Accounts	See Rider SBC	
<b>Transition Bond Charge (TBC) (\$/kWh)</b>	See Rider SEC	
<b>Market Transition Charge Tax (MTC-Tax) (\$/kWh)</b>	See Rider SEC	
<b>CIEP Standby Fee (\$/kWh)</b>	See Rider BGS	
<b>Transmission Demand Charge (\$/kW for each kW in excess of 3 kW)</b>	\$6.48	\$6.10
<b>Reliability Must Run Transmission Surcharge (\$/kWh)</b>	\$0.000000	
<b>Transmission Enhancement Charge (\$/kWh)</b>	See Rider BGS	
<b>Basic Generation Service Charge (\$/kWh)</b>	See Rider BGS	
<b>Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)</b>	See Rider RGGI	
<b>Infrastructure Investment Program Charge</b>	See Rider IIP	
<b>Conservation Incentive Program Recovery Charge</b>	See Rider CIP	

The minimum monthly bill will be \$11.90 per month plus any applicable adjustment.

**Date of Issue:**

**Effective Date:**

**Issued by:**

**RATE SCHEDULE MGS-SEVC**  
**(Monthly General Service - Secondary Electric Vehicle Charging)**

**AVAILABILITY**

This is a transitional Rate Schedule, available only to publicly-accessible direct current fast charging ("DCFC") stations or sites at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer delivered at one point and metered at or compensated to the voltage of delivery. This schedule is for secondary voltage only. The charging location DCFC chargers must be energized and operational for charging greater than 95% up time each calendar year to be eligible for this rate schedule.

This schedule is not available to residential customers. This schedule is not available to commercial and industrial customers who install DCFC chargers that are not publicly-accessible. This schedule is not available to DCFC installations that are installed behind the meter of a new or existing customer premise.

Each Charging Location is limited to 1000 kilowatts ("kW") of service capacity.

This Rate Schedule will be closed as of December 31, 2024. Any customers on this Rate Schedule at that time will be transferred to Monthly General Service Secondary in the following billing cycle.

	<b>SUMMER</b>	<b>WINTER</b>
	June Through September	October Through May
<b>Delivery Service Charges:</b>		
Customer Charge		
Single Phase	\$9.96	\$9.96
Three Phase	\$11.59	\$11.59
<b>Distribution Demand Charge (per kW)</b>	\$0.00	\$0.00
<b>Reactive Demand Charge</b>	\$0.00	\$0.00
(For each kvar over one-third of kW demand)		
<b>Distribution Rates (\$/kWh)</b>	\$0.109000	\$0.109000
<b>Non-Utility Generation Charge (NGC) (\$/kWh)</b>	See Rider NGC	
<b>Societal Benefits Charge (\$/kWh)</b>		
Clean Energy Program	See Rider SBC	
Universal Service Fund	See Rider SBC	
Lifeline	See Rider SBC	
Uncollectible Accounts	See Rider SBC	
<b>Transition Bond Charge (TBC) (\$/kWh)</b>	See Rider SEC	
<b>Market Transition Charge Tax (MTC-Tax) (\$/kWh)</b>	See Rider SEC	
<b>CIEP Standby Fee (\$/kWh)</b>	See Rider BGS	
<b>Transmission Demand Charge (\$/kW for each kW in excess of 3 kW)</b>	\$6.48	\$6.10
<b>Reliability Must Run Transmission Surcharge (\$/kWh)</b>	\$0.000000	
<b>Transmission Enhancement Charge (\$/kWh)</b>	See Rider BGS	
<b>Basic Generation Service Charge (\$/kWh)</b>	See Rider BGS	
<b>Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)</b>	See Rider RGGI	
<b>Infrastructure Investment Program Charge</b>	See Rider IIP	

The minimum monthly bill will be \$9.96 per month plus any applicable adjustment.

**Date of Issue:**

**Effective Date:**

**Issued by:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 14****RATE SCHEDULE MGS-PRIMARY  
(Monthly General Service)****AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer delivered at one point and metered at or compensated to the voltage of delivery. This schedule is not available to residential customers.

**SUMMER**                      **WINTER**  
June Through September    October Through May

**Delivery Service Charges:**

Customer Charge

Single Phase	\$17.56	\$17.56
--------------	---------	---------

Three Phase	\$19.08	\$19.08
-------------	---------	---------

Distribution Demand Charge (per kW)	\$1.89	\$1.48
-------------------------------------	--------	--------

Reactive Demand Charge	\$0.47	\$0.47
------------------------	--------	--------

(For each kvar over one-third of kW demand)

Distribution Rates (\$/kWh)	\$0.048105	\$0.046599
-----------------------------	------------	------------

Non-Utility Generation Charge (NGC) (\$/kWh)	See Rider NGC
--	---------------

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
----------------------	---------------

Universal Service Fund	See Rider SBC
------------------------	---------------

Lifeline	See Rider SBC
----------	---------------

Uncollectible Accounts	See Rider SBC
------------------------	---------------

Transition Bond Charge (TBC) (\$/kWh)	See Rider SEC
---------------------------------------	---------------

Market Transition Charge Tax (MTC-Tax) (\$/kWh)	See Rider SEC
---	---------------

CIEP Standby Fee (\$/kWh)	See Rider BGS
---------------------------	---------------

Transmission Demand Charge	\$3.63	\$3.28
----------------------------	--------	--------

(\$/kW for each kW in excess of 3 kW)

Reliability Must Run Transmission Surcharge (\$/kWh)	\$0.000000
--	------------

Transmission Enhancement Charge (\$/kWh)	See Rider BGS
--	---------------

Basic Generation Service Charge (\$/kWh)	See Rider BGS
--	---------------

Regional Greenhouse Gas Initiative

Recovery Charge (\$/kWh)	See Rider RGGI
--------------------------	----------------

Infrastructure Investment Program Charge	See Rider IIP
--	---------------

Conservation Incentive Program Recovery Charge	See Rider CIP
--	---------------

The minimum monthly bill will be \$17.56 per month plus any applicable adjustment.

**Date of Issue:****Effective Date:****Issued by:**



**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 17****RATE SCHEDULE AGS-SECONDARY  
(Annual General Service)****AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer contracting for annual service delivered at one point and metered at or compensated to the voltage of delivery.

**MONTHLY RATE****Delivery Service Charges:**

Customer Charge	\$193.22
-----------------	----------

<b>Distribution Demand Charge (\$/kW)</b>	<b>\$12.39</b>
---	----------------

<b>Reactive Demand (for each kvar over one-third of kW demand)</b>	<b>\$0.94</b>
--	---------------

<b>Non-Utility Generation Charge (NGC) (\$/kWh)</b>	See Rider NGC
---	---------------

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
----------------------	---------------

Universal Service Fund	See Rider SBC
------------------------	---------------

Lifeline	See Rider SBC
----------	---------------

Uncollectible Accounts	See Rider SBC
------------------------	---------------

<b>Transition Bond Charge (TBC) (\$/kWh)</b>	See Rider SEC
--	---------------

<b>Market Transition Charge Tax (MTC-Tax) (\$/kWh)</b>	See Rider SEC
--	---------------

<b>CIEP Standby Fee (\$/kWh)</b>	See Rider BGS
----------------------------------	---------------

<b>Transmission Demand Charge (\$/kW)</b>	<b>\$5.62</b>
---	---------------

<b>Reliability Must Run Transmission Surcharge (\$/kWh)</b>	<b>\$0.000000</b>
---	-------------------

<b>Transmission Enhancement Charge (\$/kWh)</b>	See Rider BGS
---	---------------

<b>Basic Generation Service Charge (\$/kWh)</b>	See Rider BGS
---	---------------

<b>Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)</b>	See Rider RGGI
--	----------------

<b>Infrastructure Investment Program Charge</b>	See Rider IIP
---	---------------

<b>Conservation Incentive Program Recovery Charge</b>	See Rider CIP
---	---------------

**CORPORATE BUSINESS TAX (CBT)**

Charges under this rate schedule include a component for Corporate Business Taxes as set forth in Rider CBT.

**NEW JERSEY SALES AND USE TAX (SUT)**

Charges under this rate schedule include a component for New Jersey Sales and Use Tax as set forth in Rider SUT.

**VETERANS' ORGANIZATION SERVICE**

Pursuant to N.J.S.A. 48:2-21.41, when electric service is delivered to a customer that is a veterans' organization, and where the primary use of the service is dedicated to serving the needs of veterans of the armed forces, and the customer applies for and is eligible for such service.

Each customer shall be eligible for billing under this Special Provision upon submitting an Application for Veterans' Organization Service under this rate schedule and by qualifying as a "Veterans' Organization" as defined by N.J.S.A. 48:2-21.41 as "an organization dedicated to serving the needs of veterans of the armed forces that: is chartered under federal law, qualifies as a tax exempt organization under paragraph (19) of subsection (c) of section 501 of the federal Internal Revenue Code of 1986, 26 U.S.C. s.501 (c)(19), or that is organized as a corporation under the 'New Jersey Nonprofit Corporation Act,' N.J.S.15A:1-1 et seq." Under N.J.S.A. 48: 2-21.41, a qualified Veterans' Organization shall be charged the residential rate for service delivered to the property where the Veterans' Organization primarily operates, if the residential rate is lower than the commercial rate for service at that property. The customer shall furnish satisfactory proof of eligibility of service under this special provision to the Company, who will determine eligibility.

**Date of Issue:****Effective Date:****Issued by:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 19****RATE SCHEDULE AGS-PRIMARY  
(Annual General Service)****AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer contracting for annual service delivered at one point and metered at or compensated to the voltage of delivery.

**MONTHLY RATE****Delivery Service Charges:**

Customer Charge	\$744.15
-----------------	----------

Distribution Demand Charge (\$/kW)	\$9.83
------------------------------------	--------

Reactive Demand (for each kvar over one-third of kW demand)	\$0.74
---	--------

Non-Utility Generation Charge (NGC) (\$/kWh)	See Rider NGC
--	---------------

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
----------------------	---------------

Universal Service Fund	See Rider SBC
------------------------	---------------

Lifeline	See Rider SBC
----------	---------------

Uncollectible Accounts	See Rider SBC
------------------------	---------------

Transition Bond Charge (TBC) (\$/kWh)	See Rider SEC
---------------------------------------	---------------

Market Transition Charge Tax (MTC-Tax) (\$/kWh)	See Rider SEC
---	---------------

CIEP Standby Fee (\$/kWh)	See Rider BGS
---------------------------	---------------

Transmission Demand Charge (\$/kW)	\$5.78
------------------------------------	--------

Reliability Must Run Transmission Surcharge (\$/kWh)	\$0.000000
--	------------

Transmission Enhancement Charge (\$/kWh)	See Rider BGS
--	---------------

Basic Generation Service Charge (\$/kWh)	See Rider BGS
--	---------------

Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)	See Rider RGGI
---	----------------

Infrastructure Investment Program Charge	See Rider IIP
--	---------------

Conservation Incentive Program Recovery Charge	See Rider CIP
--	---------------

**CORPORATE BUSINESS TAX (CBT)**

Charges under this rate schedule include a component for Corporate Business Taxes as set forth in Rider CBT.

**NEW JERSEY SALES AND USE TAX (SUT)**

Charges under this rate schedule include a component for New Jersey Sales and Use Tax as set forth in Rider SUT.

**VETERANS' ORGANIZATION SERVICE**

Pursuant to N.J.S.A. 48:2-21.41, when electric service is delivered to a customer that is a veterans' organization, and where the primary use of the service is dedicated to serving the needs of veterans of the armed forces, and the customer applies for and is eligible for such service.

Each customer shall be eligible for billing under this Special Provision upon submitting an Application for Veterans' Organization Service under this rate schedule and by qualifying as a "Veterans' Organization" as defined by N.J.S.A. 48:2-21.41 as "an organization dedicated to serving the needs of veterans of the armed forces that: is chartered under federal law, qualifies as a tax exempt organization under paragraph (19) of subsection (c) of section 501 of the federal Internal Revenue Code of 1986, 26 U.S.C. s.501 (c)(19), or that is organized as a corporation under the 'New Jersey Nonprofit Corporation Act,' N.J.S.15A:1-1 et seq." Under N.J.S.A. 48: 2-21.41, a qualified Veterans' Organization shall be charged the residential rate for service delivered to the property where the Veterans' Organization primarily operates, if the residential rate is lower than the commercial rate for service at that property. The customer shall furnish satisfactory proof of eligibility of service under this special provision to the Company, who will determine eligibility.

**Date of Issue:****Effective Date:****Issued by:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 29**

---

**RATE SCHEDULE TGS**  
**(Transmission General Service)**  
**(Sub Transmission Service Taken at 23kV and 34.5 kV)****AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer contracting for annual service delivered at one point and metered at or compensated to the voltage subtransmission level (23 or 34.5 kV).

**MONTHLY RATE****Delivery Service Charges:****Customer Charge**

Maximum billed demand within the most recent 12 billing months.

Less than 5,000 kW	\$131.75
5,000 – 9,000 kW	\$4,363.57
Greater than 9,000 kW	\$7,921.01

**Distribution Demand Charge (\$/kW)**

Maximum billed demand within the most recent 12 billing months.

Less than 5,000 kW	\$3.83
5,000 – 9,000 kW	\$2.95
Greater than 9,000 kW	\$1.49

**Reactive Demand (for each kvar over one-third of kW demand)**

\$0.52

**Non-Utility Generation Charge (NGC) (\$/kWh)**

See Rider NGC

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
Universal Service Fund	See Rider SBC
Lifeline	See Rider SBC
Uncollectible Accounts	See Rider SBC

**Transition Bond Charge (TBC) (\$/kWh)**

See Rider SEC

**Market Transition Charge Tax (MTC-Tax) (\$/kWh)**

See Rider SEC

**CIEP Standby Fee (\$/kWh)**

See Rider BGS

**Transmission Demand Charge (\$/kW)**

\$6.85

**Reliability Must Run Transmission Surcharge (\$/kWh)**

\$0.000000

**Transmission Enhancement Charge (\$/kWh)**

See Rider BGS

**Basic Generation Service Charge (\$/kWh)**

See Rider BGS

**Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)**

See Rider RGGI

**Infrastructure Investment Program Charge**

See Rider IIP

**Conservation Incentive Program Recovery Charge**

See Rider CIP

---

**Date of Issue:****Effective Date:****Issued by:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 29a**

---

**RATE SCHEDULE TGS**  
**(Transmission General Service)**  
**(Transmission Service Taken at or above 69kV)**

**AVAILABILITY**

Available at any point within the Company's system where facilities of adequate character and capacity exist for the entire electric service requirements of any customer contracting for annual service delivered at one point and metered at or compensated to the voltage at transmission level (69 kV or higher).

**MONTHLY RATE****Delivery Service Charges:****Customer Charge**

Maximum billed demand within the most recent 12 billing months.

Less than 5,000 kW	\$128.21
5,000 – 9,000 kW	\$4,246.42
Greater than 9,000 kW	\$19,316.15

**Distribution Demand Charge (\$/kW)**

Maximum billed demand within the most recent 12 billing months.

Less than 5,000 kW	\$2.97
5,000 – 9,000 kW	\$2.30
Greater than 9,000 kW	\$0.17

**Reactive Demand (for each kvar over one-third of kW demand)**

\$0.50

**Non-Utility Generation Charge (NGC) (\$/kWh)**

See Rider NGC

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
Universal Service Fund	See Rider SBC
Lifeline	See Rider SBC
Uncollectible Accounts	See Rider SBC

**Transition Bond Charge (TBC) (\$/kWh)**

See Rider SEC

**Market Transition Charge Tax (MTC-Tax) (\$/kWh)**

See Rider SEC

**CIEP Standby Fee (\$/kWh)**

See Rider BGS

**Transmission Demand Charge (\$/kW)**

\$3.42

**Reliability Must Run Transmission Surcharge (\$/kWh)**

\$0.000000

**Transmission Enhancement Charge (\$/kWh)**

See Rider BGS

**Basic Generation Service Charge (\$/kWh)**

See Rider BGS

**Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)**

See Rider RGGI

**Infrastructure Investment Program Charge**

See Rider IIP

**Conservation Incentive Program Recovery Charge**

See Rider CIP

---

**Date of Issue:****Effective Date:****Issued by:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service – Section IV Revised Sheet Replaces Revised Sheet No. 31**

---

**RATE SCHEDULE DDC  
(Direct Distribution Connection)****AVAILABILITY**

Available at any point within the Company's existing distribution system where facilities of adequate character exist for the connection of fixed, constant and predictable non-residential loads not to exceed one kilowatt

**MONTHLY RATES****Distribution:**

Service and Demand (per day per connection)	\$0.163476
Energy (per day for each kW of effective load)	\$0.787404

<b>Non-Utility Generation Charge (NGC) (\$/kWh)</b>	See Rider NGC
---	---------------

**Societal Benefits Charge (\$/kWh)**

Clean Energy Program	See Rider SBC
Universal Service Fund	See Rider SBC
Lifeline	See Rider SBC
Uncollectible Accounts	See Rider SBC

<b>Transition Bond Charge (TBC) (\$/kWh)</b>	See Rider SEC
--	---------------

<b>Market Transition Charge Tax (MTC-Tax) (\$/kWh)</b>	See Rider SEC
--	---------------

<b>Transmission Rate (\$/kWh)</b>	\$0.009564
-----------------------------------	------------

<b>Reliability Must Run Transmission Surcharge (\$/kWh)</b>	\$0.000000
---	------------

<b>Transmission Enhancement Charge (\$/kWh)</b>	See Rider BGS
---	---------------

<b>Basic Generation Service Charge (\$/kWh)</b>	See Rider BGS
---	---------------

<b>Regional Greenhouse Gas Initiative Recovery Charge (\$/kWh)</b>	See Rider RGGI
--	----------------

<b>Infrastructure Investment Program Charge</b>	See Rider IIP
---	---------------

**CORPORATE BUSINESS TAX (CBT)**

Charges under this rate schedule include a component for Corporate Business Taxes as set forth in Rider CBT.

**NEW JERSEY SALES AND USE TAX (SUT)**

Charges under this rate schedule include a component for New Jersey Sales and Use Tax as set forth in Rider SUT.

**LOAD CONSUMPTION**

Effective load shall be determined by the Company and be specified in the contract. Effective load is defined as the sum of the products of the connected load in kilowatts times the percent load on at one time. No changes in attached load may be made by the customer without the permission of the Company and customer shall allow the Company access to his premises to assure conformance with this provision.

---

**Date of Issue:****Issued by:****Effective Date:**

**ATLANTIC CITY ELECTRIC COMPANY****BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 44****RIDER STB-STANDBY SERVICE****(Applicable to MGS, AGS, TGS and SPP Rate Schedules)****AVAILABILITY**

This rider is available to customers having other sources of electrical energy supply, but who desire to purchase Standby Service from the Company. The terms of this rider shall not be available in any month when the customer's Generation Availability for the current and preceding five (5) months does not exceed 50%.

**DEFINITIONS**Standby Service:

Standby Service is defined as the additional electrical capacity available to a customer in the event of a forced outage and during a mutually agreed upon customer's scheduled maintenance shutdown of the customer owned electrical energy source.

Standby Service Capacity:

The Standby Service Capacity shall be the maximum electrical capacity in kW supplied by the customer owned electrical energy source during the current and preceding five (5) months. Such Standby Service Capacity may be revised with the Company's approval as changes in the customer's load conditions warrant.

Generation Availability:

Generation Availability is defined as the availability of the customer owned electrical energy source during the current and preceding five (5) months and shall be determined by dividing the Kwhrs produced during this period by the product of the Standby Service Capacity times 4380 hours.

**MODIFICATION OF DEMAND DETERMINATION**

The monthly billing demand shall be as defined under the "Demand Determination" section of the applicable rate schedule.

The Standby Service Demand shall be the "Standby Service Capacity" as defined above.

During the billing months in which a forced outage or mutually agreed upon customer's scheduled maintenance shutdown occurs, the billing demand will be determined by subtracting the Standby Service Capacity from the total demand and waives the minimum charge provision of the applicable rate schedule. Electric service is provided under the terms of the applicable rate schedule. Total demand is defined as the sum of the Company's demand meter plus demand supplied by the other sources of electrical energy, all computed to the nearest whole kilowatt during a fifteen minute period.

**STANDBY SERVICE CHARGE**

**This rider imposes a Standby Service Charge at the following voltage levels:**

<u>Tariff</u>	<u>Transmission Stand By Rate</u>	<u>Distribution Stand By Rate</u>
	<u>(\$/kW)</u>	<u>(\$/kW)</u>
MGS-Secondary and MGS-SEVC	\$0.66	\$0.18
MGS Primary	\$0.37	\$0.16
AGS Secondary	\$0.57	\$1.26
AGS Primary	\$0.59	\$1.00
TGS Sub Transmission	\$0.35	\$0.00
TGS Transmission	\$0.35	\$0.00

**Date of Issue:****Effective Date:****Issued by:**

## ATLANTIC CITY ELECTRIC COMPANY

## BPU NJ No. 11 Electric Service - Section IV Revised Sheet Replaces Revised Sheet No. 60b

RIDER (BGS) continued  
Basic Generation Service (BGS)**CIEP Standby Fee** \$0.000160 per kWh

This charge recovers the costs associated with the winning BGS-CIEP bidders maintaining the availability of the hourly priced default electric supply service plus administrative charges pursuant to N.J.S.A. 48:2-60 and New Jersey Sales and Use Tax as set forth in Rider SUT. This charge is assessed on all kWhs delivered to all CIEP- eligible customers on Rate Schedules MGS Secondary, MGS-SEVC, MGS Primary, AGS Secondary, AGS Primary or TGS.

**Transmission Enhancement Charge**

This charge reflects Transmission Enhancement Charges ("TECs"), implemented to compensate transmission owners for the annual transmission revenue requirements for "Required Transmission Enhancements" (as defined in Schedule 12 of the PJM OATT) that are requested by PJM for reliability or economic purposes and approved by the Federal Energy Regulatory Commission (FERC). The TEC charge (in \$ per kWh by Rate Schedule), including administrative charges pursuant to N.J.S.A. 48:2-60 and New Jersey Sales and Use Tax as set forth in Rider SUT, is delineated in the following table.

**Rate Class**

	<u>RS</u>	<u>MGS Secondary And MGS- SEVC</u>	<u>MGS Primary</u>	<u>AGS Secondary</u>	<u>AGS Primary</u>	<u>TGS</u>	<u>SPL/ CSL</u>	<u>DDC</u>
VEPCo	0.000367	0.000278	0.000256	0.000179	0.000156	0.000133	-	0.000114
TrAILCo	0.000275	0.000192	0.000131	0.000138	0.000113	0.000104	-	0.000082
PSE&G	0.003256	0.002478	0.002276	0.001591	0.001385	0.001184	-	0.001018
PATH	0.000010	0.000007	0.000006	0.000004	0.000004	0.000003	-	0.000003
PPL	0.000095	0.000066	0.000046	0.000048	0.000039	0.000036	-	0.000029
PECO	0.000216	0.000150	0.000103	0.000109	0.000088	0.000083	-	0.000065
Pepco	0.000022	0.000016	0.000011	0.000012	0.000010	0.000009	-	0.000006
MAIT	0.000042	0.000032	0.000029	0.000020	0.000018	0.000015	-	0.000013
JCP&L	0.000003	0.000002	0.000002	0.000001	0.000001	0.000001	-	0.000001
EL05-121	0.000019	0.000015	0.000013	0.000010	0.000009	0.000006	-	0.000006
Delmarva	0.000010	0.000006	0.000004	0.000004	0.000004	0.000003	-	0.000003
BG&E	0.000041	0.000028	0.000019	0.000020	0.000017	0.000015	-	0.000012
AEP-East	0.000081	0.000062	0.000057	0.000039	0.000034	0.000030	-	0.000026
Silver Run	0.000325	0.000247	0.000227	0.000159	0.000139	0.000118	-	0.000101
NIPSCO	0.000003	0.000002	0.000002	0.000002	0.000001	0.000001	-	0.000001
CW Edison	-	-	-	-	-	-	-	-
ER18-680 & Form 715	-	-	-	-	-	-	-	-
SFC	0.000004	0.000003	0.000003	0.000002	0.000002	0.000002	-	0.000001
PSEG ROE- TEC	(0.000112)	(0.000094)	(0.000064)	(0.000065)	(0.000052)	(0.000038)	-	(0.000039)
Duquesne	0.000002	0.000001	0.000001	0.000001	0.000001	0.000001	-	0.000001
Total	0.004659	0.003491	0.003122	0.002274	0.001969	0.001706	-	0.001443

**Date of Issue:****Effective Date:****Issued by:**

Attachment 2B – Public Service Electric and Gas Company Tariff Sheets



**PUBLIC SERVICE ELECTRIC AND GAS COMPANY**

**XXX Revised Sheet No. 76**

**B.P.U.N.J. No. 16 ELECTRIC**

**Superseding**

**XXX Revised Sheet No. 76**

**BASIC GENERATION SERVICE – RESIDENTIAL SMALL COMMERCIAL PRICING (BGS-RSCP)**

**ELECTRIC SUPPLY CHARGES**

**(Continued)**

**BGS TRANSMISSION CHARGES:**

**Applicable to Rate Schedules RS, RHS, RLM, WH, WHS, HS, BPL, BPL-POF and PSAL**

**Charges per kilowatt-hour:**

<u>Rate Schedule</u>	<u>For usage in all months</u>	
	<u>Transmission Charges</u>	<u>Charges Including SUT</u>
RS	\$0.051973	\$0.055416
RHS	0.029948	0.031932
RLM On-Peak	0.112301	0.119741
RLM Off-Peak	0.000000	0.000000
WH	0.000000	0.000000
WHS	0.000000	0.000000
HS	0.051764	0.055193
BPL	0.000000	0.000000
BPL-POF	0.000000	0.000000
PSAL	0.000000	0.000000

The above charges shall recover all costs related to the overall summer peak transmission load assigned to the Public Service Transmission Zone by the PJM Interconnection, L.L.C. (PJM) as adjusted by PJM assigned transmission capacity related factors and allocated to the above Rate Schedules. These charges will be changed from time to time on the effective date of such change to the PJM rate for charges for Network Integration Transmission Service, including the PJM Seams Elimination Cost Assignment Charges, the PJM Reliability Must Run Charge and PJM Transmission Enhancement Charges as approved by Federal Energy Regulatory Commission (FERC).

**BGS ENERGY CHARGES:**

**Applicable to Rate Schedules GLP and LPL-Sec.**

**Charges per kilowatt-hour:**

<u>Rate Schedule</u>	<u>For usage in each of the months of October through May</u>		<u>For usage in each of the months of June through September</u>	
	<u>Charges</u>	<u>Charges Including SUT</u>	<u>Charges</u>	<u>Charges Including SUT</u>
GLP	\$ 0.054749	\$ 0.058376	\$ 0.054625	\$ 0.058244
GLP Night Use	0.051554	0.054969	0.048231	0.051426
LPL-Sec. under 500 kW				
On-Peak	0.058329	0.062193	0.060868	0.064901
Off-Peak	0.051554	0.054969	0.048231	0.051426

The above Basic Generation Service Energy Charges reflect costs for Energy and Ancillary Services (including PJM Administrative Charges).

Kilowatt thresholds noted above are based upon the customer's Peak Load Share of the overall summer peak load assigned to Public Service by the Pennsylvania-New Jersey-Maryland Office of the Interconnection (PJM). See Section 9.1, Measurement of Electric Service, of the Standard Terms and Conditions of this Tariff.

Date of Issue:

Effective:

Issued by SCOTT S. JENNINGS, SVP - Corporate Planning, Strategy and Utility Finance – PSE&G  
80 Park Plaza, Newark, New Jersey 07102  
Filed pursuant to Order of Board of Public Utilities dated  
in Docket No.

**PUBLIC SERVICE ELECTRIC AND GAS COMPANY**

**XXX Revised Sheet No. 79**

**B.P.U.N.J. No. 16 ELECTRIC**

**Superseding**

**XXX Revised Sheet No. 79**

**BASIC GENERATION SERVICE – RESIDENTIAL SMALL COMMERCIAL PRICING (BGS-RSCP)  
ELECTRIC SUPPLY CHARGES**

**(Continued)**

**BGS CAPACITY CHARGES:**

**Applicable to Rate Schedules GLP and LPL-Sec.**

**Charges per kilowatt of Generation Obligation:**

Charge applicable in the months of June through September..... \$ 3.1889

Charge including New Jersey Sales and Use Tax (SUT) ..... \$ 3.4002

Charge applicable in the months of October through May ..... \$ 3.1889

Charge including New Jersey Sales and Use Tax (SUT) ..... \$ 3.4002

The above charges shall recover each customer's share of the overall summer peak load assigned to the Public Service Transmission Zone by the PJM Interconnection, L.L.C. (PJM) as adjusted by PJM assigned capacity related factors and shall be in accordance with Section 9.1, Measurement of Electric Service, of the Standard Terms and Conditions.

**BGS TRANSMISSION CHARGES**

**Applicable to Rate Schedules GLP and LPL-Sec.**

**Charges per kilowatt of Transmission Obligation:**

Currently effective Annual Transmission Rate for

Network Integration Transmission Service for the

Public Service Transmission Zone as derived from the

FERC Electric Tariff of the PJM Interconnection, LLC ..... \$ 135,358.49 per MW per year

EL05-121 ..... \$ 78.17 per MW per month

Public Service Electric and Gas ROE Refund ..... (\$ 404.92) per MW per month

FERC 680 & 715 Reallocation ..... \$ 0.00 per MW per month

PJM Seams Elimination Cost Assignment Charges ..... \$ 0.00 per MW per month

PJM Reliability Must Run Charge ..... \$ 0.00 per MW per month

PJM Transmission Enhancements

Trans-Allegheny Interstate Line Company ..... \$ 42.49 per MW per month

Virginia Electric and Power Company ..... \$ 70.58 per MW per month

Potomac-Appalachian Transmission Highline L.L.C. .... \$ 1.56 per MW per month

PPL Electric Utilities Corporation ..... \$ 183.50 per MW per month

American Electric Power Service Corporation ..... \$ 18.49 per MW per month

Atlantic City Electric Company ..... \$ 8.52 per MW per month

Delmarva Power and Light Company..... \$ 1.25 per MW per month

Potomac Electric Power Company..... \$ 2.67 per MW per month

Baltimore Gas and Electric Company ..... \$ 4.01 per MW per month

Jersey Central Power and Light ..... \$ 61.02 per MW per month

Mid Atlantic Interstate Transmission ..... \$ 16.73 per MW per month

PECO Energy Company ..... \$ 19.93 per MW per month

Silver Run Electric, Inc. .... \$ 43.21 per MW per month

Northern Indiana Public Service Company ..... \$ 0.89 per MW per month

Commonwealth Edison Company ..... \$ 0.12 per MW per month

South First Energy Operating Company ..... \$ 0.70 per MW per month

Duquesne Light Company ..... \$ 0.33 per MW per month

Above rates converted to a charge per kW of Transmission

Obligation, applicable in all months ..... \$11.4292

Charge including New Jersey Sales and Use Tax (SUT) ..... \$12.1864

The above charges shall recover each customer's share of the overall summer peak transmission load assigned to the Public Service Transmission Zone by the PJM Interconnection, L.L.C. (PJM) as adjusted by PJM assigned transmission capacity related factors and shall be in accordance with Section 9.1, Measurement of Electric Service, of the Standard Terms and Conditions. These charges will be changed from time to time on the effective date of such change to the PJM rate for charges for Network Integration Transmission Service, including the PJM Seams Elimination Cost Assignment Charges, the PJM Reliability Must Run Charge and PJM Transmission Enhancement Charges as approved by Federal Energy Regulatory Commission (FERC).

Date of Issue:

Effective:

Issued by SCOTT S. JENNINGS, SVP - Corporate Planning, Strategy and Utility Finance – PSE&G

80 Park Plaza, Newark, New Jersey 07102

Filed pursuant to Order of Board of Public Utilities dated

in Docket No.

**PUBLIC SERVICE ELECTRIC AND GAS COMPANY**

**B.P.U.N.J. No. 16 ELECTRIC**

**XXX Revised Sheet No. 83**

**Superseding**

**XXX Revised Sheet No. 83**

**BASIC GENERATION SERVICE – COMMERCIAL AND INDUSTRIAL ENERGY PRICING (CIEP)**  
**ELECTRIC SUPPLY CHARGES**  
**(Continued)**

**BGS TRANSMISSION CHARGES**

**Charges per kilowatt of Transmission Obligation:**

Currently effective Annual Transmission Rate for

Network Integration Transmission Service for the

Public Service Transmission Zone as derived from the

FERC Electric Tariff of the PJM Interconnection, LLC .....\$135,358.49 per MW per year

EL05-121 .....\$ 78.17 per MW per month

Public Service Electric and Gas ROE Refund .....(\$ 404.92) per MW per month

FERC 680 & 715 Reallocation.....\$ 0.00 per MW per month

PJM Seams Elimination Cost Assignment Charges .....\$ 0.00 per MW per month

PJM Reliability Must Run Charge.....\$ 0.00 per MW per month

PJM Transmission Enhancements

Trans-Allegheny Interstate Line Company .....\$ 42.49 per MW per month

Virginia Electric and Power Company .....\$ 70.58 per MW per month

Potomac-Appalachian Transmission Highline L.L.C. ....\$ 1.56 per MW per month

PPL Electric Utilities Corporation.....\$ 183.50 per MW per month

American Electric Power Service Corporation .....\$ 18.49 per MW per month

Atlantic City Electric Company .....\$ 8.52 per MW per month

Delmarva Power and Light Company.....\$ 1.25 per MW per month

Potomac Electric Power Company .....\$ 2.67 per MW per month

Baltimore Gas and Electric Company.....\$ 4.01 per MW per month

Jersey Central Power and Light .....\$ 61.02 per MW per month

Mid Atlantic Interstate Transmission.....\$ 16.73 per MW per month

PECO Energy Company.....\$ 19.93 per MW per month

Silver Run Electric, Inc.....\$ 43.21 per MW per month

Northern Indiana Public Service Company .....\$ 0.89 per MW per month

Commonwealth Edison Company .....\$ 0.12 per MW per month

South First Energy Operating Company .....\$ 0.70 per MW per month

Duquesne Light Company .....\$ 0.33 per MW per month

Above rates converted to a charge per kW of Transmission

Obligation, applicable in all months.....\$11.4292

Charge including New Jersey Sales and Use Tax (SUT) .....\$12.1864

The above charges shall recover each customer's share of the overall summer peak transmission load assigned to the Public Service Transmission Zone by the PJM Interconnection, L.L.C. (PJM) as adjusted by PJM assigned transmission capacity related factors and shall be in accordance with Section 9.1, Measurement of Electric Service, of the Standard Terms and Conditions. These charges will be changed from time to time on the effective date of such charge to the PJM rate for charges for Network Integration Transmission Service, including the PJM Seams Elimination Cost Assignment Charges, the PJM Reliability Must Run Charge and PJM Transmission Enhancement Charges as approved by Federal Energy Regulatory Commission (FERC).

Kilowatt threshold noted above is based upon the customer's Peak Load Share of the overall summer peak load assigned to Public Service by the Pennsylvania-New Jersey-Maryland Office of the Interconnection (PJM). See Section 9.1, Measurement of Electric Service, of the Standard Terms and Conditions of this Tariff.

Date of Issue:

Effective:

Issued by SCOTT S. JENNINGS, SVP - Corporate Planning, Strategy and Utility Finance – PSE&G  
80 Park Plaza, Newark, New Jersey 07102

Filed pursuant to Order of Board of Public Utilities dated  
in Docket No.

Attachment 2C – Jersey Central Power & Light Tariff Company Tariff Sheets

JERSEY CENTRAL POWER & LIGHT COMPANY

BPU No. 13 ELECTRIC - PART III

XX<sup>th</sup> Rev. Sheet No. 42  
Superseding XX<sup>th</sup> Rev. Sheet No. 42

**Rider BGS-RSCP**  
**Basic Generation Service – Residential Small Commercial Pricing**  
**(Applicable to Service Classifications RS, RT, RGT, GS, GST, OL, SVL, MVL, ISL and LED)**

**2) BGS Transmission Charge per KWH:** As provided in the respective tariff for Service Classifications RS, RT, RGT, GS, GST, OL, SVL, MVL, ISL and LED. Effective September 1, 2019, a RMR surcharge of **\$0.000000** per KWH (includes Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage.

Effective **December 15, 2021**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage, except lighting under Service Classifications OL, SVL, MVL, ISL and LED:

EL18-680FM715-TEC surcharge of **\$0.000000** per KWH

Effective **February 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage, except lighting under Service Classifications OL, SVL, MVL, ISL and LED:

PSEGROE-TEC surcharge of **(\$0.000061)** per KWH

Effective **April 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage, except lighting under Service Classifications OL, SVL, MVL, ISL and LED:

PSEG-TEC surcharge of **\$0.002959** per KWH  
VEPCO-TEC surcharge of **\$0.000300** per KWH  
PATH-TEC surcharge of **\$0.000007** per KWH  
AEP-East-TEC surcharge of **\$0.000076** per KWH  
MAIT-TEC surcharge of **\$0.000076** per KWH  
EL05-121-TEC surcharge of **\$0.000235** per KWH  
SRE-TEC surcharge of **\$0.000200** per KWH  
NIPSCO-TEC surcharge of **\$0.000002** per KWH  
SFC-TEC surcharge of **\$0.000004** per KWH

Effective **September 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage, except lighting under Service Classifications OL, SVL, MVL, ISL and LED:

TRAILCO-TEC surcharge of **\$0.000208** per KWH  
ACE-TEC surcharge of **\$0.000098** per KWH  
PECO-TEC surcharge of **\$0.000068** per KWH  
PPL-TEC surcharge of **\$0.000643** per KWH  
Delmarva-TEC surcharge of **\$0.000005** per KWH  
PEPCO-TEC surcharge of **\$0.000013** per KWH  
BG&E-TEC surcharge of **\$0.000016** per KWH  
COMED-TEC surcharge of **\$0.000000** Per KWH  
Duquesne-TEC surcharge of **\$0.000000** Per KWH

**3) BGS Reconciliation Charge per KWH: (\$0.008574)** (includes Sales and Use Tax as provided in Rider SUT)  
The above BGS Reconciliation Charge recovers the difference between the costs for the provision of Basic Generation Service and the revenues from BGS customers for Basic Generation Service and is subject to quarterly true-ups.

Issued:

Filed pursuant to Order of Board of Public Utilities  
Docket dated

Effective:

Issued by James V. Fakult, President  
300 Madison Avenue, Morristown, NJ 07962-1911

## JERSEY CENTRAL POWER &amp; LIGHT COMPANY

XX<sup>th</sup> Rev. Sheet No. 44

BPU No. 13 ELECTRIC - PART III

Superseding XX<sup>th</sup> Rev. Sheet No. 44

**Rider BGS-CIEP**  
**Basic Generation Service – Commercial Industrial Energy Pricing**  
 (Applicable to Service Classifications GP and GT and  
 Certain Customers under Service Classifications GS and GST)

**3) BGS Transmission Charge per KWH: (Continued)**

Effective **December 15, 2021**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage:

EL18-680Fm715-TEC

GS and GST	\$0.000000
GP	\$0.000000
GT	\$0.000000
GT – High Tension Service	\$0.000000

Effective **February 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage:

PSEGROE-TEC

GS and GST	(\$0.000061)
GP	(\$0.000036)
GT	(\$0.000034)
GT – High Tension Service	(\$0.000010)

Effective **April 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage:

	<u>PSEG-TEC</u>	<u>VEPCO-TEC</u>	<u>PATH-TEC</u>	<u>AEP-East-TEC</u>	
GS and GST	\$0.002959	\$0.000300	\$0.000007	\$0.000076	
GP	\$0.001800	\$0.000182	\$0.000004	\$0.000046	
GT	\$0.001581	\$0.000160	\$0.000004	\$0.000041	
GT – High Tension Service	\$0.000425	\$0.000043	\$0.000001	\$0.000011	
	<u>MAIT-TEC</u>	<u>EL05-121-TEC</u>	<u>SRE-TEC</u>	<u>NIPSCO-TEC</u>	<u>SFC-TEC</u>
GS and GST	\$0.000076	\$0.000235	\$0.000200	\$0.000002	\$0.000004
GP	\$0.000046	\$0.000143	\$0.000122	\$0.000001	\$0.000002
GT	\$0.000041	\$0.000126	\$0.000107	\$0.000001	\$0.000002
GT – High Tension Service	\$0.000011	\$0.000034	\$0.000029	\$0.000000	\$0.000001

Effective **September 1, 2022**, the following TEC surcharges (include Sales and Use Tax as provided in Rider SUT) will be added to the BGS Transmission Charge applicable to all KWH usage:

	<u>TRAILCO-TEC</u>	<u>ACE-TEC</u>	<u>PECO-TEC</u>	<u>Delmarva-TEC</u>	
GS and GST	\$0.000208	\$0.000098	\$0.000068	\$0.000005	
GP	\$0.000124	\$0.000059	\$0.000041	\$0.000003	
GT	\$0.000113	\$0.000053	\$0.000037	\$0.000003	
GT – High Tension Service	\$0.000033	\$0.000016	\$0.000011	\$0.000001	
	<u>PPL-TEC</u>	<u>PEPCO-TEC</u>	<u>BG&amp;E-TEC</u>	<u>COMED-TEC</u>	<u>Duquesne-TEC</u>
GS and GST	\$0.000643	\$0.000013	\$0.000016	\$0.000000	\$0.000000
GP	\$0.000383	\$0.000007	\$0.000010	\$0.000000	\$0.000000
GT	\$0.000350	\$0.000006	\$0.000009	\$0.000000	\$0.000000
GT – High Tension Service	\$0.000102	\$0.000002	\$0.000002	\$0.000000	\$0.000000

**4) BGS Reconciliation Charge per KWH: (\$0.000986)** (includes Sales and Use Tax as provided in Rider SUT)

The above BGS Reconciliation Charge recovers the difference between the costs for the provision of Basic Generation Service and the revenues from BGS customers for Basic Generation Service and is subject to quarterly true-ups.

Issued:

Filed pursuant to Order of Board of Public Utilities  
Docket

Effective:

dated

Issued by James V. Fakult, President  
300 Madison Avenue, Morristown, NJ 07962-1911

Attachment 2D – Rockland Electric Company Tariff Sheets

DRAFT

Revised Leaf No. 83  
Superseding Revised Leaf No. 83

---

SERVICE CLASSIFICATION NO. 1  
RESIDENTIAL SERVICE (Continued)

RATE – MONTHLY (Continued)

(3) Transmission Charges

- (a) These charges apply to all customers taking Basic Generation Service from the Company. These charges are also applicable to customers located in the Company's Central and Western Divisions and obtaining Competitive Energy Supply. These charges are not applicable to customers located in the Company's Eastern Division and obtaining Competitive Energy Supply. The Company's Eastern, Central and Western Divisions are defined in General Information Section No. 1.

	<u>Summer Months*</u>	<u>Other Months</u>
All kWh ..... @	1.515 ¢ per kWh	1.515 ¢ per kWh

- (b) Transmission Surcharge – This charge is applicable to all customers taking Basic Generation Service from the Company and includes surcharges related to Reliability Must Run, EL05-121 Settlement and Transmission Enhancement Charges.

All kWh ..... @	1.380 ¢ per kWh	1.380 ¢ per kWh
-----------------	-----------------	-----------------

(4) Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge.

The provisions of the Company's Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge as described in General Information Section Nos. 33, 34, 36, and 37 respectively, shall be assessed on all kWh delivered hereunder.

\* Definition of Summer Billing Months - June through September

(Continued)

---

ISSUED:

EFFECTIVE:

ISSUED BY: Robert Sanchez, President  
Mahwah, New Jersey 07430



**DRAFT**

Revised Leaf No. 90  
Superseding Revised Leaf No. 90

---

**SERVICE CLASSIFICATION NO. 2  
GENERAL SERVICE (Continued)**

**RATE – MONTHLY (Continued)**

(3) Transmission Charges (Continued)

- (b) Transmission Surcharge – This charge is applicable to all customers taking Basic Generation Service from the Company and includes surcharges related to Reliability Must Run, EL05-121 Settlement and Transmission Enhancement Charges.

	<u>Summer Months*</u>	<u>Other Months</u>
<u>Secondary Voltage Service Only</u>		
All kWh .....@	0.697 ¢ per kWh	0.697 ¢ per kWh
<u>Primary Voltage Service Only</u>		
All kWh .....@	0.788 ¢ per kWh	0.788 ¢ per kWh

- (4) Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge.

The provisions of the Company's Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge as described in General Information Section Nos. 33, 34, 36, and 37 respectively, shall be assessed on all kWh delivered hereunder.

\* Definition of Summer Billing Months - June through September

(Continued)

---

ISSUED:

EFFECTIVE:

ISSUED BY: Robert Sanchez, President  
Mahwah, New Jersey 07430

**DRAFT**

Revised Leaf No. 96  
Superseding Revised Leaf No. 96

**SERVICE CLASSIFICATION NO. 3  
RESIDENTIAL TIME-OF-DAY HEATING SERVICE (Continued)**

**RATE – MONTHLY (Continued)**

(3) Transmission Charge

- (a) These charges apply to all customers taking Basic Generation Service from the Company. These charges are also applicable to customers located in the Company's Central and Western Divisions and obtaining Competitive Energy Supply. These charges are not applicable to customers located in the Company's Eastern Division and obtaining Competitive Energy Supply. The Company's Eastern, Central and Western Divisions are defined in General Information Section No. 1.

Summer Months\*

Other Months

Peak

All kWh measured between 10:00  
a.m. and 10:00 p.m., Monday  
through Friday ..... @

1.515 ¢ per kWh

1.515 ¢ per kWh

Off-Peak

All other kWh ..... @

1.515 ¢ per kWh

1.515 ¢ per kWh

- (b) Transmission Surcharge – This charge is applicable to all customers taking Basic Generation Service from the Company and includes surcharges related to Reliability Must Run, EL05-121 Settlement and Transmission Enhancement Charges.

All kWh ..... @

1.034 ¢ per kWh

1.034 ¢ per kWh

- (4) Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge.

The provisions of the Company's Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge as described in General Information Section Nos. 33, 34, 36, and 37 respectively, shall be assessed on all kWh delivered hereunder.

\* Definition of Summer Billing Months - June through September

(Continued)

ISSUED:

EFFECTIVE:

ISSUED BY: Robert Sanchez, President  
Mahwah, New Jersey 07430

**DRAFT**

Revised Leaf No. 124  
Superseding Revised Leaf No. 124

**SERVICE CLASSIFICATION NO. 7  
LARGE GENERAL TIME-OF-DAY SERVICE (Continued)**

**RATE– MONTHLY (Continued)**

(3) Transmission Charges (Continued)

(a) (Continued)

		<u>Primary</u>	<u>High Voltage Distribution</u>
<u>Demand Charge</u>			
Period I	All kW @	\$2.41 per kW	\$2.41 per kW
Period II	All kW @	0.64 per kW	0.64 per kW
Period III	All kW @	2.41 per kW	2.41 per kW
Period IV	All kW @	0.64 per kW	0.64 per kW

<u>Usage Charge</u>			
Period I	All kWh @	0.404 ¢ per kWh	0.404 ¢ per kWh
Period II	All kWh @	0.404 ¢ per kWh	0.404 ¢ per kWh
Period III	All kWh @	0.404 ¢ per kWh	0.404 ¢ per kWh
Period IV	All kWh @	0.404 ¢ per kWh	0.404 ¢ per kWh

- (b) Transmission Surcharge – This charge is applicable to all customers taking Basic Generation Service from the Company and includes surcharges related to Reliability Must Run, EL05-121 Settlement and Transmission Enhancement Charges.

		<u>Primary</u>	<u>High Voltage Distribution</u>
All Periods	All kWh @	0.477 ¢ per kWh	0.477 ¢ per kWh

(4) Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge.

The provisions of the Company's Societal Benefits Charge, Regional Greenhouse Gas Initiative Surcharge, Temporary Tax Act Credit, and Zero Emission Certificate Recovery Charge as described in General Information Section Nos. 33, 34, 36, and 37 respectively, shall be assessed on all kWh delivered hereunder.

(Continued)

ISSUED:

EFFECTIVE:

ISSUED BY: Robert Sanchez, President  
Mahwah, New Jersey 07430

**DRAFT**

Revised Leaf No. 127  
Superseding Revised Leaf No. 127

---

**SERVICE CLASSIFICATION NO. 7  
LARGE GENERAL TIME-OF-DAY SERVICE (Continued)**

**SPECIAL PROVISIONS**

(A) Space Heating

Customers who take service under this classification for 10 kW or more of permanently installed space heating equipment may elect to have the electricity for this service billed separately. All monthly use shall be billed at a Distribution Charge of 3.973 ¢ per kWh during the billing months of October through May and 6.423 ¢ per kWh during the summer billing months, a Transmission Charge of 0.404 ¢ per kWh and a Transmission Surcharge of 0.477 ¢ per kWh during all billing months. The applicability of Transmission Charges and the Transmission Surcharge is described in Part (3) of RATE – MONTHLY.

When this option is requested it shall apply for at least 12 months and shall be subject to a minimum charge of \$26.87 per year per kW of space heating capacity. This provision applies for both heating and cooling where the two services are combined by the manufacturer in a single self-contained unit.

All usage under this Special Provision shall also be subject to Parts (4), (5), and (6) of RATE – MONTHLY. This Special Provision is not available to those customers taking high voltage distribution service.

This special provision is closed to new customers effective August 1, 2014.

(B) Budget Billing Plan

Any condominium association or cooperative housing corporation who takes service hereunder and any other customer taking service under Special Provision B of this Service Classification may, upon request, be billed monthly in accordance with the budget billing plan provided for in General Information Section 8 of this tariff.

(Continued)

---

ISSUED:

EFFECTIVE:

ISSUED BY: Robert Sanchez, President  
Mahwah, New Jersey 07430

## Attachment 3 – Proposed ACE Transmission Rate Design

**Atlantic City Electric Company**  
Proposed Transmission Rate Design  
Formula Rate Effective September 1, 2022  
Change in FERC Formual Based Rate

	<b>2021 Booked Total Revenue (\$)</b>	<b>Annualized Transmission Revenue based on Current Billing Determinants (\$)</b>	<b>Transmission Peak Load Share (kW)</b>	<b>Transmission Revenue based on Peak Load Share (\$)</b>	<b>Increase/(Decrease)</b>	
					<b>(\$)</b>	<b>(%)</b>
<b>Residential</b>						
Residential	\$ 725,943,844	\$ 97,830,841	1,577,055	\$ 123,436,189	\$ 25,605,348	3.53%
<b>Commercial and Industrial</b>						
MGS Secondary*	\$ 182,750,470	\$ 28,020,340	348,905	\$ 27,308,787	\$ (711,553)	-0.39%
MGS Primary	\$ 5,908,469	\$ 597,374	8,502	\$ 665,436	\$ 68,062	1.15%
AGS Secondary	\$ 110,940,151	\$ 22,678,052	315,412	\$ 24,687,310	\$ 2,009,257	1.81%
AGS Primary	\$ 31,160,572	\$ 5,805,623	88,221	\$ 6,905,080	\$ 1,099,456	3.53%
TGS - Subtransmission	\$ 31,046,616	\$ 5,975,589	91,682	\$ 7,175,956	\$ 1,200,367	3.87%
TGS - Transmission	\$ 15,791,861	\$ 2,560,764	47,950	\$ 3,753,011	\$ 1,192,247	7.55%
SPL/CSL	\$ 20,439,954	\$ -	-	\$ -	\$ -	0.00%
DDC	\$ 1,030,240	\$ 126,252	1,713	\$ 134,038	\$ 7,786	0.76%
<b>Subtotal Commercial and Industrial</b>	<b>\$ 399,068,333</b>	<b>\$ 65,763,994</b>	<b>902,384</b>	<b>\$ 70,629,617</b>	<b>\$ 4,865,622</b>	<b>1.22%</b>
<b>Total Jurisdiction</b>	<b>\$ 1,125,012,178</b>	<b>\$ 163,594,835</b>	<b>2,479,439</b>	<b>\$ 194,065,806</b>	<b>\$ 30,470,971</b>	<b>2.71%</b>
Wholesale Transmission Rate		\$ 78.03				
Rate Including Regulatory Assessment		\$ 78.27				

\*MGS Secondary includes MGS Secondary and MGS Secondary Electric Vehicle Charging

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Residential ("RS")**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
kWh	4,074,078,244	\$ 0.025604	\$ 0.024013	\$ 97,830,841	\$ 0.006285	\$ 0.030298	\$ 0.032305
<b>Transmission Rate Change</b>				\$ 25,605,348			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Monthly General Service - Secondary (MGS Secondary)**

	Billing Determinants	Rate	Rate w/o SUT	Annualized Present Revenue w/o SUT	Rate Adjustment	Proposed Rate w/o SUT	Proposed Rate w/SUT
<u>Demand</u>							
SUM > 3 KW	1,843,997	\$ 6.64	\$ 6.23	\$ 11,488,101	\$ (0.150000)	\$ 6.08	\$ 6.48
WIN > 3 KW	2,816,395	\$ 6.26	\$ 5.87	\$ 16,532,239	\$ (0.150000)	\$ 5.72	\$ 6.10
TOTAL KW	<u>4,660,392</u>			<u>\$ 28,020,340</u>			
<b>Transmission Rate Change</b>				\$ (711,553)			



**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Monthly General Service - Primary (MGS Primary)**

	Billing Determinants	Rate	Rate w/o SUT	Annualized Present Revenue w/o SUT	Rate Adjustment	Proposed Rate w/o SUT	Proposed Rate w/SUT
<u>Demand</u>							
SUM > 3 KW	77,231	\$ 3.27	\$ 3.07	\$ 237,099	\$ 0.33	\$ 3.40	\$ 3.63
WIN > 3 KW	131,009	\$ 2.93	\$ 2.75	\$ 360,275	\$ 0.33	\$ 3.08	\$ 3.28
TOTAL KW	<u>208,240</u>			<u>\$ 597,374</u>			
<b>Transmission Rate Change</b>				\$ 68,062			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Annual General Service Secondary (AGS Secondary)**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
Demand KW	4,685,548	\$ 5.16	\$ 4.84	\$ 22,678,052	\$ 0.43	\$ 5.27	\$ 5.62
<b>Transmission Rate Change</b>				\$ 2,009,257			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Annual General Service Primary (AGS Primary)**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
Demand KW	1,273,163	\$ 4.86	\$ 4.56	\$ 5,805,623	\$ 0.86	\$ 5.42	\$ 5.78
<b>Transmission Rate Change</b>				\$ 1,099,456			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Sub Transmission General Service (TGS)**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
Demand KW	1,116,933	\$ 5.70	\$ 5.35	\$ 5,975,589	\$ 1.07	\$ 6.42	\$ 6.85
<b>Transmission Rate Change</b>				\$ 1,200,367			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Transmission General Service (TGS)**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
Demand KW	1,169,299	\$ 2.34	\$ 2.19	\$ 2,560,764	\$ 1.02	\$ 3.21	\$ 3.42
<b>Transmission Rate Change</b>				\$ 1,192,247			

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Street and Private Lighting (SPL)**

**Contributed Street Lighting (CSL)**

	Billing Determinants	Rate	Rate w/o SUT	Annualized Present Revenue w/o SUT	Rate Adjustment	Proposed Rate w/o SUT	Proposed Rate w/SUT
Kilowatthour charge Annual	69,605,845	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
<b>Transmission Rate Change</b>				\$ -	\$ -		

**ATLANTIC CITY ELECTRIC**

Proposed Transmission Rate Design

Formula Rate Effective September 1, 2022

**Direct Distribution Connection (DDC)**

	<u>Billing Determinants</u>	<u>Rate</u>	<u>Rate w/o SUT</u>	<u>Annualized Present Revenue w/o SUT</u>	<u>Rate Adjustment</u>	<u>Proposed Rate w/o SUT</u>	<u>Proposed Rate w/SUT</u>
Kilowatthour charge							
Annual	14,942,786	\$ 0.009009	\$ 0.008449	\$ 126,252	\$ 0.000521	\$ 0.008970	\$ 0.009564
<b>Transmission Rate Change</b>				\$ 7,786			

Atlantic City Electric Company  
Standby Rate Development  
Formula Rate Effective September 1, 2022

Rate Schedule	Demand Rates (\$/kW)		Standby Rates (\$/kW)		Transmission
	Transmission		Transmission		Standby Factor
MGS Secondary	\$	6.48	\$	0.66	0.101604278
MGS Primary	\$	3.63	\$	0.37	0.101604278
AGS Secondary	\$	5.62	\$	0.57	0.101604278
AGS Primary	\$	5.78	\$	0.59	0.101604278
TGS Transmission	\$	3.42	\$	0.35	0.101604278



Attachment 4A – Translation of 2022/2023 Schedule 12 Charges into Rates – ACE  
Attachment 4B – Translation of 2022/2023 Schedule 12 Charges into Rates – PSE&G  
Attachment 4C – Translation of 2022/2023 Schedule 12 Charges into Rates – JCP&L  
Attachment 4D – Translation of 2022/2023 Schedule 12 Charges into Rates – RECO

Attachment 4A – Translation of 2022/2023 Schedule 12 Charges into Rates – ACE

**Atlantic City Electric Company**

Proposed TrAIL CO Projects Transmission Enhancement Charge (TrAIL Co Project-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	144,641
	\$	144,641

2022 ACE Zone Transmission Peak Load (MW)	2,631
---	-------

Transmission Enhancement Rate (\$/MW)	\$	54.98
---------------------------------------	----	-------

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 1,040,393	4,053,632,865	\$ 0.000257	\$ 0.000258	\$ 0.000275
MGS Secondary	349	\$ 230,175	1,286,085,535	\$ 0.000179	\$ 0.000180	\$ 0.000192
MGS Primary	9	\$ 5,609	45,690,273	\$ 0.000123	\$ 0.000123	\$ 0.000131
AGS Secondary	315	\$ 208,079	1,610,533,369	\$ 0.000129	\$ 0.000129	\$ 0.000138
AGS Primary	88	\$ 58,200	550,675,023	\$ 0.000106	\$ 0.000106	\$ 0.000113
TGS	140	\$ 92,116	935,780,777	\$ 0.000098	\$ 0.000098	\$ 0.000104
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 1,130	14,627,511	\$ 0.000077	\$ 0.000077	\$ 0.000082
	2,479	\$ 1,635,702	8,568,464,579			

**Atlantic City Electric Company**

Proposed PPL Projects Transmission Enhancement Charge (PPL Project-TEC Surcharge) effective September 1, 2022  
To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	50,327
	\$	50,327

2022 ACE Zone Transmission Peak Load (MW) 2,631

Transmission Enhancement Rate (\$/MW) \$ 19.13

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 362,002	4,053,632,865	\$ 0.000089	\$ 0.000089	\$ 0.000095
MGS Secondary	349	\$ 80,089	1,286,085,535	\$ 0.000062	\$ 0.000062	\$ 0.000066
MGS Primary	9	\$ 1,952	45,690,273	\$ 0.000043	\$ 0.000043	\$ 0.000046
AGS Secondary	315	\$ 72,401	1,610,533,369	\$ 0.000045	\$ 0.000045	\$ 0.000048
AGS Primary	88	\$ 20,251	550,675,023	\$ 0.000037	\$ 0.000037	\$ 0.000039
TGS	140	\$ 32,051	935,780,777	\$ 0.000034	\$ 0.000034	\$ 0.000036
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 393	14,627,511	\$ 0.000027	\$ 0.000027	\$ 0.000029
	2,479	\$ 569,137	8,568,464,579			

**Atlantic City Electric Company**

Proposed PECO Projects Transmission Enhancement Charge (PECO-TEC Surcharge) effective September 1, 2022  
To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	113,993
	\$	113,993

2022 ACE Zone Transmission Peak Load (MW) 2,631

Transmission Enhancement Rate (\$/MW) \$ 43.33

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 819,950	4,053,632,865	\$ 0.000202	\$ 0.000203	\$ 0.000216
MGS Secondary	349	\$ 181,404	1,286,085,535	\$ 0.000141	\$ 0.000141	\$ 0.000150
MGS Primary	9	\$ 4,420	45,690,273	\$ 0.000097	\$ 0.000097	\$ 0.000103
AGS Secondary	315	\$ 163,990	1,610,533,369	\$ 0.000102	\$ 0.000102	\$ 0.000109
AGS Primary	88	\$ 45,868	550,675,023	\$ 0.000083	\$ 0.000083	\$ 0.000088
TGS	140	\$ 72,598	935,780,777	\$ 0.000078	\$ 0.000078	\$ 0.000083
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 890	14,627,511	\$ 0.000061	\$ 0.000061	\$ 0.000065
	2,479	\$ 1,289,121	8,568,464,579			

**Atlantic City Electric Company**

Proposed PEPCO Projects Transmission Enhancement Charge (PEPCO Project-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	11,999
	\$	11,999

2022 ACE Zone Transmission Peak Load (MW)	2,631
---	-------

Transmission Enhancement Rate (\$/MW)	\$	4.56
---------------------------------------	----	------

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 86,305	4,053,632,865	\$ 0.000021	\$ 0.000021	\$ 0.000022
MGS Secondary	349	\$ 19,094	1,286,085,535	\$ 0.000015	\$ 0.000015	\$ 0.000016
MGS Primary	9	\$ 465	45,690,273	\$ 0.000010	\$ 0.000010	\$ 0.000011
AGS Secondary	315	\$ 17,261	1,610,533,369	\$ 0.000011	\$ 0.000011	\$ 0.000012
AGS Primary	88	\$ 4,828	550,675,023	\$ 0.000009	\$ 0.000009	\$ 0.000010
TGS	140	\$ 7,641	935,780,777	\$ 0.000008	\$ 0.000008	\$ 0.000009
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 94	14,627,511	\$ 0.000006	\$ 0.000006	\$ 0.000006
	2,479	\$ 135,689	8,568,464,579			

**Atlantic City Electric Company**

Proposed DPL Projects Transmission Enhancement Charge (DPL Project-TEC Surcharge) effective September 1, 2022  
To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	4,818
	\$	4,818

2022 ACE Zone Transmission Peak Load (MW) 2,631

Transmission Enhancement Rate (\$/MW) \$ 1.83

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 34,655	4,053,632,865	\$ 0.000009	\$ 0.000009	\$ 0.000010
MGS Secondary	349	\$ 7,667	1,286,085,535	\$ 0.000006	\$ 0.000006	\$ 0.000006
MGS Primary	9	\$ 187	45,690,273	\$ 0.000004	\$ 0.000004	\$ 0.000004
AGS Secondary	315	\$ 6,931	1,610,533,369	\$ 0.000004	\$ 0.000004	\$ 0.000004
AGS Primary	88	\$ 1,939	550,675,023	\$ 0.000004	\$ 0.000004	\$ 0.000004
TGS	140	\$ 3,068	935,780,777	\$ 0.000003	\$ 0.000003	\$ 0.000003
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 38	14,627,511	\$ 0.000003	\$ 0.000003	\$ 0.000003
	2,479	\$ 54,485	8,568,464,579			

**Atlantic City Electric Company**

Proposed BG&amp;E Projects Transmission Enhancement Charge (BG&amp;E Project-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	21,244
	\$	21,244

2022 ACE Zone Transmission Peak Load (MW)	2,631
---	-------

Transmission Enhancement Rate (\$/MW)	\$	8.07
---------------------------------------	----	------

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 152,804	4,053,632,865	\$ 0.000038	\$ 0.000038	\$ 0.000041
MGS Secondary	349	\$ 33,806	1,286,085,535	\$ 0.000026	\$ 0.000026	\$ 0.000028
MGS Primary	9	\$ 824	45,690,273	\$ 0.000018	\$ 0.000018	\$ 0.000019
AGS Secondary	315	\$ 30,561	1,610,533,369	\$ 0.000019	\$ 0.000019	\$ 0.000020
AGS Primary	88	\$ 8,548	550,675,023	\$ 0.000016	\$ 0.000016	\$ 0.000017
TGS	140	\$ 13,529	935,780,777	\$ 0.000014	\$ 0.000014	\$ 0.000015
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 166	14,627,511	\$ 0.000011	\$ 0.000011	\$ 0.000012
	2,479	\$ 240,238	8,568,464,579			



**Atlantic City Electric Company**

Proposed CW Edison Projects Transmission Enhancement Charge (PPL Project-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	190
	\$	190

2022 ACE Zone Transmission Peak Load (MW) 2,631

Transmission Enhancement Rate (\$/MW) \$ 0.07

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 1,364	4,053,632,865	\$ -	\$ -	\$ -
MGS Secondary	349	\$ 302	1,286,085,535	\$ -	\$ -	\$ -
MGS Primary	9	\$ 7	45,690,273	\$ -	\$ -	\$ -
AGS Secondary	315	\$ 273	1,610,533,369	\$ -	\$ -	\$ -
AGS Primary	88	\$ 76	550,675,023	\$ -	\$ -	\$ -
TGS	140	\$ 121	935,780,777	\$ -	\$ -	\$ -
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 1	14,627,511	\$ -	\$ -	\$ -
	2,479	\$ 2,144	8,568,464,579			

**Atlantic City Electric Company**

Proposed Duquesne Projects Transmission Enhancement Charge (Duquesne Surcharge) effective September 1, 2022  
To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 1, 2022

Transmission Enhancement Costs Allocated to ACE Zone (2022)	\$	950
	\$	950
2022 ACE Zone Transmission Peak Load (MW)		2,631
Transmission Enhancement Rate (\$/MW)	\$	0.36

Rate Class	Col. 1 Transmission Obligation (MW)	Col. 2 Allocated Cost Recovery	Col. 3 BGS Eligible Sales June 2022 - May 2023 (kWh)	Col. 4 = Col. 2/Col. 3 Transmission Enhancement Charge (\$/kWh)	Col. 5 = Col. 4 x 1/(1-Effective Rate) Transmission Enhancement Charge w/ BPU Assessment (\$/kWh)	Col. 6 = Col. 5 x 1.06625 Transmission Enhancement Charge w/ SUT (\$/kWh)
RS	1,577	\$ 6,831	4,053,632,865	\$ 0.000002	\$ 0.000002	\$ 0.000002
MGS Secondary	349	\$ 1,511	1,286,085,535	\$ 0.000001	\$ 0.000001	\$ 0.000001
MGS Primary	9	\$ 37	45,690,273	\$ 0.000001	\$ 0.000001	\$ 0.000001
AGS Secondary	315	\$ 1,366	1,610,533,369	\$ 0.000001	\$ 0.000001	\$ 0.000001
AGS Primary	88	\$ 382	550,675,023	\$ 0.000001	\$ 0.000001	\$ 0.000001
TGS	140	\$ 605	935,780,777	\$ 0.000001	\$ 0.000001	\$ 0.000001
SPL/CSL	-	\$ -	71,439,227	\$ -	\$ -	\$ -
DDC	2	\$ 7	14,627,511	\$ 0.000001	\$ 0.000001	\$ 0.000001
	2,479	\$ 10,739	8,568,464,579			

ACE Project Transmission Enhancement Charge - TEC Surcharge

Rate Class								
	MGS Secondary &							
	RS	MGS-SEVC	MGS Primary	AGS Secondary	AGS Primary	TGS	SPL/CSL	DDC
VEPCo	0.000367	0.000278	0.000256	0.000179	0.000156	0.000133	-	0.000114
TrAILCo	0.000300	0.000250	0.000170	0.000173	0.000138	0.000101	-	0.000104
PSE&G	0.003256	0.002478	0.002276	0.001591	0.001385	0.001184	-	0.001018
PATH	0.000010	0.000007	0.000006	0.000004	0.000004	0.000003	-	0.000003
PPL	0.000090	0.000068	0.000063	0.000044	0.000038	0.000033	-	0.000028
PECO	0.000211	0.000175	0.000119	0.000123	0.000097	0.000071	-	0.000074
Pepco	0.000021	0.000018	0.000013	0.000013	0.000010	0.000007	-	0.000007
MAIT	0.000042	0.000032	0.000029	0.000020	0.000018	0.000015	-	0.000013
JCP&L	0.000003	0.000002	0.000002	0.000001	0.000001	0.000001	-	0.000001
EL05-121	0.000019	0.000015	0.000013	0.000010	0.000009	0.000006	-	0.000006
Delmarva	0.000009	0.000007	0.000005	0.000005	0.000004	0.000003	-	0.000003
BG&E	0.000049	0.000041	0.000028	0.000029	0.000022	0.000017	-	0.000017
AEP - East	0.000081	0.000062	0.000057	0.000039	0.000034	0.000030	-	0.000026
Silver Run	0.000325	0.000247	0.000227	0.000159	0.000139	0.000118	-	0.000101
NIPSCO	0.000003	0.000002	0.000002	0.000002	0.000001	0.000001	-	0.000001
CW Edison	-	-	-	-	-	-	-	-
ER18-680 and Form 715	-	-	-	-	-	-	-	-
SFC	0.000004	0.000003	0.000003	0.000002	0.000002	0.000002	-	0.000001
PSEG ROE-TEC	(0.000112)	(0.000094)	(0.000064)	(0.000065)	(0.000052)	(0.000038)	-	(0.000039)
Total Effective @ 4/1/2022	0.004678	0.003591	0.003205	0.002329	0.002006	0.001687	-	0.001478

  

	MGS Secondary &							
	RS	MGS-SEVC	MGS Primary	AGS Secondary	AGS Primary	TGS	SPL/CSL	DDC
VEPCo	0.000367	0.000278	0.000256	0.000179	0.000156	0.000133	-	0.000114
TrAILCo	0.000275	0.000192	0.000131	0.000138	0.000113	0.000104	-	0.000082
PSE&G	0.003256	0.002478	0.002276	0.001591	0.001385	0.001184	-	0.001018
PATH	0.000010	0.000007	0.000006	0.000004	0.000004	0.000003	-	0.000003
PPL	0.000095	0.000066	0.000046	0.000048	0.000039	0.000036	-	0.000029
PECO	0.000216	0.000150	0.000103	0.000109	0.000088	0.000083	-	0.000065
Pepco	0.000022	0.000016	0.000011	0.000012	0.000010	0.000009	-	0.000006
MAIT	0.000042	0.000032	0.000029	0.000020	0.000018	0.000015	-	0.000013
JCP&L	0.000003	0.000002	0.000002	0.000001	0.000001	0.000001	-	0.000001
EL05-121	0.000019	0.000015	0.000013	0.000010	0.000009	0.000006	-	0.000006
Delmarva	0.000010	0.000006	0.000004	0.000004	0.000004	0.000003	-	0.000003
BG&E	0.000041	0.000028	0.000019	0.000020	0.000017	0.000015	-	0.000012
AEP - East	0.000081	0.000062	0.000057	0.000039	0.000034	0.000030	-	0.000026
Silver Run	0.000325	0.000247	0.000227	0.000159	0.000139	0.000118	-	0.000101
NIPSCO	0.000003	0.000002	0.000002	0.000002	0.000001	0.000001	-	0.000001
CW Edison	-	-	-	-	-	-	-	-
ER18-680 and Form 715	-	-	-	-	-	-	-	-
SFC	0.000004	0.000003	0.000003	0.000002	0.000002	0.000002	-	0.000001
PSEG ROE-TEC	(0.000112)	(0.000094)	(0.000064)	(0.000065)	(0.000052)	(0.000038)	-	(0.000039)
Duquesne	0.000002	0.000001	0.000001	0.000001	0.000001	0.000001	-	0.000001
Total Proposed TEC Effective 9/1/2022	0.004659	0.003491	0.003122	0.002274	0.001969	0.001706	-	0.001443

Attachment 4B – Translation of 2022/2023 Schedule 12 Charges into Rates – PSE&G

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for Allegheny TrAILCo Projects**

TEC Charges for June 2022 - May 2023 \$ 5,131,471.09  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 42.49 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 509.88 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.192587	\$ 0.111333	\$ 0.418258	\$ -	\$ -	\$ 0.191329	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000193	\$ 0.000111	\$ 0.000418	\$ -	\$ -	\$ 0.000191	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1 MW						= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0 MWh						= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5 MWh	unrounded					= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 3,781,321	unrounded					= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.1489 /MWh	unrounded					= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.15 /MWh	rounded to 2 decimal places					= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 3,809,631	unrounded					= (6) * (3)
8	Difference due to rounding	\$ 28,310	unrounded					= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP****Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023****Calculation of costs and monthly PJM charges for BG&E**

TEC Charges for June 2022 - May 2023 \$ 484,837.38  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 4.01 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 48.12 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.018175	\$ 0.010507	\$ 0.039473	\$ -	\$ -	\$ 0.018057	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000018	\$ 0.000011	\$ 0.000039	\$ -	\$ -	\$ 0.000018	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1 MW		= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0 MWh		= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5 MWh	unrounded	= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 356,863	unrounded	= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.0141 /MWh	unrounded	= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.01 /MWh	rounded to 2 decimal places	= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 253,975	unrounded	= (6) * (3)
8	Difference due to rounding	\$ (102,887)	unrounded	= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**

**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**

**Calculation of costs and monthly PJM charges for PPL Projects**

TEC Charges for June 2022 - May 2023 \$ 22,160,806.11  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 183.50 /MW/month  
converted to \$/MW/yr = \$ 2,202.00 /MW/yr

all values show w/o NJ SUT

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.831719	\$ 0.480809	\$ 1.806316	\$ -	\$ -	\$ 0.826284	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000832	\$ 0.000481	\$ 0.001806	\$ -	\$ -	\$ 0.000826	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1 MW						= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0 MWh						= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5 MWh	unrounded					= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 16,330,252	unrounded					= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.6430 /MWh	unrounded					= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.64 /MWh	rounded to 2 decimal places					= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 16,254,425	unrounded					= (6) * (3)
8	Difference due to rounding	\$ (75,827)	unrounded					= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for ACE Projects**

TEC Charges for June 2022 - May 2023 \$ 1,029,122.36  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 8.52 /MW/month  
converted to \$/MW/yr = \$ 102.24 /MW/yr  
all values show w/o NJ SUT

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.038617	\$ 0.022324	\$ 0.083868	\$ -	\$ -	\$ 0.038365	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000039	\$ 0.000022	\$ 0.000084	\$ -	\$ -	\$ 0.000038	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1 MW							= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0 MWh							= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5 MWh	unrounded						= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 758,222	unrounded						= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.0299 /MWh	unrounded						= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.03 /MWh	rounded to 2 decimal places						= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 761,926	unrounded						= (6) * (3)
8	Difference due to rounding	\$ 3,704	unrounded						= (7) - (4)



**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for Delmarva Projects**

TEC Charges for June 2022 - May 2023 \$ 150,846.44  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 1.25 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 15.00 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy charge in \$/MWh	\$ 0.005666	\$ 0.003275	\$ 0.012305	\$ -	\$ -	\$ 0.005629	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000006	\$ 0.000003	\$ 0.000012	\$ -	\$ -	\$ 0.000006	\$ -	\$ -

Line #

1	Total BGS-RSCP eligible Trans Obl	7,416.1 MW						= sum of BGS-RSCP eligible Trans Obl
2	Total BGS-RSCP eligible energy @ cust	24,088,681.0 MWh						= sum of BGS-RSCP eligible kWh @ cust
3	Total BGS-RSCP eligible energy @ trans nodes	25,397,539.5 MWh	unrounded					= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 111,242	unrounded					= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.0044 /MWh	unrounded					= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ - /MWh	rounded to 2 decimal places					= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ -	unrounded					= (6) * (3)
8	Difference due to rounding	\$ (111,242)	unrounded					= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for PEPCO Projects**

TEC Charges for June 2022 - May 2023	\$	321,993.54	
PSE&G Zonal Transmission Load for Effective Yr. (MW)		10,064.1	
Term (Months)		12	
OATT rate	\$	2.67 /MW/month	all values show w/o NJ SUT
converted to \$/MW/yr =	\$	32.04 /MW/yr	

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.012102	\$ 0.006996	\$ 0.026283	\$ -	\$ -	\$ 0.012023	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000012	\$ 0.000007	\$ 0.000026	\$ -	\$ -	\$ 0.000012	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1	MW		= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0	MWh		= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5	MWh	unrounded	= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 237,612		unrounded	= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.0094	/MWh	unrounded	= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.01	/MWh	rounded to 2 decimal places	= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 253,975		unrounded	= (6) * (3)
8	Difference due to rounding	\$ 16,364		unrounded	= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for PECO Energy Company Transmission Projects**

TEC Charges for June 2022 - May 2023 \$ 2,407,268.96  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 19.93 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 239.16 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy Charge								
in \$/MWh	\$ 0.090333	\$ 0.052221	\$ 0.196185	\$ -	\$ -	\$ 0.089743	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000090	\$ 0.000052	\$ 0.000196	\$ -	\$ -	\$ 0.000090	\$ -	\$ -

Line #

1	Total BGS-RSCP Trans Obl	7,416.1 MW				= sum of BGS-RSCP eligible Trans Obl adjusted for migration
2	Total BGS-RSCP energy @ cust	24,088,681.0 MWh				= sum of BGS-RSCP eligible kWh @ cust adjusted for migration
3	Total BGS-RSCP energy @ trans nodes	25,397,539.5 MWh	unrounded			= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 1,773,634	unrounded			= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.0698 /MWh	unrounded			= (4) / (3)
6	Change in Average Supplier Payment Rate	\$ 0.07 /MWh	rounded to 2 decimal places			= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ 1,777,828	unrounded			= (6) * (3)
8	Difference due to rounding	\$ 4,193	unrounded			= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for Commonwealth Edison**

TEC Charges for June 2022 - May 2023 \$ 14,789.31  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 0.12 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 1.44 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy charge								
in \$/MWh	\$ 0.000544	\$ 0.000314	\$ 0.001181	\$ -	\$ -	\$ 0.000540	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000001	\$ -	\$ 0.000001	\$ -	\$ -	\$ 0.000001	\$ -	\$ -

Line #

1	Total BGS-RSCP eligible Trans Obl	7,416.1 MW				= sum of BGS-RSCP eligible Trans Obl
2	Total BGS-RSCP eligible energy @ cust	24,088,681.0 MWh				= sum of BGS-RSCP eligible kWh @ cust
3	Total BGS-RSCP eligible energy @ trans nodes	25,397,539.5 MWh	unrounded			= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 10,679.1840	unrounded			= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.00 /MWh	unrounded			= (4) / (3)
6	Change in Average Supplier Payment Rate	0 /MWh	rounded to 2 decimal places			= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ -	unrounded			= (6) * (3)
8	Difference due to rounding	\$ (10,679)	unrounded			= (7) - (4)

**Transmission Charge Adjustment - BGS-RSCP**  
**Attachment 4B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for Duquesne**

TEC Charges for June 2022 - May 2023 \$ 39,711.33  
PSE&G Zonal Transmission Load for Effective Yr. (MW) 10,064.1  
Term (Months) 12  
OATT rate \$ 0.33 /MW/month all values show w/o NJ SUT  
converted to \$/MW/yr = \$ 3.96 /MW/yr

	RS	RHS	RLM	WH	WHS	HS	PSAL	BPL
Trans Obl - MW	4,775.1	20.0	64.5	0.0	0.0	3.0	0.0	0.0
Total Annual Energy - MWh	12,642,216.8	91,595.6	78,629.1	575.0	11.0	7,994.8	141,581.0	300,241.0
Energy charge								
in \$/MWh	\$ 0.001496	\$ 0.000865	\$ 0.003248	\$ -	\$ -	\$ 0.001486	\$ -	\$ -
in \$/kWh - rounded to 6 places	\$ 0.000001	\$ 0.000001	\$ 0.000003	\$ -	\$ -	\$ 0.000001	\$ -	\$ -

Line #

1	Total BGS-RSCP eligible Trans Obl	7,416.1 MW			= sum of BGS-RSCP eligible Trans Obl
2	Total BGS-RSCP eligible energy @ cust	24,088,681.0 MWh			= sum of BGS-RSCP eligible kWh @ cust
3	Total BGS-RSCP eligible energy @ trans nodes	25,397,539.5 MWh	unrounded		= (2) * loss expansion factor to trans node
4	Change in OATT rate * total Trans Obl	\$ 29,367.7560	unrounded		= Change in OATT rate * Total BGS-RSCP eligible Trans Obl
5	Change in Average Supplier Payment Rate	\$ 0.00 /MWh	unrounded		= (4) / (3)
6	Change in Average Supplier Payment Rate	0 /MWh	rounded to 2 decimal places		= (5) rounded to 2 decimal places
7	Proposed Total Supplier Payment	\$ -	unrounded		= (6) * (3)
8	Difference due to rounding	\$ (29,368)	unrounded		= (7) - (4)

Attachment 4C – Translation of 2022/2023 Schedule 12 Charges into Rates – JCP&L

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed Trailco Project Transmission Enhancement Charge (Trailco-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved Trailco Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly Trailco-TEC Costs Allocated to JCP&L Zone	\$303,085.84	(1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10	
Trailco-Transmission Enhancement Rate (\$/MW-month)	\$49.13	

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	Trailco-TEC Surcharge (\$/kWh)	Trailco-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$3,191,669	16,394,489,049	\$0.000195	\$0.000208
Primary	318.5	\$187,790	1,618,140,790	\$0.000116	\$0.000124
Transmission @ 34.5 kV	270.4	\$159,409	1,506,974,917	\$0.000106	\$0.000113
Transmission @ 230 kV	18.6	\$10,966	354,832,301	\$0.000031	\$0.000033
Total	6,021.2	\$3,549,835	19,874,437,057		

(1) Cost Allocation of Trailco Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on Trailco Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

BGS-RSCP Transmission Payment Adjustment

Line No.

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	Trailco-Transmission Enhancement Costs	\$2,823,874 = Line 3 x \$49.13 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.16 = Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed BG&E Project Transmission Enhancement Charge (BG&E-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved BG&E Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly BG&E-TEC Costs Allocated to JCP&L Zone	\$23,381.92 (1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10
BG&E-Transmission Enhancement Rate (\$/MW-month)	\$3.79

September 1, 2022					
BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	BG&E-TEC Surcharge (\$/kWh)	BG&E-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$246,225	16,394,489,049	\$0.000015	\$0.000016
Primary	318.5	\$14,487	1,618,140,790	\$0.000009	\$0.000010
Transmission @ 34.5 kV	270.4	\$12,298	1,506,974,917	\$0.000008	\$0.000009
Transmission @ 230 kV	18.6	\$846	354,832,301	\$0.000002	\$0.000002
Total	6,021.2	\$273,856	19,874,437,057		

(1) Cost Allocation of BG&E Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on BG&E Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

BGS-RSCP Transmission Payment Adjustment

Line No.

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	BG&E-Transmission Enhancement Costs	\$217,840 = Line 3 x \$3.79 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.01 = Line 4 / Line 2



**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed PPL Project Transmission Enhancement Charge (PPL-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved PPL Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly PPL-TEC Costs Allocated to JCP&L Zone	\$938,471.92 (1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10
PPL-Transmission Enhancement Rate (\$/MW-month)	\$152.12

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	PPL-TEC Surcharge (\$/kWh)	PPL-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$9,882,652	16,394,489,049	\$0.000603	\$0.000643
Primary	318.5	\$581,472	1,618,140,790	\$0.000359	\$0.000383
Transmission @ 34.5 kV	270.4	\$493,593	1,506,974,917	\$0.000328	\$0.000350
Transmission @ 230 kV	18.6	\$33,954	354,832,301	\$0.000096	\$0.000102
Total	6,021.2	\$10,991,672	19,874,437,057		

(1) Cost Allocation of PPL Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on PPL Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

**BGS-RSCP Transmission Payment Adjustment**

**Line No.**

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	PPL-Transmission Enhancement Costs	\$8,743,493 = Line 3 x \$152.12 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.51 = Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed ACE Project Transmission Enhancement Charge (ACE-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved ACE Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly ACE-TEC Costs Allocated to JCP&L Zone	\$142,907.99	(1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10	
ACE-Transmission Enhancement Rate (\$/MW-month)	\$23.17	

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	ACE-TEC Surcharge (\$/kWh)	ACE-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$1,504,904	16,394,489,049	\$0.000092	\$0.000098
Primary	318.5	\$88,545	1,618,140,790	\$0.000055	\$0.000059
Transmission @ 34.5 kV	270.4	\$75,163	1,506,974,917	\$0.000050	\$0.000053
Transmission @ 230 kV	18.6	\$5,170	354,832,301	\$0.000015	\$0.000016
Total	6,021.2	\$1,673,782	19,874,437,057		

(1) Cost Allocation of ACE Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on ACE Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

BGS-RSCP Transmission Payment Adjustment

Line No.

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538	MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608	MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80	MW
4	ACE-Transmission Enhancement Costs	\$1,331,756	= Line 3 x \$23.17 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.08	= Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed Delmarva Project Transmission Enhancement Charge (Delmarva-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved Delmarva Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly Delmarva-TEC Costs Allocated to JCP&L Zone	\$8,284.68	(1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10	
Delmarva-Transmission Enhancement Rate (\$/MW-month)	\$1.34	

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	Delmarva-TEC Surcharge (\$/kWh)	Delmarva-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$87,242	16,394,489,049	\$0.000005	\$0.000005
Primary	318.5	\$5,133	1,618,140,790	\$0.000003	\$0.000003
Transmission @ 34.5 kV	270.4	\$4,357	1,506,974,917	\$0.000003	\$0.000003
Transmission @ 230 kV	18.6	\$300	354,832,301	\$0.000001	\$0.000001
Total	6,021.2	\$97,033	19,874,437,057		

(1) Cost Allocation of Delmarva Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on Delmarva Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

**BGS-RSCP Transmission Payment Adjustment**

**Line No.**

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538	MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608	MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80	MW
4	Delmarva-Transmission Enhancement Costs	\$77,020	= Line 3 x \$1.34 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.00	= Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed PEPCO Project Transmission Enhancement Charge (PEPCO-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved PEPCO Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly PEPCO-TEC Costs Allocated to JCP&L Zone	\$18,403.99 (1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10
PEPCO-Transmission Enhancement Rate (\$/MW-month)	\$2.98

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	PEPCO-TEC Surcharge (\$/kWh)	PEPCO-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$193,805	16,394,489,049	\$0.000012	\$0.000013
Primary	318.5	\$11,403	1,618,140,790	\$0.000007	\$0.000007
Transmission @ 34.5 kV	270.4	\$9,680	1,506,974,917	\$0.000006	\$0.000006
Transmission @ 230 kV	18.6	\$666	354,832,301	\$0.000002	\$0.000002
Total	6,021.2	\$215,553	19,874,437,057		

(1) Cost Allocation of PEPCO Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on PEPCO Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

BGS-RSCP Transmission Payment Adjustment

Line No.

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	PEPCO-Transmission Enhancement Costs	\$171,283 = Line 3 x \$2.98 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.01 = Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed PECO Project Transmission Enhancement Charge (PECO-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved PECO Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly PECO-TEC Costs Allocated to JCP&L Zone	\$99,288.64	(1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10	
PECO-Transmission Enhancement Rate (\$/MW-month)	\$16.09	

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	PECO-TEC Surcharge (\$/kWh)	PECO-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$1,045,567	16,394,489,049	\$0.000064	\$0.000068
Primary	318.5	\$61,519	1,618,140,790	\$0.000038	\$0.000041
Transmission @ 34.5 kV	270.4	\$52,221	1,506,974,917	\$0.000035	\$0.000037
Transmission @ 230 kV	18.6	\$3,592	354,832,301	\$0.000010	\$0.000011
Total	6,021.2	\$1,162,899	19,874,437,057		

(1) Cost Allocation of PECO Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on PECO Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

**BGS-RSCP Transmission Payment Adjustment**

**Line No.**

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538	MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608	MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80	MW
4	PECO-Transmission Enhancement Costs	\$924,815	= Line 3 x \$16.09 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.05	= Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed CW Edison Project Transmission Enhancement Charge (CW Edison-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved CW Edison Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly CW Edison-TEC Costs Allocated to JCP&L Zone	\$547.75 (1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10
CW Edison-Transmission Enhancement Rate (\$/MW-month)	\$0.09

September 1, 2022					
BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	CW Edison-TEC Surcharge (\$/kWh)	CW Edison-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$5,768	16,394,489,049	\$0.000000	\$0.000000
Primary	318.5	\$339	1,618,140,790	\$0.000000	\$0.000000
Transmission @ 34.5 kV	270.4	\$288	1,506,974,917	\$0.000000	\$0.000000
Transmission @ 230 kV	18.6	\$20	354,832,301	\$0.000000	\$0.000000
Total	6,021.2	\$6,415	19,874,437,057		

(1) Cost Allocation of CW Edison Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on CW Edison Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

BGS-RSCP Transmission Payment Adjustment

Line No.

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	CW Edison-Transmission Enhancement Costs	\$5,173 = Line 3 x \$0.09 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.00 = Line 4 / Line 2

**Attachment 4c - JCP&L Translation of Schedule 12 Transmission Enhancement Charges into Customer Rates (Riders RSCP and CIEP)**

**Jersey Central Power & Light Company**

Proposed Duquesne Project Transmission Enhancement Charge (Duquesne-TEC Surcharge) effective September 1, 2022

To reflect FERC-approved Duquesne Project Transmission Enhancement Charge (Schedule 12 PJM OATT) effective June 2022 - May 2023

2022 Average Monthly Duquesne-TEC Costs Allocated to JCP&L Zone	\$0.00	(1)
2022 JCP&L Zone Transmission Peak Load (MW)	6,169.10	
Duquesne-Transmission Enhancement Rate (\$/MW-month)	\$0.00	

**September 1, 2022**

BGS by Voltage Level	Retail Transmission Obligation (MW)	Allocated Cost Recovery (\$) (2)	BGS Eligible Sales (kWh) (3)	Duquesne-TEC Surcharge (\$/kWh)	Duquesne-TEC Surcharge w/ SUT(\$/kWh)
Secondary (excluding lighting)	5,413.7	\$0	16,394,489,049	\$0.000000	\$0.000000
Primary	318.5	\$0	1,618,140,790	\$0.000000	\$0.000000
Transmission @ 34.5 kV	270.4	\$0	1,506,974,917	\$0.000000	\$0.000000
Transmission @ 230 kV	18.6	\$0	354,832,301	\$0.000000	\$0.000000
Total	6,021.2	\$0	19,874,437,057		

(1) Cost Allocation of Duquesne Project Schedule 12 Charges to JCP&L Zone for 2022

(2) Based on Duquesne Project costs from June 2022 through May 2023

(3) September 2022 through August 2023

**BGS-RSCP Transmission Payment Adjustment**

**Line No.**

1	BGS-RSCP Eligible Sales June through May @ Customer	15,600,538 MWH
2	BGS-RSCP Eligible Sales June through May @ Transmission Node	17,289,608 MWH
3	BGS-RSCP Eligible Transmission Obligation	4,789.80 MW
4	Duquesne-Transmission Enhancement Costs	\$0 = Line 3 x \$0 x 12
5	Change to Transmission Payment Rates \$/MWH (rounded to 2 decimals)	\$0.00 = Line 4 / Line 2

Attachment 4D – Translation of 2022/2023 Schedule 12 Charges into Rates – RECO



**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (TrAILCo) effective September 1, 2022

To reflect FERC-approved TrAILCo Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly TrAILCo-TEC Costs Allocated to RECO	\$	17,609	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	35.97	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$17,609 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 138,459	675,953,000	\$ 0.00020	\$ 0.00021
SC2 Secondary	117.3	23.96%	\$ 50,619	490,902,000	\$ 0.00010	\$ 0.00011
SC2 Primary	15.2	3.11%	\$ 6,574	57,502,000	\$ 0.00011	\$ 0.00012
SC3	0.1	0.02%	\$ 51	328,000	\$ 0.00016	\$ 0.00017
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 15,603	225,169,000	\$ 0.00007	\$ 0.00007
Total	489.5 (2)	100.00%	\$ 211,306	1,461,801,000		

(1) Attachment 5A- Cost Allocation of TrAILCo Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 195,703.77	= Line 3 x \$35.97 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.18	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (BG&amp;E) effective September 1, 2022

To reflect FERC-approved BG&amp;E Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly BG&E-TEC Costs Allocated to RECO	\$	1,519	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	3.10	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$1,519 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 11,944	675,953,000	\$ 0.00002	\$ 0.00002
SC2 Secondary	117.3	23.96%	\$ 4,367	490,902,000	\$ 0.00001	\$ 0.00001
SC2 Primary	15.2	3.11%	\$ 567	57,502,000	\$ 0.00001	\$ 0.00001
SC3	0.1	0.02%	\$ 4	328,000	\$ 0.00001	\$ 0.00001
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 1,346	225,169,000	\$ 0.00001	\$ 0.00001
Total	489.5 (2)	100.00%	\$ 18,228	1,461,801,000		

(1) Attachment 5B- Cost Allocation of BG&amp;E Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 16,866.32	= Line 3 x \$3.1 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.02	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (PPL) effective September 1, 2022

To reflect FERC-approved PPL Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly PPL-TEC Costs Allocated to RECO	\$	72,242	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	147.57	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$72,242 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 568,046	675,953,000	\$ 0.00084	\$ 0.00090
SC2 Secondary	117.3	23.96%	\$ 207,670	490,902,000	\$ 0.00042	\$ 0.00045
SC2 Primary	15.2	3.11%	\$ 26,971	57,502,000	\$ 0.00047	\$ 0.00050
SC3	0.1	0.02%	\$ 210	328,000	\$ 0.00064	\$ 0.00068
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 64,012	225,169,000	\$ 0.00028	\$ 0.00030
Total	489.5 (2)	100.00%	\$ 866,909	1,461,801,000		

(1) Attachment 6k- Cost Allocation of PPL Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 802,891.46	= Line 3 x \$147.57 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.73	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (ACE) effective September 1, 2022

To reflect FERC-approved ACE Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly ACE-TEC Costs Allocated to RECO	\$	2,487	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	5.08	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$2,487 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 19,556	675,953,000	\$ 0.00003	\$ 0.00003
SC2 Secondary	117.3	23.96%	\$ 7,149	490,902,000	\$ 0.00001	\$ 0.00001
SC2 Primary	15.2	3.11%	\$ 929	57,502,000	\$ 0.00002	\$ 0.00002
SC3	0.1	0.02%	\$ 7	328,000	\$ 0.00002	\$ 0.00002
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 2,204	225,169,000	\$ 0.00001	\$ 0.00001
Total	489.5 (2)	100.00%	\$ 29,845	1,461,801,000		

(1) Attachment 5D- Cost Allocation of ACE Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 27,639.01	= Line 3 x \$5.08 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.03	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (Delmarva) effective September 1, 2022

To reflect FERC-approved Delmarva Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly Delmarva-TEC Costs Allocated to RECO	\$	392	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	0.80	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$392 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 3,081	675,953,000	\$ -	\$ -
SC2 Secondary	117.3	23.96%	\$ 1,126	490,902,000	\$ -	\$ -
SC2 Primary	15.2	3.11%	\$ 146	57,502,000	\$ -	\$ -
SC3	0.1	0.02%	\$ 1	328,000	\$ -	\$ -
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 347	225,169,000	\$ -	\$ -
Total	489.5 (2)	100.00%	\$ 4,701	1,461,801,000		

(1) Attachment 5E- Cost Allocation of Delmarva Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 4,352.60	= Line 3 x \$0.8 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ -	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (PEPCO) effective September 1, 2022

To reflect FERC-approved PEPCO Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly PEPCO-TEC Costs Allocated to RECO	\$	743	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	1.52	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$743 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 5,839	675,953,000	\$ 0.00001	\$ 0.00001
SC2 Secondary	117.3	23.96%	\$ 2,135	490,902,000	\$ -	\$ -
SC2 Primary	15.2	3.11%	\$ 277	57,502,000	\$ -	\$ -
SC3	0.1	0.02%	\$ 2	328,000	\$ 0.00001	\$ 0.00001
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 658	225,169,000	\$ -	\$ -
Total	489.5 (2)	100.00%	\$ 8,911	1,461,801,000		

(1) Attachment 5F- Cost Allocation of PEPCO Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 8,269.94	= Line 3 x \$1.52 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.01	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (PECO) effective September 1, 2022

To reflect FERC-approved PECO Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly PECO-TEC Costs Allocated to RECO	\$	7,618	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	15.56	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$7,618 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 59,900	675,953,000	\$ 0.00009	\$ 0.00010
SC2 Secondary	117.3	23.96%	\$ 21,899	490,902,000	\$ 0.00004	\$ 0.00004
SC2 Primary	15.2	3.11%	\$ 2,844	57,502,000	\$ 0.00005	\$ 0.00005
SC3	0.1	0.02%	\$ 22	328,000	\$ 0.00007	\$ 0.00007
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 6,750	225,169,000	\$ 0.00003	\$ 0.00003
Total	489.5 (2)	100.00%	\$ 91,415	1,461,801,000		

(1) Attachment 5G- Cost Allocation of PECO Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 84,658.07	= Line 3 x \$15.56 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ 0.08	= Line 4/Line 2

**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (CW Edison) effective September 1, 2022

To reflect FERC-approved CW Edison Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2022

2022 Average Monthly CW Edison-TEC Costs Allocated to RECO	\$	147	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	0.30	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$147 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ 1,160	675,953,000	\$ -	\$ -
SC2 Secondary	117.3	23.96%	\$ 424	490,902,000	\$ -	\$ -
SC2 Primary	15.2	3.11%	\$ 55	57,502,000	\$ -	\$ -
SC3	0.1	0.02%	\$ -	328,000	\$ -	\$ -
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ 131	225,169,000	\$ -	\$ -
Total	489.5 (2)	100.00%	\$ 1,770	1,461,801,000		

(1) Attachment 5H- Cost Allocation of CW Edison Schedule 12 Charges to RECO Zone for June 2022 - May 2022

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH
3	BGS-RSCP Eligible Transmission Obligation	453	MW
4	Transmission Enhancement Costs to RSCP Suppliers	\$ 1,631.81	= Line 3 x \$0.3 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ -	= Line 4/Line 2



**Rockland Electric Company**

Calculation of Transmission Surcharges reflecting changes in Transmission Enhancement Charges (Duquesne) effective September 1, 2022

To reflect FERC-approved Duquesne Project Schedule 12 Charges (Schedule 12 PJM OATT) for the period June 2022 - May 2023

2022 Average Monthly Duquesne-TEC Costs Allocated to RECO	\$	-	(1)
2022 RECO Zone Transmission Peak Load (MW)		489.5	(2)
Transmission Enhancement Rate (\$/MW-month)	\$	-	
SUT		6.625%	

	Col. 1	Col. 2	Col.3=Col.2 x \$000 x 12	Col. 4	Col. 5 = Col. 3/Col. 4	Col. 6 = Col. 5 x 1.07
Rate Class	BGS-Eligible Transmission Obligation (MW)	Transmission Obligation (Pct)	Allocated Cost Recovery (1)	BGS Eligible Sales September 2022 - August 2023 (kWh)	Transmission Enhancement Charge (\$/kWh)	Transmission Enhancement Charge w/ SUT (\$/kWh)
SC1/SC5	320.8	65.53%	\$ -	675,953,000	\$ -	\$ -
SC2 Secondary	117.3	23.96%	\$ -	490,902,000	\$ -	\$ -
SC2 Primary	15.2	3.11%	\$ -	57,502,000	\$ -	\$ -
SC3	0.1	0.02%	\$ -	328,000	\$ -	\$ -
SC4	0.0	0.00%	\$ -	6,629,000	\$ -	\$ -
SC6	0.0	0.00%	\$ -	5,318,000	\$ -	\$ -
SC7	36.1	7.38%	\$ -	225,169,000	\$ -	\$ -
Total	489.5 (2)	100.00%	\$ -	1,461,801,000		

(1) Attachment 5A- Cost Allocation of Duquesne Schedule 12 Charges to RECO Zone for June 2022 - May 2023

(2) Includes RECO's Central and Western Divisions

**BGS-FP Supplier Payment Adjustment**Line No.

1	BGS-RSCP Eligible Sales Sep - Aug @ cust (RECO Eastern Division)	1,182,864	MWH	
2	BGS-RSCP Eligible Sales Sep - Aug @ trans node (RECO Eastern Division)	1,099,367	MWH	
3	BGS-RSCP Eligible Transmission Obligation	453	MW	
4	Transmission Enhancement Costs to RSCP Suppliers	\$ -		= Line 3 x \$0 * 12
5	Change in Supplier Payment Rate \$/MWH (rounded to 2 decimals)	\$ -		= Line 4/Line 2

**Rockland Electric Company**

Attachment 4D

Calculation of Transmission Surcharges reflecting proposed changes effective September 1, 2022

To reflect: RMR Costs

FERC-approved ACE Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved AEP-East Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved BG&E Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved Delmarva Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved PATH Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved PEPCO Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved PPL Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved PSE&G Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved TrailCo Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved VEPco Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved MAIT Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved JCP&L Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved PECO Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved CW Edison Project Schedule 12 Charges (Schedule 12 PJM OATT)  
 FERC-approved EL05-121 Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved Silver Run Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved NIPSCO Project Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved SFC Projects Schedule 12 Charges (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved PSEG Projects Schedule 12 ROE TEC rates (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved PSEG Projects Schedule 12 ROE TEC rates (Schedule 12 PJM OATT) currently in RECO's rates  
 FERC-approved Duquesne Project Schedule 12 Charges (Schedule 12 PJM OATT)

**(A) Transmission Surcharge rates by Transmission Project and Service Class (excluding SUT)**

Transmission Projects	Note	SC1	SC2 Sec	SC2 Pri	SC3	SC4	SC6	SC7
Reliability Must Run	(1)	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
ACE - TEC	(2)	0.00003	0.00001	0.00002	0.00002	0.00000	0.00000	0.00001
AEP-East - TEC	(3)	0.00009	0.00005	0.00005	0.00007	0.00000	0.00000	0.00003
BG&E- TEC	(4)	0.00002	0.00001	0.00001	0.00001	0.00000	0.00000	0.00001
Delmarva - TEC	(5)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
PATH - TEC	(6)	0.00001	0.00000	0.00000	0.00001	0.00000	0.00000	0.00000
PEPCO - TEC	(7)	0.00001	0.00000	0.00000	0.00001	0.00000	0.00000	0.00000
PPL - TEC	(8)	0.00084	0.00042	0.00047	0.00064	0.00000	0.00000	0.00028
PSE&G - TEC	(9)	0.01078	0.00546	0.00619	0.00808	0.00000	0.00000	0.00376
TrailCo - TEC	(10)	0.00020	0.00010	0.00011	0.00016	0.00000	0.00000	0.00007
VEPco - TEC	(11)	0.00035	0.00018	0.00020	0.00026	0.00000	0.00000	0.00012
MAIT -TEC	(12)	0.00007	0.00003	0.00004	0.00005	0.00000	0.00000	0.00002
JCP&L -TEC	(13)	0.00029	0.00015	0.00017	0.00022	0.00000	0.00000	0.00010
PECO -TEC	(14)	0.00009	0.00004	0.00005	0.00007	0.00000	0.00000	0.00003
CW Edison-TEC	(15)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
EL05-121	(16)	0.00034	0.00017	0.00020	0.00026	0.00000	0.00000	0.00012
Silver RunTEC	(17)	0.00015	0.00008	0.00009	0.00011	0.00000	0.00000	0.00005
NIPSCO TEC	(18)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
SFC TEC	(19)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
PSE&G ROE-TEC	(20)	(0.00032)	(0.00016)	(0.00020)	(0.00026)	0.00000	0.00000	(0.00012)
Duquesne-TEC	(21)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
Total (\$/kWh and excl SUT)		\$0.01295	\$0.00654	\$0.00740	\$0.00971	\$0.00000	\$0.00000	\$0.00448
Total (¢/kWh and excl SUT)		1.295 ¢	0.654 ¢	0.740 ¢	0.971 ¢	0.000 ¢	0.000 ¢	0.448 ¢

**(B) Transmission Surcharge rates by Transmission Project and Service Class (including SUT)**

6.625%

Transmission Projects	Note	SC1	SC2 Sec	SC2 Pri	SC3	SC4	SC6	SC7
Reliability Must Run	(1)	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000	\$0.00000
ACE - TEC	(2)	0.00003	0.00001	0.00002	0.00002	0.00000	0.00000	0.00001
AEP-East- TEC	(3)	0.00010	0.00005	0.00005	0.00007	0.00000	0.00000	0.00003
BG&E- TEC	(4)	0.00002	0.00001	0.00001	0.00001	0.00000	0.00000	0.00001
Delmarva - TEC	(5)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
PATH - TEC	(6)	0.00001	0.00000	0.00000	0.00001	0.00000	0.00000	0.00000
PEPCO - TEC	(7)	0.00001	0.00000	0.00000	0.00001	0.00000	0.00000	0.00000
PPL - TEC	(8)	0.00090	0.00045	0.00050	0.00068	0.00000	0.00000	0.00030
PSE&G - TEC	(9)	0.01149	0.00582	0.00660	0.00862	0.00000	0.00000	0.00401
TrailCo - TEC	(10)	0.00021	0.00011	0.00012	0.00017	0.00000	0.00000	0.00007
VEPco - TEC	(11)	0.00037	0.00019	0.00021	0.00028	0.00000	0.00000	0.00013
MAIT -TEC	(12)	0.00007	0.00003	0.00004	0.00005	0.00000	0.00000	0.00002
JCP&L -TEC	(13)	0.00031	0.00016	0.00018	0.00023	0.00000	0.00000	0.00011
PECO -TEC	(14)	0.00010	0.00004	0.00005	0.00007	0.00000	0.00000	0.00003
CW Edison-TEC	(15)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
EL05-121	(16)	0.00036	0.00018	0.00021	0.00028	0.00000	0.00000	0.00013
Silver Run TEC	(17)	0.00016	0.00009	0.00010	0.00012	0.00000	0.00000	0.00005
NIPSCO TEC	(18)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
SFC -TEC	(19)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
PSE&G ROE - TEC	(20)	(0.00034)	(0.00017)	(0.00021)	(0.00028)	0.00000	0.00000	(0.00013)
Duquesne-TEC	(21)	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
Total (\$/kWh and incl SUT)		\$0.01380	\$0.00697	\$0.00788	\$0.01034	\$0.00000	\$0.00000	\$0.00477
Total (¢/kWh and incl SUT)		1.380 ¢	0.697 ¢	0.788 ¢	1.034 ¢	0.000 ¢	0.000 ¢	0.477 ¢

**Notes:**

- (1) RMR rates based on allocation by transmission zone.
- (2) ACE-TEC rates calculated in attachment 6D of the joint filing.
- (3) AEP-East-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (4) BG&E-TEC rates calculated in attachment 6B of the joint filing.
- (5) Delmarva-TEC rates calculated in attachment 6E of the joint filing.
- (6) PATH-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (7) PEPCO-TEC rates calculated in attachment 6F of the joint filing.
- (8) PPL-TEC rates calculated in attachment 6C of the joint filing.
- (9) PSE&G-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (10) TrailCo-TEC rates calculated in attachment 6A of the joint filing.
- (11) VEPco-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (12) MAIT-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (13) JCP&L-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (14) PECO-TEC rates calculated in attachment 6G of the joint filing.
- (15) CW Edison-TEC rates calculated in attachment 6H of the joint filing.
- (16) EL05-121 rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (17) Silver Run-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (18) NIPSCO-TEC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (19) SFC rates pursuant to the Board's Order dated March 9, 2022 in Docket No. ER22010028.
- (20) PSE&G ROE-TEC rates pursuant to the Board's Order dated January 12, 2022 in Docket No. ER21121246.
- (21) Duquesne-TEC rates calculated in attachment 6I of the joint filing.

Attachment 5A – Cost Allocation of 2022/2023 TrailCo Schedule 12 Charges  
Attachment 5B – Cost Allocation of 2022/2023 BG&E Schedule 12 Charges  
Attachment 5C – Cost Allocation of 2022/2023 PPL Schedule 12 Charges  
Attachment 5D – Cost Allocation of 2022/2023 ACE Schedule 12 Charges  
Attachment 5E – Cost Allocation of 2022/2023 Delmarva Schedule 12 Charges  
Attachment 5F – Cost Allocation of 2022/2023 PEPCO Schedule 12 Charges  
Attachment 5G – Cost Allocation of 2022/2023 PECO Schedule 12 Charges  
Attachment 5H – Cost Allocation of 2022/2023 CW Edison Schedule 12 Charges  
Attachment 5I – Cost Allocation of 2022/2023 Duquesne Schedule 12 Charges

Attachment 5A – Cost Allocation of 2022/2023 TrailCo Schedule 12 Charges

**Attachment 5A PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for Allegheny TrAILCo Projects**

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
			<i>per PJM Open Access Transmission Tariff</i>								
502 Junction-Mt Storm-Meadowbrook (>=500kV) - CWIP <sup>1</sup>	b0328.1; b0328.2; b0347.1; b0347.2; b0347.3; b0347.4	\$ 54,156,794.17	1.67%	3.92%	6.40%	0.27%	\$904,418	\$2,122,946	\$3,466,035	\$146,223	\$6,639,623
Wylie Ridge <sup>2</sup>	b0218	\$ 2,144,504.74	11.83%	15.56%	0.00%	0.00%	\$253,695	\$333,685	\$0	\$0	\$587,380
Black Oak	b0216	\$ 2,317,090.39	1.67%	3.92%	6.40%	0.27%	\$38,695	\$90,830	\$148,294	\$6,256	\$284,075
Meadowbrook 200 MVAR capacitor	b0559	\$ 327,214.24	1.67%	3.92%	6.40%	0.27%	\$5,464	\$12,827	\$20,942	\$883	\$40,116
Replace Kammer 765/500 kV TXfmr	b0495	\$ 1,832,881.17	1.67%	3.92%	6.40%	0.27%	\$30,609	\$71,849	\$117,304	\$4,949	\$224,711
Doubs TXfmr 2	b0343	\$ 487,347.95	1.85%	0.00%	0.00%	0.00%	\$9,016	\$0	\$0	\$0	\$9,016
Doubs TXfmr 3	b0344	\$ 380,773.38	1.86%	0.00%	0.00%	0.00%	\$7,082	\$0	\$0	\$0	\$7,082
Doubs TXfmr 4	b0345	\$ 605,726.54	1.85%	0.00%	0.00%	0.00%	\$11,206	\$0	\$0	\$0	\$11,206
New Osage 138KV Ckt	b0674	\$ 2,337,099.75	0.00%	0.00%	0.25%	0.01%	\$0	\$0	\$5,843	\$234	\$6,076
Cap at Grover 230 Upgrade transformer 500/230	b0556	\$ 89,958.82	8.58%	18.16%	26.13%	0.97%	\$7,718	\$16,337	\$23,506	\$873	\$48,434
Build a 300 MVAR Switched Shunt at Doubs 500kV	b1153	\$ 2,945,594.54	3.74%	12.57%	20.52%	0.72%	\$110,165	\$370,261	\$604,436	\$21,208	\$1,106,071
	b1803	\$ 255,000.10	1.67%	3.92%	6.40%	0.27%	\$4,259	\$9,996	\$16,320	\$689	\$31,263
Install 500 MVAR svc at Hunterstown 500kV Sub	b1800	\$ 2,246,867.25	1.67%	3.92%	6.40%	0.27%	\$37,523	\$88,077	\$143,800	\$6,067	\$275,466
Install 500 MVAR svc at Hunterstown 500kV Sub	b1800_dfax	\$ 2,246,867.25	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0
Install a new 600 MVAR SVC at Meadowbrook 500 kV	b1804	\$ 3,803,881.35	1.67%	3.92%	6.40%	0.27%	\$63,525	\$149,112	\$243,448	\$10,270	\$466,356
Build 250 MVAR svc at Altoona 230kV	b1801	\$ 3,704,050.22	6.47%	8.14%	8.18%	0.33%	\$239,652	\$301,510	\$302,991	\$12,223	\$856,376
Convert Moshannon sub to 4 breaker 230 kv ring bus	b1964	\$ 781,150.82	0.00%	5.48%	0.00%	0.00%	\$0	\$42,807	\$0	\$0	\$42,807

Attachment 5A PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023  
Calculation of costs and monthly PJM charges for Allegheny TrAILCo Projects

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
			<i>per PJM Open Access Transmission Tariff</i>								
Install 100 MVAR capacitor at Johnstown 230 kV substation	b0555	\$ 147,539.83	8.58%	18.16%	26.13%	0.97%	\$12,659	\$26,793	\$38,552	\$1,431	\$79,435
							\$1,735,687	\$3,637,030	\$5,131,471	\$211,306	\$10,715,495

Notes on calculations >>>

= (a) \* (b)

= (a) \* (c)

= (a) \* (d)

= (a) \* (e)

= (f) + (g) + (h) + (i)

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load <i>per PJM website</i>	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 427,622.59	10,064.1	\$ 42.49	\$ 2,993,358	\$ 2,138,113	\$ 5,131,471
JCP&L	\$ 303,085.84	6,169.1	\$ 49.13	\$ 2,121,601	\$ 1,515,429	\$ 3,637,030
ACE	\$ 144,640.61	2,631.0	\$ 54.98	\$ 1,012,484	\$ 723,203	\$ 1,735,687
RE	\$ 17,608.86	427.4	\$ 41.20	\$ 123,262	\$ 88,044	\$ 211,306
Total Impact on NJ Zones	\$ 892,957.90			\$ 6,250,705	\$ 4,464,790	\$ 10,715,495

Notes on calculations >>>

= (k) \* (l)

= (k) \* 7

= (k) \* 5

= (n) \* (o)

Notes:  
1) 2022 allocation share percentages are from PJM OATT

## SCHEDULE 12 – APPENDIX

### (14) Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0216	Install -100/+525 MVAR dynamic reactive device at Black Oak	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPSCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  APS (39.20%) / BGE (13.05%) / Dominion (31.49%) / PEPSCO (16.26%)</p>
b0218	Install third Wylie Ridge 500/345 kV transformer	<p>As specified under the procedures detailed in Attachment H-18B, Section 1.b</p> <p>AEC (11.83%) / DPL (19.40%) / Dominion (13.81%) / JCPL (15.56%) / PECO (39.40%)</p>
b0220	Upgrade coolers on Wylie Ridge 500/345 kV #7	<p>AEC (11.83%) / DPL (19.40%) / Dominion (13.81%) / JCPL (15.56%) / PECO (39.40%)</p>
b0229	Install fourth Bedington 500/138 kV	<p>APS (50.98%) / BGE (13.42%) / DPL (2.03%) / Dominion (14.50%) / ME (1.43%) / PEPSCO (17.64%)</p>
b0230	Install fourth Meadowbrook 500/138 kV	<p>As specified under the procedures detailed in Attachment H-18B, Section 1.b</p> <p>APS (79.16%) / BGE (3.61%) / DPL (0.86%) / Dominion (11.75%) / ME (0.67%) / PEPSCO (3.95%)</p>

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0238	Reconductor Doubs – Dickerson and Doubs – Aqueduct 1200 MVA	As specified under the procedures detailed in Attachment H-18B, Section 1.b	BGE (16.66%) / Dominion (33.66%) / PEPCO (49.68%)
b0240	Open the Black Oak #3 500/138 kV transformer for the loss of Hatfield – Back Oak 500 kV line		APS (100%)
b0245	Replacement of the existing 954 ACSR conductor on the Bedington – Nipetown 138 kV line with high temperature/low sag conductor		APS (100%)
b0246	Rebuild of the Double Tollgate – Old Chapel 138 kV line with 954 ACSR conductor	As specified under the procedures detailed in Attachment H-18B, Section 1.b	APS (100%)
b0273	Open both North Shenandoah #3 transformer and Strasburg – Edinburgh 138 kV line for the loss of Mount Storm – Meadowbrook 572 500 kV		APS (100%)
b0322	Convert Lime Kiln substation to 230 kV operation		APS (100%)
b0323	Replace the North Shenandoah 138/115 kV transformer	As specified under the procedures detailed in Attachment H-18B, Section 1.b	APS (100%)



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0328.2	Build new Meadow Brook – Loudoun 500 kV circuit (20 of 50 miles)	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> BGE (8.29%) / Dominion (79.93%) / PEPCO (11.78%)
b0343	Replace Doubs 500/230 kV transformer #2	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		AEC (1.85%) / BGE (21.49%) / DPL (3.91%) / Dominion (28.86%) / ME (2.97%) / PECO (5.73%) / PEPCO (35.19%)
b0344	Replace Doubs 500/230 kV transformer #3	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		AEC (1.86%) / BGE (21.50%) / DPL (3.91%) / Dominion (28.82%) / ME (2.97%) / PECO (5.74%) / PEPCO (35.20%)
b0345	Replace Doubs 500/230 kV transformer #4	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		AEC (1.85%) / BGE (21.49%) / DPL (3.90%) / Dominion (28.83%) / ME (2.98%) / PECO (5.75%) / PEPCO (35.20%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.1	Build new Mt. Storm – 502 Junction 500 kV circuit	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.2	Build new Mt. Storm – Meadow Brook 500 kV circuit	As specified under the procedures detailed in Attachment H-18B, Section 1.b
		<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.3	Build new 502 Junction 500 kV substation	As specified under the procedures detailed in Attachment H-18B, Section 1.b
b0347.4	Upgrade Meadow Brook 500 kV substation	As specified under the procedures detailed in Attachment H-18B, Section 1.b

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.5	Replace Harrison 500 kV breaker HL-3	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.6	Upgrade (per ABB inspection) breaker HL-6	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.7	Upgrade (per ABB inspection) breaker HL-7	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)</p>
b0347.8	Upgrade (per ABB inspection) breaker HL-8	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)</p>

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.9	Upgrade (per ABB inspection) breaker HL-10	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.10	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-1	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.11	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-3	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.12	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-4	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.13	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-6	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.14	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-7	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)

\*Neptune Regional Transmission System, LLC



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.15	Upgrade (per ABB Inspection) Hatfield 500 kV breakers HFL-9	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)
b0347.16	Upgrade (per ABB inspection) Harrison 500 kV breaker 'HL-3'	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (47.31%) / BGE (20.76%) / PEPCO (31.93%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.17	Replace Meadow Brook 138 kV breaker 'MD-10'	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.18	Replace Meadow Brook 138 kV breaker 'MD-11'	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.19	Replace Meadow Brook 138 kV breaker 'MD-12'	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.20	Replace Meadow Brook 138 kV breaker 'MD-13'	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.21	Replace Meadow Brook 138 kV breaker ‘MD-14’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.22	Replace Meadow Brook 138 kV breaker ‘MD-15’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.23	Replace Meadow Brook 138 kV breaker ‘MD-16’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.24	Replace Meadow Brook 138 kV breaker ‘MD-17’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.25	Replace Meadow Brook 138 kV breaker ‘MD-18’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.26	Replace Meadow Brook 138 kV breaker ‘MD-22#1 CAP’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.27	Replace Meadow Brook 138 kV breaker ‘MD-4’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.28	Replace Meadow Brook 138 kV breaker ‘MD-5’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.29	Replace Meadowbrook 138 kV breaker ‘MD-6’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.30	Replace Meadowbrook 138 kV breaker ‘MD-7’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.31	Replace Meadowbrook 138 kV breaker ‘MD-8’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0347.32	Replace Meadowbrook 138 kV breaker ‘MD-9’	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0347.33	Replace Meadow Brook 138 kV breaker 'MD-1'	APS (100%)
b0347.34	Replace Meadow Brook 138 kV breaker 'MD-2'	APS (100%)
b0348	Upgrade Stonewall – Inwood 138 kV with 954 ACSR conductor	APS (100%)
b0373	Convert Doubs – Monocacy 138 kV facilities to 230 kV operation	AEC (1.82%) / APS (76.84%) / DPL (2.64%) / JCPL (4.53%) / ME (9.15%) / NEPTUNE* (0.42%) / PPL (4.60%)
b0393	Replace terminal equipment at Harrison 500 kV and Belmont 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (44.89%) / Dayton (17.18%) / DEOK (28.83%) / EKPC (9.10%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0406.1	Replace Mitchell 138 kV breaker “#4 bank”	APS (100%)
b0406.2	Replace Mitchell 138 kV breaker “#5 bank”	APS (100%)
b0406.3	Replace Mitchell 138 kV breaker “#2 transf	APS (100%)
b0406.4	Replace Mitchell 138 kV breaker “#3 bank”	APS (100%)
b0406.5	Replace Mitchell 138 kV breaker “Charlerio #2”	APS (100%)
b0406.6	Replace Mitchell 138 kV breaker “Charlerio #1”	APS (100%)
b0406.7	Replace Mitchell 138 kV breaker “Shepler Hill Jct”	APS (100%)
b0406.8	Replace Mitchell 138 kV breaker “Union Jct”	APS (100%)
b0406.9	Replace Mitchell 138 kV breaker “#1-2 138 kV bus tie”	APS (100%)
b0407.1	Replace Marlowe 138 kV breaker “#1 transf	APS (100%)
b0407.2	Replace Marlowe 138 kV breaker “MBO”	APS (100%)
b0407.3	Replace Marlowe 138 kV breaker “BMA”	APS (100%)
b0407.4	Replace Marlowe 138 kV breaker “BMR”	APS (100%)
b0407.5	Replace Marlowe 138 kV breaker “WC-1”	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0407.6	Replace Marlowe 138 kV breaker “R11”	APS (100%)
b0407.7	Replace Marlowe 138 kV breaker “W”	APS (100%)
b0407.8	Replace Marlowe 138 kV breaker “138 kV bus tie”	APS (100%)
b0408.1	Replace Trissler 138 kV breaker “Belmont 604”	APS (100%)
b0408.2	Replace Trissler 138 kV breaker “Edgelawn 90”	APS (100%)
b0409.1	Replace Weirton 138 kV breaker “Wylie Ridge 210”	APS (100%)
b0409.2	Replace Weirton 138 kV breaker “Wylie Ridge 216”	APS (100%)
b0410	Replace Glen Falls 138 kV breaker “McAlpin 30”	APS (100%)
b0417	Reconductor Mitchell – Shepler Hill Junction 138 kV with 954 ACSR	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0418	Install a breaker failure auto-restoration scheme at Cabot 500 kV for the failure of the #6 breaker	AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPSCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
b0419	Install a breaker failure auto-restoration scheme at Bedington 500 kV for the failure of the #1 and #2 breakers	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPSCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (100%)
b0420	Operating Procedure to open the Black Oak 500/138 kV transformer #3 for the loss of Hatfield – Ronco 500 kV and the Hatfield #3 Generation	APS (100%)
b0445	Upgrade substation equipment and reconductor the Tidd – Mahans Lane – Weirton 138 kV circuit with 954 ACSR	APS (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 14 Monongahela Power Company, Th

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0460		<p>Raise limiting structures on Albright – Bethelboro 138 kV to raise the rating to 175 MVA normal 214 MVA emergency</p> <p>APS (100%)</p>
b0491	As specified under the procedures detailed in Attachment H-19B	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE* (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)</p>

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0492	Construct a Welton Spring to Kemptown 765 kV line (APS equipment)	As specified under the procedures detailed in Attachment H-19B
		<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE* (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)
b0492.3	Replace Eastalco 230 kV breaker D-26	APS (100%)
b0492.4	Replace Eastalco 230 kV breaker D-28	APS (100%)

\*Neptune Regional Transmission System, LLC



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0492.5	Replace Eastalco 230 kV breaker D-31	APS (100%)
b0495	Replace existing Kammer 765/500 kV transformer with a new larger transformer	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEP (2.21%) / APS (1.71%) / BGE (45.34%) / Dayton (0.76%) / DEOK (1.02%) / EKPC (0.26%) / PEPCO (48.70%)</p>
b0533	Reconductor the Powell Mountain – Sutton 138 kV line	APS (100%)
b0534	Install a 28.61 MVAR capacitor on Sutton 138 kV	APS (100%)
b0535	Install a 44 MVAR capacitor on Dutch Fork 138 kV	APS (100%)
b0536	Replace Doubs circuit breaker DJ1	APS (100%)
b0537	Replace Doubs circuit breaker DJ7	APS (100%)
b0538	Replace Doubs circuit breaker DJ10	APS (100%)
b0572.1	Reconductor Albright – Mettiki – Williams – Parsons – Loughs Lane 138 kV with 954 ACSR	APS (100%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0572.2	Reconductor Albright – Mettiki – Williams – Parsons – Loughs Lane 138 kV with 954 ACSR	APS (100%)
b0573	Reconfigure circuits in Butler – Cabot 138 kV area	APS (100%)
b0577	Replace Fort Martin 500 kV breaker FL-1	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPSCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (100%)
b0584	Install 33 MVAR 138 kV capacitor at Necessity 138 kV	APS (100%)
b0585	Increase Cecil 138 kV capacitor size to 44 MVAR, replace five 138 kV breakers at Cecil due to increased short circuit fault duty as a result of the addition of the Prexy substation	APS (100%)
b0586	Increase Whiteley 138 kV capacitor size to 44 MVAR	APS (100%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0587	Reconductor AP portion of Tidd – Carnegie 138 kV and Carnegie – Weirton 138 kV with 954 ACSR	APS (100%)
b0588	Install a 40.8 MVAR 138 kV capacitor at Grassy Falls	APS (100%)
b0589	Replace five 138 kV breakers at Cecil	APS (100%)
b0590	Replace #1 and #2 breakers at Charleroi 138 kV	APS (100%)
b0591	Install a 25.2 MVAR capacitor at Seneca Caverns 138 kV	APS (100%)
b0673	Rebuild Elko – Carbon Center Junction using 230 kV construction	APS (100%)
b0674	Construct new Osage – Whiteley 138 kV circuit	APS (97.68%) / DL (0.96%) / PENELEC (1.09%) / ECP** (0.01%) / PSEG (0.25%) / RE (0.01%)
b0674.1	Replace the Osage 138 kV breaker ‘CollinsF126’	APS (100%)
b0675.1	Convert Monocacy - Walkersville 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.2	Convert Walkersville - Catoctin 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0675.3	Convert Ringgold - Catoctin 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.4	Convert Catoctin - Carroll 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.5	Convert portion of Ringgold Substation from 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.6	Convert Catoctin Substation from 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.7	Convert portion of Carroll Substation from 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0675.8	Convert Monocacy Substation from 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0675.9	Convert Walkersville Substation from 138 kV to 230 kV	AEC (1.02%) / APS (81.96%) / DPL (0.85%) / JCPL (1.75%) / ME (6.37%) / NEPTUNE* (0.15%) / PECO (3.09%) / PPL (2.24%) / PSEG (2.42%) / RE (0.09%) / ECP** (0.06%)
b0676.1	Reconductor Doubs - Lime Kiln (#207) 230 kV	AEC (0.64%) / APS (86.70%) / DPL (0.53%) / JCPL (1.93%) / ME (4.04%) / NEPTUNE* (0.18%) / PECO (1.93%) / PENELEC (0.93%) / PSEG (2.92%) / RE (0.12%) / ECP** (0.08%)
b0676.2	Reconductor Doubs - Lime Kiln (#231) 230 kV	AEC (0.64%) / APS (86.70%) / DPL (0.53%) / JCPL (1.93%) / ME (4.04%) / NEPTUNE* (0.18%) / PECO (1.93%) / PENELEC (0.93%) / PSEG (2.92%) / RE (0.12%) / ECP** (0.08%)
b0677	Reconductor Double Toll Gate – Riverton with 954 ACSR	APS (100%)
b0678	Reconductor Glen Falls - Oak Mound 138 kV with 954 ACSR	APS (100%)
b0679	Reconductor Grand Point – Letterkenny with 954 ACSR	APS (100%)
b0680	Reconductor Greene – Letterkenny with 954 ACSR	APS (100%)
b0681	Replace 600/5 CT's at Franklin 138 kV	APS (100%)
b0682	Replace 600/5 CT's at Whiteley 138 kV	APS (100%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0684	Reconductor Guilford – South Chambersburg with 954 ACSR	APS (100%)
b0685	Replace Ringgold 230/138 kV #3 with larger transformer	APS (71.93%) / JCPL (4.17%) / ME (6.79%) / NEPTUNE* (0.38%) / PECO (4.05%) / PENELEC (5.88%) / ECP** (0.18%) / PSEG (6.37%) / RE (0.25%)
b0704	Install a third Cabot 500/138 kV transformer	APS (74.36%) / DL (2.73%) PENELEC (22.91%)
b0797	Advance n0321 (Replace Doubs Circuit Breaker DJ2)	APS (100%)
b0798	Advance n0322 (Replace Doubs Circuit Breaker DJ3)	APS (100%)
b0799	Advance n0323 (Replace Doubs Circuit Breaker DJ6)	APS (100%)
b0800	Advance n0327 (Replace Doubs Circuit Breaker DJ16)	APS (100%)
b0941	Replace Opequon 138 kV breaker 'BUSTIE'	APS (100%)
b0942	Replace Butler 138 kV breaker '#1 BANK'	APS (100%)
b0943	Replace Butler 138 kV breaker '#2 BANK'	APS (100%)
b0944	Replace Yukon 138 kV breaker 'Y-8'	APS (100%)
b0945	Replace Yukon 138 kV breaker 'Y-3'	APS (100%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0946	Replace Yukon 138 kV breaker 'Y-1'	APS (100%)
b0947	Replace Yukon 138 kV breaker 'Y-5'	APS (100%)
b0948	Replace Yukon 138 kV breaker 'Y-2'	APS (100%)
b0949	Replace Yukon 138 kV breaker 'Y-19'	APS (100%)
b0950	Replace Yukon 138 kV breaker 'Y-4'	APS (100%)
b0951	Replace Yukon 138 kV breaker 'Y-9'	APS (100%)
b0952	Replace Yukon 138 kV breaker 'Y-11'	APS (100%)
b0953	Replace Yukon 138 kV breaker 'Y-13'	APS (100%)
b0954	Replace Charleroi 138 kV breaker '#1 XFMR BANK'	APS (100%)
b0955	Replace Yukon 138 kV breaker 'Y-7'	APS (100%)
b0956	Replace Pruntytown 138 kV breaker 'P-9'	APS (100%)
b0957	Replace Pruntytown 138 kV breaker 'P-12'	APS (100%)
b0958	Replace Pruntytown 138 kV breaker 'P-15'	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0959	Replace Charleroi 138 kV breaker '#2 XFMR BANK'	APS (100%)
b0960	Replace Pruntytown 138 kV breaker 'P-2'	APS (100%)
b0961	Replace Pruntytown 138 kV breaker 'P-5'	APS (100%)
b0962	Replace Yukon 138 kV breaker 'Y-18'	APS (100%)
b0963	Replace Yukon 138 kV breaker 'Y-10'	APS (100%)
b0964	Replace Pruntytown 138 kV breaker 'P-11'	APS (100%)
b0965	Replace Springdale 138 kV breaker '138E'	APS (100%)
b0966	Replace Pruntytown 138 kV breaker 'P-8'	APS (100%)
b0967	Replace Pruntytown 138 kV breaker 'P-14'	APS (100%)
b0968	Replace Ringgold 138 kV breaker '#3 XFMR BANK'	APS (100%)
b0969	Replace Springdale 138 kV breaker '138C'	APS (100%)
b0970	Replace Rivesville 138 kV breaker '#8 XFMR BANK'	APS (100%)
b0971	Replace Springdale 138 kV breaker '138F'	APS (100%)



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0972	Replace Belmont 138 kV breaker 'B-16'	APS (100%)
b0973	Replace Springdale 138 kV breaker '138G'	APS (100%)
b0974	Replace Springdale 138 kV breaker '138V'	APS (100%)
b0975	Replace Armstrong 138 kV breaker 'BROOKVILLE'	APS (100%)
b0976	Replace Springdale 138 kV breaker '138P'	APS (100%)
b0977	Replace Belmont 138 kV breaker 'B-17'	APS (100%)
b0978	Replace Springdale 138 kV breaker '138U'	APS (100%)
b0979	Replace Springdale 138 kV breaker '138D'	APS (100%)
b0980	Replace Springdale 138 kV breaker '138R'	APS (100%)
b0981	Replace Yukon 138 kV breaker 'Y-12'	APS (100%)
b0982	Replace Yukon 138 kV breaker 'Y-17'	APS (100%)
b0983	Replace Yukon 138 kV breaker 'Y-14'	APS (100%)
b0984	Replace Rivesville 138 kV breaker '#10 XFMR BANK'	APS (100%)
b0985	Replace Belmont 138 kV breaker 'B-14'	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0986	Replace Armstrong 138 kV breaker 'RESERVE BUS'	APS (100%)
b0987	Replace Yukon 138 kV breaker 'Y-16'	APS (100%)
b0988	Replace Springdale 138 kV breaker '138T'	APS (100%)
b0989	Replace Edgelawn 138 kV breaker 'GOFF RUN #632'	APS (100%)
b0990	Change reclosing on Cabot 138 kV breaker 'C-9'	APS (100%)
b0991	Change reclosing on Belmont 138 kV breaker 'B-7'	APS (100%)
b0992	Change reclosing on Belmont 138 kV breaker 'B-12'	APS (100%)
b0993	Change reclosing on Belmont 138 kV breaker 'B-9'	APS (100%)
b0994	Change reclosing on Belmont 138 kV breaker 'B-19'	APS (100%)
b0995	Change reclosing on Belmont 138 kV breaker 'B-21'	APS (100%)
b0996	Change reclosing on Willow Island 138 kV breaker 'FAIRVIEW #84'	APS (100%)
b0997	Change reclosing on Cabot 138 kV breaker 'C-4'	APS (100%)
b0998	Change reclosing on Cabot 138 kV breaker 'C-1'	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0999	Replace Redbud 138 kV breaker 'BUS TIE'	APS (100%)
b1022.1	Reconfigure the Peters to Bethel Park 138 kV line and Elrama to Woodville 138 kV line to create a 138 kV path from Woodville to Peters and a 138 kV path from Elrama to Bethel Park	APS (96.98%) / DL (3.02%)
b1022.3	Add static capacitors at Smith 138 kV	APS (96.98%) / DL (3.02%)
b1022.4	Add static capacitors at North Fayette 138 kV	APS (96.98%) / DL (3.02%)
b1022.5	Add static capacitors at South Fayette 138 kV	APS (96.98%) / DL (3.02%)
b1022.6	Add static capacitors at Manifold 138 kV	APS (96.98%) / DL (3.02%)
b1022.7	Add static capacitors at Houston 138 kV	APS (96.98%) / DL (3.02%)
b1023.1	Install a 500/138 kV transformer at 502 Junction	APS (100%)
b1023.2	Construct a new Franklin - 502 Junction 138 kV line including a rebuild of the Whiteley - Franklin 138 kV line to double circuit	APS (100%)
b1023.3	Construct a new 502 Junction - Osage 138 kV line	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1023.4	Construct Braddock 138 kV breaker station that connects the Charleroi - Gordon 138 kV line, Washington - Franklin 138 kV line and the Washington - Vanceville 138 kV line including a 66 MVAR capacitor	APS (100%)
b1027	Increase the size of the shunt capacitors at Enon 138 kV	APS (100%)
b1028	Raise three structures on the Osage - Collins Ferry 138 kV line to increase the line rating	APS (100%)
b1128	Reconductor the Edgewater – Vasco Tap; Edgewater – Loyalhanna 138 kV lines with 954 ACSR	APS (100%)
b1129	Reconductor the East Waynesboro – Ringgold 138 kV line with 954 ACSR	APS (100%)
b1131	Upgrade Double Tollgate – Meadowbrook MDT Terminal Equipment	APS (100%)
b1132	Upgrade Double Tollgate-Meadowbrook MBG terminal equipment	APS (100%)
b1133	Upgrade terminal equipment at Springdale	APS (100%)
b1135	Reconductor the Bartonville – Meadowbrook 138 kV line with high temperature conductor	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1137	Reconductor the Eastgate – Luxor 138 kV; Eastgate – Sony 138 kV line with 954 ACSR	APS (78.59%) / PENELEC (14.08%) / ECP** (0.23%) / PSEG (6.83%) / RE (0.27%)
b1138	Reconductor the King Farm – Sony 138 kV line with 954 ACSR	APS (100%)
b1139	Reconductor the Yukon – Waltz Mills 138 kV line with high temperature conductor	APS (100%)
b1140	Reconductor the Bracken Junction – Luxor 138 kV line with 954 ACSR	APS (100%)
b1141	Reconductor the Sewickley – Waltz Mills Tap 138 kV line with high temperature conductor	APS (100%)
b1142	Reconductor the Bartonsville – Stephenson 138 kV; Stonewall – Stephenson 138 kV line with 954 ACSR	APS (100%)
b1143	Reconductor the Youngwood – Yukon 138 kV line with high temperature conductor	APS (89.92%) / PENELEC (10.08%)
b1144	Reconductor the Bull Creek Junction – Cabot 138 kV line with high temperature conductor	APS (100%)

\*\*East Coast Power, L.L.C.

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1145	Reconductor the Lawson Junction – Cabot 138 kV line with high temperature conductor	APS (100%)
b1146	Replace Layton - Smithton #61 138 kV line structures to increase line rating	APS (100%)
b1147	Replace Smith – Yukon 138 kV line structures to increase line rating	APS (100%)
b1148	Reconductor the Loyalhanna – Luxor 138 kV line with 954 ACSR	APS (100%)
b1149	Reconductor the Luxor – Stony Springs Junction 138 kV line with 954 ACSR	APS (100%)
b1150	Upgrade terminal equipment at Social Hall	APS (100%)
b1151	Reconductor the Greenwood – Redbud 138 kV line with 954 ACSR	APS (100%)
b1152	Reconductor Grand Point – South Chambersburg	APS (100%)
b1159	Replace Peters 138 kV breaker ‘Bethel P OCB’	APS (100%)
b1160	Replace Peters 138 kV breaker ‘Cecil OCB’	APS (100%)
b1161	Replace Peters 138 kV breaker ‘Union JctOCB’	APS (100%)
b1162	Replace Double Toll Gate 138 kV breaker ‘DRB-2’	APS (100%)
b1163	Replace Double Toll Gate 138 kV breaker ‘DT 138 kV OCB’	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1164	Replace Cecil 138 kV breaker ‘Enlow OCB’	APS (100%)
b1165	Replace Cecil 138 kV breaker ‘South Fayette’	APS (100%)
b1166	Replace Wylie Ridge 138 kV breaker ‘W-9’	APS (100%)
b1167	Replace Reid 138 kV breaker ‘RI-2’	APS (100%)
b1171.1	Install the second Black Oak 500/138 kV transformer, two 138 kV breaker, and related substation work	BGE (20.76%) / DPL (3.14%) / Dominion (39.55%) / ME (2.71%) / PECO (3.36%) / PEPCO (30.48%)
b1171.3	Install six 500 kV breakers and remove BOL1 500 kV breaker at Black Oak	AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
b1200	Reconductor Double Toll Gate – Greenwood 138 kV with 954 ACSR conductor	APS (100%)
b1221.1	Convert Carbon Center from 138 kV to a 230 kV ring bus	APS (100%)
b1221.2	Construct Bear Run 230 kV substation with 230/138 kV transformer	APS (100%)

\*Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1221.3	Loop Carbon Center Junction – Williamette line into Bear Run	APS (100%)
b1221.4	Carbon Center – Carbon Center Junction & Carbon Center Junction – Bear Run conversion from 138 kV to 230 kV	APS (100%)
b1230	Reconductor Willow-Eureka & Eureka-St Mary 138 kV lines	APS (100%)
b1232	Reconductor Nipetown – Reid 138 kV with 1033 ACCR	AEC (1.40%) / APS (75.74%) / DPL (1.92%) / JCPL (2.92%) / ME (6.10%) / NEPTUNE* (0.27%) / PECO (4.40%) / PENELEC (3.26%) / PPL (3.99%)
b1233.1	Upgrade terminal equipment at Washington	APS (100%)
b1234	Replace structures between Ridgeway and Paper city	APS (100%)
b1235	Reconductor the Albright – Black Oak AFA 138 kV line with 795 ACSS/TW	APS (30.25%) / BGE (16.10%) / Dominion (30.51%) / PEPCO (23.14%)
b1237	Upgrade terminal equipment at Albright, replace bus and line side breaker disconnects and leads, replace breaker risers, upgrade RTU and line	APS (100%)
b1238	Install a 138 kV 44 MVAR capacitor at Edgelawn substation	APS (100%)

\* Neptune Regional Transmission System, LLC



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1239	Install a 138 kV 44 MVAR capacitor at Ridgeway substation	APS (100%)
b1240	Install a 138 kV 44 MVAR capacitor at Elko Substation	APS (100%)
b1241	Upgrade terminal equipment at Washington substation on the GE Plastics/DuPont terminal	APS (100%)
b1242	Replace structures between Collins Ferry and West Run	APS (100%)
b1243	Install a 138 kV capacitor at Potter Substation	APS (100%)
b1261	Replace Butler 138 kV breaker ‘1-2 BUS 138’	APS (100%)
b1383	Install 2nd 500/138 kV transformer at 502 Junction	APS (93.27%) / DL (5.39%) / PENELEC (1.34%)
b1384	Reconductor approximately 2.17 miles of Bedington – Shepherdstown 138 kV with 954 ACSR	APS (100%)
b1385	Reconductor Halfway – Paramount 138 kV with 1033 ACCR	APS (100%)
b1386	Reconductor Double Tollgate – Meadow Brook 138 kV ckt 2 with 1033 ACCR	APS (93.33%) / BGE (3.39%) / PEPCO (3.28%)
b1387	Reconductor Double Tollgate – Meadow Brook 138 kV	APS (93.33%) / BGE (3.39%) / PEPCO (3.28%)
b1388	Reconductor Feagans Mill – Millville 138 kV with 954 ACSR	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1389	Reconductor Bens Run – St. Mary’s 138 kV with 954 ACSR	AEP (12.40%) / APS (17.80%) / DL (69.80%)
b1390	Replace Bus Tie Breaker at Opequon	APS (100%)
b1391	Replace Line Trap at Gore	APS (100%)
b1392	Replace structure on Belmont – Trissler 138 kV line	APS (100%)
b1393	Replace structures Kingwood – Pruntytown 138 kV line	APS (100%)
b1395	Upgrade Terminal Equipment at Kittanning	APS (100%)
b1401	Change reclosing on Pruntytown 138 kV breaker ‘P-16’ to 1 shot at 15 seconds	APS (100%)
b1402	Change reclosing on Rivesville 138 kV breaker ‘Pruntytown #34’ to 1 shot at 15 seconds	APS (100%)
b1403	Change reclosing on Yukon 138 kV breaker ‘Y21 Shepler’ to 1 shot at 15 seconds	APS (100%)
b1404	Replace the Kiski Valley 138 kV breaker ‘Vandergrift’ with a 40 kA breaker	APS (100%)
b1405	Change reclosing on Armstrong 138 kV breaker ‘GARETTRJCT’ at 1 shot at 15 seconds	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1406	Change reclosing on Armstrong 138 kV breaker 'KITTANNING' to 1 shot at 15 seconds	APS (100%)
b1407	Change reclosing on Armstrong 138 kV breaker 'BURMA' to 1 shot at 15 seconds	APS (100%)
b1408	Replace the Weirton 138 kV breaker 'Tidd 224' with a 40 kA breaker	APS (100%)
b1409	Replace the Cabot 138 kV breaker 'C9 Kiski Valley' with a 40 kA breaker	APS (100%)
b1507.2	Terminal Equipment upgrade at Doubs substation	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (20.09%) / BGE (13.46%) / Dominion (52.77%) / PEPCO (13.68%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1507.3	Mt. Storm – Doubs transmission line rebuild in Maryland – Total line mileage for APS is 2.71 miles	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  APS (20.09%) / BGE (13.46%) / Dominion (52.77%) / PEPCO (13.68%)</p>
b1510	Install 59.4 MVAR capacitor at Waverly	APS (100%)
b1672	Install a 230 kV breaker at Carbon Center	APS (100%)
b0539	Replace Doubs circuit breaker DJ11	APS (100%)
b0540	Replace Doubs circuit breaker DJ12	APS (100%)
b0541	Replace Doubs circuit breaker DJ13	APS (100%)
b0542	Replace Doubs circuit breaker DJ20	APS (100%)
b0543	Replace Doubs circuit breaker DJ21	APS (100%)
b0544	Remove instantaneous reclose from Eastalco circuit breaker D-26	APS (100%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0545	Remove instantaneous reclose from Eastalco circuit breaker D-28	APS (100%)
b0559	Install 200 MVAR capacitor at Meadow Brook 500 kV substation	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b0560	Install 250 MVAR capacitor at Kemptown 500 kV substation	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (5.01%) / AEP (4.39%) / APS (9.26%) / BGE (4.43%) / DL (0.02%) / DPL (6.91%) / Dominion (10.82%) / JCPL (11.64%) / ME (2.94%) / NEPTUNE* (1.12%) / PECO (14.51%) / PEPCO (6.11%) / PPL (6.39%) / PSEG (15.86%) / RE (0.59%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1803	Build a 300 MVAR Switched Shunt at Doubs 500 kV and increase (~50 MVAR) in size the existing Switched Shunt at Doubs 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (20.09%) / BGE (13.46%) / Dominion (52.77%) / PEPCO (13.68%)
b1804	Install a new 600 MVAR SVC at Meadowbrook 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> APS (30.25%) / BGE (8.80%) / Dominion (46.80%) / PEPCO (14.15%)
b1816.1	Replace relaying at the Mt. Airy substation on the Carroll - Mt. Airy 230 kV line	APS (100%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1816.2 Adjust the control settings of all existing capacitors at Mt Airy 34.5 kV, Monocacy 138 kV, Ringgold 138 kV served by Potomac Edison's Eastern 230 kV network to ensure that all units will be on during the identified N-1-1 contingencies		APS (100%)
b1816.3 Replace existing unidirectional LTC controller on the No. 4, 230/138 kV transformer at Carroll substation with a bidirectional unit		APS (100%)
b1816.4 Isolate and bypass the 138 kV reactor at Germantown Substation		APS (100%)
b1816.6 Replace 336.4 ACSR conductor on the Catoctin - Carroll 138 kV line using 556.5 ACSR (26/7) or equivalent on existing structures (12.7 miles), 800 A wave traps at Carroll and Catoctin with 1200 A units, and 556.5 ACSR SCCIR (Sub-conductor) line risers and bus traps with 795 ACSR or equivalent		APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1822	Replace the 1200 A wave trap, line risers, breaker risers with 1600 A capacity terminal equipment at Reid 138 kV SS	APS (100%)
b1823	Replace the 800 A wave trap with a 1200 A wave trap at Millville 138 kV substation	APS (100%)
b1824	Reconductor Grant Point - Guilford 138 kV line approximately 8 miles of 556 ACSR with 795 ACSR	APS (100%)
b1825	Replace the 800 Amp line trap at Butler 138 kV Sub on the Cabot East 138 kV line	APS (100%)
b1826	Change the CT ratio at Double Toll Gate 138 kV SS on MDT line	APS (100%)
b1827	Change the CT ratio at Double Toll Gate 138 kV SS on MBG line	APS (100%)
b1828.1	Reconductor the Bartonville – Stephenson 3.03 mile 138 kV line of 556 ACSR with 795 ACSR	APS (100%)



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1828.2	Reconductor the Stonewall – Stephenson 2.08 mile 138 kV line of 556 ACSR with 795 ACSR	APS (100%)
b1829	Replace the existing 138 kV 556.5 ACSR substation conductor risers with 954 ACSR at the Redbud 138 kV substation, including but not limited to the line side disconnect leads	APS (100%)
b1830	Replace 1200 A wave trap and 1024 ACAR breaker risers at Halfway 138 kV substation, and replace 1024 ACAR breaker risers at Paramount 138 kV substation	APS (100%)
b1832	Replace the 1200 A line side and bus side disconnect switches with 1600 A switches, replace bus side, line side, and disconnect leads at Lime Kiln SS on the Doubs - Lime Kiln 1 (207) 230 kV line terminal	APS (100%)
b1833	Replace the 1200 A line side and bus side disconnect switches with 1600 A switches, replace bus side, line side, and disconnect leads at Lime Kiln SS on the Doubs - Lime Kiln 2 (231) 230 kV line terminal	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1835	Reconductor 14.3 miles of 556 ACSR with 795 ACSR from Old Chapel to Millville 138 kV and upgrade line risers at Old Chapel 138 kV and Millville 138 kV and replace 1200 A wave trap at Millville 138 kV	APS (37.68%) / Dominion (34.46%) / PEPCO (13.69%) / BGE (11.45%) / ME (2.01%) / PENELEC (0.53%) / DL (0.18%)
b1836	Replace 1200 A wave trap with 1600 A wave trap at Reid 138 kV SS	APS (100%)
b1837	Replace 750 CU breaker risers with 795 ACSR at Marlowe 138 kV and replace 1200 A wave traps with 1600 A wave traps at Marlowe 138 kV and Bedington 138 kV	APS (100%)
b1838	Replace the 1200 A Bedington 138 kV line air switch and the 1200 A 138 kV bus tie air switch at Nipetown 138 kV with 1600 A switches	APS (100%)
b1839	Install additional 33 MVAR capacitors at Grand Point 138 kV SS and Guildford 138 kV SS	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1840	Construct a 138 kV line between Buckhannon and Weston 138 kV substations	APS (100%)
b1902	Replace line trap at Stonewall on the Stephenson 138 kV line terminal	APS (100%)
b1941	Loop the Homer City- Handsome Lake 345 kV line into the Armstrong substation and install a 345/138 kV transformer at Armstrong	APS (67.86%) / PENELEC (32.14%)
b1942	Change the CT ratio at Millville to improve the Millville – Old Chapel 138 kV line ratings	APS (100%)
b1964	Convert Moshannon substation to a 4 breaker 230 kV ring bus	APS (41.06%) / DPL (6.68%) / JCPL (5.48%) / ME (10.70%) / NEPTUNE* (0.53%) / PECO (15.53%) / PPL (20.02%)
b1965	Install a 44 MVAR 138 kV capacitor at Luxor substation	APS (100%)
b1986	Upgrade the AP portion of the Elrama – Mitchell 138 kV line by replace breaker risers on the Mitchell 138 kV bus on the Elrama terminal	APS (100%)
b1987	Reconductor the Osage-Collins Ferry 138 kV line with 795 ACSS. Upgrade terminal equipment at Osage and Collins Ferry	APS (100%)

\* Neptune Regional Transmission System, LLC

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1988	Raise structures between Lake Lynn and West Run to eliminate the clearance de-rates on the West Run – Lake Lynn 138 kV line	APS (100%)
b1989	Raise structures between Collins Ferry and West Run to eliminate the clearance de-rates on the Collins Ferry - West Run 138 kV line	APS (100%)
b2095	Replace Weirt 138 kV breaker 'S-TORONTO226' with 63 kA rated breaker	APS (100%)
b2096	Revise the reclosing of Weirt 138 kV breaker '2&5 XFMR'	APS (100%)
b2097	Replace Ridgeley 138 kV breaker '#2 XFMR OCB'	APS (100%)
b2098	Revise the reclosing of Ridgeley 138 kV breaker 'AR3' with 40 kA rated breaker	APS (100%)
b2099	Revise the reclosing of Ridgeley 138 kV breaker 'RC1'	APS (100%)
b2100	Replace Ridgeley 138 kV breaker 'WC4' with 40 kA rated breaker	APS (100%)
b2101	Replace Ridgeley 138 kV breaker '1 XFMR OCB' with 40 kA rated breaker	APS (100%)
b2102	Replace Armstrong 138 kV breaker 'GARETTRJCT' with 40 kA rated breaker	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2103	Replace Armstrong 138 kV breaker 'BURMA' with 40 kA rated breaker	APS (100%)
b2104	Replace Armstrong 138 kV breaker 'KITANNING' with 40 kA rated breaker	APS (100%)
b2105	Replace Armstrong 138 kV breaker 'KISSINGERJCT' with 40 kA rated breaker	APS (100%)
b2106	Replace Wylie Ridge 345 kV breaker 'WK-1' with 63 kA rated breaker	APS (100%)
b2107	Replace Wylie Ridge 345 kV breaker 'WK-2' with 63 kA rated breaker	APS (100%)
b2108	Replace Wylie Ridge 345 kV breaker 'WK-3' with 63 kA rated breaker	APS (100%)
b2109	Replace Wylie Ridge 345 kV breaker 'WK-4' with 63 kA rated breaker	APS (100%)
b2110	Replace Wylie Ridge 345 kV breaker 'WK-6' with 63 kA rated breaker	APS (100%)
b2111	Replace Wylie Ridge 138 kV breaker 'WK-7' with 63 kA rated breaker	APS (100%)
b2112	Replace Wylie Ridge 345 kV breaker 'WK-5'	APS (100%)
b2113	Replace Weirton 138 kV breaker 'NO 6 XFMR' with 63 kA rated breaker	APS (100%)
b2114	Replace Armstrong 138 kV breaker 'Bus-Tie' (Status On-Hold pending retirement)	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2124.1	Add a new 138 kV line exit	APS (100%)
b2124.2	Construct a 138 kV ring bus and install a 138/69 kV autotransformer	APS (100%)
b2124.3	Add new 138 kV line exit and install a 138/25 kV transformer	APS (100%)
b2124.4	Construct approximately 5.5 miles of 138 kV line	APS (100%)
b2124.5	Convert approximately 7.5 miles of 69 kV to 138 kV	APS (100%)
b2156	Install a 75 MVAR 230 kV capacitor at Shingletown Substation	APS (100%)
b2165	Replace 800A wave trap at Stonewall with a 1200 A wave trap	APS (100%)
b2166	Reconductor the Millville – Sleepy Hollow 138 kV 4.25 miles of 556 ACSR with 795 ACSR, upgrade line risers at Sleepy Hollow, and change 1200 A CT tap at Millville to 800	APS (100%)
b2168	For Grassy Falls 138 kV Capacitor bank adjust turn-on voltage to 1.0 pu with a high limit of 1.04 pu, For Crupperneck and Powell Mountain 138 kV Capacitor Banks adjust turn-on voltage to 1.01 pu with a high limit of 1.035 pu	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2169	Replace/Raise structures on the Yukon-Smithton 138 kV line section to eliminate clearance de-rate	APS (100%)
b2170	Replace/Raise structures on the Smithton-Shepler Hill Jct 138 kV line section to eliminate clearance de-rate	APS (100%)
b2171	Replace/Raise structures on the Parsons-William 138 kV line section to eliminate clearance de-rate	APS (100%)
b2172	Replace/Raise structures on the Parsons - Loughs Lane 138 kV line section to eliminate clearance de-rate	APS (100%)

## SCHEDULE 12 – APPENDIX A

### (14) Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2117	Reconductor 0.33 miles of the Parkersburg - Belpre line and upgrade Parkersburg terminal equipment	APS (100%)
b2118	Add 44 MVAR Cap at New Martinsville	APS (100%)
b2120	Six-Wire Lake Lynn - Lardin 138 kV circuits	APS (100%)
b2142	Replace Weirton 138 kV breaker “Wylie Ridge 210” with 63 kA breaker	APS (100%)
b2143	Replace Weirton 138 kV breaker “Wylie Ridge 216” with 63 kA breaker	APS (100%)
b2174.8	Replace relays at Mitchell substation	APS (100%)
b2174.9	Replace primary relay at Piney Fork substation	APS (100%)
b2174.10	Perform relay setting changes at Bethel Park substation	APS (100%)
b2213	Armstrong Substation: Relocate 138 kV controls from the generating station building to new control building	APS (100%)
b2214	Albright Substation: Install a new control building in the switchyard and relocate controls and SCADA equipment from the generating station building the new control center	APS (100%)
b2215	Rivesville Switching Station: Relocate controls and SCADA equipment from the generating station building to new control building	APS (100%)



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2216	Willow Island: Install a new 138 kV cross bus at Belmont Substation and reconnect and reconfigure the 138 kV lines to facilitate removal of the equipment at Willow Island switching station	APS (100%)
b2235	130 MVAR reactor at Monocacy 230 kV	APS (100%)
b2260	Install a 32.4 MVAR capacitor at Bartonville	APS (100%)
b2261	Install a 33 MVAR capacitor at Damascus	APS (100%)
b2267	Replace 1000 Cu substation conductor and 1200 amp wave trap at Marlowe	APS (100%)
b2268	Reconductor 6.8 miles of 138kV 336 ACSR with 336 ACSS from Double Toll Gate to Riverton	APS (100%)
b2299	Reconductor from Collins Ferry - West Run 138 kV with 556 ACSS	APS (100%)
b2300	Reconductor from Lake Lynn - West Run 138 kV	APS (100%)
b2341	Install 39.6 MVAR Capacitor at Shaffers Corner 138 kV Substation	APS (100%)
b2342	Construct a new 138 kV switching station (Shuman Hill substation), which is next the Mobley 138 kV substation and install a 31.7 MVAR capacitor	APS (100%)
b2343	Install a 31.7 MVAR capacitor at West Union 138 kV substation	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2362	Install a 250 MVAR SVC at Squab Hollow 230 kV	APS (100%)
b2362.1	Install a 230 kV breaker at Squab Hollow 230 kV substation	APS (100%)
b2363	Convert the Shingletown 230 kV bus into a 6 breaker ring bus	APS (100%)
b2364	Install a new 230/138 kV transformer at Squab Hollow 230 kV substation. Loop the Forest - Elko 230 kV line into Squab Hollow. Loop the Brookville - Elko 138 kV line into Squab Hollow	APS (100%)
b2412	Install a 44 MVAR 138 kV capacitor at the Hempfield 138 kV substation	APS (100%)
b2433.1	Install breaker and a half 138 kV substation (Waldo Run) with 4 breakers to accommodate service to MarkWest Sherwood Facility including metering which is cut into Glen Falls Lamberton 138 kV line	APS (100%)
b2433.2	Install a 70 MVAR SVC at the new WaldoRun 138 kV substation	APS (100%)
b2433.3	Install two 31.7 MVAR capacitors at the new WaldoRun 138 kV substation	APS (100%)
b2424	Replace the Weirton 138 kV breaker 'WYLIE RID210' with 63 kA breakers	APS (100%)
b2425	Replace the Weirton 138 kV breaker 'WYLIE RID216' with 63 kA breakers	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2426	Replace the Oak Grove 138 kV breaker 'OG1' with 63 kA breakers	APS (100%)
b2427	Replace the Oak Grove 138 kV breaker 'OG2' with 63 kA breakers	APS (100%)
b2428	Replace the Oak Grove 138 kV breaker 'OG3' with 63 kA breakers	APS (100%)
b2429	Replace the Oak Grove 138 kV breaker 'OG4' with 63 kA breakers	APS (100%)
b2430	Replace the Oak Grove 138 kV breaker 'OG5' with 63 kA breakers	APS (100%)
b2431	Replace the Oak Grove 138 kV breaker 'OG6' with 63 kA breakers	APS (100%)
b2432	Replace the Ridgeley 138 kV breaker 'RC1' with a 40 kA rated breaker	APS (100%)
b2440	Replace the Cabot 138kV breaker 'C9-KISKI VLY' with 63kA	APS (100%)
b2472	Replace the Ringgold 138 kV breaker 'RCM1' with 40kA breakers	APS (100%)
b2473	Replace the Ringgold 138 kV breaker '#4 XMFR' with 40kA breakers	APS (100%)
b2475	Construct a new line between Oak Mound 138 kV substation and Waldo Run 138 kV substation	APS (100%)
b2545.1	Construct a new 138 kV substation (Shuman Hill substation) connected to the Fairview –Willow Island (84) 138 kV line	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2545.2	Install a ring bus station with five active positions and two 52.8 MVAR capacitors with 0.941 mH reactors	APS (100%)
b2545.3	Install a +90/-30 MVAR SVC protected by a 138 kV breaker	APS (100%)
b2545.4	Remove the 31.7 MVAR capacitor bank at Mobley 138 kV	APS (100%)
b2546	Install a 51.8 MVAR (rated) 138 kV capacitor at Nyswaner 138 kV substation	APS (100%)
b2547.1	Construct a new 138 kV six breaker ring bus Hillman substation	APS (100%)
b2547.2	Loop Smith- Imperial 138 kV line into the new Hillman substation	APS (100%)
b2547.3	Install +125/-75 MVAR SVC at Hillman substation	APS (100%)
b2547.4	Install two 31.7 MVAR 138 kV capacitors	APS (100%)
b2548	Eliminate clearance de-rate on Wylie Ridge – Smith 138 kV line and upgrade terminals at Smith 138 kV, new line ratings 294 MVA (Rate A)/350 MVA (Rate B)	APS (100%)
b2612.1	Relocate All Dam 6 138 kV line and the 138 kV line to AE units 1&2	APS (100%)
b2612.2	Install 138 kV, 3000A bus-tie breaker in the open bus-tie position next to the Shaffers corner 138 kV line	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2612.3	Install a 6-pole manual switch, foundation, control cable, and all associated facilities		APS (100%)
b2666	Yukon 138 kV Breaker Replacement		APS (100%)
b2666.1	Replace Yukon 138 kV breaker "Y-11(CHARL1)" with an 80 kA breaker		APS (100%)
b2666.2	Replace Yukon 138 kV breaker "Y-13(BETHEL)" with an 80 kA breaker		APS (100%)
b2666.3	Replace Yukon 138 kV breaker "Y-18(CHARL2)" with an 80 kA breaker		APS (100%)
b2666.4	Replace Yukon 138 kV breaker "Y-19(CHARL2)" with an 80 kA breaker		APS (100%)
b2666.5	Replace Yukon 138 kV breaker "Y-4(4B-2BUS)" with an 80 kA breaker		APS (100%)
b2666.6	Replace Yukon 138 kV breaker "Y-5(LAYTON)" with an 80 kA breaker		APS (100%)
b2666.7	Replace Yukon 138 kV breaker "Y-8(HUNTING)" with an 80 kA breaker		APS (100%)
b2666.8	Replace Yukon 138 kV breaker "Y-9(SPRINGD)" with an 80 kA breaker		APS (100%)
b2666.9	Replace Yukon 138 kV breaker "Y-10(CHRL-SP)" with an 80 kA breaker		APS (100%)
b2666.10	Replace Yukon 138 kV breaker "Y-12(1-1BUS)" with an 80 kA breaker		APS (100%)
b2666.11	Replace Yukon 138 kV breaker "Y-14(4-1BUS)" with an 80 kA breaker		APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2666.12	Replace Yukon 138 kV breaker "Y-2(1B-BETHE)" with an 80 kA breaker		APS (100%)
b2666.13	Replace Yukon 138 kV breaker "Y-21(SHEPJ)" with an 80 kA breaker		APS (100%)
b2666.14	Replace Yukon 138 kV breaker "Y-22(SHEPHJT)" with an 80 kA breaker		APS (100%)
b2672	Change CT Ratio at Seneca Caverns from 120/1 to 160/1 and adjust relay settings accordingly		APS (100%)
b2688.3	Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPSCO (15.85%) / RECO (0.12%)
b2689.3	Upgrade terminal equipment at structure 27A		APS (100%)
b2696	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations. New rating of line will be 353 MVA summer normal/422 MVA emergency		APS (100%)
b2700	Remove existing Black Oak SPS		APS (100%)
b2743.6	Reconfigure the Ringgold 230 kV substation to double bus double breaker scheme		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPSCO (20.88%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.6.1	Replace the two Ringgold 230/138 kV transformers	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.7	Rebuild/Reconductor the Ringgold – Catoctin 138 kV circuit and upgrade terminal equipment on both ends	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2747.1	Relocate the FirstEnergy Pratts 138 kV terminal CVTs at Gordonsville substation to allow for the installation of a new motor operated switch being installed by Dominion	APS (100%)
b2763	Replace the breaker risers and wave trap at Bredinville 138 kV substation on the Cabrey Junction 138 kV terminal	APS (100%)
b2764	Upgrade Fairview 138 kV breaker risers and disconnect leads; Replace 500 CU breaker risers and 556 ACSR disconnect leads with 795 ACSR	APS (100%)
b2964.1	Replace terminal equipment at Pruntytown and Glen Falls 138 kV station	APS (100%)
b2964.2	Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2965	Reconductor the Charleroi – Allenport 138 kV line with 954 ACSR conductor. Replace breaker risers at Charleroi and Allenport	DL (100%)
b2966	Reconductor the Yukon – Smithton – Shepler Hill Jct 138 kV line with 795 ACSS conductor. Replace Line Disconnect Switch at Yukon	APS (100%)
b2966.1	Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV line and replace terminal equipment as necessary to achieve required rating	APS (100%)
b2967	Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV line into two separate 138 kV lines. New lines will be Butler - Keisters and Butler - Shanor Manor - Krendale 138 kV	APS (100%)
b2970	Ringgold – Catoctin Solution	APS (100%)
b2970.1	Install two new 230 kV positions at Ringgold for 230/138 kV transformers	APS (100%)
b2970.2	Install new 230 kV position for Ringgold – Catoctin 230 kV line	APS (100%)
b2970.3	Install one new 230 kV breaker at Catoctin substation	APS (100%)
b2970.4	Install new 230/138 kV transformer at Catoctin substation. Convert Ringgold – Catoctin 138 kV line to 230 kV operation	APS (100%)



**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2970.5	Convert Garfield 138/12.5 kV substation to 230/12.5 kV	APS (100%)
b2996	Construct new Flint Run 500/138 kV substation	See sub-IDs for cost allocations
b2996.1	Construct a new 500/138 kV substation as a 4-breaker ring bus with expansion plans for double-breaker-double-bus on the 500 kV bus and breaker-and-a-half on the 138 kV bus to provide EHV source to the Marcellus shale load growth area. Projected load growth of additional 160 MVA to current plan of 280 MVA, for a total load of 440 MVA served from Waldo Run substation. Construct additional 3-breaker string at Waldo Run 138 kV bus. Relocate the Sherwood #2 line terminal to the new string. Construct two single circuit Flint Run - Waldo Run 138 kV lines using 795 ACSR (approximately 3 miles). After terminal relocation on new 3-breaker string at Waldo Run, terminate new Flint Run 138 kV lines onto the two open terminals	APS (100%)
b2996.2	Loop the Belmont – Harrison 500 kV line into and out of the new Flint Run 500 kV substation (less than 1 mile). Replace primary relaying and carrier sets on Belmont and Harrison 500 kV remote end substations	APS (100%)
b2996.3	Upgrade two (2) existing 138 kV breakers (Rider 50 and #1/4 transformer breaker) at Glen Falls with 63 kA 3000A units	APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3005	Reconductor 3.1 mile 556 ACSR portion of Cabot to Butler 138 kV with 556 ACSS and upgrade terminal equipment. 3.1 miles of line will be reconducted for this project. The total length of the line is 7.75 miles	APS (100%)
b3006	Replace four Yukon 500/138 kV transformers with three transformers with higher rating and reconfigure 500 kV bus	APS (73.55%) / DL (26.45%)
b3007.1	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - AP portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Social Hall, meters, relays, bus conductor, a wave trap, circuit breaker and disconnects will be replaced	APS (100%)
b3010	Replace terminal equipment at Keystone and Cabot 500 kV buses. At Keystone, bus tubing and conductor, a wave trap, and meter will be replaced. At Cabot, a wave trap and bus conductor will be replaced	APS (100%)
b3011.1	Construct new Route 51 substation and connect 10 138 kV lines to new substation	DL (100%)
b3011.2	Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line (New Yukon to Route 51 #4 138 kV line)	DL (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3011.3	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #1 138 kV line	DL (100%)
b3011.4	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #2 138 kV line	DL (100%)
b3011.5	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line	DL (100%)
b3011.6	Upgrade remote end relays for Yukon – Allenport – Iron Bridge 138 kV line	DL (100%)
b3012.1	Construct two new 138 kV ties with the single structure from APS’s new substation to Duquesne’s new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase	ATSI (38.21%) / DL (61.79%)
b3012.3	Construct a new Elrama – Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconducted portion. Install a new line terminal at APS Route 51 substation	DL (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3013	Reconductor Vasco Tap to Edgewater Tap 138 kV line. 4.4 miles. The new conductor will be 336 ACSS replacing the existing 336 ACSR conductor		APS (100%)
b3015.6	Reconductor Elrama to Mitchell 138 kV line – AP portion. 4.2 miles total. 2x 795 ACSS/TW 20/7		DL (100%)
b3015.8	Upgrade terminal equipment at Mitchell for Mitchell – Elrama 138 kV line		APS (100%)
b3028	Upgrade substation disconnect leads at William 138 kV substation		APS (100%)
b3051.1	Ronceverte cap bank and terminal upgrades		APS (100%)
b3052	Install a 138 kV capacitor (29.7 MVAR effective) at West Winchester 138 kV		APS (100%)
b3064.3	Upgrade line relaying at Piney Fork and Bethel Park for Piney For – Elrama 138 kV line and Bethel Park – Elrama 138 kV		APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3068	Reconductor the Yukon – Westraver 138 kV line (2.8 miles), replace the line drops and relays at Yukon 138 kV and replace switches at Westraver 138 kV bus		APS (100%)
b3069	Reconductor the Westraver – Route 51 138 kV line (5.63 miles) and replace line switches at Westraver 138 kV bus		APS (100%)
b3070	Reconductor the Yukon – Route 51 #1 138 kV line (8 miles), replace the line drops, relays and line disconnect switch at Yukon 138 kV bus		APS (100%)
b3071	Reconductor the Yukon – Route 51 #2 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3072	Reconductor the Yukon – Route 51 #3 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3074	Reconductor the 138 kV bus at Armstrong substation		APS (100%)
b3075	Replace the 500/138 kV transformer breaker and reconductor 138 kV bus at Cabot substation		APS (100%)
b3076	Reconductor the Edgewater – Loyalhanna 138 kV line (0.67 mile)		APS (100%)
b3079	Replace the Wylie Ridge 500/345 kV transformer #7		ATSI (72.30%) / DL (27.70%)
b3083	Reconductor the 138 kV bus at Butler and reconductor the 138 kV bus and replace line trap at Karns City		APS (100%)

**Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3128	Relocate 34.5 kV lines from generating station roof R. Paul Smith 138 kV station	APS (100%)
b3230	At Enon substation install a second 138 kV, 28.8 MVAR nameplate, capacitor and the associated 138 kV capacitor switcher	APS (100%)
b3240	Upgrade Cherry Run and Morgan terminals to make the transmission line the limiting component	APS (100%)
b3241	Install 138 kV, 36 MVAR capacitor and a 5 uF reactor protected by a 138 kV capacitor switcher. Install a breaker on the 138 kV Junction terminal. Install a 138 kV 3.5 uF reactor on the existing Hardy 138 kV capacitor	APS (100%)
b3242	Reconfigure Stonewall 138 kV substation from its current configuration to a six-breaker, breaker-and-a-half layout and add two (2) 36 MVAR capacitors with capacitor switchers	APS (100%)
b3318	Reconductor the Shanor Manor - Butler 138 kV line with an upgraded circuit breaker at Butler 138 kV station	APS (100%)
b3325	Reconductor the Charleroi - Union 138 kV line and upgrade terminal equipment at Charleroi 138 kV station	APS (100%)

Attachment 5B – Cost Allocation of 2022/2023 BG&E Schedule 12 Charges

**Attachment 5B PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for BG&E**

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022 - May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup> <i>per PJM Open Access Transmission Tariff</i>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
Install a second Conastone – Graceton 230 kV circuit	b0497	\$ 2,685,400.00	9.00%	9.64%	14.07%	0.52%	\$241,686	\$258,873	\$377,836	\$13,964	\$892,358
Upgrade Conastone Substation Equipment 500kv	b2766.1	\$ 553,839	1.67%	3.92%	6.40%	0.27%	\$9,249	\$21,710	\$35,446	\$1,495	\$67,901
Upgrade Conastone Substation Equipment 500kv	2766.1_dfax	\$ 553,839	0.72%	0.00%	12.92%	0.50%	\$3,988	\$0	\$71,556	\$2,769	\$78,313
		\$ -					\$0	\$0	\$0	\$0	\$0
Totals							\$254,923	\$280,583	\$484,837	\$18,229	\$1,038,572

Notes on calculations >>>

$$= (a) * (b) \quad = (a) * (c) \quad = (a) * (d) \quad = (a) * (e) \quad = (f) + (g) + (h) + (i)$$

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM website	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 40,403.11	10,064.1	\$ 4.01	\$ 282,822	\$ 202,016	\$ 484,837
JCP&L	\$ 23,381.92	6,169.1	\$ 3.79	\$ 163,673	\$ 116,910	\$ 280,583
ACE	\$ 21,243.56	2,631.0	\$ 8.07	\$ 148,705	\$ 106,218	\$ 254,923
RE	\$ 1,519.05	427.4	\$ 3.55	\$ 10,633	\$ 7,595	\$ 18,229
<b>Total Impact on NJ Zones</b>	<b>\$ 86,547.65</b>			<b>\$ 605,834</b>	<b>\$ 432,738</b>	<b>\$ 1,038,572</b>

Notes on calculations >>>

$$= (k) * (l) \quad = (k) * 7 \quad = (k) * 5 \quad = (n) * (o)$$

**Notes:**

1) 2022 allocation share percentages are from PJM OATT



## SCHEDULE 12 – APPENDIX

### (2) Baltimore Gas and Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0152 Add (2) 230 kV Breakers at High Ridge and install two Northwest 230 kV 120 MVAR capacitors		BGE (100%)
b0244 Install a 4 <sup>th</sup> Waugh Chapel 500/230 kV transformer, terminate the transformer in a new 500 kV bay and operate the existing in-service spare transformer on standby		BGE (85.56%) / ME (0.83%) / PEPSCO (13.61%)
b0298 Replace both Conastone 500/230 kV transformers with larger transformers	As specified in Attachment H-2A, Attachment 7, the Transmission Enhancement Charge Worksheet	BGE (75.85%) / Dominion (11.54%) / ME (4.73%) / PEPSCO (7.88%)
b0298.1 Replace Conastone 230 kV breaker 500-3/2323		BGE (100%)
b0474 Add a fourth 230/115 kV transformer, two 230 kV circuit breakers and a 115 kV breaker at Waugh Chapel		BGE (100%)
b0475 Create two 230 kV ring buses at North West, add two 230/115 kV transformers at North West and create a new 115 kV station at North West		BGE (100%)
b0476 Rebuild High Ridge 230 kV substation to Breaker and Half configuration		BGE (100%)
b0477 Replace the Waugh Chapel 500/230 kV transformer #1 with three single phase transformers		BGE (90.56%) / ME (1.51%) / PECO (.92%) / PEPSCO (4.01%) / PPL (3.00%)

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0497	Install a second Conastone – Graceton 230 kV circuit		AEC (9.00%) / DPL (16.85%) / JCPL (9.64%) / ME (1.48%) / NEPTUNE* (0.95%) / PECO (30.79%) / PPL (16.41%) / ECP** (0.29%) / PSEG (14.07%) / RE (0.52%)
b0497.1	Replace Conastone 230 kV breaker #4		BGE (100%)
b0497.2	Replace Conastone 230 kV breaker #7		BGE (100%)
b0500.2	Replace wavetrap and raise operating temperature on Conastone – Otter Creek 230 kV line to 165 deg		AEC (6.27%) / DPL (8.65 %) / JCPL (14.54%) / ME (10.59%) / NEPTUNE* (1.37%) / PECO (15.66%) / PPL (21.02%) / ECP** (0.57%) / PSEG (20.56%) / RE (0.77%)
b0512.33	MAPP Project Install new Hallowing Point – Calvert Cliffs 500 kV circuit and associated substation work at Calvert Cliffs substation		AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

## Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.43	MAPP Project Install new Hallowing Point – Calvert Cliffs 500 kV circuit and associated substation work at Calvert Cliffs substation	AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
b0729	Rebuild both Harford – Perryman 110615-A and 110616-A 115 kV circuits	BGE (100%)
b0749	Replace 230 kV breaker and associated CT's at Riverside 230 kV on 2345 line; replace all dead-end structures at Brandon Shores, Hawkins Point, Sollers Point and Riverside; Install a second conductor per phase on the spans entering each station	BGE (100%)

\* Neptune Regional Transmission System, LLC

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0795	Install a 115 kV breaker at Chesaco Park		BGE (100%)
b0796	Install 2, 115 kV breakers at Gwynnbrook		BGE (100%)
b0819	Remove line drop limitations at the substation terminations for Gwynnbrook – Mays Chapel 115 kV		BGE (100%)
b0820	Remove line drop limitations at the substation terminations and replace switch for Delight – Gwynnbrook 115 kV		BGE (100%)
b0821	Remove line drop limitations at the substation terminations for Northwest – Delight 115 kV		BGE (100%)
b0822	Remove line drop limitations at the substation terminations for Gwynnbrook – Sudbrook 115 kV		BGE (100%)
b0823	Remove line drop limitations at the substation terminations for Windy Edge – Texas 115 kV		BGE (100%)
b0824	Remove line drop limitations at the substation terminations for Granite – Harrisonville 115 kV		BGE (100%)
b0825	Remove line drop limitations at the substation terminations for Harrison – Dolefield 115 kV		BGE (100%)

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0826 Remove line drop limitations at the substation terminations for Riverside – East Point 115 kV		BGE (100%)
b0827 Install an SPS for one year to trip a Mays Chapel 115 kV breaker one line 110579 for line overloads 110509		BGE (100%)
b0828 Disable the HS throwover at Harrisonville for one year		BGE (100%)
b0870 Rebuild each line (0.2 miles each) to increase the normal rating to 968 MVA and the emergency rating to 1227 MVA		BGE (100%)
b0906 Increase contact parting time on Wagner 115 kV breaker 32-3/2		BGE (100%)
b0907 Increase contact parting time on Wagner 115 kV breaker 34-1/3		BGE (100%)
b1016 Rebuild Graceton - Bagley 230 kV as double circuit line using 1590 ACSR. Terminate new line at Graceton with a new circuit breaker		APS (2.02%) / BGE (75.22%) / Dominion (16.10%) / PEPCO (6.66%)
b1055 Upgrade wire drops at Center 115 kV on the Center - Westport 115 kV circuit		BGE (100%)
b1029 Upgrade wire sections at Wagner on both 110534 and 110535 115 kV circuits. Reconfigure Lipins Corner substation		BGE (100%)

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-2.

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1030 Move the Hillen Rd substation from circuits 110507/110508 to circuits 110505/110506		BGE (100%)
b1031 Replace wire sections on Westport - Pumphrey 115 kV circuits #110521, 110524, 110525, and 110526		BGE (100%)
b1083 Upgrade wire sections of the Mays Chapel – Mt Washington circuits (110701 and 110703) to improve the rating to 260/300 SN/SE MVA		BGE (100%)
b1084 Extend circuit 110570 from Deer Park to Northwest, and retire the section of circuit 110560 from Deer Park to Deer Park tap and retire existing Deer Park Breaker		BGE (100%)
b1085 Upgrade substation wire conductors at Lipins Corner to improve the rating of Solley-Lipins Corner sections of circuits 110534 and 110535 to 275/311 MVA SN/SE		BGE (100%)
b1086 Build a new 115 kV switching station between Orchard St. and Monument St.		BGE (100%)
b1175 Apply SPS at Mt. Washington to delay load pick-up for one outage and for the other outage temporarily drop load		BGE (100%)

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1176	Transfer 6 MW of load from Mt. Washington – East Towson	BGE (100%)
b1251	Build a second Raphael – Bagley 230 kV	APS (4.42%) / BGE (66.95%) / ComEd (4.12%) / Dayton (0.49%) / Dominion (18.76%) / PENELEC (0.05%) / PEPCO (5.21%)
b1251.1	Re-build the existing Raphael – Bagley 230 kV	APS (4.42%) / BGE (66.95%) / ComEd (4.12%) / Dayton (0.49%) / Dominion (18.76%) / PENELEC (0.05%) / PEPCO (5.21%)
b1252	Upgrade terminal equipment (remove terminal limitation at Pumphrey Tap to bring the circuit to 790N/941E	BGE (100%)

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1253	Replace the existing Northeast 230/115 kV transformer #3 with 500 MVA	BGE (100%)
b1253.1	Replace the Northeast 230 kV breaker '2317/315'	BGE (100%)
b1253.2	Revise reclosing on Windy Edge 115 kV breaker '110515'	BGE (100%)
b1253.3	Revise reclosing on Windy Edge 115 kV breaker '110516'	BGE (100%)
b1253.4	Revise reclosing on Windy Edge 115 kV breaker '110517'	BGE (100%)
b1254	Build a new 500/230 kV substation (Emory Grove)	APS (4.07%) / BGE (53.19%) / ComEd (3.71%) / Dayton (0.50%) / Dominion (16.44%) / PENELEC (0.59%) / PEPCO (21.50%)
b1254.1	Bundle the Emory – North West 230 kV circuits	BGE (100%)
b1267	Rebuild existing Erdman 115 kV substation to a dual ring-bus configuration to enable termination of new circuits	BGE (100%)
b1267.1	Construct 115 kV double circuit underground line from existing Coldspring to Erdman substation	BGE (100%)
b1267.2	Replace Mays Chapel 115 kV breaker '110515A'	BGE (100%)
b1267.3	Replace Mays Chapel 115 kV breaker '110579C'	BGE (100%)



### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1544	Advance the baseline upgrade B1252 to upgrade terminal equipment removing terminal limitation at Pumphrey Tap on BGE 230 kV circuit 2332-A	BGE (100%)
b1545	Upgrade terminal equipment at both Brandon Shores and Waugh Chapel removing terminal limitation on BGE 230 kV circuit 2343	BGE (100%)
b1546	Upgrade terminal equipment at Graceton removing terminal limitation on BGE portion of the 230 kV Graceton – Cooper circuit 2343	BGE (100%)
b1583	Replace Hazelwood 115 kV breaker '110602'	BGE (100%)
b1584	Replace Hazelwood 115 kV breaker '110604'	BGE (100%)
b1606.1	Moving the station supply connections of the Hazelwood 115/13 kV station	BGE (100%)
b1606.2	Installing 115 kV tie breakers at Melvale	BGE (100%)
b1785	Revise the reclosing for Pumphrey 115 kV breaker '110521 DR'	BGE (100%)
b1786	Revise the reclosing for Pumphrey 115 kV breaker '110526 DR'	BGE (100%)
b1789	Revise the reclosing for Pumphrey 115 kV breaker '110524DR'	BGE (100%)
b1806	Rebuild Wagner 115 kV substation to 80 kA	BGE (100%)

## SCHEDULE 12 – APPENDIX A

### (2) Baltimore Gas and Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2219	Install a 115 kV tie breaker at Wagner to create a separation from line 110535 and transformer 110-2	BGE (100%)
b2220	Install four 115 kV breakers at Chestnut Hill	BGE (100%)
b2221	Install an SPS to trip approximately 19 MW load at Green St. and Concord	BGE (100%)
b2307	Install a 230/115 kV transformer at Raphael Rd and construct approximately 3 miles of 115 kV line from Raphael Rd. to Joppatowne. Construct a 115 kV three breaker ring at Joppatowne	BGE (100%)
b2308	Build approximately 3 miles of 115 kV underground line from Bestgate tap to Waugh Chapel. Create two breaker bay at Waugh Chapel to accommodate the new underground circuit	BGE (100%)
b2396	Build a new Camp Small 115 kV station and install 30 MVAR capacitor	BGE (100%)

## Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2396.1	Install a tie breaker at Mays Chapel 115 kV substation	BGE (100%)
b2567	Upgrade the Riverside 115 kV substation strain bus conductors on circuits 115012 and 115011 with double bundled 1272 ACSR to achieve ratings of 491/577 MVA SN/SE on both transformer leads	BGE (100%)
b2568	Reconductor Northwest – Northwest #2 115 kV 110574 substation tie circuit with 2167 ACSR to achieve ratings of 400/462 MVA SN/SE	BGE (100%)
b2752.6	Conastone 230 kV substation tie-in work (install a new circuit breaker at Conastone 230 kV and upgrade any required terminal equipment to terminate the new circuit)	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2752.7	Reconductor/Rebuild the two Conastone – Northwest 230 kV lines and upgrade terminal equipment on both ends	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2752.8	Replace the Conastone 230 kV ‘2322 B5’ breaker with a 63 kA breaker	BGE (100%)

### Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2752.9	Replace the Conastone 230 kV '2322 B6' breaker with a 63 kA breaker	BGE (100%)
b2766.1	Upgrade substation equipment at Conastone 500 kV to increase facility rating to 2826 MVA normal and 3525 MVA emergency	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (0.72%) / APS (11.06%) / ATSI (1.43%) / BGE (34.25%) / DPL (1.83%) / PECO (1.80%) / PEPCO (35.49%) / PSEG (12.92%) / RE (0.50%)</p>

\*Neptune Regional Transmission System, LLC

## Baltimore Gas and Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2816	Re-connect the Crane – Windy Edge 110591 & 110592 115 kV circuits into the Northeast Substation with the addition of a new 115 kV 3-breaker bay	BGE (100%)
b2992.1	Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits. Replace 7 disconnect switches at Conastone substation	AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.2	Add Bundle conductor on the Graceton – Bagley – Raphael Road 2305 & 2313 230 kV circuits	AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.3	Replacing short segment of substation conductor on the Windy Edge to Glenarm 110512 115 kV circuit	AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.4	Reconductor the Raphael Road – Northeast 2315 & 2337 230 kV circuits	AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b3228	Replace two (2) relays at Center substation to increase ratings on the Westport to Center 110552 115 kV circuit	BGE (100%)
b3305	Replace Pumphrey 230/115 kV transformer	BGE (100%)

Attachment 5C – Cost Allocation of 2022/2023 PPL Schedule 12 Charges

**Attachment 5C PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for PPL Projects**

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement			Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
per PJM website	PJM Upgrade ID per PJM spreadsheet	June 2022- May 2023 Annual Revenue Requirement per PJM website	ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
New 500 KV Susquehanna- Roseland Line	b0487	\$ 31,253,716.50	1.67%	3.92%	6.40%	0.27%	\$521,937	\$1,225,146	\$2,000,238	\$84,385	\$3,831,706
New 500 KV Susquehanna- Roseland Line	b0487_dfax	\$ 31,253,716.50	0.00%	30.99%	62.66%	2.43%	\$0	\$9,685,527	\$19,583,579	\$759,465	\$30,028,571
Replace wave trap at Alburtus 500 kV Sub	b0171.2	\$ 3,487.00	1.67%	3.92%	6.40%	0.27%	\$58	\$137	\$223	\$9	\$428
Replace wave trap at Alburtus 500 kV Sub	b0171.2_dfax	\$ 3,487.00	9.80%	19.56%	0.00%	0.00%	\$342	\$682	\$0	\$0	\$1,024
Replace wavetrapp at Hosensack 500KV Sub	b0172.1	\$ 2,500.50	1.67%	3.92%	6.40%	0.27%	\$42	\$98	\$160	\$7	\$307
Replace wavetrapp at Hosensack 500KV Sub	b0172.1_dfax	\$ 2,500.50	8.24%	30.19%	54.60%	2.12%	\$206	\$755	\$1,365	\$53	\$2,379
Replace wavetraps at Juniata 500KV Sub	b0284.2	\$ 5,062.00	1.67%	3.92%	6.40%	0.27%	\$85	\$198	\$324	\$14	\$621
Replace wavetraps at Juniata 500KV Sub	b0284.2_dfax	\$ 5,062.00	5.89%	19.26%	26.53%	1.03%	\$298	\$975	\$1,343	\$52	\$2,668
New S-R additions < 500kv <sup>2</sup>	b0487.1	\$ 1,488,654.00	0.00%	0.00%	5.13%	0.19%	\$0	\$0	\$76,368	\$2,828	\$79,196
New substation and transformers Middletown	b0468	\$ 2,016,535.00	0.00%	4.55%	5.93%	0.22%	\$0	\$91,752	\$119,581	\$4,436	\$215,769
Install Lauschtown 500/230 kV Sub below 500kv portion	b2006	\$ 944,183.00	1.10%	9.61%	11.35%	0.45%	\$10,386	\$90,736	\$107,165	\$4,249	\$212,536
Install Lauschtown 500/230 kV Sub 500kv portion tie line	b2006.1	\$ 1,999,623.00	1.67%	3.92%	6.40%	0.27%	\$33,394	\$78,385	\$127,976	\$5,399	\$245,154
Install Lauschtown 500/230 kV Sub 500kv portion tie line	b2006.1_dfax	\$ 1,999,623.00	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0
200 MVAR shunt reactor at Alburtis 500kv	b2237	\$ 720,809.50	1.67%	3.92%	6.40%	0.27%	\$12,038	\$28,256	\$46,132	\$1,946	\$88,371
200 MVAR shunt reactor at Alburtis 500kv	b2237_dfax	\$ 720,809.50	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0

Attachment 5C PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023  
Calculation of costs and monthly PJM charges for PPL Projects

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
			Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022- May 2023 Annual Revenue Requirement <i>per PJM website</i>	ACE Zone Share <sup>1</sup> <i>per PJM Open Access Transmission Tariff</i>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
200 MVAR shunt reactor at Lackawana 500kv	b2716	\$ 680,596.50	1.67%	3.92%	6.40%	0.27%	\$11,366	\$26,679	\$43,558	\$1,838	\$83,441
200 MVAR shunt reactor at Lackawana 500kv	b2716_dfax	\$ 680,596.50	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0
Add 3rd Bay w/3 Breakers at Lackawanna 500kv	b2824	\$ 824,922.00	1.67%	3.92%	6.40%	0.27%	\$13,776	\$32,337	\$52,795	\$2,227	\$101,135
Add 3rd Bay w/3 Breakers at Lackawanna 500kv	b2824_dfax	\$ 824,922.00	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0
Totals							\$603,927	\$11,261,663	\$22,160,806	\$866,909	\$34,893,305

Notes on calculations >>>

$$= (a) * (b) \quad = (a) * (c) \quad = (a) * (d) \quad = (a) * (e) \quad = (f) + (g) + (h) + (i)$$

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM website	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 1,846,733.84	10,064.1	\$ 183.50	\$ 12,927,137	\$ 9,233,669	\$ 22,160,806
JCP&L	\$ 938,471.92	6,169.1	\$ 152.12	\$ 6,569,303	\$ 4,692,360	\$ 11,261,663
ACE	\$ 50,327.24	2,631.0	\$ 19.13	\$ 352,291	\$ 251,636	\$ 603,927
RE	\$ 72,242.42	427.4	\$ 169.03	\$ 505,697	\$ 361,212	\$ 866,909
<b>Total Impact on NJ Zones</b>	<b>\$ 2,907,775.43</b>			<b>\$ 20,354,428</b>	<b>\$ 14,538,877</b>	<b>\$ 34,893,305</b>

Notes on calculations >>>

$$= (k) * (l) \quad = (k) * 7 \quad = (k) * 5 \quad = (n) * (o)$$

**Notes:**

1) 2022 allocation share percentages are from PJM OATT



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

## SCHEDULE 12 – APPENDIX

### (9) PPL Electric Utilities Corporation

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0074	Rebuild 12 miles of S. Akron – Berks 230 kV to double circuit, looping Met Ed's S. Lebanon – S. Reading line into Berks; replacement of S. Reading 230 kV breaker 107252	PPL (100%)
b0171.2	Replace wavetrap at Hosensack 500 kV substation to increase rating of Elroy - Hosensack 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%) <b>DFAX Allocation:</b> AEC (9.80%) / DPL (8.43%) / JCPL (19.56%) / PECO (62.21%)

\* Neptune Regional Transmission System, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0172.1	Replace wave trap at Alburdis 500 kV substation	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) /  APS (5.64%) / ATSI (8.02%) /  BGE (4.12%) / ComEd (13.46%)  / Dayton (2.12%) / DEOK  (3.37%) / DL (1.76%) / DPL  (2.55%) / Dominion (12.97%) /  EKPC (1.81%) / JCPL (3.92%) /  ME (1.95%) / NEPTUNE*  (0.24%) / OVEC (0.07%) / PECO  (5.39%) / PENELEC (1.84%) /  PEPCO (3.71%) / PPL (4.78%) /  PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (8.24%) / JCPL (30.19%) /  NEPTUNE* (4.85%) / PSEG  (54.60%) / RE (2.12%)</p>
b0284.2	Replace two wave traps at Juniata 500 kV – on the two Juniata – Airydale 500 kV	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) /  APS (5.64%) / ATSI (8.02%) /  BGE (4.12%) / ComEd (13.46%)  / Dayton (2.12%) / DEOK  (3.37%) / DL (1.76%) / DPL  (2.55%) / Dominion (12.97%) /  EKPC (1.81%) / JCPL (3.92%) /  ME (1.95%) / NEPTUNE*  (0.24%) / OVEC (0.07%) / PECO  (5.39%) / PENELEC (1.84%) /  PEPCO (3.71%) / PPL (4.78%) /  PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (5.89%) / BGE (14.03%) /  JCPL (19.26%) / ME (10.43%) /  NEPTUNE* (2.13%) / PECO  (20.70%) / PSEG (26.53%) / RE  (1.03%)</p>

\* Neptune Regional Transmission System, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0284.4	Changes at Juniata 500 kV substation		PPL (100%)
b0293.1	Replace wavetrap at the Martins Creek 230 kV bus		PPL (100%)
b0293.2	Raise the operating temperature of the 2-1590 ACSR to 140C for the Martins Creek – Portland 230 kV circuit		PPL (100%)
b0440	Spare Juniata 500/230 kV transformer		PPL (100%)
b0468	Build a new substation with two 150 MVA transformers between Dauphin and Hummelstown 230/69 kV substations by sectionalizing the Middletown Junction – New Lebanon 230 kV line		JCPL (4.55%) / NEPTUNE* (0.37%) / PECO (1.79%) / PENELEC (0.33%) / PPL (86.63%) / ECP** (0.18%) / PSEG (5.93%) / RE (0.22%)

\* Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0469	Install 130 MVAR capacitor at West Shore 230 kV line	PPL (100%)
b0487	Build new 500 kV transmission facilities from Susquehanna to Pennsylvania – New Jersey border at Bushkill	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)  <b>DFAX Allocation:</b> JCPL (30.99%) / NEPTUNE* (3.92%) / PSEG (62.66%) / RE (2.43%)
b0487.1	Install Lackawanna 500/230 kV transformer and upgrade 230 kV substation and switchyard	PENELEC (16.90%) / PPL (77.59%) / ECP** (0.19%) / PSEG (5.13%) / RE (0.19%)
b0500.1	Conastone – Otter Creek 230 kV – Reconductor approximately 17.2 miles of 795 kcmil ACSR with new 795 kcmil ACSS operated at 160 deg C	AEC (6.27%) / DPL (8.65%) / JCPL (14.54%) / ME (10.59%) / Neptune* (1.37%) / PECO (15.66%) / PPL (21.02%) / ECP** (0.57%) / PSEG (20.56%) / RE (0.77%)

\*Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

The Annual Revenue Requirements associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-8G.

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0558	Install 250 MVAR capacitor at Juniata 500 kV substation	AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
b0593	Eldred – Pine Grove 69 kV line Rebuild Part 2: 8 miles	PPL (100%)
b0595	Rebuild Lackawanna – Edella 69 kV line to double circuit	PPL (100%)
b0596	Reconductor and rebuild Stanton – Providence 69 kV #1 and #2 lines with 69 kV design; approximately 8 miles total	PPL (100%)
b0597	Reconductor Suburban – Providence 69 kV #1 and resectionalize the Suburban 69 kV lines	PPL (100%)
b0598	Reconductor Suburban Taps #1 and #2 for 69 kV line portions	PPL (100%)

\* Neptune Regional Transmission System, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0600 Tripp Park Substation: 69 kV tap off Stanton – Providence 69 kV line #3 to new substation		PPL (100%)
b0601 Jessup Substation: New 138/69 kV tap off of Peckville – Jackson 138/69 kV line		PPL (100%)
b0604 Add 150 MVA, 230/138/69 transformer #6 to Harwood substation		PPL (100%)
b0605 Reconductor Stanton – Old Forge 69 kV line and resectionalize the Jenkins – Scranton 69 kV #1 and #2 lines		PPL (100%)
b0606 New 138 kV tap off Monroe – Jackson 138 kV #1 line to Bartonsville substation		PPL (100%)
b0607 New 138 kV taps off Monroe – Jackson 138 kV lines to Stroudsburg substation		PPL (100%)
b0608 New 138 kV tap off Siegfried – Jackson 138 kV #2 to transformer #2 at Gilbert substation		PPL (100%)
b0610 At South Farmersville substation, a new 69 kV tap off Nazareth – Quarry #2 to transformer #2		PPL (100%)
b0612 Rebuild Siegfried – North Bethlehem portion (6.7 miles) of Siegfried – Quarry 69 kV line		PPL (100%)
b0613 East Tannersville Substation: New 138 kV tap to new substation		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0614 Elroy substation expansion and new Elroy – Hatfield 138/69 kV double circuit lines (1.9 miles)		PPL (100%)
b0615 Reconductor and rebuild 12 miles of Seidersville – Quakerstown 138/69 kV and a new 75 MVA, 230/69 kV transformer #4		PPL (100%)
b0616 New Springfield 230/69 kV substation and transmission line connections		PPL (100%)
b0620 New 138 kV line and terminal at Monroe 230/138 substation		PPL (100%)
b0621 New 138 kV line and terminal at Siegfried 230/138 kV substation and add a second circuit to Siegfried – Jackson for 8.0 miles		PPL (100%)
b0622 138 kV yard upgrades and transmission line rearrangements at Jackson 138/69 kV substation		PPL (100%)
b0623 New West Shore – Whitehill Taps 138/69 kV double circuit line (1.3 miles)		PPL (100%)
b0624 Reconductor Cumberland – Wertzville 69 kV portion (3.7 miles) of Cumberland – West Shore 69 kV line		PPL (100%)
b0625 Reconductor Mt. Allen – Rossmoyne 69 kV portions (1.6 miles) of West Shore – Cumberland #3 and #4 lines		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0627	Replace UG cable from Walnut substation to Center City Harrisburg substation for higher ampacity (0.25 miles)	PPL (100%)
b0629	Lincoln substation: 69 kV tap to convert to modified Twin A	PPL (100%)
b0630	W. Hempfield – Donegal 69 kV line: Reconductor / rebuild from Landisville Tap – Mt. Joy (2 miles)	PPL (100%)
b0631	W. Hempfield – Donegal 69 kV line: Reconductor / rebuild to double circuit from Mt. Joy – Donegal (2 miles)	PPL (100%)
b0632	Terminate new S. Manheim – Donegal 69 kV circuit into S. Manheim 69 kV #3	PPL (100%)
b0634	Rebuild S. Manheim – Fuller 69 kV portion (1.0 mile) of S. Manheim – West Hempfield 69 kV #3 line into a 69 kV double circuit	PPL (100%)
b0635	Reconductor Fuller Tap – Landisville 69 kV (4.1 miles) into a 69 kV double circuit	PPL (100%)
b0703	Berks substation modification on Berks – South Akron 230 kV line. Modification will isolate the line fault on the South Akron line and will allow Berks transformer #2 to be energized by the South Lebanon 230 kV circuit	PPL (100%)



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0705	New Derry – Millville 69 kV line	PPL (100%)
b0707	Construct Bohemia – Twin Lakes 69 kV line, install a 10.9 MVAR capacitor bank near Bohemia 69 kV substation	PPL (100%)
b0708	New 69 kV double circuit from Jackson – Lake Naomi Tap	PPL (100%)
b0709	Install new 69 kV double circuit from Carlisle – West Carlisle	PPL (100%)
b0710	Install a third 69 kV line from Reese’s Tap to Hershey substation	PPL (100%)
b0711	New 69 kV that taps West Shore – Cumberland 69 kV #1 to Whitehill 69 kV substation	PPL (100%)
b0712	Construct a new 69 kV line between Strassburg Tap and the Millwood – Engleside 69 kV #1 line	PPL (100%)
b0713	Construct a new 138 kV double circuit line between Dillersville Tap and the West Hempfield – Prince 138 kV line	PPL (100%)
b0714	Prepare Roseville Tap for 138 kV conversion	PPL (100%)
b0715	Transfer S. Akron – S. Manheim #1 and #2 lines from the S. Akron 69 kV Yard to the S. Akron 138 kV Yard; Install switches on S. Akron – S. Manheim 138 kV #1 and #2 lines	PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0716	Add a second 69 kV line from Morgantown – Twin Valley	PPL (100%)
b0717	Rebuild existing Brunner Island – West Shore 230 kV line and add a second Brunner Island – West Shore 230 kV line	PPL (100%)
b0718	SPS scheme to drop 190 MVA of 69 kV radial load at West Shore and 56 MVA of 69 kV radial load at Cumberland	PPL (100%)
b0719	SPS scheme at Jenkins substation to open the Stanton #1 and Stanton #2 230 kV circuit breakers after the second contingency	PPL (100%)
b0791	Add a fourth 230/69 kV transformer at Stanton	PENELEC (9.55%) / PPL (90.45%)
b1074	Install motor operators on the Jenkins 230 kV ‘2W’ disconnect switch and build out Jenkins Bay 3 and have MOD ‘3W’ operated as normally open	PPL (100%)
b0881	Install motor operators on Susquehanna T21 - Susquehanna 230 kV line East CB at Susquehanna 230 kV switching station	PPL (100%)
b0908	Install motor operators at South Akron 230 kV	PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0909	Convert Jenkins 230 kV yard into a 3-breaker ring bus		PPL (100%)
b0910	Install a second 230 kV line between Jenkins and Stanton		PPL (100%)
b0911	Install motor operators at Frackville 230 kV		PPL (100%)
b0912	Install 2, 10.8 MVAR capacitor banks at Scranton 69 kV		PPL (100%)
b0913	Extend Cando Tap to the Harwood-Jenkins #2 69 kV line		PPL (100%)
b0914	Build a 3rd 69 kV line from Harwood to Valmont Taps		PPL (100%)
b0915	Replace Walnut-Center City 69 kV cable		PPL (100%)
b0916	Reconductor Sunbury-Dalmatia 69 kV line		PPL (100%)
b1021	Install a new (#4) 138/69 kV transformer at Wescosville		PPL (100%)
b1196	Remove the Siegfried bus tie breaker and install a new breaker on the Martins Creek 230 kV line west bay to maintain two ties between the 230 kV buses		PPL (100%)
b1201	Rebuild the Hercules Tap to Double Circuit 69 kV		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1202 Mack-Macungie Double Tap, Single Feed Arrangement		PPL (100%)
b1203 Add the 2nd Circuit to the East Palmerton-Wagners-Lake Naomi 138/69 kV Tap		PPL (100%)
b1204 New Breinigsville 230-69 kV Substation		PPL (100%)
b1205 Siegfried-East Palmerton #1 69 kV Line- Install new 69 kV LSAB, Sectionalize, and Transfer Treichlers Substation		PPL (100%)
b1206 Siegfried-Quarry #1 & #2 69 kV Lines- Rebuild 3.3 mi from Quarry Substation to Macada Taps		PPL (100%)
b1209 Convert Neffsville Taps from 69 kV to 138 kV Operation		PPL (100%)
b1210 Convert Roseville Taps from 69 kV to 138 kV Operation (Part 1 – operate on the 69 kV system)		PPL (100%)
b1211 Convert Roseville Taps from 69 kV to 138 kV Operation (Part 2 – operate on the 138 kV system)		PPL (100%)
b1212 New 138 kV Taps to Flory Mill 138/69 kV Substation		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1213	Convert East Petersburg Taps from 69 kV to 138 kV operation, install two 10.8 MVAR capacitor banks	PPL (100%)
b1214	Terminate South Manheim-Donegal #2 at South Manheim, Reduce South Manheim 69 kV Capacitor Bank, Resectionalize 69 kV	PPL (100%)
b1215	Reconductor and rebuild 16 miles of Peckville-Varden 69 kV line and 4 miles of Blooming Grove-Honesdale 69 kV line	PPL (100%)
b1216	Build approximately 2.5 miles of new 69 kV transmission line to provide a “double tap – single feed” connection to Kimbles 69/12 kV substation	PPL (100%)
b1217	Provide a “double tap – single feed” connection to Tafton 69/12 kV substation	PPL (100%)
b1524	Build a new Pocono 230/69 kV substation	PPL (100%)
b1524.1	Build approximately 14 miles new 230 kV South Pocono – North Pocono line	PPL (100%)
b1524.2	Install MOLSABs at Mt. Pocono substation	PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1525	Build new West Pocono 230/69 kV Substation	PPL (100%)
b1525.1	Build approximately 14 miles new 230 kV Jenkins-West Pocono 230 kV Line	PPL (100%)
b1525.2	Install Jenkins 3E 230 kV circuit breaker	PPL (100%)
b1526	Install a new Honeybrook – Twin Valley 69/138 kV tie	PPL (100%)
b1528	Install Motor-Operated switches on the Wescosville-Trexlerstown #1 & #2 69 kV lines at East Texas Substation	PPL (100%)
b1529	Add a double breaker 230 kV bay 3 at Hosensack	PPL (100%)
b1530	Replace Lock Haven 69 kV ring bus with standard breaker and half design	PPL (100%)
b1532	Install new 32.4 MVAR capacitor bank at Sunbury	PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1533	Rebuild Lycoming-Lock Haven #1 and Lycoming-Lock Haven #2 69 kV lines		PPL (100%)
b1534	Rebuild 1.4 miles of the Sunbury-Milton 69 kV		PPL (100%)
b1601	Re-configure the Breinigsville 500 kV substation with addition two 500 kV circuit breakers		AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)†
b1602	Re-configure the ElimSPORT 230 kV substation to breaker and half scheme and install 80 MVAR capacitor		PPL (100%)
b1740	Install a 90 MVAR cap bank on the Frackville 230 kV bus #207973		PPL (100%)
b1756	Install a 3rd West Shore 230/69 kV transformer		PPL (100%)
b1757	Install a 230 kV motor-operated air-break switch on the Clinton - ElimSPORT 230 kV line		PPL (100%)

\* Neptune Regional Transmission System, LLC

† Cost allocations associated with Regional Facilities and Necessary Lower Voltage Facilities associated with the project

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1758	Rebuild 1.65 miles of Columbia - Danville 69 kV line		PPL (100%)
b1759	Install a 69 kV 16.2 MVAR Cap at Milton substation		PPL (100%)
b1760	Install motor operated devices on the existing disconnect switches that are located on each side of all four 230 kV CBs at Stanton		PPL (100%)
b1761	Build a new Paupack - North 230 kV line (Approximately 21 miles)		PPL (100%)
b1762	Replace 3.7 miles of the existing 230 kV Blooming Grove - Peckville line by building 8.4 miles of new 230 kV circuit onto the Lackawanna - Hopatcong tower-line		PPL (100%)
b1763	Re-terminate the Peckville - Jackson and the Peckville - Varden 69 kV lines from Peckville into Lackawanna		PPL (100%)
b1764	Build a new 230-69 kV substations (Paupack)		PPL (100%)
b1765	Install a 16.2 MVAR capacitor bank at Bohemia 69-12 kV substation		PPL (100%)
b1766	Reconductor/rebuild 3.3 miles of the Siegfried - Quarry #1 and #2 lines		PPL (100%)
b1767	Install 6 motor-operated disconnect switches at Quarry substation		PPL (100%)



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1788 Install a new 500 kV circuit breaker at Wescosville		PPL (100%)
b1890 Add a second 230/69 kV transformer at North Pocono (NE/Pocono Reliability Project)		PPL (100%)
b1891 Build a new 230/138 kV Yard at Lackawanna (138 kV conversion from Lackawanna to Jenkins)		PPL (100%)
b1892 Rebuild the Throop Taps for 138 kV operation (138 kV Conversion from Lackawanna to Jenkins)		PPL (100%)
b1893 Swap the Staton - Old Forge and Stanton - Brookside 69 kV circuits at Stanton (138 kV Conversion from Lackawanna to Jenkins)		PPL (100%)
b1894 Rebuild and re-conductor 2.5 miles of the Stanton - Avoca 69 kV line		PPL (100%)
b1895 Rebuild and re-conductor 4.9 miles of the Stanton - Providence #1 69 kV line		PPL (100%)
b1896 Install a second 230/138 kV transformer and expand the 138 kV yard at Monroe		PPL (100%)
b1897 Build a new 230/138 kV substation at Jenkins (138 kV Conversion from Lackawanna to Jenkins)		PPL (100%)
b1898 Install a 69 kV Tie Line between Richfield and Dalmatia substations		PPL (100%)
b2004 Replace the CTs and switch in South Akron Bay 4 to increase the rating		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2005	Replace the CTs and switch in SAKR Bay 3 to increase the rating of the Millwood-South Akron 230 kV Line and of the rating in Bay 3	PPL (100%)
b2006	Install North Lancaster 500/230 kV substation (below 500 kV portion)	AEC (1.10%) / ECP** (0.37%) / HTP*** (0.37%) / JCPL (9.61%) / ME (19.42%) / NEPTUNE* (0.75%) / PECO (6.01%) / PPL (50.57%) / PSEG (11.35%) / RE (0.45%)
b2006.1	Install North Lancaster 500/230 kV substation (500 kV portion)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%) <b>DFAX Allocation:</b> BGE (19.51%) / PPL (80.49%)
b2006.2	Construct a new 230/69 kV North Lancaster substation. The sub will be supplied from the SAKR-BERK 230 kV Line	PPL (100%)
b2006.3	Construct new 69/138 kV transmission from North Lancaster 230/69 kV sub to Brecknock and Honeybrook areas	PPL (100%)

\* Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

\*\*\* Hudson Transmission Partners, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 9 PPL Electric Utilities Corpora

**PPL Electric Utilities Corporation (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2007	Install a 90 MVAR capacitor bank at the Frackville 230 kV Substation		PPL (100%)
b2158	Install 10.8 MVAR capacitor at West Carlisle 69/12 kV substation		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

## SCHEDULE 12 – APPENDIX A

### (9) PPL Electric Utilities Corporation

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1813.12	Replace the Blooming Grove 230 kV breaker 'Peckville'		PPL (100%)
b2223	Rebuild and reconductor 2.6 miles of the Sunbury - Dauphin 69 kV circuit		PPL (100%)
b2224	Add a 2nd 150 MVA 230/69 kV transformer at Springfield		PPL (100%)
b2237	150 MVAR shunt reactor at Alburtis 500 kV		<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			<b>DFAX Allocation:</b> PPL (100%)
b2238	100 MVAR shunt reactor at Elimsport 230 kV		PPL (100%)

\* Neptune Regional Transmission System, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2269 Rebuild approximately 23.7 miles of the Susquehanna - Jenkins 230 kV circuit. This replaces a temporary SPS that is already planned to mitigate the violation until this solution is implemented		PPL (100%)
b2282 Rebuild the Siegfried-Frackville 230 kV line		PPL (100%)
b2406.1 Rebuild Stanton-Providence 69 kV 2&3 9.5 miles with 795 SCSR		PPL (100%)
b2406.2 Reconductor 7 miles of the Lackawanna - Providence 69 kV #1 and #2 with 795 ACSR		PPL (100%)
b2406.3 Rebuild SUB2 Tap 1 (Lackawanna - Scranton 1) 69 kV 1.5 miles 556 ACSR		PPL (100%)
b2406.4 Rebuild SUB2 Tap 2 (Lackawanna - Scranton 1) 69 kV 1.6 miles 556 ACSR		PPL (100%)
b2406.5 Create Providence - Scranton 69 kV #1 and #2, 3.5 miles with 795 ACSR		PPL (100%)
b2406.6 Rebuild Providence 69 kV switchyard		PPL (100%)
b2406.7 Install 2 - 10.8 MVAR capacitors at EYNO 69 kV		PPL (100%)
b2406.8 Rebuild Stanton 230 kV yard		PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2446	Replace wave trap and protective relays at Montour	PPL (100%)
b2447	Replace wave trap and protective relays at Montour	PPL (100%)
b2448	Install a 2nd Sunbury 900 MVA 500-230 kV transformer and associated equipment	PPL (100%)
b2552.2	Reconductor the North Meshoppen - Oxbow – Lackawanna 230 kV circuit and upgrade terminal equipment (PPL portion)	PENELEC (98.84%) / PPL (1.16%)
b2574	Replace the Sunbury 230 kV ‘MONTOUR NORT’ breaker with a 63 kA breaker	PPL (100%)
b2690	Reconductor two spans of the Graceton – Safe Harbor 230 kV transmission line. Includes termination point upgrades	PPL (100%)
b2691	Reconductor three spans limiting Brunner Island – Yorkana 230 kV line, add 2 breakers to Brunner Island switchyard, upgrade associated terminal equipment	PPL (100%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2716	Add a 200 MVAR shunt reactor at Lackawanna 500 kV substation		<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) <b>DFAX Allocation:</b> PPL (100%)
b2754.1	Install 7 miles of optical ground wire (OPGW) between Gilbert and Springfield 230 kV substations		PPL (100%)
b2754.4	Use ~ 40 route miles of existing fibers on PPL 230 kV system to establish direct fiber circuits		PPL (100%)
b2754.5	Upgrade relaying at Martins Creek 230 kV		PPL (100%)
b2756	Install 2% reactors at Martins Creek 230 kV		PPL (100%)
b2813	Expand existing Lycoming 69 kV yard to double bus double breaker arrangement		PPL (100%)

\* Neptune Regional Transmission System, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2824	Reconfigure/Expand the Lackawanna 500 kV substation by adding a third bay with three breakers		<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) <b>DFAX Allocation:</b> PPL (100%)
b2838	Build a new 230/69 kV substation by tapping the Montour – Susquehanna 230 kV double circuits and Berwick – Hunlock & Berwick – Colombia 69 kV circuits		PPL (100%)
b2979	Replace Martins Creek 230 kV circuit breakers with 80 kA rating		PPL (100%)
b3221	Replace terminal equipment (bus conductor) on the 230 kV side of the Steel City 500/230 kV Transformer #1		PPL (100%)
b3222	Install one (1) 7.2 MVAR fixed cap bank on the Lock Haven – Reno 69 kV line and one (1) 7.2 MVAR fixed cap bank on the Lock Haven – Flemington 69 kV line near the Flemington 69/12 kV substation		PPL (100%)

\* Neptune Regional Transmission System, LLC



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 9 PPL Electric Utilities Corpo

### PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
<div data-bbox="212 537 293 569">b3664</div> <div data-bbox="334 373 667 737"> <p>Replace the limiting 230 kV T2 transformer leads, bay conductor and bus conductor with double bundle 1590 ACSR at the Juniata station; Replace the limiting 1200 A MODs on the bus tie breaker with 3000 A MODs</p> </div>		<div data-bbox="1149 772 1308 808">PPL (100%)</div>

Attachment 5D – Cost Allocation of 2022/2023 ACE Schedule 12 Charges

**Attachment 5D PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for ACE Projects**

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022 - May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
			<i>per PJM Open Access Transmission Tariff</i>								
Upgrade AE portion of Delco Tap	b0265	\$ 443,066.00	89.87%	9.48%	0.00%	0.00%	\$398,183	\$42,003	\$0	\$0	\$440,186
Replace Monroe 230/69 kV TXfms	b0276	\$ 678,062.00	91.28%	0.00%	8.29%	0.23%	\$618,935	\$0	\$56,211	\$1,560	\$676,706
Reconductor Union - Corson 138 kV	b0211	\$ 1,153,534.00	65.23%	25.87%	6.35%	0.00%	\$752,450	\$298,419	\$73,249	\$0	\$1,124,119
New 500/230 Kv Sub on Salem-East Windsor (>500 kV portion)	b0210.A	\$ 1,153,775.50	1.67%	3.92%	6.40%	0.27%	\$19,268	\$45,228	\$73,842	\$3,115	\$141,453
New 500/230 Kv Sub on Salem-East Windsor (>500 kV portion)	b0210.A_dfax	\$ 1,153,775.50	78.34%	21.66%	0.00%	0.00%	\$903,868	\$249,908	\$0	\$0	\$1,153,776
New 500/230kV Sub on Salem-East Windsor (< 500kV) portion <sup>2</sup>	b0210.B	\$ 1,645,369.00	65.23%	25.87%	6.35%	0.00%	\$1,073,274	\$425,657	\$104,481	\$0	\$1,603,412
Reconductor the existing Mickleton – Goucester 230 kV circuit (AE portion)	b1398.5	\$ 419,717.00	0.00%	12.82%	31.46%	1.25%	\$0	\$53,808	\$132,043	\$5,246	\$191,097
Build second 230kV parallel from Mickelton to Gloucester	b1398.3.1	\$ 1,307,433.00	0.00%	12.82%	31.46%	1.25%	\$0	\$167,613	\$411,318	\$16,343	\$595,274
Upgrade the Mill T2 138/69 kV Transformer	b1600	\$ 1,556,923.00	88.83%	4.74%	5.78%	0.23%	\$1,383,015	\$73,798	\$89,990	\$3,581	\$1,550,384

**Attachment 5D PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023**  
**Calculation of costs and monthly PJM charges for ACE Projects**

			(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Orchard-Cumberland												
Install 2nd 230 kV line	b0210.1	\$	1,379,652.00	65.23%	25.87%	6.35%	0.00%	\$899,947	\$356,916	\$87,608	\$0	\$1,344,471
Corson Upgrade												
138kV Line trap	b0212	\$	5,978.00	65.23%	25.87%	6.35%	0.00%	\$3,899	\$1,547	\$380	\$0	\$5,826
								<b>\$6,052,840</b>	<b>\$1,714,896</b>	<b>\$1,029,122</b>	<b>\$29,845</b>	<b>\$8,826,703</b>

Notes on calculations >>>

= (a) \* (b)      = (a) \* (c)      = (a) \* (d)      = (a) \* (e)      = (f) + (g) + (h) + (i)

	(k)	(l)	(m)	(n)	(o)	(p)
<b>Zonal Cost Allocation for New Jersey Zones</b>	<b>Average Monthly Impact on Zone Customers in 22/23</b>	<b>2022TX Peak Load per PJM website</b>	<b>Rate in \$/MW-mo.</b>	<b>2022 Impact (7 months)</b>	<b>2023 Impact (5 months)</b>	<b>2022-2023 Impact (12 months)</b>
PSE&G	\$ 85,760.20	10,064.1	\$ 8.52	\$ 600,321	\$ 428,801	\$ 1,029,122
JCP&L	\$ 142,907.99	6,169.1	\$ 23.17	\$ 1,000,356	\$ 714,540	\$ 1,714,896
ACE	\$ 504,403.31	2,631.0	\$ 191.72	\$ 3,530,823	\$ 2,522,017	\$ 6,052,840
RE	\$ 2,487.09	427.4	\$ 5.82	\$ 17,410	\$ 12,435	\$ 29,845
<b>Total Impact on NJ Zones</b>	<b>\$ 735,558.59</b>			<b>\$ 5,148,910</b>	<b>\$ 3,677,793</b>	<b>\$ 8,826,703</b>

Notes on calculations >>>

= (k) \* (l)      = (k) \* 7      = (k) \* 5      = (n) \* (o)

**Notes:**

1) 2022 allocation share percentages are from PJM OATT

## SCHEDULE 12 – APPENDIX

### (1) Atlantic City Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0135 Build new Cumberland – Dennis 230 kV circuit which replaces existing Cumberland – Corson 138 kV		AEC (100%)
b0136 Install Dennis 230/138 kV transformer, Dennis 150 MVAR SVC and 50 MVAR capacitor		AEC (100%)
b0137 Build new Dennis – Corson 138 kV circuit		AEC (100%)
b0138 Install Cardiff 230/138 kV transformer and a 50 MVAR capacitor at Cardiff		AEC (100%)
b0139 Build new Cardiff – Lewis 138 kV circuit		AEC (100%)
b0140 Reconductor Laurel – Woodstown 69 kV		AEC (100%)
b0141 Reconductor Monroe – North Central 69 kV		AEC (100%)
b0265 Upgrade AE portion of Delco Tap – Mickleton 230 kV circuit		AEC (89.87%) / JCPL (9.48%) / NEPTUNE* (0.65%)
b0276 Replace both Monroe 230/69 kV transformers		AEC (91.28%) / PSEG (8.29%) / RE (0.23%) / ECP** (0.20%)
b0276.1 Upgrade a strand bus at Monroe to increase the rating of transformer #2		AEC (100%)
b0277 Install a second Cumberland 230/138 kV transformer		AEC (100%)
b0281.1 Install 35 MVAR capacitor at Lake Ave 69 kV substation		AEC (100%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

### Atlantic City Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0281.2	Install 15 MVAR capacitor at Shipbottom 69 kV substation	AEC (100%)
b0281.3	Install 8 MVAR capacitors on the AE distribution system	AEC (100%)
b0142	Reconductor Landis – Minotola 138 kV	AEC (100%)
b0143	Reconductor Beckett – Paulsboro 69 kV	AEC (100%)
b0210	Install a new 500/230 kV substation in AEC area. The high side will be tapped on the Salem - East Windsor 500 kV circuit and the low side will be tapped on the Churchtown - Cumberland 230 kV circuit.	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (78.34%) / JCPL (21.66%)
b0210.1	Orchard – Cumberland – Install second 230 kV line	AEC (65.23%) / JCPL (25.87%) / NEPTUNE* (2.55%) / PSEG (6.35%)††
b0210.2	Install a new 500/230 kV substation in AEC area, the high side will be tapped on the Salem - East Windsor 500 kV circuit and the low side will be tapped on the Churchtown - Cumberland 230 kV circuit.	AEC (65.23%) / JCPL (25.87%) / NEPTUNE* (2.55%) / PSEG (6.35%)††

\* Neptune Regional Transmission System, LLC

††Cost allocations associated with below 500 kV elements of the project

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-1.

### Atlantic City Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0211	Reconductor Union - Corson 138 kV circuit	AEC (65.23%) / JCPL (25.87%) / NEPTUNE* (2.55%) / PSEG (6.35%)
b0212	Substation upgrades at Union and Corson 138 kV	AEC (65.23%) / JCPL (25.87%) / NEPTUNE* (2.55%) / PSEG (6.35%)
b0214	Install 50 MVAR capacitor at Cardiff 230 kV substation	AEC (100%)
b0431	Monroe Upgrade New Freedom strand bus	AEC (100%)
b0576	Move the Monroe 230/69 kV to Mickleton	AEC (100%)
b0744	Upgrade a strand bus at Mill 138 kV	AEC (100%)
b0871	Install 35 MVAR capacitor at Motts Farm 69 kV	AEC (100%)
b1072	Modify the existing EMS load shedding scheme at Cedar to additionally sense the loss of both Cedar 230/69 kV transformers and shed load accordingly	AEC (100%)
b1127	Build a new Lincoln-Minitola 138 kV line	AEC (100%)
b1195.1	Upgrade the Corson sub T2 terminal	AEC (100%)
b1195.2	Upgrade the Corson sub T1 terminal	AEC (100%)

\* Neptune Regional Transmission System, LLC

### Atlantic City Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1244	Install 10 MVAR capacitor at Peermont 69 kV substation	AEC (100%)
b1245	Rebuild the Newport-South Millville 69 kV line	AEC (100%)
b1250	Reconductor the Monroe – Glassboro 69 kV	AEC (100%)
b1250.1	Upgrade substation equipment at Glassboro	AEC (100%)
b1280	Sherman: Upgrade 138/69 kV transformers	AEC (100%)
b1396	Replace Lewis 138 kV breaker ‘L’	AEC (100%)
b1398.5	Reconductor the existing Mickleton – Gloucester 230 kV circuit (AE portion)	JCPL (12.82%) / NEPTUNE* (1.18%) / HTP*** (0.79%) / PECO (51.08%) / PEPCO (0.57%) / ECP** (0.85%) / PSEG (31.46%) / RE (1.25%)
b1598	Reconductor Sherman Av – Carl’s Corner 69 kV circuit	AEC (100%)
b1599	Replace terminal equipments at Central North 69 kV substation	AEC (100%)
b1600	Upgrade the Mill T2 138/69 kV transformer	AEC (88.83%) / JCPL (4.74%) / HTP*** (0.20%) / ECP** (0.22%) / PSEG (5.78%) / RE (0.23%)
b2157	Re-build 5.3 miles of the Corson - Tuckahoe 69 kV circuit	AEC (100%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-1.



## SCHEDULE 12 – APPENDIX A

### (1) Atlantic City Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2123	Upgrade the 69 kV bus at Laurel	AEC (100%)
b2226	Upgrade the Tackahoe to Mill 69 kV circuit	AEC (100%)
b2227	50 MVAR shunt reactor at Mickleton 230 kV and relocate Mickleton #1 230 69 kV transformer	AEC (100%)
b2228	+150/-100 MVAR SVC at Cedar 230 kV	AEC (100%)
b2296	Replace the Mickleton 230kV breaker PCB U with 63kA breaker	AEC (100%)
b2297	Replace the Mickleton 230kV breaker PCB V with 63kA breaker	AEC (100%)
b2305	Rebuild and reconductor 1.2 miles of the US Silica to US Silica #1 69 kV circuit	AEC (100%)
b2306	Rebuild and reconductor 1.67 miles of the US Silica #1 to W1-089 TAP 69 kV circuit	AEC (100%)
b2351	Reconductor section A of Corson - Sea Isle - Swanton 69 kV line	AEC (100%)
b2353	Upgrade the overcurrent protective relaying at Middle T3 and T4 138/69 kV transformers	AEC (100%)
b2354	Install second 230/69 kV transformer and 230 kV circuit breaker at Churchtown substation	AEC (100%)

### Atlantic City Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2354.1	Replace Churchtown 69kV breaker 'D'	AEC (100%)
b2476	Install new Dennis 230/69 kV transformer	AEC (100%)
b2477	Upgrade 138 kV and 69 kV breakers at Corson substation	AEC (100%)
b2478	Reconductor 2.74 miles of Sherman - Lincoln 138 kV line and associated substation upgrades	AEC (100%)
b2479	New Orchard - Cardiff 230 kV line (remove, rebuild and reconfigure existing 138 kV line) and associated substation upgrades	AEC (100%)
b2480.1	New Upper Pittsgrove - Lewis 138 kV line and associated substation upgrades	AEC (100%)
b2480.2	Relocate Monroe to Deepwater Tap 138 kV to Landis 138 kV and associated substation upgrades	AEC (100%)
b2480.3	New Landis - Lewis 138 kV line and associated substation upgrades	AEC (100%)
b2481	New Cardiff - Lewis #2 138 kV line and associated substation upgrades	AEC (100%)
b2489	Install a 100 MVAR capacitor at BL England	AEC (100%)

### Atlantic City Electric Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2538	Replace the Mickleton 230kV 'MK' breaker with 63kA breaker	AEC (100%)
b2553	Replace Middle T3 138/69 kV transformer with 225 MVA nameplate	AEC (100%)
b2723.1	Replace the Mickleton 69 kV 'PCB A' breaker with 63kA breaker	AEC (100%)
b2723.2	Replace the Mickleton 69 kV 'PCB B' breaker with 63kA breaker	AEC (100%)
b2723.3	Replace the Mickleton 69 kV 'PCB C' breaker with 63kA breaker	AEC (100%)
b2723.4	Replace the Mickleton 69 kV 'PCB Q' breaker with 63kA breaker	AEC (100%)
b2839	Replace the Sickler 69 kV 'H' breaker with 63kA breaker	AEC (100%)
b2840	Replace the Sickler 69 kV 'M' breaker with 63kA breaker	AEC (100%)
b2841	Replace the Sickler 69 kV 'A' breaker with 63kA breaker	AEC (100%)
b2945.1	Rebuild the BL England – Middle Tap 138 kV line to 2000A on double circuited steel poles and new foundations	AEC (100%)
b2945.2	Reconductor BL England – Merion 138 kV (1.9 miles) line	AEC (100%)
b2945.3	Reconductor Merion – Corson 138 kV (8 miles) line	AEC (100%)

**Atlantic City Electric Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3135	Install back-up relay on the 138 kV bus at Corson substation	AEC (100%)
b3226	Add 10 MVAR 69 kV capacitor bank at Swanton substation	AEC (100%)
b3227	Rebuild the Corson – Court 69 kV line to achieve ratings equivalent to 795 ACSR conductor or better	AEC (100%)

Attachment 5E – Cost Allocation of 2022/2023 Delmarva Schedule 12 Charges

Attachment 5E PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023  
Calculation of costs and monthly PJM charges for Delmarva Projects

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE	JCP&L	PSE&G	RE	ACE	JCP&L	PSE&G	RE	Total
			Zone	Zone	Zone	Zone	Zone	Zone	Zone	Zone	NJ Zones
			Share <sup>1</sup>	Share <sup>1</sup>	Share <sup>1</sup>	Share <sup>1</sup>	Charges	Charges	Charges	Charges	Charges
			<i>per PJM Open Access Transmission Tariff</i>								
Replace line trap- Keeney	b0272.1	\$ 10,413.50	1.67%	3.92%	6.40%	0.27%	\$174	\$408	\$666	\$28	\$1,277
Replace line trap- Keeney	b0272.1_dfax	\$ 10,413.50	17.53%	0.00%	3.01%	0.12%	\$1,825	\$0	\$313	\$12	\$2,151
Add two breakers- Keeney	b0751	\$ 241,848.50	1.67%	3.92%	6.40%	0.27%	\$4,039	\$9,480	\$15,478	\$653	\$29,651
Add two breakers- Keeney	b0751_dfax	\$ 241,848.50	0.00%	0.00%	0.00%	0.00%	\$0	\$0	\$0	\$0	\$0
Interconnect new Silver Run 230 kV Substation	b2633.1	\$ 646,408.00	8.01%	13.85%	20.79%	0.62%	\$51,777	\$89,528	\$134,388	\$4,008	\$279,701
Totals							\$57,816	\$99,416	\$150,846	\$4,701	\$312,779

Notes on calculations >>>

$$= (a) * (b) \quad = (a) * (c) \quad = (a) * (d) \quad = (a) * (e) \quad = (f) + (g) + (h) + (i)$$

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM website	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 12,570.54	10,064.1	\$ 1.25	\$ 87,994	\$ 62,853	\$ 150,846
JCP&L	\$ 8,284.68	6,169.1	\$ 1.34	\$ 57,993	\$ 41,423	\$ 99,416
ACE	\$ 4,817.96	2,631.0	\$ 1.83	\$ 33,726	\$ 24,090	\$ 57,816
RE	\$ 391.78	427.4	\$ 0.92	\$ 2,742	\$ 1,959	\$ 4,701
<b>Total Impact on NJ Zones</b>	<b>\$ 26,064.96</b>			<b>\$ 182,455</b>	<b>\$ 130,325</b>	<b>\$ 312,779</b>

Notes on calculations >>>

$$= (k) * (l) \quad = (k) * 7 \quad = (k) * 5 \quad = (n) * (o)$$

Notes:

1) 2022 allocation share percentages are from PJM OATT

## SCHEDULE 12 – APPENDIX

### (3) Delmarva Power & Light Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0144.1 Build new Red Lion – Milford – Indian River 230 kV circuit		DPL (100%)
b0144.2 Indian River Sub – 230 kV Terminal Position		DPL (100%)
b0144.3 Red Lion Sub – 230 kV Terminal Position		DPL (100%)
b0144.4 Milford Sub – (2) 230 kV Terminal Positions		DPL (100%)
b0144.5 Indian River – 138 kV Transmission Line to AT-20		DPL (100%)
b0144.6 Indian River – 138 & 69 kV Transmission Ckts. Undergrounding		DPL (100%)
b0144.7 Indian River – (2) 230 kV bus ties		DPL (100%)
b0148 Re-rate Glasgow – Mt. Pleasant 138 kV and North Seaford – South Harrington 138 kV		DPL (100%)
b0149 Complete structure work to increase rating of Cheswold – Jones REA 138 kV		DPL (100%)
b0221 Replace disconnect switch on Edgewood-N. Salisbury 69 kV		DPL (100%)
b0241.1 Keeny Sub – Replace overstressed breakers		DPL (100%)
b0241.2 Edgemoor Sub – Replace overstressed breakers		DPL (100%)
b0241.3 Red Lion Sub – Substation reconfigure to provide for second Red Lion 500/230 kV transformer		DPL (84.5%) / PECO (15.5%)
b0261 Replace 1200 Amp disconnect switch on the Red Lion – Reybold 138 kV circuit		DPL (100%)

## Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0262	Reconductor 0.5 miles of Christiana – Edgemoor 138 kV	DPL (100%)
b0263	Replace 1200 Amp wavetrapp at Indian River on the Indian River – Frankford 138 kV line	DPL (100%)
b0272.1	Replace line trap and disconnect switch at Keeney 500 kV substation – 5025 Line Terminal Upgrade	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (17.53%) / BGE (1.84%) / DPL (43.46%) / PECO (18.79%) / PEPCO (1.52%) / PPL (13.73%) / PSEG (3.01%) / RE (0.12%)</p>
b0282	Install 46 MVAR capacitors on the DPL distribution system	DPL (100%)
b0291	Replace 1600A disconnect switch at Harmony 230 kV and for the Harmony – Edgemoor 230 kV circuit, increase the operating temperature of the conductor	DPL (100%)

\*Neptune Regional Transmission System, LLC



### Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0295	Raise conductor temperature of North Seaford – Pine Street – Dupont Seaford	DPL (100%)
b0296	Rehoboth/Cedar Neck Tap (6733-2) upgrade	DPL (100%)
b0320	Create a new 230 kV station that splits the 2 <sup>nd</sup> Milford to Indian River 230 kV line, add a 230/69 kV transformer, and run a new 69 kV line down to Harbeson 69 kV	DPL (100%)
b0382	Cambridge Sub – Close through to Todd Substation	DPL (100%)
b0383	Wye Mills AT-1 and AT-2 138/69 kV Replacements	DPL (100%)
b0384	Replace Indian River AT-20 (400 MVA)	DPL (100%)
b0385	Oak Hall to New Church (13765) Upgrade	DPL (100%)
b0386	Cheswold/Kent (6768) Rebuild	DPL (100%)
b0387	N. Seaford – Add a 2 <sup>nd</sup> 138/69 kV autotransformer	DPL (100%)
b0388	Hallwood/Parksley (6790-2) Upgrade	DPL (100%)
b0389	Indian River AT-1 and AT-2 138/69 kV Replacements	DPL (100%)
b0390	Rehoboth/Lewes (6751-1 and 6751-2) Upgrade	DPL (100%)
b0391	Kent/New Meredith (6704-2) Upgrade	DPL (100%)
b0392	East New Market Sub – Establish a 69 kV Bus Arrangement	DPL (100%)
b0415	Increase the temperature ratings of the Edgemoor – Christiana – New Castle 138 kV by replacing six transmission poles	DPL (100%)

### Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0437 Spare Keeney 500/230 kV transformer		DPL (100%)
b0441 Additional spare Keeney 500/230 kV transformer		DPL (100%)
b0480 Rebuild Lank – Five Points 69 kV		DPL (100%)
b0481 Replace wave trap at Indian River 138 kV on the Omar – Indian River 138 kV circuit		DPL (100%)
b0482 Rebuild Millsboro – Zoar REA 69 kV		DPL (100%)
b0483 Replace Church 138/69 kV transformer and add two breakers		DPL (100%)
b0483.1 Build Oak Hall – Wattsville 138 kV line		DPL (100%)
b0483.2 Add 138/69 kV transformer at Wattsville		DPL (100%)
b0483.3 Establish 138 kV bus position at Oak Hall		DPL (100%)
b0484 Re-tension Worcester – Berlin 69 kV for 125°C		DPL (100%)
b0485 Re-tension Taylor – North Seaford 69 kV for 125°C		DPL (100%)
b0494.1 Install a 2 <sup>nd</sup> Red Lion 230/138 kV		DPL (100%)
b0494.2 Hares Corner – Relay Improvement		DPL (100%)
b0494.3 Reybold – Relay Improvement		DPL (100%)
b0494.4 New Castle – Relay Improvement		DPL (100%)

## Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512	MAPP Project – install new 500 kV transmission from Possum Point to Calvert Cliffs and install a DC line from Calvert Cliffs to Vienna and a DC line from Calvert Cliffs to Indian River	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)</p>
b0513	Rebuild the Ocean Bay – Maridel 69 kV line	DPL (100%)
b0527	Replace existing 12 MVAR capacitor at Bethany with a 30 MVAR capacitor	DPL (100%)
b0528	Replace existing 69/12 kV transformer at Bethany with a 138/12 kV transformer	DPL (100%)

\*Neptune Regional Transmission System, LLC

### Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0529	Install an additional 8.4 MVAR capacitor at Grasonville 69 kV	DPL (100%)
b0530	Replace existing 12 MVAR capacitor at Wye Mills with a 30 MVAR capacitor	DPL (100%)
b0531	Create a four breaker 138 kV ring bus at Wye Mills and add a second 138/69 kV transformer	DPL (100%)
b0566	Rebuild the Trappe Tap – Todd 69 kV line	DPL (100%)
b0567	Rebuild the Mt. Pleasant – Townsend 138 kV line	DPL (100%)
b0568	Install a third Indian River 230/138 kV transformer	DPL (100%)
b0725	Add a third Steele 230/138 kV transformer	DPL (100%)
b0732	Rebuild Vaugh – Wells 69 kV	DPL (100%)
b0733	Add a second 230/138 kV transformer at Harmony	DPL (97.06%) / PECO (2.94%)
b0734	Rebuild Church – Steele 138 kV	DPL (100%)
b0735	Rebuild Indian River – Omar – Bethany 138 kV	DPL (100%)
b0736	Rebuild Dupont Edgemoor – Edgemoor – Silverside 69 kV	DPL (69.46%) / PECO (17.25%) / ECP** (0.27%) / PSEG (12.53%) / RE (0.49%)
b0737	Build a new Indian River – Bishop 138 kV line	DPL (100%)

\*\*East Coast Power, LLC

## Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0750	Convert 138 kV network path from Vienna – Loretto – Piney - Grove to 230 kV, add 230/138 kV transformer to Loretto 230 kV	DPL (100%)
b0751	Add two additional breakers at Keeney 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%) <b>DFAX Allocation:</b> DPL (100%)
b0752	Replace two circuit breakers to bring the emergency rating up to 348 MVA	DPL (100%)
b0753	Add a second Loretto 230/138 kV transformer	DPL (100%)
b0754	Rebuild 10 miles of Glasgow to Mt. Pleasant 138 kV line to bring the normal rating to 298 MVA and the emergency rating to 333 MVA	DPL (100%)
b0792	Reconfigure Cecil Sub into 230 and 138 kV ring buses, add a 230/138 kV transformer, and operate the 34.5 kV bus normally open	DPL (100%)

\*Neptune Regional Transmission System, LLC

### Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0873	Build 2nd Glasgow-Mt Pleasant 138 kV line	DPL (100%)
b0874	Reconfigure Brandywine substation	DPL (100%)
b0876	Install 50 MVAR SVC at 138th St 138 kV	DPL (100%)
b0877	Build a 2nd Vienna-Steele 230 kV line	DPL (100%)
b0879.1	Apply a special protection scheme (load drop at Stevensville and Grasonville)	DPL (100%)
b1246	Re-build the Townsend – Church 138 kV circuit	DPL (100%)
b1247	Re-build the Glasgow – Cecil 138 kV circuit	DPL (72.06%) / PECO (27.94%)
b1248	Install two 15 MVAR capacitor at Loretto 69 kV	DPL (100%)
b1249	Reconfigure the existing Sussex 69 kV capacitor	DPL (100%)
b1603	Upgrade 19 miles conductor of the Wattsville - Signepost - Stockton - Kenney 69 kV circuit	DPL (100%)
b1604	Replace CT at Reybold 138 kV substation	DPL (100%)
b1723	Replace strand bus and disconnect switch at Glasgow 138 kV substation	DPL (100%)

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-3.

### **Delmarva Power & Light Company (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b1899.1	Install new variable reactors at Indian River and Nelson 138 kV		DPL (100%)
b1899.2	Install new variable reactors at Cedar Creek 230 kV		DPL (100%)
b1899.3	Install new variable reactors at New Castle 138 kV and Easton 69 kV		DPL (100%)

## SCHEDULE 12 – APPENDIX A

### (3) Delmarva Power & Light Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2288	Build a new 138 kV line from Piney Grove – Wattsville	DPL (100%)
b2395	Reconductor the Harmony – Chapel St 138 kV circuit	DPL (100%)
b2569	Replace Terminal equipment at Silverside 69 kV substation	DPL (100%)
b2633.7	Implement high speed relaying utilizing OPGW on Red Lion – Hope Creek 500 kV line	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)
b2633.10	Interconnect the new Silver Run 230 kV substation with existing Red Lion – Cartanza and Red Lion – Cedar Creek 230 kV lines	AEC (8.01%) / BGE (1.94%) / DPL (12.99%) / JCPL (13.85%) / ME (5.88%) / NEPTUNE* (3.45%) / PECO (17.62%) / PPL (14.85%) / PSEG (20.79%) / RE (0.62%)

\*Neptune Regional Transmission System, LLC



## Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2695	Rebuild Worcester – Ocean Pine 69 kV ckt. 1 to 1400A capability summer emergency	DPL (100%)
b2946	Convert existing Preston 69 kV substation to DPL’s current design standard of a 3-breaker ring bus	DPL (100%)
b2947.1	Upgrade terminal equipment at DPL’s Naamans substation (Darley - Naamans 69 kV)	DPL (100%)
b2947.2	Reconductor 0.11 mile section of Darley - Naamans 69 kV circuit	DPL (100%)
b2948	Upgrade terminal equipment at DPL’s Silverside Road substation (Dupont Edge Moor – Silver R. 69 kV)	DPL (100%)
b2987	Install a 30 MVAR capacitor bank at DPL’s Cool Springs 69 kV substation. The capacitor bank would be installed in two separate 15 MVAR stages allowing DPL operational flexibility	DPL (100%)
b3143.1	Reconductor the Silverside Road – Darley 69 kV circuit	DPL (100%)
b3143.2	Reconductor the Darley – Naamans 69 kV circuit	DPL (100%)
b3143.3	Replace three (3) existing 1200 A disconnect switches with 2000 A disconnect switches and install three (3) new 2000 A disconnect switches at Silverside 69 kV station	DPL (100%)

### Delmarva Power & Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3143.4	Replace two (2) 1200 A disconnect switches with 2000 A disconnect switches. Replace existing 954 ACSR and 500 SDCU stranded bus with two (2) 954 ACSR stranded bus. Reconfigure four (4) CTs from 1200 A to 2000 A and install two (2) new 2000 A disconnect switches and two (2) new 954 ACSR stranded bus at Naamans 69 kV station	DPL (100%)
b3143.5	Replace four (4) 1200 A disconnect switches with 2000 A disconnect switches. Replace existing 954 ACSR and 1272 MCM AL stranded bus with two (2) 954 ACSR stranded bus. Reconfigure eight (8) CTs from 1200 A to 2000 A and install four (4) new 2000 A (310 MVA SE / 351 MVA WE) disconnect switches and two (2) new 954 ACSR (331 MVA SE / 369 MVA WE) stranded bus at Darley 69 kV station	DPL (100%)
b3155	Rebuild approx. 12 miles of Wye Mills – Stevensville line	DPL (100%)
b3224	Replace a disconnect switch and reconductor a short span of the Mt. Pleasant – Middletown tap 138 kV line	DPL (100%)

### **Delmarva Power & Light Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3326	Rebuild the Vienna - Nelson 138 kV line	DPL (100%)
b3327	Upgrade the disconnect switch at Kent 69 kV station	DPL (100%)
b3328	Upgrade the disconnect switch and CT at Vienna 138 kV station	DPL (100%)
b3329	Rebuild the Farmview - Milford 138 kV line	DPL (100%)
b3330	Rebuild the Farmview - S. Harrington 138 kV line	DPL (100%)
b3331	Upgrade stranded bus and relay at Seaford 138 kV station	DPL (100%)
b3332	Rebuild the Steel - Milford 230 kV line	DPL (100%)

Attachment 5F – Cost Allocation of 2022/2023 PEPCO Schedule 12 Charges

Attachment 5F PJM Schedule 12 - Transmission Enhancement Charges for June 2022 to May 2023  
Calculation of costs and monthly PJM charges for PEPCO Projects

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
			<i>per PJM Open Access Transmission Tariff</i>								
Reconductor 23035 for Dickerson-Quince	b0367.1-2	\$ 2,329,621.00	1.78%	2.67%	3.81%	0.00%	\$41,467	\$62,201	\$88,759	\$0	\$192,427
Replace 230 1A breaker	b0512.7	\$ 110,593.50	1.67%	3.92%	6.40%	0.27%	\$1,847	\$4,335	\$7,078	\$299	\$13,559
Replace 230 1A breaker	b0512.7_dfax	\$ 110,593.50	3.94%	9.43%	14.71%	0.54%	\$4,357	\$10,429	\$16,268	\$597	\$31,652
Replace 230 1B breaker	b0512.8	\$ 110,593.50	1.67%	3.92%	6.40%	0.27%	\$1,847	\$4,335	\$7,078	\$299	\$13,559
Replace 230 1B breaker	b0512.8_dfax	\$ 110,593.50	3.94%	9.43%	14.71%	0.54%	\$4,357	\$10,429	\$16,268	\$597	\$31,652
Replace 230 2A breaker	b0512.9	\$ 110,593.50	1.67%	3.92%	6.40%	0.27%	\$1,847	\$4,335	\$7,078	\$299	\$13,559
Replace 230 2A breaker	b0512.9_dfax	\$ 110,593.50	3.94%	9.43%	14.71%	0.54%	\$4,357	\$10,429	\$16,268	\$597	\$31,652
Replace 230 3A breaker	b0512.12	\$ 111,749.00	1.67%	3.92%	6.40%	0.27%	\$1,866	\$4,381	\$7,152	\$302	\$13,700
Replace 230 3A breaker	b0512.12_dfax	\$ 111,749.00	3.94%	9.43%	14.71%	0.54%	\$4,403	\$10,538	\$16,438	\$603	\$31,983
Ritchie-Benning 230 lines	b0526	\$ 6,647,900.00	0.77%	1.39%	2.10%	0.08%	\$51,189	\$92,406	\$139,606	\$5,318	\$288,519
Reconductor Dickerson- Pleasant View 230 kV	b0467.1	\$ 990,145.00	1.75%	0.71%	0.00%	0.00%	\$17,328	\$7,030	\$0	\$0	\$24,358
Reconductor Dickerson staion H and Upgrade Equipment	b1596	\$ 1,139,687.00	0.80%	0.00%	0.00%	0.00%	\$9,117	\$0	\$0	\$0	\$9,117
Totals							\$143,983	\$220,848	\$321,994	\$8,911	\$695,735

Notes on calculations >>>

$$= (a) * (b) \quad = (a) * (c) \quad = (a) * (d) \quad = (a) * (e) \quad = (f) + (g) + (h) + (i)$$

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM website	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 26,832.79	10,064.1	\$ 2.67	\$ 187,830	\$ 134,164	\$ 321,994
JCP&L	\$ 18,403.99	6,169.1	\$ 2.98	\$ 128,828	\$ 92,020	\$ 220,848
ACE	\$ 11,998.59	2,631.0	\$ 4.56	\$ 83,990	\$ 59,993	\$ 143,983
RE	\$ 742.58	427.4	\$ 1.74	\$ 5,198	\$ 3,713	\$ 8,911
<b>Total Impact on NJ Zones</b>	<b>\$ 57,977.96</b>			<b>\$ 405,846</b>	<b>\$ 289,890</b>	<b>\$ 695,735</b>

Notes on calculations >>>

$$= (k) * (l) \quad = (k) * 7 \quad = (k) * 5 \quad = (n) * (o)$$

**Notes:**

1) 2022 allocation share percentages are from PJM OATT

## SCHEDULE 12 – APPENDIX

### (10) Potomac Electric Power Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0146	Installation of (2) new 230 kV circuit breakers at Quince Orchard substation on circuits 23028 and 23029	PEPCO (100%)
b0219	Install two new 230 kV circuits between Palmers Corner and Blue Plains	PEPCO (100%)
b0228	Upgrade Burtonsville – Sandy Springs 230 kV circuit	PEPCO (100%)
b0238.1	Modify Dickerson Station H 230 kV	PEPCO (100%)
b0251	Install 100 MVAR of 230 kV capacitors at Bells Mill	PEPCO (100%)
b0252	Install 100 MVAR of 230 kV capacitors at Bells Mill	PEPCO (100%)
b0288	Brighton Substation – add 2 <sup>nd</sup> 1000 MVA 500/230 kV transformer, 2 500 kV circuit breakers and miscellaneous bus work	BGE (19.33%) / Dominion (17%) / PEPCO (63.67%)
b0319	Add a second 1000 MVA Bruches Hill 500/230 kV transformer	PEPCO (100%)
b0366	Install a 4 <sup>th</sup> Ritchie 230/69 kV transformer	PEPCO (100%)
b0367.1	Reconductor circuit “23035” for Dickerson – Quince Orchard 230 kV	AEC (1.78%) / BGE (26.52%) / DPL (3.25%) / JCPL (2.67%) / ME (1.16%) / NEPTUNE* (0.25%) / PECO (4.79%) / PEPCO (52.46%) / PPL (3.23%) / PSEG (3.81%) / ECP** (0.08%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-9.

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0367.2	Reconductor circuit “23033” for Dickerson – Quince Orchard 230 kV	AEC (1.78%) / BGE (26.52%) / DPL (3.25%) / JCPL (2.67%) / ME (1.16%) / NEPTUNE* (0.25%) / PECO (4.79%) / PEPCO (52.46%) / PPL (3.23%) / PSEG (3.81%) / ECP** (0.08%)
b0375	Install 0.5% reactor at Dickerson on the Pleasant View – Dickerson 230 kV circuit	AEC (1.02%) / BGE (25.42%) / DPL (2.97%) / ME (1.72%) / PECO (3.47%) / PEPCO (65.40%)
b0467.1	Reconductor the Dickerson – Pleasant View 230 kV circuit	AEC (1.75%) / APS (19.70%) / BGE (22.13%) / DPL (3.70%) / JCPL (0.71%) / ME (2.48%) / NEPTUNE* (0.06%) / PECO (5.54%) / PEPCO (41.86%) / PPL (2.07%)
b0478	Reconductor the four circuits from Burches Hill to Palmers Corner	APS (1.68%) / BGE (1.83%) / PEPCO (96.49%)
b0496	Replace existing 500/230 kV transformer at Brighton	APS (5.67%) / BGE (29.68%) / Dominion (10.91%) / PEPCO (53.74%)
b0499	Install third Burches Hill 500/230 kV transformer	APS (3.54%) / BGE (7.31%) / PEPCO (89.15%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

The Annual Revenue Requirement associated with the Transmission Enhancement Charges are set forth and determined in Appendix A to Attachment H-9.

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512	MAPP Project – install new 500 kV transmission from Possum Point to Calvert Cliffs and install a DC line from Calvert Cliffs to Vienna and a DC line from Calvert Cliffs to Indian River	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)</p>
b0512.7	Advance n0772 (Replace Chalk Point 230 kV breaker (1A) with 80 kA breaker)	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)</p>



\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.8	Advance n0773 (Replace Chalk Point 230 kV breaker (1B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.9	Advance n0774 (Replace Chalk Point 230 kV breaker (2A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.10	Advance n0775 (Replace Chalk Point 230 kV breaker (2B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.11	Advance n0776 (Replace Chalk Point 230 kV breaker (2C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.12	Advance n0777 (Replace Chalk Point 230 kV breaker (3A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.13	Advance n0778 (Replace Chalk Point 230 kV breaker (3B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.14	Advance n0779 (Replace Chalk Point 230 kV breaker (3C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.15	Advance n0780 (Replace Chalk Point 230 kV breaker (4A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 10 Potomac Electric Power Compan

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.16	Advance n0781 (Replace Chalk Point 230 kV breaker (4B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.17	Advance n0782 (Replace Chalk Point 230 kV breaker (5A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.18	Advance n0783 (Replace Chalk Point 230 kV breaker (5B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.19	Advance n0784 (Replace Chalk Point 230 kV breaker (6A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

## Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.20	Advance n0785 (Replace Chalk Point 230 kV breaker (6B) with 80 kA breaker	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.21	Advance n0786 (Replace Chalk Point 230 kV breaker (7B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 10 Potomac Electric Power Compan

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.22	Advance n0787 (Replace Chalk Point 230 kV breaker (8A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.23	Advance n0788 (Replace Chalk Point 230 kV breaker (8B) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 10 Potomac Electric Power Compan

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.24	Advance n0789 (Replace Chalk Point 230 kV breaker (7A) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.25	Advance n0790 (Replace Chalk Point 230 kV breaker (1C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 – APPENDIX --> OATT SCHEDULE 12.APPENDIX 10 Potomac Electric Power Compan

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.26	Advance n0791 (Replace Chalk Point 230 kV breaker (4C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.27	Advance n0792 (Replace Chalk Point 230 kV breaker (5C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

## Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0512.28	Advance n0793 (Replace Chalk Point 230 kV breaker (6C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)
b0512.29	Advance n0794 (Replace Chalk Point 230 kV breaker (7C) with 80 kA breaker)	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (3.94%) / APS (0.33%) / BGE (34.54%) / DPL (14.69%) / Dominion (0.30%) / JCPL (9.43%) / ME (2.16%) / NEPTUNE* (0.90%) / PECO (10.52%) / PEPCO (2.44%) / PPL (5.50%) / PSEG (14.71%) / RE (0.54%)

\* Neptune Regional Transmission System, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0526	Build two Ritchie – Benning Station A 230 kV lines		AEC (0.77%) / BGE (16.76%) / DPL (1.22%) / JCPL (1.39%) / ME (0.59%) / NEPTUNE* (0.13%) / PECO (2.10%) / PEPCO (74.86%) / PSEG (2.10%) / RE (0.08%)
b0561	Install 300 MVAR capacitor at Dickerson Station “D” 230 kV substation		AEC (8.58%) / APS (1.69%) / DPL (12.24%) / JCPL (18.16%) / ME (1.55%) / NEPTUNE* (1.77%) / PECO (21.78%) / PPL (6.40%) / ECP** (0.73%) / PSEG (26.13%) / RE (0.97%)
b0562	Install 500 MVAR capacitor at Brighton 230 kV substation		AEC (8.58%) / APS (1.69%) / DPL (12.24%) / JCPL (18.16%) / ME (1.55%) / NEPTUNE* (1.77%) / PECO (21.78%) / PPL (6.40%) / ECP** (0.73%) / PSEG (26.13%) / RE (0.97%)
b0637	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0638	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0639	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0640	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0641	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0642	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0643	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0644	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0645	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0646	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0647	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0648	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)
b0649	Replace 13 Oak Grove 230 kV breakers		PEPCO (100%)

\*Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.





### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0701	Expand Benning 230 kV station, add a new 250 MVA 230/69 kV transformer at Benning Station 'A', new 115 kV Benning switching station	BGE (30.57%) / PEPCO (69.43%)
b0702	Add a second 50 MVAR 230 kV shunt reactor at the Benning 230 kV substation	PEPCO (100%)
b0720	Upgrade terminal equipment on both lines	PEPCO (100%)
b0721	Upgrade Oak Grove – Ritchie 23061 230 kV line	PEPCO (100%)
b0722	Upgrade Oak Grove – Ritchie 23058 230 kV line	PEPCO (100%)
b0723	Upgrade Oak Grove – Ritchie 23059 230 kV line	PEPCO (100%)
b0724	Upgrade Oak Grove – Ritchie 23060 230 kV line	PEPCO (100%)
b0730	Add slow oil circulation to the four Bells Mill Road – Bethesda 138 kV lines, add slow oil circulation to the two Buzzard Point – Southwest 138 kV lines; increasing the thermal ratings of these six lines allows for greater adjustment of the O Street phase shifters	PEPCO (100%)

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0731	Implement an SPS to automatically shed load on the 34 kV Bells Mill Road bus for this N-2 condition. The SPS will be in effect for 2013 and 2014 until a third Bells Mill 230/34 kV is placed in-service in 2015	PEPCO (100%)
b0746	Upgrade circuit for 3,000 amps using the ACCR	AEC (0.73%) / BGE (31.05%) / DPL (1.45%) / PECO (2.46%) / PEPCO (62.88%) / PPL (1.43%)
b0747	Upgrade terminal equipment on both lines: Quince Orchard - Bells Mill 230 kV (030) and (028)	PEPCO (100%)
b0802	Advance n0259 (Replace Dickerson Station H Circuit Breaker 412A)	PEPCO (100%)
b0803	Advance n0260 (Replace Dickerson Station H Circuit Breaker 42A)	PEPCO (100%)
b0804	Advance n0261 (Replace Dickerson Station H Circuit Breaker 42C)	PEPCO (100%)
b0805	Advance n0262 (Replace Dickerson Station H Circuit Breaker 43A)	PEPCO (100%)
b0806	Advance n0264 (Replace Dickerson Station H Circuit Breaker 44A)	PEPCO (100%)

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0809 Advance n0267 (Replace Dickerson Station H Circuit Breaker 45B)		PEPCO (100%)
b0810 Advance n0270 (Replace Dickerson Station H Circuit Breaker 47A)		PEPCO (100%)
b0811 Advance n0726 (Replace Dickerson Station H Circuit Breaker SPARE )		PEPCO (100%)
b0845 Replace Chalk Point 230 kV breaker (1A) with 80 kA breaker		PEPCO (100%)
b0846 Replace Chalk Point 230 kV breaker (1B) with 80 kA breaker		PEPCO (100%)
b0847 Replace Chalk Point 230 kV breaker (2A) with 80 kA breaker		PEPCO (100%)
b0848 Replace Chalk Point 230 kV breaker (2B) with 80 kA breaker		PEPCO (100%)
b0849 Replace Chalk Point 230 kV breaker (2C) with 80 kA breaker		PEPCO (100%)
b0850 Replace Chalk Point 230 kV breaker (3A) with 80 kA breaker		PEPCO (100%)
b0851 Replace Chalk Point 230 kV breaker (3B) with 80 kA breaker		PEPCO (100%)
b0852 Replace Chalk Point 230 kV breaker (3C) with 80 kA breaker		PEPCO (100%)
b0853 Replace Chalk Point 230 kV breaker (4A) with 80 kA breaker		PEPCO (100%)
b0854 Replace Chalk Point 230 kV breaker (4B) with 80 kA breaker		PEPCO (100%)
b0855 Replace Chalk Point 230 kV breaker (5A) with 80 kA breaker		PEPCO (100%)

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0856	Replace Chalk Point 230 kV breaker (5B) with 80 kA breaker		PEPCO (100%)
b0857	Replace Chalk Point 230 kV breaker (6A) with 80 kA breaker		PEPCO (100%)
b0858	Replace Chalk Point 230 kV breaker (6B) with 80 kA breaker		PEPCO (100%)
b0859	Replace Chalk Point 230 kV breaker (7B) with 80 kA breaker		PEPCO (100%)
b0860	Replace Chalk Point 230 kV breaker (8A) with 80 kA breaker		PEPCO (100%)
b0861	Replace Chalk Point 230 kV breaker (8B) with 80 kA breaker		PEPCO (100%)
b0862	Replace Chalk Point 230 kV breaker (7A) with 80 kA breaker		PEPCO (100%)
b0863	Replace Chalk Point 230 kV breaker (1C) with 80 kA breaker		PEPCO (100%)
b1104	Replace Burtonsville 230 kV breaker '1C'		PEPCO (100%)
b1105	Replace Burtonsville 230 kV breaker '2C'		PEPCO (100%)
b1106	Replace Burtonsville 230 kV breaker '3C'		PEPCO (100%)
b1107	Replace Burtonsville 230 kV breaker '4C'		PEPCO (100%)
b1125	Convert the 138 kV line from Buzzard 138 - Ritchie 851 to a 230 kV line and Remove 230/138 kV Transformer at Ritchie and install a spare 230/138 kV transformer at Buzzard Pt		APS (4.74%) / PEPCO (95.26%)
b1126	Upgrade the 230 kV line from Buzzard 016 – Ritchie 059		APS (4.74%) / PEPCO (95.26%)

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1592 Reconductor the Oak Grove – Bowie 230 kV circuit and upgrade terminal equipments at Oak Grove and Bowie 230 kV substations		AEC (2.39%) / APS (3.82%) / BGE (65.72%) / DPL (4.43%) / JCPL (3.93%) / ME (2.16%) / NEPTUNE* (0.39%) / HTP*** (0.10%) / PECO (8.35%) / PPL (2.83%) / ECP** (0.13%) / PSEG (5.53%) / RE (0.22%)
b1593 Reconductor the Bowie - Burtonsville 230 kV circuit and upgrade terminal equipments at Bowie and Burtonsville 230 kV substations		AEC (2.39%) / APS (3.82%) / BGE (65.72%) / DPL (4.43%) / JCPL (3.93%) / ME (2.16%) / NEPTUNE* (0.39%) / HTP*** (0.10%) / PECO (8.35%) / PPL (2.83%) / ECP** (0.13%) / PSEG (5.53%) / RE (0.22%)
b1594 Reconductor the Oak Grove – Bowie 230 kV ‘23042’ circuit and upgrade terminal equipments at Oak Grove and Bowie 230 kV substations		AEC (2.38%) / APS (3.84%) / BGE (65.72%) / DPL (4.44%) / JCPL (3.93%) / ME (2.16%) / NEPTUNE* (0.39%) / HTP*** (0.10%) / PECO (8.33%) / PPL (2.83%) / ECP** (0.13%) / PSEG (5.53%) / RE (0.22%)
b1595 Reconductor the Bowie – Burtonsville 230 kV ‘23042’ circuit and upgrade terminal equipments at Oak Grove and Burtonsville 230 kV substations		AEC (2.38%) / APS (3.84%) / BGE (65.72%) / DPL (4.44%) / JCPL (3.93%) / ME (2.16%) / NEPTUNE* (0.39%) / HTP*** (0.10%) / PECO (8.33%) / PPL (2.83%) / ECP** (0.13%) / PSEG (5.53%) / RE (0.22%)
b1596 Reconductor the Dickerson station “H” – Quince Orchard 230 kV ‘23032’ circuit and upgrade terminal equipments at Dickerson station “H” and Quince Orchard 230 kV substations		AEC (0.80%) / BGE (33.68%) / DPL (2.09%) / PECO (3.07%) / PEPCO (60.36%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

### Potomac Electric Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1597 Reconnector the Oak Grove - Aquasco 230 kV '23062' circuit and upgrade terminal equipments at Oak Grove and Aquasco 230 kV substations		AEC (1.44%) / BGE (48.60%) / DPL (2.52%) / PECO (5.00%) / PEPCO (42.44%)
b2008 Reconnector feeder 23032 and 23034 to high temp. conductor (10 miles)		BGE (33.05%) / DPL (1.38%) / PECO (1.35%) / PEPCO (64.22%) /
b2136 Reconnector the Morgantown - V3-017 230 kV '23086' circuit and replace terminal equipments at Morgantown		PEPCO (100%)
b2137 Reconnector the Morgantown - Talbert 230 kV '23085' circuit and replace terminal equipment at Morgantown		PEPCO (100%)
b2138 Replace terminal equipments at Hawkins 230 kV substation		PEPCO (100%)

Attachment 5G – Cost Allocation of 2022/2023 PECO Schedule 12 Charges



**Attachment 5G - Transmission Enhancement Charges for June 2021 - May 2022**  
**Calculation of costs and monthly PJM charges for PECO Energy Company Transmission Projects**

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)		
	Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix ACE Zone Share <sup>1</sup> JCP&L Zone Share <sup>1</sup> PSE&G Zone Share <sup>1</sup> RE Zone Share <sup>1</sup> <i>per PJM Open Access Transmission Tariff</i>				Estimated New Jersey EDC Zone Charges by Project ACE Zone Charges    JCP&L Zone Charges    PSE&G Zone Charges    RE Zone Charges    Total NJ Zones Charges				
Install a new 500 kV Center Point substation in PECO by tapping the Elroy – Whitpain 500 kV circuit.	b0269	\$	2,637,829.50	1.67%	3.92%	6.40%	0.27%	\$44,052	\$103,403	\$168,821	\$7,122	\$323,398
Install a new 500 kV Center Point substation in PECO by tapping the Elroy – Whitpain 500 kV circuit.	b0269_dfax	\$	2,637,829.50	6.70%	0.00%	0.00%	0.00%	\$176,735	\$0	\$0	\$0	\$176,735
Add a new 230 kV circuit between Whitpain and Heaton substations	b0269.10	\$	1,882,353.00	8.25%	0.00%	0.00%	0.00%	\$155,294	\$0	\$0	\$0	\$155,294
Add a new 500kV brkr. at Whitpain bet. #3 transfmr. and 5029 line	b0269.6	\$	224,626.00	1.67%	3.92%	6.40%	0.27%	\$3,751	\$8,805	\$14,376	\$606	\$27,539
Add a new 500kV brkr. at Whitpain bet. #3 transfmr. and 5029 line	b0269.6_dfax	\$	224,626.00	6.70%	0.00%	0.00%	0.00%	\$15,050	\$0	\$0	\$0	\$15,050
Replace 2-500 kV circit brkrs and 2 wave traps at Elroy subs to increase rating of Elroy - Hosensack 500kV	b0171.1	\$	303,041.00	1.67%	3.92%	6.40%	0.27%	\$5,061	\$11,879	\$19,395	\$818	\$37,153
Replace 2-500 kV circit brkrs and 2 wave traps at Elroy subs to increase rating of Elroy - Hosensack 500kV	b0171.1_dfax	\$	303,041.00	9.80%	19.56%	0.00%	0.00%	\$29,698	\$59,275	\$0	\$0	\$88,973
Increase the rating of lines 220-39 and 220-43 (Linwood-Chicester 230kV lines) and install reactors.	b1900	\$	4,454,800.00	0.00%	6.02%	20.83%	0.83%	\$0	\$268,179	\$927,935	\$36,975	\$1,233,089
Rebuild Bryn Mawr-Plymouth Meeting 138 kV line (130-35 Line)	b0727	\$	2,693,506.00	1.25%	0.00%	0.00%	0.00%	\$33,669	\$0	\$0	\$0	\$33,669
Recndr Chichester - Saville 138 kV line and upgrade term equip	b1182	\$	2,573,658.00	0.00%	5.08%	14.20%	0.56%	\$0	\$130,742	\$365,459	\$14,412	\$510,614
Add a second 230/138 kV trans at Chichester. Add an inductor in series with the parallel tranfmrs	b1178	\$	1,179,805.00	0.00%	4.14%	12.10%	0.48%	\$0	\$48,844	\$142,756	\$5,663	\$197,263
Increase Bradford - Planebrook 230 kV Ckt.220-31 line rating. Replace terminal equipment	b0790	\$	250,240.00	0.00%	17.30%	33.68%	1.31%	\$0	\$43,292	\$84,281	\$3,278	\$130,850
Reconductor the North Wales - Hartman 230 kV circuit	b0506	\$	312,135.00	8.58%	0.00%	0.00%	0.00%	\$26,781	\$0	\$0	\$0	\$26,781
Reconductor the North Wales - Whitpain 230 kV circuit	b0505	\$	349,633.00	8.58%	0.00%	0.00%	0.00%	\$29,999	\$0	\$0	\$0	\$29,999
Increase Bradford - Planebrook 230 kV Ckt.220-02 line rating. Replace terminal equipment	b0789	\$	342,651.00	0.72%	17.36%	33.52%	1.31%	\$2,467	\$59,484	\$114,857	\$4,489	\$181,297
Install 161MVAR capacitor at Planebrook 230kV substation	b0206	\$	470,622.00	14.20%	0.00%	3.47%	0.00%	\$66,828	\$0	\$16,331	\$0	\$83,159
Install 161MVAR capacitor at Newlinville 230kV substation	b0207	\$	633,392.00	14.20%	0.00%	3.47%	0.00%	\$89,942	\$0	\$21,979	\$0	\$111,920

**Attachment 5G - Transmission Enhancement Charges for June 2021 - May 2022**  
**Calculation of costs and monthly PJM charges for PECO Energy Company Transmission Projects**

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
<i>per PJM Open Access Transmission Tariff</i>											
Install 2% series reactor at Chichester substation on the Chichester - Mickleton 230kV circuit	b0209	\$ 358,618.00	65.23%	25.87%	6.35%	0.00%	\$233,927	\$92,774	\$22,772	\$0	\$349,473
Upgrade Chichester - Delco Tap 230kV and the PECO portion of the Delco Tap - Mickleton 230kV cicuit	b0264	\$ 298,003.00	89.87%	9.48%	0.00%	0.00%	\$267,815	\$28,251	\$0	\$0	\$296,066
Reconductor Buckingham - Pleasant Valley 230kV; same impedance as existing line; ratings of 760MVA normal/882MVA emergency	b0357	\$ 292,915.00	0.00%	37.17%	54.14%	2.32%	\$0	\$108,877	\$158,584	\$6,796	\$274,256
Reconductor Richmond-Waneeta kv and replace terminal equipment at Waneeta Substation	b1398.8	\$ 228,217.00	0.00%	12.82%	31.46%	1.25%	\$0	\$29,257	\$71,797	\$2,853	\$103,907
Install 600 MVAR cap banks at Elroy 500kv Substation	b0287	\$ 373,790.00	1.67%	3.92%	6.40%	0.27%	\$6,242	\$14,653	\$23,923	\$1,009	\$45,827
Install 600 MVAR cap banks at Elroy 500kv Substation	b2087_dfax	\$ 373,790.00	9.80%	19.56%	0.00%	0.00%	\$36,631	\$73,113	\$0	\$0	\$109,745
Install 161 MVAR capcitor at Heaton 230kV Substation	b0208	\$ 561,301.00	14.20%	0.00%	3.47%	0.00%	\$79,705	\$0	\$19,477	\$0	\$99,182
Increase Ratings at Peach Bottom 500/230kV Tfmr to 1839 MVA Emgcy	b2694	\$ 1,586,968.00	3.97%	6.84%	14.13%	0.44%	\$63,003	\$108,549	\$224,239	\$6,983	\$402,772
Upgrade sub equipment at Peach Bottom	b2766.2	\$ 53,250.50	1.67%	3.92%	6.40%	0.27%	\$889	\$2,087	\$3,408	\$144	\$6,529
Upgrade sub equipment at Peach Bottom	b2766.2_dfax	\$ 53,250.50	0.72%	0.00%	12.92%	0.50%	\$383	\$0	\$6,880	\$266	\$7,530
							\$1,367,922	\$1,191,464	\$2,407,269	\$91,414	\$5,058,069

Notes on calculations >>>

$$= (a) * (b) \quad = (a) * (c) \quad = (a) * (d) \quad = (a) * (e) \quad = (f) + (g) + (h) + (i)$$

	(k)	(l)	(m)	(n)	(o)	(n)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM website	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 200,605.75	10,064.1	\$ 19.93	\$ 1,404,240	\$ 1,003,029	\$ 2,407,269
JCP&L	\$ 99,288.64	6,169.1	\$ 16.09	\$ 695,021	\$ 496,443	\$ 1,191,464
ACE	\$ 113,993.47	2,631.0	\$ 43.33	\$ 797,954	\$ 569,967	\$ 1,367,922
RE	\$ 7,617.86	427.4	\$ 17.82	\$ 53,325	\$ 38,089	\$ 91,414
<b>Total Impact on NJ Zones</b>	<b>\$ 421,505.72</b>			<b>\$ 2,950,540</b>	<b>\$ 2,107,529</b>	<b>\$ 5,058,069</b>

Notes on calculations >>>

$$= (k) * (l) \quad = (k) * 7 \quad = (k) * 5 \quad = (k) * 12$$

Attachment 5G - Transmission Enhancement Charges for June 2021 - May 2022  
Calculation of costs and monthly PJM charges for PECO Energy Company Transmission Projects

	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022-May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE	JCP&L	PSE&G	RE	ACE	JCP&L	PSE&G	RE	Total
			Zone	Zone	Zone	Zone	Zone	Zone	Zone	Zone	NJ Zones
			Share <sup>1</sup>	Share <sup>1</sup>	Share <sup>1</sup>	Share <sup>1</sup>	Charges	Charges	Charges	Charges	Charges
			<i>per PJM Open Access Transmission Tariff</i>								

Notes:  
1) 2022 allocation share percentages are from PJM OATT

## SCHEDULE 12 – APPENDIX

### (8) PECO Energy Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0171.1	Replace two 500 kV circuit breakers and two wave traps at Elroy substation to increase rating of Elroy - Hosensack 500 kV	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPSCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
		<b>DFAX Allocation:</b> AEC (9.80%) / DPL (8.43%) / JCPL (19.56%) / PECO (62.21%)
b0180	Replace Whitpain 230 kV circuit breaker #165	PECO (100%)
b0181	Replace Whitpain 230 kV circuit breaker #J105	PECO (100%)
b0182	Upgrade Plymouth Meeting 230 kV circuit breaker #125	PECO (100%)
b0205	Install three 28.8 Mvar capacitors at Planebrook 35 kV substation	PECO (100%)
b0206	Install 161 Mvar capacitor at Planebrook 230 kV substation	AEC (14.20%) / DPL (24.39%) / PECO (57.94%) / PSEG (3.47%)

\* Neptune Regional Transmission System, LLC

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0207	Install 161 Mvar capacitor at Newlinville 230 kV substation	AEC (14.20%) / DPL (24.39%) / PECO (57.94%) / PSEG (3.47%)
b0208	Install 161 Mvar capacitor Heaton 230 kV substation	AEC (14.20%) / DPL (24.39%) / PECO (57.94%) / PSEG (3.47%)
b0209	Install 2% series reactor at Chichester substation on the Chichester - Mickleton 230 kV circuit	AEC (65.23%) / JCPL (25.87%) / NEPTUNE* (2.55%) / PSEG (6.35%)
b0264	Upgrade Chichester – Delco Tap 230 kV and the PECO portion of the Delco Tap – Mickleton 230 kV circuit	AEC (89.87%) / JCPL (9.48%) / NEPTUNE* (0.65%)
b0266	Replace two wave traps and ammeter at Peach Bottom, and two wave traps and ammeter at Newlinville 230 kV substations	PECO (100%)
b0269	Install a new 500 kV Center Point substation in PECO by tapping the Elroy – Whitpain 500 kV circuit	<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)†
		<b>DFAX Allocation:</b> AEC (6.70%) / PECO (93.30%)

\* Neptune Regional Transmission System, LLC

†Cost allocations associated with Regional Facilities and Necessary Lower Voltage Facilities associated with the project

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0269.1	Add a new 230 kV circuit between Whitpain and Heaton substations	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††
b0269.2	Reconductor the Whitpain 1 – Plymtg 1 230 kV circuit	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††
b0269.3	Convert the Heaton bus to a ring bus	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††
b0269.4	Reconductor the Heaton – Warminster 230 kV circuit	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††
b0269.5	Reconductor Warminster – Buckingham 230 kV circuit	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††

††Cost allocations associated with below 500 kV elements of the project

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0269.6	Add a new 500 kV breaker at Whitpain between #3 transformer and 5029 line	<p><b>Load-Ratio Share Allocation:</b>  AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)</p> <p><b>DFAX Allocation:</b>  AEC (6.70%) / PECO (93.30%)</p>
b0269.7	Replace North Wales 230 kV breaker #105	PECO (100%)
b0269.10	Install a new 230 kV Center Point substation in PECO by tapping the North Wales – Perkiomen 230 kV circuit. Install a new 500/230 kV Center Point transformer	AEC (8.25%) / DPL (9.56%) / PECO (82.19%)††
b0280.1	Install 161 MVAR capacitor at Warrington 230 kV substation	PECO 100%
b0280.2	Install 161 MVAR capacitor at Bradford 230 kV substation	PECO 100%
b0280.3	Install 28.8 MVAR capacitor at Warrington 34 kV substation	PECO 100%

\* Neptune Regional Transmission System, LLC

††Cost allocations associated with below 500 kV elements of the project

### PECO Energy Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b0280.4	Install 18 MVAR capacitor at Waverly 13.8 kV substation		PECO 100%
b0287	Install 600 MVAR Dynamic Reactive Device in Whitpain 500 kV vicinity		<b>Load-Ratio Share Allocation:</b> AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)
			<b>DFAX Allocation:</b> AEC (9.80%) / DPL (8.43%) / JCPL (19.56%) / PECO (62.21%)
b0351	Reconductor Tunnel – Grays Ferry 230 kV		PECO (100%)
b0352	Reconductor Tunnel – Parrish 230 kV		PECO (100%)
b0353.1	Install 2% reactors on both lines from Eddystone – Llanerch 138 kV		PECO (100%)
b0353.2	Install identical second 230/138 kV transformer in parallel with existing 230/138 kV transformer at Plymouth Meeting		PECO 100%
b0353.3	Replace Whitpain 230 kV breaker 135		PECO (100%)
b0353.4	Replace Whitpain 230 kV breaker 145		PECO (100%)

\* Neptune Regional Transmission System, LLC



### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0354	Eddystone – Island Road Upgrade line terminal equipment	PECO 100%
b0355	Reconductor Master – North Philadelphia 230 kV line	PECO 100%
b0357	Reconductor Buckingham – Pleasant Valley 230 kV	JCPL (37.17%) / NEPTUNE* (4.46%) / PSEG (54.14%) / RE (2.32%) / ECP** (1.91%)
b0359	Reconductor North Philadelphia – Waneeta 230 kV circuit	PECO 100%
b0402.1	Replace Whitpain 230 kV breaker #245	PECO (100%)
b0402.2	Replace Whitpain 230 kV breaker #255	PECO (100%)
b0438	Spare Whitpain 500/230 kV transformer	PECO (100%)
b0443	Spare Peach Bottom 500/230 kV transformer	PECO (100%)
b0505	Reconductor the North Wales – Whitpain 230 kV circuit	AEC (8.58%) / DPL (7.76%) / PECO (83.66%)
b0506	Reconductor the North Wales – Hartman 230 kV circuit	AEC (8.58%) / DPL (7.76%) / PECO (83.66%)
b0507	Reconductor the Jarrett – Whitpain 230 kV circuit	AEC (8.58%) / DPL (7.76%) PECO (83.66%)
b0508.1	Replace station cable at Hartman on the Warrington - Hartman 230 kV circuit	PECO (100%)
b0509	Reconductor the Jarrett – Heaton 230 kV circuit	PECO (100%)

\*Neptune Regional Transmission Partners, LLC

\*\*East Coast Power, L.L.C.

## PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0727	Rebuild Bryn Mawr – Plymouth Meeting 138 kV line	AEC (1.25%) / DPL (3.11%) / PECO (95.64%)
b0789	Reconductor the line to provide a normal rating of 677 MVA and an emergency rating of 827 MVA	AEC (0.72%) / JCPL (17.36%) / NEPTUNE* (1.70%) / PECO (44.47%) / ECP** (0.92%) / PSEG (33.52%) / RE (1.31%)
b0790	Reconductor the Bradford – Planebrook 230 kV Ckt. 220-31 to provide a normal rating of 677 MVA and emergency rating of 827 MVA	JCPL (17.30%) / NEPTUNE* (1.69%) / PECO (45.09%) / ECP** (0.93%) / PSEG (33.68%) / RE (1.31%)
b0829.1	Replace Whitpain 230 kV breaker '155'	PECO (100%)
b1073	Install 2 new 230 kV breakers at Planebrook (on the 220-02 line terminal and on the 230 kV side of the #9 transformer)	PECO (100%)
b0829.2	Replace Whitpain 230 kV breaker '525'	PECO (100%)
b0829.3	Replace Whitpain 230 kV breaker '175'	PECO (100%)
b0829.4	Replace Plymouth Meeting 230 kV breaker '225'	PECO (100%)
b0829.5	Replace Plymouth Meeting 230 kV breaker '335'	PECO (100%)
b0841	Move the connection points for the 2nd Plymouth Meeting 230/138 kV XFMR	PECO (100%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b0842	Install a 2nd 230/138 kV XFMR and 35 MVAR CAP at Heaton 138 kV bus	PECO (100%)
b0842.1	Replace Heaton 138 kV breaker '150'	PECO (100%)
b0843	Install a 75 MVAR CAP at Llanerch 138 kV bus	PECO (100%)
b0844	Move the connection point for the Llanerch 138/69 kV XFMR	PECO (100%)
b0887	Replace Richmond-Tacony 69 kV line	PECO (100%)
b0920	Replace station cable at Whitpain and Jarrett substations on the Jarrett - Whitpain 230 kV circuit	PECO (100%)
b1014.1	Replace Circuit breaker, Station Cable, CTs and Wave Trap at Eddystone 230 kV	PECO (100%)
b1014.2	Replace Circuit breaker, Station Cable, CTs Disconnect Switch and Wave Trap at Island Rd. 230 kV	PECO (100%)
b1015	Replace Breakers #115 and #125 at Printz 230 kV substation	PECO (100%)
b1156.1	Upgrade at Richmond 230 kV breaker '525'	PECO (100%)
b1156.2	Upgrade at Richmond 230 kV breaker '415'	PECO (100%)
b1156.3	Upgrade at Richmond 230 kV breaker '475'	PECO (100%)
b1156.4	Upgrade at Richmond 230 kV breaker '575'	PECO (100%)

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1156.5	Upgrade at Richmond 230 kV breaker ‘185’	PECO (100%)
b1156.6	Upgrade at Richmond 230 kV breaker ‘285’	PECO (100%)
b1156.7	Upgrade at Richmond 230 kV breaker ‘85’	PECO (100%)
b1156.8	Upgrade at Waneeta 230 kV breaker ‘425’	PECO (100%)
b1156.9	Upgrade at Emilie 230 kV breaker ‘815’	PECO (100%)
b1156.10	Upgrade at Plymouth Meeting 230 kV breaker ‘265’	PECO (100%)
b1156.11	Upgrade at Croydon 230 kV breaker ‘115’	PECO (100%)
b1156.12	Replace Emilie 138 kV breaker ‘190’	PECO (100%)
b1178	Add a second 230/138 kV transformer at Chichester. Add an inductor in series with the parallel transformers	JCPL (4.14%) / Neptune* (0.44%) / PECO (82.19%) / ECP** (0.33%) / HTP*** (0.32%) / PSEG (12.10%) / RE (0.48%)
b1179	Replace terminal equipment at Eddystone and Saville and replace underground section of the line	PECO (100%)
b1180.1	Replace terminal equipment at Chichester	PECO (100%)
b1180.2	Replace terminal equipment at Chichester	PECO (100%)
b1181	Install 230/138 kV transformer at Eddystone	PECO (100%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1182	Reconductor Chichester – Saville 138 kV line and upgrade terminal equipment	JCPL (5.08%) / Neptune* (0.54%) / PECO (78.85%) / ECP** (0.39%) / HTP*** (0.38%) / PSEG (14.20%) / RE (0.56%)
b1183	Replace 230/69 kV transformer #6 at Cromby. Add two 50 MVAR 230 kV banks at Cromby	PECO (100%)
b1184	Add 138 kV breakers at Cromby, Perkiomen, and North Wales; add a 35 MVAR capacitor at Perkiomen 138 kV	PECO (100%)
b1185	Upgrade Eddystone 230 kV breaker #365	PECO (100%)
b1186	Upgrade Eddystone 230 kV breaker #785	PECO (100%)
b1197	Reconductor the PECO portion of the Burlington – Croydon circuit	PECO (100%)
b1198	Replace terminal equipments including station cable, disconnects and relay at Conowingo 230 kV station	PECO (100%)
b1338	Replace Printz 230 kV breaker ‘225’	PECO (100%)
b1339	Replace Printz 230 kV breaker ‘315’	PECO (100%)
b1340	Replace Printz 230 kV breaker ‘215’	PECO (100%)
b1398.6	Reconductor the Camden – Richmond 230 kV circuit (PECO portion) and upgrade terminal equipments at Camden substations	JCPL (12.82%) / NEPTUNE* (1.18%) / HTP*** (0.79%) / PECO (51.08%) / PEPCO (0.57%) / ECP** (0.85%) / PSEG (31.46%) / RE (1.25%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1398.8	Reconductor Richmond – Waneeta 230 kV and replace terminal equipments at Richmond and Waneeta substations	JCPL (12.82%) / NEPTUNE* (1.18%) / HTP*** (0.79%) / PECO (51.08%) / PEPCO (0.57%) / ECP** (0.85%) / PSEG (31.46%) / RE (1.25%)
b1398.12	Replace Graysferry 230 kV breaker ‘115’	PECO (100%)
b1398.13	Upgrade Peach Bottom 500 kV breaker ‘225’	AEC (1.67%) / AEP (13.94%) / APS (5.64%) / ATSI (8.02%) / BGE (4.12%) / ComEd (13.46%) / Dayton (2.12%) / DEOK (3.37%) / DL (1.76%) / DPL (2.55%) / Dominion (12.97%) / EKPC (1.81%) / JCPL (3.92%) / ME (1.95%) / NEPTUNE* (0.24%) / OVEC (0.07%) / PECO (5.39%) / PENELEC (1.84%) / PEPCO (3.71%) / PPL (4.78%) / PSEG (6.40%) / RE (0.27%)†
b1398.14	Replace Whitpain 230 kV breaker ‘105’	PECO (100%)
b1590.1	Upgrade the PECO portion of the Camden – Richmond 230 kV to a six wire conductor and replace terminal equipment at Richmond.	BGE (3.05%) / ME (0.83%) / HTP*** (0.21%) / PECO (91.36%) / PEPCO (1.93%) / PPL (2.46%) / ECP** (0.16%)
b1591	Reconductor the underground portion of the Richmond – Waneeta 230 kV and replace terminal equipment	BGE (4.54%) / DL (0.27%) / ME (1.04%) / HTP*** (0.03%) / PECO (88.08%) / PEPCO (2.79%) / PPL (3.25%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

†Cost allocations associated with Regional Facilities and Necessary Lower Voltage Facilities associated with the project

### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1717	Install a second Waneeta 230/138 kV transformer on a separate bus section	HTP*** (0.04%) / PECO (99.96%)
b1718	Reconductor the Crescentville - Foxchase 138 kV circuit	PECO (100%)
b1719	Reconductor the Foxchase - Bluegrass 138 kV circuit	PECO (100%)
b1720	Increase the effective rating of the Eddystone 230/138 kV transformer by replacing a circuit breaker at Eddystone	PECO (100%)
b1721	Increase the rating of the Waneeta - Tuna 138 kV circuit by replacing two 138 kV CTs at Waneeta	PECO (100%)
b1722	Increase the normal rating of the Cedarbrook - Whitemarsh 69 kV circuit by changing the CT ratio and replacing station cable at Whitemarsh 69 kV	PECO (100%)
b1768	Install 39 MVAR capacitor at Cromby 138 kV bus	PECO (100%)
b1900	Add a 3rd 230 kV transmission line between Chichester and Linwood substations and remove the Linwood SPS	PECO (69.62%) / JCPL (6.02%) / ATSI (1.23%) / PSEG (20.83%) / RE (0.83%) / NEPTUNE* (0.59%) / ECP** (0.45%) / HTP*** (0.43%)
b2140	Install a 3rd Emilie 230/138 kV transformer	PECO (97.04%) / ECP** (1.62%) / HTP*** (1.34%)
b2145	Replace two sections of conductor inside Richmond substation	PECO (100%)

\* Neptune Regional Transmission System, LLC

\*\*East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

## SCHEDULE 12 – APPENDIX A

### (8) PECO Energy Company

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2130	Replace Waneeta 138 kV breaker '15' with 63 kA rated breaker		PECO (100%)
b2131	Replace Waneeta 138 kV breaker '35' with 63 kA rated breaker		PECO (100%)
b2132	Replace Waneeta 138 kV breaker '875' with 63 kA rated breaker		PECO (100%)
b2133	Replace Waneeta 138 kV breaker '895' with 63 kA rated breaker		PECO (100%)
b2134	Plymouth Meeting 230 kV breaker '115' with 63 kA rated breaker		PECO (100%)
b2222	Install a second Eddystone 230/138 kV transformer		PECO (100%)
b2222.1	Replace the Eddystone 138 kV #205 breaker with 63 kA breaker		PECO (100%)
b2222.2	Increase Rating of Eddystone #415 138 kV Breaker		PECO (100%)
b2236	50 MVAR reactor at Buckingham 230 kV		PECO (100%)
b2527	Replace Whitpain 230 kV breaker '155' with 80 kA breaker		PECO (100%)
b2528	Replace Whitpain 230 kV breaker '525' with 80 kA breaker		PECO (100%)
b2529	Replace Whitpain 230 kV breaker '175' with 80 kA breaker		PECO (100%)
b2549	Replace terminal equipment inside Chichester substation on the 220-36 (Chichester – Eddystone) 230 kV line		PECO (100%)



### PECO Energy Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2550	Replace terminal equipment inside Nottingham substation on the 220-05 (Nottingham – Daleville- Bradford) 230 kV line	PECO (100%)
b2551	Replace terminal equipment inside Llanerch substation on the 130-45 (Eddystone to Llanerch) 138 kV line	PECO (100%)
b2572	Replace the Peach Bottom 500 kV ‘#225’ breaker with a 63 kA breaker	PECO (100%)
b2694	Increase ratings of Peach Bottom 500/230 kV transformer to 1479 MVA normal/1839 MVA emergency	AEC (3.97%)/ AEP (5.77%)/ APS (4.27%)/ ATSI (6.15%)/ BGE (1.63%)/ ComEd (0.72%)/ Dayton (1.06%)/ DEOK (1.97%)/ DL (2.25%)/ Dominion (0.35%)/ DPL (14.29%)/ ECP** (0.69%)/ EKPC (0.39%)/ HTP*** (0.96%)/ JCPL (6.84%) MetEd (3.28%)/ NEPTUNE* (2.14%)/ PECO (16.42%)/ PENELEC (3.94%)/ PPL (8.32%)/ PSEG (14.13%)/ RE (0.44%)
b2752.2	Tie in new Furnace Run substation to Peach Bottom – TMI 500 kV	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2752.3	Upgrade terminal equipment and required relay communication at Peach Bottom 500 kV: on the Beach Bottom – TMI 500 kV circuit	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)

\*Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

**PECO Energy Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2766.2	Upgrade substation equipment at Peach Bottom 500 kV to increase facility rating to 2826 MVA normal and 3525 MVA emergency	<b>Load-Ratio Share Allocation:</b> AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		<b>DFAX Allocation:</b> AEC (3.52%) / APS (9.95%) / ATSI (10.68%) / BGE (6.92%) / DPL (16.32%) / JCPL (11.32%) / NEPTUNE* (1.22%) / PENELEC (2.30%) / PEPCO (12.59%) / PSEG (24.22%) / RE (0.96%)

\*Neptune Regional Transmission System, LLC

**PECO Energy Company (cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2774 Reconnector the Emilie - Falls 138 kV line, and replace station cable and relay		PECO (100%)
b2775 Reconnector the Falls - U.S. Steel 138 kV line		PECO (100%)
b2850 Replace the Waneeta 230 kV "285" with 63 kA breaker		PECO (100%)
b2852 Replace the Chichester 230 kV "195" with 63 kA breaker		PECO (100%)
b2854 Replace the North Philadelphia 230 kV "CS 775" with 63 kA breaker		PECO (100%)
b2855 Replace the North Philadelphia 230 kV "CS 885" with 63 kA breaker		PECO (100%)
b2856 Replace the Parrish 230 kV "CS 715" with 63 kA breaker		PECO (100%)
b2857 Replace the Parrish 230 kV "CS 825" with 63 kA breaker		PECO (100%)
b2858 Replace the Parrish 230 kV "CS 935" with 63 kA breaker		PECO (100%)
b2859 Replace the Plymouth Meeting 230 kV "215" with 63 kA breaker		PECO (100%)
b2860 Replace the Plymouth Meeting 230 kV "235" with 63 kA breaker		PECO (100%)
b2861 Replace the Plymouth Meeting 230 kV "325" with 63 kA breaker		PECO (100%)
b2862 Replace the Grays Ferry 230 kV "705" with 63 kA breaker		PECO (100%)

**PECO Energy Company (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2863	Replace the Grays Ferry 230 kV "985" with 63 kA breaker		PECO (100%)
b2864	Replace the Grays Ferry 230 kV "775" with 63 kA breaker		PECO (100%)
b2923	Replace the China Tap 230 kV 'CS 15' breaker with a 63 kA breaker		PECO (100%)
b2924	Replace the Emilie 230 kV 'CS 15' breaker with 63 kA breaker		PECO (100%)
b2925	Replace the Emilie 230 kV 'CS 25' breaker with 63 kA breaker		PECO (100%)
b2926	Replace the Chichester 230 kV '215' breaker with 63 kA breaker		PECO (100%)
b2927	Replace the Plymouth Meeting 230 kV '125' breaker with 63 kA breaker		PECO (100%)
b2985	Replace the 230 kV CB #225 at Linwood Substation (PECO) with a double circuit breaker (back to back circuit breakers in one device)		PECO (100%)
b3041	Peach Bottom – Furnace Run 500 kV terminal equipment		PECO (100%)
b3120	Replace the Whitpain 230 kV breaker "125" with a 63 kA breaker		PECO (100%)
b3138	Move 2 MVA load from the Roxborough to Bala substation. Adjust the tap setting on the Master 138/69 kV transformer #2		PECO (100%)
b3146	Upgrade the Richmond 69 kV breaker "140" with 40 kA breaker		PECO (100%)

**PECO Energy Company (cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3335	Reconductor a 0.76 mile portion of the Croydon - Burlington 230 kV line		PECO (100%)

## Attachment 5H – Cost Allocation of 2022/2023 CW Edison Schedule 12 Charges

Attachment 5H PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023  
Calculation of costs and monthly PJM charges for Commonwealth Edison

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022 - May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup> <i>per PJM Open Access Transmission Tariff</i>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
Replace station equipment at Nelson and upgrade conductor ratings 345 kV lines	b2692.1-b2692.2	\$ 1,264,044.00	0.18%	0.52%	1.17%	0.14%	\$2,275	\$6,573	\$14,789	\$1,770	\$25,407
Totals		\$ -					\$0 \$2,275	\$0 \$6,573	\$0 \$14,789	\$0 \$1,770	\$0 \$25,407

Notes on calculations >>>

= (a) \* (b) = (a) \* (c) = (a) \* (d) = (a) \* (e) = (f) + (g) + (h) + (i)

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM <i>website</i>	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 1,232.44	10,064.1	\$ 0.12	\$ 8,627	\$ 6,162	\$ 14,789
JCP&L	\$ 547.75	6,169.1	\$ 0.09	\$ 3,834	\$ 2,739	\$ 6,573
ACE	\$ 189.61	2,631.0	\$ 0.07	\$ 1,327	\$ 948	\$ 2,275
RE	\$ 147.47	427.4	\$ 0.35	\$ 1,032	\$ 737	\$ 1,770
Total Impact on NJ Zones	\$ 2,117.27			\$ 14,821	\$ 10,586	\$ 25,407

Notes on calculations >>>

= (k) \* (l) = (k) \* 7 = (k) \* 5 = (n) \* (o)

Notes:  
1) 2022 allocation share percentages are from PJM OATT

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 15 Commonwealth Edison Company

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.  
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2468	Replace the Skokie 138 kV breaker '88 L8803' with 63kA breaker		ComEd (100%)
b2469	Replace the Des Plaines 138 kV breaker '46 11702' with 63 kA breaker		ComEd (100%)
b2561	Install a new 345 kV circuit breaker 5-7 at Elwood substation		ComEd (100%)
b2562	Remove 2.0 miles of wood poles on 138 kV line 17105, erect new steel structures, and install new 1113 kmil ACSR conductor from Roscoe Bert to Harlem		ComEd (100%)
b2613	Replace relays at Mazon substation		ComEd (100%)
b2692.1	Replace station equipment at Nelson, ESS H-471 and Quad Cities		AEC (0.18%) / AEP (18.68%) / APS (5.86%) / ATSI (7.85%) / BGE (3.32%) / ComEd (38.21%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / HTP (0.05%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)



Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 15 Commonwealth Edison Company

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.  
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2692.2	Upgrade conductor ratings of Cordova – Nelson, Quad Cities – ESS H-471 and ESS H-471 – Nelson 345 kV lines and mitigating sag limitations		AEC (0.18%) / AEP (18.68%) / APS (5.86%) / ATSI (7.85%) / BGE (3.32%) / ComEd (38.21%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / HTP (0.05%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)
b2693	Replace L7815 B phase line trap at Wayne substation		ComEd (100%)
b2699.1	Replace 5 Powerton 345 kV CB's with 2 cycle IPO breakers, install one new 345 kV CB; swap line 0302 and line 0303 bus positions; reconfigure Powerton 345 kV bus as single ring configuration		ComEd (100%)
b2699.2	Remove SPS logic at Powerton that trips generators or sectionalizes bus under normal conditions; minimal SPS logic will remain		ComEd (100%)
b2721	Goodings Grove – Balance Station Load (swap bus positions for 345 kV lines 1312 & 11620 and 345 kV lines 11604 & 11622) and replace 138 kV bus tie 2-3		ComEd (100%)

## Attachment 5I – Cost Allocation of 2022/2023 Duquesne Schedule 12 Charges

Attachment 5I PJM Schedule 12 - Transmission Enhancement Charges for June 2022 - May 2023  
Calculation of costs and monthly PJM charges for Duquesne

(a)			(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)
Required Transmission Enhancement <i>per PJM website</i>	PJM Upgrade ID <i>per PJM spreadsheet</i>	June 2022 - May 2023 Annual Revenue Requirement <i>per PJM website</i>	Responsible Customers - Schedule 12 Appendix				Estimated New Jersey EDC Zone Charges by Project				
			ACE Zone Share <sup>1</sup> <i>per PJM Open Access Transmission Tariff</i>	JCP&L Zone Share <sup>1</sup>	PSE&G Zone Share <sup>1</sup>	RE Zone Share <sup>1</sup>	ACE Zone Charges	JCP&L Zone Charges	PSE&G Zone Charges	RE Zone Charges	Total NJ Zones Charges
Reconductor 7 miles of Woodville- Peters 138 kV circuit	b2689.1-2	\$ 1,151,053.00	0.99%	0.00%	3.45%	0.00%	\$11,395	\$0	\$39,711	\$0	\$51,107
		\$ -					\$0	\$0	\$0	\$0	\$0
Totals							\$11,395	\$0	\$39,711	\$0	\$51,107

Notes on calculations >>> = (a) \* (b) = (a) \* (c) = (a) \* (d) = (a) \* (e) = (f) + (g) + (h) + (i)

	(k)	(l)	(m)	(n)	(o)	(p)
Zonal Cost Allocation for New Jersey Zones	Average Monthly Impact on Zone Customers in 22/23	2022TX Peak Load per PJM <i>website</i>	Rate in \$/MW-mo.	2022 Impact (7 months)	2023 Impact (5 months)	2022-2023 Impact (12 months)
PSE&G	\$ 3,309.28	10,064.1	\$ 0.33	\$ 23,165	\$ 16,546	\$ 39,711
JCP&L	\$ -	6,169.1	\$ -	\$ -	\$ -	\$ -
ACE	\$ 949.62	2,631.0	\$ 0.36	\$ 6,647	\$ 4,748	\$ 11,395
RE	\$ -	427.4	\$ -	\$ -	\$ -	\$ -
Total Impact on NJ Zones	\$ 4,258.90			\$ 29,812	\$ 21,294	\$ 51,107

Notes on calculations >>> = (k) \* (l) = (k) \* 7 = (k) \* 5 = (n) \* (o)

Notes:  
1) 2022 allocation share percentages are from PJM OATT

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 18 Duquesne Light Company

### Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2209	Revise the reclosing for the Cheswick 138 kV breaker Z-51 WILMERD'	DL (100%)
b2280	Replace the USAP 138 kV breaker 'XFMR'	DL (100%)
b2303	Revise the reclosing to the Dravosburg 138 kV breaker 'Z73 West Mifflin' from 5 sec to 15 sec	DL (100%)
b2563	Operate with the Crescent 345/138 kV #3 autotransformer in-service by replacing 8 overdutied 138 kV breakers at Crescent, 3 138 kV breakers at Beaver Valley, install #1 section 345 kV breaker for 331 circuit at Crescent	DL (100%)
b2632	Replace the Oakland 138 kV 'Z-101 Arsenal' breaker	DL (100%)
b2639	Replace the Crescent 138 kV 'NO3 – 4 138' breaker with a 63 kA breaker	DL (100%)
b2640	Replace the Crescent 138 kV 'Z-143 SWCKLY' breaker with a 63 kA breaker	DL (100%)
b2641	Replace the Crescent 138 kV 'Z-24 MONTOUR' breaker with a 63 kA breaker	DL (100%)
b2642	Replace the Crescent 138 kV 'Z-28 BEAVER' breaker with a 63 kA breaker	DL (100%)
b2689.1	Reconductor approximately 7 miles of the Woodville – Peters (Z-117) 138 kV circuit	AEC (0.99%)/ APS (66.14%)/ BGE (4.60%)/ Dominion (8.81%)/ DPL (5.83%)/ ECP** (0.34%)/ HTP*** (0.04%)/ NEPTUNE* (0.12%)/ PECO (3.39%)/ PEPCO (6.29%)/ PSEG (3.45%)

\*Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC

Intra-PJM Tariffs --> OPEN ACCESS TRANSMISSION TARIFF --> OATT VI. ADMINISTRATION AND STUDY OF NEW SERVICE REQUESTS; R --> OATT SCHEDULE 12 - APPENDIX A - Required Transmission Enhanc --> OATT SCHEDULE 12.APPENDIX A - 18 Duquesne Light Company

### Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2689.2 Reconfigure West Mifflin-USS Clairton (Z-15) 138 kV circuit to establish Dravosburg-USS Clairton (Z-14) 138 kV circuit and West Mifflin-Wilson (Z-15) 138 kV circuit		AEC (0.99%)/ APS (66.14%)/ BGE (4.60%)/ Dominion (8.81%)/ DPL (5.83%)/ ECP** (0.34%)/ HTP*** (0.04%)/ NEPTUNE* (0.12%)/ PECO (3.39%)/ PEPCO (6.29%)/ PSEG (3.45%)
b3011.7 Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z-70 line position/bay, with the breaker duty as 63kA		DL (100%)
b3011.8 Upgrade 138 kV breaker “Z-78 Logans” at Dravosburg		DL (100%)
b3012.2 Construct two new ties from a new FirstEnergy substation to a new Duquesne substation by using two separate structures – Duquesne portion		ATSI (38.21%) / DL (61.79%)
b3012.4 Establish the new tie line in place of the existing Elrama – Mitchell 138 kV line		DL (100%)
b3015.1 Construct new Elrama 138 kV substation and connect 7 138 kV lines to new substation		DL (100%)
b3015.2 Reconductor Elrama to Wilson 138 kV line. 4.8 miles		APS (100%)
b3015.3 Reconductor Dravosburg to West Mifflin 138 kV line. 3 miles		DL (100%)
b3015.4 Run new conductor on existing tower to establish the new Dravosburg – Elrama (Z-75) circuit. 10 miles		DL (100%)

\*Neptune Regional Transmission System, LLC

\*\* East Coast Power, L.L.C.

\*\*\*Hudson Transmission Partners, LLC