Control Narrative: SUSV Operation

Equipment: SUSV-110

Parameter: Incoming Flow Rate (FT-201.IN)

Parameter: Outgoing Flow Rate (FT-201.OUT)

Variable: Weight Change Rate (V-110.dWT)

Condition: IF deviation > Tolerance (P-TOL)

Action: Trigger Alarm (V-110.Alarm_Deviation)