

Control Narrative: Storage Tank Level

Equipment: Tank T-300

Parameter: Liquid Level (LT-300)

Parameter: Temperature (TT-300)

Condition: IF Level > 90% (P-L_HIGH)

Action: Close Inlet Valve (XV-301.Close)

Action: Sound High Level Alarm (L-ALM-HIGH)