

Control Narrative: Feed Pump Logic

Equipment: Pump P-501

Parameter: Discharge Pressure (PT-501)

Parameter: Motor Current (IT-501)

Variable: Vibration Level (VT-501)

Condition: IF Vibration > High Limit (P-VIB_HIGH)

Action: Trip Pump (P-501.Trip)