

Pipe Wall Thickness Calculation Report

Report Generated: 2026-07-01 15:23:16

Input Parameters

Nominal Pipe Size (NPS)	2
Design Pressure	1.034 MPa
Design Temperature	260 °C
Material	A53 Grade B
Weld Type	Seamless
Corrosion Allowance	1.5875 mm
Threaded	Yes
Mill Tolerance	12.5%

Calculation Results

Outside Diameter (Dext)	60.30 mm
Allowable Stress (S)	130.31 MPa
Weld Joint Factor (E)	1.00
Y Coefficient	0.40
Corrosion Allowance (CA)	1.59 mm
Thread Depth (TD)	1.91 mm
Total Allowance (OT)	3.50 mm
Pressure Design Thickness (t_dis)	0.2385 mm
Required Thickness (t_req)	3.7390 mm
Minimum Thickness (t_min)	4.2731 mm
Thin Wall Check	Passed
Recommended Schedule	80
Available Thickness	5.54 mm
Status	PASS

Available Schedules

Schedule	Thickness (mm)	Status
5	2.77	Inadequate

10	3.05	Inadequate
40	3.91	Inadequate
80	5.54	Adequate
120	7.01	Adequate
160	8.74	Adequate
XXS	11.07	Adequate