ग्रिड-इंडिया
GRID-INDIA

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
GRID CONTROLLER OF INDIA LIMITED
(A Government of India Enterprise)
[formerly Power System Operation Corporation Limited (POSOCO)]

आज़ादी का अमृत महोत्सव

केन्द्रीय कार्यालय : 61, आई एफ सी आई टावर, 8वां और 9वां तल, नेहरु प्लेस, नई दिल्ली -110019
Corporate Office : 61, IFCI Tower, 8th & 9th Floor, Nehru Place, New Delhi - 110019
CIN : U40105DL2009GOI188682, Website : www.grid-india.in, E-mail : gridindiacc@grid-india.in, Tel.: 011- 40234672

संदर्भ संख्या:- GRID-INDIA/NLDC/MR/

दिनांक: **24.06.2025**

सेवा में,

वितरण सूची के अनुसार

विषय:- निष्पादन रिपोर्ट – **मई 2025**

महोदय,

आई०ई०जी०सी०-2023 की धारा-38 के अनुपालन में, **मई 2025** माह की अखिल भारतीय प्रणाली की निष्पादन रिपोर्ट संलग्न है।

धन्यवाद

भवदीय

एस.सी. डंभारे
मुख्य महाप्रबन्धक
प्रणाली प्रचालन, रा.भा.प्रे.कें.

संलग्नक: मासिक प्रणाली रिपोर्ट

पंजीकृत कार्यालय : प्रथम तल, बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराय, नई दिल्ली - 110016
Registered Office : First Floor, B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi -110016

वितरण सूची
Distribution List

1 सचिव, के.वि.नि.आ. तीसरा एवं चौथा तल, चंद्रलोक भवन, 36, जनपथ, नई दिल्ली–110001
Secretary, CERC, 3rd & 4th Floor, Chanderlok Building,36,Janpath,New Delhi-110001

2 मुख्य अभियंता (जी एम), के.वि.प्रा., सेवा भवन, आर. के. पुरम, नई दिल्ली–110066
Chief Engineer (GM), CEA,Sewa Bhavan, R.K.Puram , New Delhi-110066

3 सदस्य सचिव, उ. क्षे. वि. स., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
Member Secretary, NRPC,18/A,SJSS Marg, Katwaria Sarai, New Delhi-110016

4 सदस्य सचिव, प. क्षे. वि. स., एफ–3, एम आई डी सी क्षेत्र, अंधेरी (पूर्व), मुंबई – 400093
Member Secretary, WRPC, F-3,MIDC Area, Andheri (East),Mumbai-400093

5 सदस्य सचिव, द. क्षे. वि. स., 29, रेस कोर्स क्रॉस रोड, बंगलूरु – 560009
Member Secretary, SRPC, 29,Race Course Cross Road,Bangalore-560009

6 सदस्य सचिव, पू. क्षे. वि. स., 14, गोल्फ क्लब रोड, कोलकाता – 700033
Member Secretary, ERPC, 14,Golf Club Road , Kolkata-700033

7 सदस्य सचिव,उ. पू. क्षे. वि. स.,मेघालय राज्य आवासीय वित्त सहकारी समिति लिमिटेड भवन, नोंग्रिम हिल्स, शिलोंग – 793003
Member Secretary, NERPC, Meghalaya State Housing Finance Cooperative Society Ltd. Building, Nongrim Hills , Shillong -793003

8 मुख्य अभियंता, राष्ट्रीय विद्युत समिति, एनआरपीसी भवन, तृतीय तल, 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
Chief Engineer, National Power Committee, NRPC Building, 3rd floor, 18/A,SJSS Marg, Katwaria Sarai, New Delhi-110016

9 कार्यपालक निदेशक, पू. क्षे. भा. प्रे. के., 14, गोल्फ क्लब रोड, कोलकाता – 700033
Executive Director, ERLDC,14, Golf Club Road , Kolkata-700033


10 कार्यपालक निदेशक, प. क्षे. भा. प्रे. के., एफ–3, एम आई डी सी क्षेत्र, अंधेरी (पूर्व), मुंबई – 400093
Executive Director, WRLDC,F-3,MIDC Area, Andheri (East),Mumbai-400093

11 कार्यपालक निदेशक , उ.क्षे.भा.प्रे.के, 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
Executive Director, NRLDC,18/A,SJSS Marg, Katwaria Sarai, New Delhi-110016

12 कार्यपालक निदेशक, द. क्षे. भा. प्रे. के, 29, रेस कोर्स क्रॉस रोड, बंगलूरु – 560009
Executive Director, SRLDC, 29,Race Course Cross Road,Bangalore-560009

13 कार्यपालक निदेशक, पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह, लापलंग, शिलोंग- 793006
Executive Director, NERLDC, Dongtieh, Lower Nongrah, Laplang, Shillong-793006

ग्रिड-इंडिया
GRID-INDIA



मासिक प्रचालन रिपोर्ट
MONTHLY OPERATIONAL REPORT

राष्ट्रीय भार प्रेषण केन्द्र
NATIONAL LOAD DESPATCH CENTRE

MAY-2025

GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड





grid-india.in

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

GRID CONTROLLER OF INDIA LIMITED
Formerly Power System Operation Corporation Limited

NATIONAL LOAD DESPATCH CENTRE, NEW DELHI

माह मई 2025 के लिए प्रचालन निष्पादन रिपोर्ट

OPERATIONAL PERFORMANCE REPORT FOR THE MONTH OF MAY-2025

पृष्ठसूची **CONTENTS**

1	माह मई 2025 की सारांश रिपोर्ट Summary of report for the month of MAY 2025	1-5
2	क्षेत्रवार स्थापित विद्युत क्षमता Region wise Installed Capacity	6
3	राष्ट्रीय स्तर पर संध्याकालीन शिखर अवधि की विद्युत मांग पूर्ति Evening Peak Hour Demand Met at National level	7-8
4	राष्ट्रीय स्तर पर विद्युत ऊर्जा खपत Energy consumption at National level	9-10
5	फ्रिक्वेंसी रूपरेखा Frequency profile	11-12
6	राष्ट्रीय स्तर पर जल विद्युत ऊर्जा उत्पादन Hydro generation at National level	13-14
7	राष्ट्रीय स्तर पर पवन ऊर्जा उत्पादन Wind generation at National level	15
8	राष्ट्रीय स्तर पर सौर ऊर्जा उत्पादन Solar generation at National level	16
9	राष्ट्रीय स्तर पर दैनिक अधिकतम विद्युत मांग पूर्ति Daily maximum demand met at National level	17
10	15 मई के माँग एवं उत्पादन प्लॉट (अधिकतम मांग पूर्ति) व माँग का डाटा (15 मिनट अंतराल) Demand and generation plots for 15-MAY (Max Demand Met) and Demand data (15-minute interval)	18-22
11	ऊर्जा आपूर्ति की वास्तविक स्थिति Actual power supply position	23
12	ऊर्जा आवश्यकता एवं आपूर्ति की पिछले वर्ष माह मई 2024 से तुलना Energy requirement and met comparison with MAY 2024	24


13	शिखर मांग आवश्यकता एवं आपूर्ति की पिछले वर्ष माह मई 2024 से तुलना Peak demand requirement and met comparison with MAY 2024	25
14	क्षेत्रीय स्तर पर शिड्यूल एवं ड्रावल Schedule & drawal at regional level	26
15	अंतर क्षेत्रीय विनिमय Inter-regional exchanges	27-39
16	अंतर राष्ट्रीय विद्युत विनिमय Inter-national exchanges	40-42
17	एसटीओए (द्विपक्षीय एवं सामूहिक)एवं यू आइ का ब्यौरा Bilateral and collective short-term open access & UI details	43
18	पावर मार्केट की सूचना Power market information	44-48
19	अक्षय ऊर्जा प्रमाण पत्र प्रक्रिया Renewable energy certificate mechanism	49-51
20	मुख्य घटनाएँ एवं डिस्टर्बेंस Important events/disturbances	52-66
21	नए चार्ज किये गए तत्व New elements Charged	67
22	विभव रूपरेखा Voltage profile	68
23	अब तक उच्चतम (मांग व ऊर्जा) आँकड़े : माह मई 2025 तक All Time Highest (Demand & Energy) figures: Till MAY 2025	69
24	मई 2025 के लिए सिस्टम रिलाइबिलिटी सूचकांक System Reliability Indices for MAY 2025	70

1. SUMMARY OF REPORT FOR THE MONTH OF MAY-2025

EVENING PEAK HOUR (at 2000hrs) DEMAND MET AT NATIONAL LEVEL (MW)


Decreased by 1.07% as compared to Apr'25

Decreased by 1.70% as compared to May'24




*Source: As per daily data furnished by states


Frequency within IEGC Band



ENERGY MET AT NATIONAL LEVEL (MU)




AVERAGE ENERGY MET AT NATIONAL LEVEL (MU/Day)



HYDRO GENERATION AT NATIONAL LEVEL (MU)


Increased by 8.24% as compared to May'24



AVERAGE HYDRO GENERATION AT NATIONAL LEVEL (MU/Day)


Increased by 36.61% as compared to Apr'25

Increased by 8.24% as compared to May'24



WIND GENERATION AT NATIONAL LEVEL (MU)


Increased by 14.20% as compared to May'24




AVERAGE WIND GENERATION AT NATIONAL LEVEL (MU/Day)

Increased by 43.51% as compared to Apr'25


Increased by 14.20% as compared to May'24



SOLAR GENERATION AT NATIONAL LEVEL (MU)



AVERAGE SOLAR GENERATION AT NATIONAL LEVEL (MU/Day)



2. ALL INDIA REGIONWISE INSTALLED CAPACITY

As on 31.05.2025
(All figures are in MW)

S No	Region	THERMAL					NUCLEAR	HYDRO	RES @ MNRE	GRAND TOTAL
		COAL	LIGNITE	GAS	DIESEL	TOTAL				
1	NR	59298	1580	5712	0	66590	2220	21591	48408	138809
2	WR	72948	1400	9399	0	83747	3240	7604	65118	159708
3	SR	50456	3640	3356	434	57885	3320	11927	62114	135247
4	ER	28775	0	0	0	28775	0	4862	2479	36116
5	NER	1242	0	1665	36	2943	0	1944	664	5551
6	ISLANDS	0	0	0	120	120	0	0	41	160
	ALL INDIA	212718	6620	20132	589	240060	8780	47928	178823	475590

Source: Central Electricity Authority

3. राष्ट्रीय स्तर पर संध्याकालीन शिखर अवधि की विद्युत मांग पूर्ति
EVENING PEAK HOUR (at 20:00hrs) DEMAND MET AT NATIONAL LEVEL


माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मेगावाट मे All figures in MW

दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL
1-May-25	66594	63775	46744	20526	2499	200138
2-May-25	63661	69503	48417	26239	2853	210673
3-May-25	62400	63568	51026	25570	3076	205640
4-May-25	57272	62897	43143	24574	3082	190968
5-May-25	56924	57217	51238	26734	3166	195279
6-May-25	62144	56978	50232	26723	2998	199075
7-May-25	61009	58109	50320	27381	3206	200025
8-May-25	63101	61919	50825	28988	3254	208087
9-May-25	63685	62383	52315	28843	3447	210673
10-May-25	65706	63191	52223	29747	2474	213341
11-May-25	56959	60508	48381	28530	2529	196907
12-May-25	67039	64605	51796	27921	3054	214415
13-May-25	64734	64850	50933	28700	2988	212205
14-May-25	71006	65790	51699	31898	3107	223500
15-May-25	71963	66333	51720	28252	3022	221290
16-May-25	71608	65049	50695	27904	3060	218316
17-May-25	73595	65266	47103	24927	2931	213822
18-May-25	73515	62838	44554	25202	2651	208760
19-May-25	78012	64914	48338	26416	2892	220572
20-May-25	79326	62769	47116	27110	2857	219178
21-May-25	56202	61577	46714	25422	3119	193034
22-May-25	68694	63903	47936	27301	3264	211098
23-May-25	75428	63824	46629	27170	3476	216527
24-May-25	66147	62283	44478	27282	3502	203692
25-May-25	67271	61085	39781	27145	3175	198457
26-May-25	74094	64008	43816	27346	3355	212619
27-May-25	75539	61712	44897	28515	3548	214211
28-May-25	76028	61035	45118	27950	3287	213418
29-May-25	71890	63483	45787	26676	2789	210625
30-May-25	72942	64184	44904	27840	1997	211867
31-May-25	63911	63145	47405	28282	2646	205389
उच्चतम MAXIMUM	79326	69503	52315	31898	3548	223500
निम्नतम MINIMUM	56202	56978	39781	20526	1997	190968
औसत AVERAGE	67690	62990	47945	27197	3010	208832
अब तक का उच्चतम All Time Max.	82312	71713	55925	**31898**	3787	227354
दिनांक Date	23.07.24	24.04.25	28.03.25	**14.05.25**	19.09.24	29.05.24

Source: As per daily data furnished by states

EVENING PEAK HOUR DEMAND(at 2000hrs) MET DURING THE MONTH OF MAY' 2025




4. राष्ट्रीय स्तर पर विद्युत ऊर्जा आपूर्ति ENERGY MET AT NATIONAL LEVEL

माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मिलियन यूनिट मे All figures in MU

दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL
01-May-25	1502	1605	1181	503	50	4841
02-May-25	1276	1642	1220	529	52	4719
03-May-25	1372	1629	1206	555	56	4817
04-May-25	1287	1541	1114	546	58	4545
05-May-25	1249	1525	1181	583	60	4597
06-May-25	1301	1385	1217	571	57	4531
07-May-25	1360	1364	1209	605	59	4598
08-May-25	1336	1429	1221	632	59	4678
09-May-25	1379	1456	1252	659	64	4810
10-May-25	1408	1488	1260	668	62	4886
11-May-25	1365	1468	1198	659	48	4737
12-May-25	1448	1522	1263	651	55	4939
13-May-25	1510	1551	1258	642	55	5015
14-May-25	1562	1548	1235	673	55	5072
15-May-25	1632	1579	1206	670	54	5142
16-May-25	1643	1575	1191	660	57	5126
17-May-25	1639	1561	1127	609	54	4990
18-May-25	1643	1509	1008	575	51	4785
19-May-25	1724	1555	1052	595	53	4979
20-May-25	1789	1545	1041	615	53	5043
21-May-25	1679	1483	1017	607	55	4841
22-May-25	1450	1457	1025	582	60	4573
23-May-25	1647	1481	1048	616	65	4856
24-May-25	1634	1472	1001	598	65	4771
25-May-25	1284	1428	911	602	64	4289
26-May-25	1553	1467	944	607	61	4631
27-May-25	1655	1457	979	612	66	4768
28-May-25	1709	1431	984	621	68	4813
29-May-25	1704	1421	1018	600	58	4802
30-May-25	1600	1443	1025	611	40	4719
31-May-25	1593	1443	1030	644	47	4757
कुल TOTAL	46932	46458	34621	18900	1761	148671
उच्चतम MAXIMUM	1789	1642	1263	673	68	5142
निम्नतम MINIMUM	1249	1364	911	503	40	4289
औसत AVERAGE	1514	1499	1117	610	57	4796
संचयी 2025-26 Cumulative 2025-26	86635	96789	73081	36238	3413	296156
अब तक का उच्चतम All Time Max.	1990	1742	1460	692	80	5466
दिनांक Date	18.06.24	25.04.25	19.03.25	10.06.24	20.09.24	30.05.24

ENERGY MET DURING THE MONTH OF MAY' 2025



5. वर्ष 2025-26 के लिए आवृत्ति रूपरेखा FREQUENCY PROFILE FOR YEAR 2025-26

राष्ट्रीय ग्रिड NATIONAL GRID								
फ्रिक्वेंसी रूपरेखा (Hz)			<49.9	49.9-50.05	>50.05	उच्चतम फ्रिक्वेंसी	निम्नतम फ्रिक्वेंसी	औसत फ्रिक्वेंसी
% समय	Apr-25	All India Grid	5.16	75.64	19.20	50.49	49.42	50.00
	May-25	All India Grid	3.60	73.30	23.11	50.49	49.59	50.02
	2025-26 (upto May)	All India Grid	**4.37**	**74.45**	**21.18**	**50.49**	**49.42**	**50.01**

5.1 मई 2025 के लिए आवृत्ति रूपरेखा FREQUENCY PROFILE FOR MAY 2025

फ्रिक्वेंसी रूपरेखा (Hz)		<49.9	49.9-50.05	>50.05		उच्चतम फ्रिक्वेंसी	निम्नतम फ्रिक्वेंसी	औसत फ्रिक्वेंसी	एफ़.वी.आई.
% समय	01-May-25	1.77	66.92	31.31		50.35	49.82	50.04	0.07
	02-May-25	2.87	59.76	37.37		50.25	49.80	50.03	0.05
	03-May-25	2.13	81.76	16.11		50.29	49.83	50.01	0.03
	04-May-25	2.09	70.96	26.94		50.42	49.85	50.03	0.09
	05-May-25	5.23	65.67	29.10		50.34	49.76	50.01	0.06
	06-May-25	4.13	73.99	21.88		50.37	49.76	50.01	0.05
	07-May-25	2.96	84.06	12.97		50.24	49.83	50.00	0.03
	08-May-25	5.97	76.00	18.03		50.25	49.63	50.00	0.04
	09-May-25	7.50	79.56	12.94		50.18	49.79	49.99	0.03
	10-May-25	5.84	66.77	27.38		50.25	49.66	50.01	0.06
	11-May-25	5.73	75.81	18.46		50.21	49.65	50.00	0.04
	12-May-25	2.93	81.64	15.43		50.23	49.79	50.00	0.03
	13-May-25	2.48	81.81	15.72		50.17	49.84	50.00	0.02
	14-May-25	3.13	86.05	10.82		50.25	49.84	50.00	0.03
	15-May-25	3.43	77.22	19.35		50.19	49.82	50.00	0.03
	16-May-25	3.45	81.16	15.39		50.23	49.73	50.00	0.03
	17-May-25	1.99	82.27	15.74		50.21	49.86	50.00	0.03
	18-May-25	2.38	64.34	33.28		50.49	49.78	50.06	0.18
	19-May-25	0.80	91.40	7.80		50.22	49.86	49.99	0.02
	20-May-25	1.30	82.85	15.86		50.19	49.87	50.00	0.02
	21-May-25	3.09	70.41	26.50		50.32	49.80	50.01	0.05
	22-May-25	5.34	57.22	37.44		50.49	49.59	50.06	0.22
	23-May-25	8.46	67.91	23.63		50.28	49.81	50.00	0.05
	24-May-25	2.06	71.35	26.59		50.22	49.84	50.01	0.04
	25-May-25	1.54	68.87	29.59		50.45	49.82	50.04	0.11
	26-May-25	7.41	68.01	24.58		50.35	49.66	50.01	0.09
	27-May-25	1.86	76.00	22.14		50.40	49.83	50.02	0.05
	28-May-25	3.98	68.85	27.16		50.27	49.83	50.02	0.05
	29-May-25	3.39	60.29	36.32		50.34	49.80	50.04	0.07
	30-May-25	0.71	70.58	28.72		50.44	49.85	50.04	0.09
	31-May-25	5.50	62.69	31.82		50.45	49.84	50.03	0.12


6.राष्ट्रीय स्तर पर जल विद्युत उत्पादन
HYDRO GENERATION AT NATIONAL LEVEL

माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मिलियन यूनिट मे All figures in MU

दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL
01-May-25	256	21	68	31	13	390
02-May-25	235	39	72	30	16	391
03-May-25	230	27	75	28	15	375
04-May-25	215	17	71	27	14	344
05-May-25	227	29	80	34	15	385
06-May-25	232	28	85	30	16	391
07-May-25	237	23	81	30	15	386
08-May-25	242	17	81	28	15	381
09-May-25	254	30	85	32	13	414
10-May-25	262	30	84	29	13	417
11-May-25	267	22	75	35	16	415
12-May-25	263	40	80	32	14	429
13-May-25	247	30	78	43	15	413
14-May-25	241	37	82	45	14	419
15-May-25	252	53	87	46	19	458
16-May-25	284	43	82	49	25	483
17-May-25	289	29	74	43	26	461
18-May-25	304	31	58	38	20	450
19-May-25	333	41	76	41	21	512
20-May-25	311	49	68	47	25	499
21-May-25	323	39	69	49	25	505
22-May-25	330	46	66	49	30	520
23-May-25	362	47	74	44	25	551
24-May-25	351	45	70	41	23	531
25-May-25	352	36	74	45	23	529
26-May-25	347	38	77	43	21	527
27-May-25	359	39	89	56	23	565
28-May-25	355	36	90	55	27	564
29-May-25	323	44	92	56	29	544
30-May-25	299	38	83	75	36	531
31-May-25	311	42	93	76	39	560
कुल TOTAL	8893	1084	2417	1307	641	14343
उच्चतम MAXIMUM	362	53	93	76	39	565
निम्नतम MINIMUM	215	17	58	27	13	344
औसत AVERAGE	287	35	78	42	21	463
संचयी 2025-26 Cumulative 2025-26	14355	2431	4606	2134	977	24503
अब तक का उच्चतम All Time Max.	443	167	208	157	43	877
दिनांक Date	01.08.23	18.12.14	31.08.18	14.09.22	27.06.24	30.08.22

HYDRO ENERGY DURING THE MONTH OF MAY' 2025



7. राष्ट्रीय स्तर पर पवन ऊर्जा उत्पादन
WIND GENERATION AT NATIONAL LEVEL

माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मिलियन यूनिट मे All figures in MU

दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL
01-May-25	25	189	68	----------	----------	281
02-May-25	17	165	63	----------	----------	246
03-May-25	19	182	94	----------	----------	295
04-May-25	20	174	88	----------	----------	282
05-May-25	22	143	58	----------	----------	223
06-May-25	12	108	67	----------	----------	187
07-May-25	8	106	71	----------	----------	185
08-May-25	20	80	77	----------	----------	176
09-May-25	20	65	54	----------	----------	139
10-May-25	6	72	66	----------	----------	144
11-May-25	16	77	92	----------	----------	185
12-May-25	44	74	120	----------	----------	238
13-May-25	40	97	106	----------	----------	243
14-May-25	28	88	64	----------	----------	180
15-May-25	29	73	60	----------	----------	162
16-May-25	49	107	86	----------	----------	242
17-May-25	47	115	85	----------	----------	247
18-May-25	54	83	66	----------	----------	202
19-May-25	61	84	45	----------	----------	190
20-May-25	37	82	115	----------	----------	234
21-May-25	44	82	156	----------	----------	283
22-May-25	44	90	156	----------	----------	290
23-May-25	46	94	165	----------	----------	305
24-May-25	25	156	209	----------	----------	390
25-May-25	14	145	210	----------	----------	369
26-May-25	23	154	263	----------	----------	440
27-May-25	18	202	282	----------	----------	502
28-May-25	19	199	259	----------	----------	477
29-May-25	31	184	236	----------	----------	451
30-May-25	33	287	269	----------	----------	589
31-May-25	63	315	262	----------	----------	640
कुल TOTAL	933	4071	4013	----------	----------	9017
उच्चतम MAXIMUM	63	315	282	----------	----------	640
निम्नतम MINIMUM	6	65	45	----------	----------	139
औसत AVERAGE	30	131	129	----------	----------	291
संचयी 2025-26 Cumulative 2025-26	1596	7976	5525	----------	----------	15097
अब तक का उच्चतम All Time Max.	86	**315**	323	----------	----------	**640**
दिनांक Date	07.08.23	**31.05.25**	26.07.24	----------	----------	**31.05.25**

*__Source:__ As reported by SLDCs. Limited visibility of embedded wind generator data.

8. राष्ट्रीय स्तर पर सौर ऊर्जा उत्पादन
SOLAR GENERATION AT NATIONAL LEVEL

माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मिलियन यूनिट मे All figures in MU

दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL
01-May-25	192	155	140	3.8	0.5	491
02-May-25	180	153	135	4.7	1.1	473
03-May-25	193	149	140	3.7	1.2	487
04-May-25	186	133	140	4.2	1.1	464
05-May-25	165	127	140	4.2	0.9	437
06-May-25	191	114	143	3.7	0.9	453
07-May-25	207	116	140	4.0	1.1	469
08-May-25	198	132	143	4.0	0.8	478
09-May-25	194	135	151	3.9	1.1	485
10-May-25	206	132	139	4.1	1.1	483
11-May-25	204	131	137	3.9	0.7	476
12-May-25	210	132	139	4.0	0.8	486
13-May-25	214	140	136	3.7	0.6	495
14-May-25	219	144	137	3.1	0.7	504
15-May-25	220	137	129	3.7	0.6	490
16-May-25	218	144	126	3.7	0.7	492
17-May-25	217	147	108	3.9	0.7	477
18-May-25	216	144	121	3.7	0.5	486
19-May-25	216	146	96	3.2	0.8	462
20-May-25	215	136	107	4.1	0.5	462
21-May-25	220	133	105	3.6	0.5	462
22-May-25	214	137	120	3.1	0.7	474
23-May-25	220	138	129	2.6	1.0	491
24-May-25	213	129	102	3.1	0.9	448
25-May-25	140	118	89	2.8	0.9	350
26-May-25	188	126	78	3.2	0.7	395
27-May-25	190	111	90	2.8	1.1	394
28-May-25	170	120	103	3.0	1.1	397
29-May-25	184	129	99	3.0	0.4	415
30-May-25	172	132	97	3.1	0.2	405
31-May-25	171	134	125	3.1	0.5	433
कुल TOTAL	6143	4153	3784	111	24	14216
उच्चतम MAXIMUM	220	155	151	4.7	1.2	504
निम्नतम MINIMUM	140	111	78	2.6	0.2	350
औसत AVERAGE	198	134	122	3.6	0.8	459
संचयी 2025-26 Cumulative 2025-26	12425	8557	7902	219	51.7	29154
अब तक का उच्चतम All Time Max.	228	160	156	5.7	3.5	534
दिनांक Date	22.04.25	24.04.25	06.03.25	18.03.25	08.09.24	23.04.25

∗**Source**: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

9. राष्ट्रीय स्तर पर दैनिक अधिकतम विद्युत मांग पूर्ति
DAILY MAXIMUM DEMAND MET AT NATIONAL LEVEL

माह: मई 2025 MONTH:- MAY 2025

सभी आंकड़े मेगावाट मे All figures in MW


दिनांक Date	ऊत्तरी क्षे. NR	पश्चिमी क्षे. WR	दक्षिणी क्षे. SR	पूर्वी क्षे. ER	पूर्वोत्तर क्षे. NER	कुल TOTAL	विभिन्नता फ़ैक्टर Diversity Factor*
01-May-25	68969	72275	54485	24317	2616	215096	1.035
02-May-25	64381	76526	59186	26545	2946	213636	1.075
03-May-25	63903	72349	57363	25861	3078	214714	1.037
04-May-25	61474	68040	49700	26056	3155	202747	1.028
05-May-25	58042	69749	56831	27131	3276	208328	1.032
06-May-25	62761	61146	57924	27849	3108	202394	1.051
07-May-25	62407	58435	57593	28223	3262	202213	1.038
08-May-25	63451	62162	57115	30579	3362	208590	1.039
09-May-25	64559	62927	59102	31347	3527	212517	1.042
10-May-25	65717	63943	59142	31977	3073	216414	1.034
11-May-25	63240	63370	54172	31715	2556	212447	1.012
12-May-25	68333	66211	61911	30945	3134	223579	1.031
13-May-25	69315	66106	60740	30844	3039	226127	1.017
14-May-25	72589	68030	60023	31898	3148	230007	1.025
15-May-25	73081	68699	57708	31636	3115	230993	1.014
16-May-25	75681	69043	55690	30106	3067	228757	1.021
17-May-25	77090	68776	52487	29384	3011	223508	1.032
18-May-25	78486	65065	45505	26570	2729	215854	1.012
19-May-25	80176	68594	49243	28270	3026	223891	1.024
20-May-25	82978	69655	47720	28583	2974	226936	1.022
21-May-25	81724	65426	47702	28279	3200	220795	1.025
22-May-25	73628	65973	48432	29046	3284	215308	1.023
23-May-25	79111	65190	47716	28650	3574	220359	1.018
24-May-25	78130	64060	45015	28641	3583	215361	1.019
25-May-25	70889	61698	40756	28809	3260	200719	1.023
26-May-25	77745	63482	44708	28330	3464	212993	1.022
27-May-25	79187	62652	45625	28912	3617	213435	1.031
28-May-25	79125	61536	45904	28335	3424	213192	1.024
29-May-25	78931	62457	45976	27496	2910	212469	1.025
30-May-25	77574	61824	47316	29556	2045	212060	1.029
31-May-25	75309	62919	47965	29877	2762	213922	1.023
उच्चतम MAXIMUM	82978	76526	61911	31977	3617	230993	1.075
निम्नतम MINIMUM	58042	58435	40756	24317	2045	200719	1.012
औसत AVERAGE	71871	65752	52283	28896	3107	215786	1.029
अब तक का उच्चतम All Time Max.	91215	80000	69942	32531	3905	250070	
दिनांक Date	19.06.24	08.02.25	21.03.25	10.06.24	19.09.24	30.05.24	


* Diversity factor = (Sum of regional max demands) / All India max demand


नोट : यह आंकड़े एनएलडीसी स्काडा प्रणाली में दर्ज दैनिक अधिकतम मांगपूर्ति दर्शाते हैं ।


Note: The above figures denote daily maximum demand met recorded in NLDC SCADA.

10. DEMAND AND GENERATION PLOTS FOR 15thMAY (MAXIMUM DEMAND MET)




REGIONAL DEMAND MET PLOT FOR 15-MAY-2025
DEMAND MET (GW) -->
90
80
70
60
50
40
30
20
10
0
0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23
TIME -->
NR
WR
SR
ER
NER


ALL INDIA GENERATION PLOT FOR 15-MAY-2025
Thermal, Total (GW) -->
Hydro, Solar, Wind, Gas, Nuclear (GW) -->
250
200
150
100
50
0
70
60
50
40
30
20
10
0
0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23
TIME -->
Thermal
Total
Hydro
Solar
Wind
Gas
Nuclear


ALL INDIA FUEL-WISE GENERATION PATTERNS FOR 15-MAY-2025
Generation (GW) -->
250
200
150
100
50
0
0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23
Time -->
Nuclear
Thermal
Hydro
Gas
Solar
Wind

15 मई 2025 (अधिकतम माँग) की आल इंडिया माँग आपूर्ति

ALL INDIA DEMAND MET FOR 15 MAY 2025 (MAXIMUM DEMAND*)

Time (hrs)	All India Demand (MW)		Time (hrs)	All India Demand (MW)
00:05	217848		**12:05**	222164
00:20	217249		**12:20**	223077
00:35	216291		**12:35**	222891
00:50	215545		**12:50**	222838
01:05	213171		**13:05**	221078
01:20	212622		**13:20**	221421
01:35	211768		**13:35**	220629
01:50	210422		**13:50**	225272
02:05	208153		**14:05**	226494
02:20	207157		**14:20**	227624
02:35	206260		**14:35**	229005
02:50	204991		**14:50**	230535
03:05	204096		**15:05**	229959
03:20	203143		**15:20**	229396
03:35	201993		**15:35**	228460
03:50	200971		**15:50**	227906
04:05	200044		**16:05**	224781
04:20	200232		**16:20**	223224
04:35	200452		**16:35**	221447
04:50	200275		**16:50**	219938
05:05	198428		**17:05**	216399
05:20	199559		**17:20**	214654
05:35	199854		**17:35**	213089
05:50	199682		**17:50**	211019
06:05	198145		**18:05**	206997
06:20	198775		**18:20**	207286
06:35	198094		**18:35**	209537
06:50	197467		**18:50**	212964
07:05	196061		**19:05**	215276
07:20	197032		**19:20**	218697
07:35	196251		**19:35**	220432
07:50	196393		**19:50**	221685
08:05	196566		**20:05**	220341
08:20	199564		**20:20**	220237
08:35	201019		**20:35**	220565
08:50	203606		**20:50**	220427
09:05	206448		**21:05**	219726
09:20	210795		**21:20**	219641
09:35	212895		**21:35**	220664
09:50	215048		**21:50**	221680
10:05	215009		**22:05**	222151
10:20	216828		**22:20**	223286
10:35	217368		**22:35**	222979
10:50	217644		**22:50**	222402
11:05	217958		**23:05**	222880
11:20	219818		**23:20**	222118
11:35	220930		**23:35**	220529
11:50	222852		**23:50**	219513
Maximum Demand of 230993MW met@ 14:59 hrs (from 1 min. interval SCADA DATA)				

* 15 minute interval SCADA DATA of instanteneous demand

11. ACTUAL POWER SUPPLY POSITION - MAY 2025

REGION	STATE	Energy Requirement & Met (MU/Day)			Energy Requirement & Met (MU)				Peak Demand/Peak Met in MW			
		Requirement	Energy met	Surplus(+)/ Deficit(-)	Requirement	Energy met	Surplus(+)/ Deficit(-)	% Shortage	Requirement	Peak Demand Met	Surplus(+)/ Deficit(-)	% Shortage
NR	Chandigarh	6	6	0.0	191	191	0	0.0	431	431	0	0.0
	Delhi	123	123	0.0	3814	3814	0	0.0	7748	7748	0	0.0
	Haryana	201	200	-0.4	6227	6214	-14	-0.2	12526	12526	0	0.0
	Himachal Pradesh	36	36	0.0	1124	1124	0	0.0	1866	1866	0	0.0
	J&K(UT) and Ladakh(UT)	50	50	0.0	1557	1556	-1	0.0	2797	2797	0	0.0
	Punjab	215	215	0.0	6651	6651	0	0.0	13969	13969	0	0.0
	Rajasthan	309	309	0.0	9588	9588	0	0.0	17336	17336	0	0.0
	Uttar Pradesh	515	515	0.0	15964	15964	0	0.0	29873	29873	0	0.0
	Uttarakhand	50	50	0.0	1551	1551	0	0.0	2668	2668	0	0.0
	Railway_NR ISTS	4	4	0.0	132	132	0	0.0	232	232	0	0.0
	NFL	0	0	0.0	2	2	0	0.0	5	5	0	0.0
	TOTAL	1510	1509	-0.5	46803	46789	-14	0.0	82387	81787	-600	-0.7
WR	Gujarat	458	458	0.0	14192	14192	0	0.0	25699	25681	-18	-0.1
	Madhya Pradesh	274	274	-0.1	8499	8497	-2	0.0	13844	13844	0	0.0
	Chhattisgarh	116	116	0.0	3588	3588	0	0.0	5720	5720	0	0.0
	Maharashtra	570	570	0.0	17683	17682	-1	0.0	29124	29124	0	0.0
	Goa	16	16	0.0	501	501	-1	-0.2	864	864	0	0.0
	DNHDDPDCL	31	31	0.0	947	947	0	0.0	1384	1384	0	0.0
	AMNSIL	18	18	0.0	571	571	0	0.0	915	915	0	0.0
	BALCO	13	13	0.0	395	395	0	0.0	537	537	0	0.0
	RIL JAMNAGAR*	3	3	0.0	86	86	0	0.0	200	200	0	0.0
	TOTAL	1499	1499	-0.1	46462	46458	-5	0.0	76126	76126	0	0.0
SR	Andhra Pradesh	214	214	0.0	6636	6636	0	0.0	12600	12600	0	0.0
	Telangana	200	200	0.0	6193	6193	0	0.0	10803	10803	0	0.0
	Karnataka	238	238	0.0	7377	7377	0	0.0	15952	15952	0	0.0
	Kerala	89	89	0.0	2766	2766	0	0.0	5194	5194	0	0.0
	Tamil Nadu	366	366	0.0	11332	11332	0	0.0	19416	19416	0	0.0
	Puducherry	10	10	0.0	317	317	0	0.0	545	545	0	0.0
	TOTAL	1117	1117	0.0	34621	34621	0	0.0	61899	61899	0	0.0
ER	Bihar	142	142	-0.1	4416	4414	-2	0.0	7736	7736	0	0.0
	Jharkhand	44	44	0.0	1349	1349	0	0.0	2230	2230	0	0.0
	DVC	70	70	0.0	2177	2177	0	0.0	3462	3462	0	0.0
	Odisha	133	133	0.0	4113	4112	0	0.0	6882	6882	0	0.0
	West Bengal	223	223	0.0	6922	6922	0	0.0	12781	12781	0	0.0
	Sikkim	1	1	0.0	40	40	0	0.0	109	109	0	0.0
	Railways_ER ISTS	0	0	0.0	7	7	0	0.0	31	31	0	0.0
	TOTAL	614	614	-0.1	19023	19021	-2	0.0	32069	31985	-84	-0.3
NER	Arunachal Pradesh	3	3	0.0	97	97	0	0.0	184	184	0	0.0
	Assam	37	37	0.0	1136	1136	0	0.0	2336	2336	0	0.0
	Manipur	3	3	0.0	97	97	0	0.0	248	248	0	0.0
	Meghalaya	5	5	0.0	168	168	0	0.0	339	339	0	0.0
	Mizoram	2	2	0.0	60	60	0	0.0	138	138	0	0.0
	Nagaland	3	3	0.0	82	82	0	0.0	187	187	0	0.0
	Tripura	5	5	0.0	169	169	0	0.0	347	347	0	0.0
	TOTAL	58	58	0.0	1809	1809	0	0.0	3606	3606	0	0.0
ALL INDIA		4797	4797	-0.7	148718	148698	-21	0.0				

* RIL Jamnagar has been added as new entity wef 01.12.2024

NOTE: BASED ON THE DATA FURNISHED BY ENTITIES ON DAILY BASIS

12. ENERGY COMPARISON OF MAY 2025 vs MAY 2024

REGION	STATE	Energy Requirement (MU)					Energy Met (MU)				
		May-24	May-25	Difference	% Change	Average MU/day for Oct-24	May-24	May-25	Difference	% Change	Average MU/day for Oct-24
NR	Chandigarh	210	191	-18	-9	6	210	191	-18	-9	6
	Delhi	4208	3814	-394	-9	123	4208	3814	-394	-9	123
	Haryana	6839	6227	-612	-9	201	6839	6214	-625	-9	200
	Himachal Pradesh	1077	1124	47	4	36	1073	1124	51	5	36
	J&K(UT) and Ladakh(UT)	1647	1557	-90	-5	50	1641	1556	-85	-5	50
	Punjab	7239	6651	-588	-8	215	7239	6651	-588	-8	215
	Rajasthan	10357	9588	-769	-7	309	10280	9588	-692	-7	309
	Uttar Pradesh	17457	15964	-1493	-9	515	17457	15964	-1493	-9	515
	Uttarakhand	1669	1551	-119	-7	50	1668	1551	-117	-7	50
	Railway_NR ISTS/NFL	133	135	1	1	4	133	135	1	1	4
	TOTAL	50836	46803	-4034	-8	1510	50747	46789	-3959	-8	1509
WR	Gujarat	14990	14192	-798	-5	458	14990	14192	-798	-5	458
	Madhya Pradesh	9053	8499	-553	-6	274	9049	8497	-552	-6	274
	Chhattisgarh	3679	3588	-91	-2	116	3679	3588	-91	-2	116
	Maharashtra	18846	17683	-1163	-6	570	18845	17682	-1164	-6	570
	Goa	506	501	-5	-1	16	506	501	-6	-1	16
	DNHDDPDCL	922	947	24	3	31	922	947	24	3	31
	AMNSIL	563	571	7	1	18	563	571	7	1	18
	BALCO	387	395	8	2	13	387	395	8	2	13
	RIL JAMNAGAR*	-	86	-	-	-	-	86	-	-	-
	TOTAL	48947	46462	-2484	-5	1499	48943	46458	-2485	-5	1499
SR	Andhra Pradesh	7072	6636	-436	-6	214	7072	6636	-436	-6	214
	Telangana	6218	6193	-24	0	200	6218	6193	-24	0	200
	Karnataka	7892	7377	-515	-7	238	7892	7377	-515	-7	238
	Kerala	2846	2766	-80	-3	89	2846	2766	-80	-3	89
	Tamil Nadu	11838	11332	-506	-4	366	11838	11332	-506	-4	366
	Puducherry	333	317	-16	-5	10	333	317	-16	-5	10
	TOTAL	36198	34621	-1577	-4	1117	36198	34621	-1577	-4	1117
ER	Bihar	4201	4416	214	5	142	4179	4414	235	6	142
	Jharkhand	1402	1349	-53	-4	44	1394	1349	-45	-3	44
	DVC	2310	2177	-133	-6	70	2310	2177	-133	-6	70
	Odisha	4099	4113	14	0	133	4099	4112	14	0	133
	West Bengal	6680	6922	242	4	223	6680	6922	242	4	223
	Sikkim	46	40	-6	-13	1	46	40	-6	-13	1
	Railways_ER ISTS	4	7	3	58	0	4	7	3	58	0
	TOTAL	18743	19023	280	1	614	18712	19021	309	2	614
NER	Arunachal Pradesh	86	97	11	13	3	86	97	11	13	3
	Assam	1123	1136	13	1	37	1118	1136	18	2	37
	Manipur	86	97	11	13	3	86	97	11	13	3
	Meghalaya	160	168	8	5	5	160	168	8	5	5
	Mizoram	57	60	3	5	2	57	60	3	5	2
	Nagaland	80	82	2	3	3	80	82	2	3	3
	Tripura	164	169	5	3	5	164	169	5	3	5
	TOTAL	1756	1809	53	3	58	1751	1809	58	3	58
ALL INDIA		156480	148718	-7762	-5	4797	156352	148698	-7654	-5	4797

* RIL Jamnagar has been added as new entity wef 01.12.2024

13. DEMAND COMPARISON OF MAY 2025 vs MAY 2024

REGION	STATE	Peak Requirement (MW)				Peak Met (MW)			
		May-24	May-25	Difference	% Change	May-24	May-25	Difference	% Change
NR	Chandigarh	432	431	-1	-0.2	432	431	-1	-0.2
	Delhi	8302	7748	-554	-6.7	8302	7748	-554	-6.7
	Haryana	12451	12526	75	0.6	12451	12526	75	0.6
	Himachal Pradesh	1827	1866	39	2.1	1827	1866	39	2.1
	J&K(UT) and Ladakh(UT)	2878	2797	-81	-2.8	2878	2797	-81	-2.8
	Punjab	14519	13969	-550	-3.8	14519	13969	-550	-3.8
	Rajasthan	17567	17336	-231	-1.3	17567	17336	-231	-1.3
	Uttar Pradesh	29727	29873	146	0.5	29727	29873	146	0.5
	Uttarakhand	2781	2668	-113	-4.1	2781	2668	-113	-4.1
	Railway_NR ISTS/NFL	239	237	-2	-0.9	239	237	-2	-0.9
WR	Gujarat	24922	25699	777	3	24922	25681	759	3.0
	Madhya Pradesh	14309	13844	-465	-3	14309	13844	-465	-3.2
	Chhattisgarh	6073	5720	-353	-6	6073	5720	-353	-5.8
	Maharashtra	28452	29124	672	2	28452	29124	672	2.4
	Goa	803	864	61	8	803	864	61	7.6
	DNHDDPDCL	1348	1384	36	2.7	1348	1384	36	2.7
	AMNSIL	911	915	4	0.4	911	915	4	0.4
	BALCO	525	537	12	2.3	525	537	12	2.3
	RIL JAMNAGAR*	-	200	-	-	-	200	-	-
SR	Andhra Pradesh	13712	12600	-1112	-8.1	13712	12600	-1112	-8.1
	Telangana	11277	10803	-474	-4.2	11257	10803	-454	-4.0
	Karnataka	16826	15952	-873	-5.2	16826	15952	-873	-5.2
	Kerala	5797	5194	-603	-10.4	5797	5194	-603	-10.4
	Tamil Nadu	20830	19416	-1414	-6.8	20830	19416	-1414	-6.8
	Puducherry	517	545	28	5.4	517	545	28	5.4
ER	Bihar	7546	7736	190	2.5	7546	7736	190	2.5
	Jharkhand	2346	2230	-116	-4.9	2346	2230	-116	-4.9
	DVC	3562	3462	-100	-2.8	3562	3462	-100	-2.8
	Odisha	6988	6882	-106	-1.5	6988	6882	-106	-1.5
	West Bengal	12670	12781	111	0.9	12670	12781	111	0.9
	Sikkim	102	109	7	6.9	102	109	7	6.9
	Railways_ER ISTS	23	31	8	34.8	23	31	8	34.8
NER	Arunachal Pradesh	198	184	-14	-7.1	198	184	-14	-7.1
	Assam	2404	2336	-68	-2.8	2404	2336	-68	-2.8
	Manipur	227	248	21	9.3	227	248	21	9.3
	Meghalaya	394	339	-55	-14.0	394	339	-55	-14.0
	Mizoram	130	138	8	6.2	130	138	8	6.2
	Nagaland	177	187	10	5.6	177	187	10	5.6
	Tripura	386	347	-39	-10.1	386	347	-39	-10.1

* RIL Jamnagar has been added as new entity wef 01.12.2024

14. SCHEDULE AND DRAWAL OF CONSTITUENTS - MAY 2025

REGION	STATE	SCHEDULE (MU)	ACTUAL DRAWAL (MU)	Over drawal(+)/ Under Drawal(-) (MU)	% OD/UD	SCHEDULE (MU/DAY)	ACTUAL DRAWAL (MU/DAY)	Over drawal(+)/ Under Drawal(-) (MU/DAY)
NR	Chandigarh	194.28	193.28	-1.00	-0.51	6.27	6.23	-0.03
	Delhi	3530.46	3492.13	-38.33	-1.09	113.89	112.65	-1.24
	Haryana	4660.75	4535.46	-125.29	-2.69	150.35	146.31	-4.04
	Himachal Pradesh	223.88	193.92	-29.96	-13.38	7.22	6.26	-0.97
	J&K(UT) and Ladakh(UT)	983.09	905.65	-77.44	-7.88	31.71	29.21	-2.50
	Punjab	3586.84	3440.31	-146.53	-4.09	115.70	110.98	-4.73
	Rajasthan	3576.39	3490.73	-85.66	-2.40	115.37	112.60	-2.76
	Uttar Pradesh	6622.48	6558.58	-63.90	-0.96	213.63	211.57	-2.06
	Uttarakhand	928.85	943.76	14.91	1.61	29.96	30.44	0.48
	Railways_NR ISTS	121.35	132.33	10.98	9.05	3.91	4.27	0.35
	NFL	2.64	2.47	-0.16	-6.25	0.09	0.08	-0.01
	Total	24431.01	23888.64	-542.37	-2.22	788.10	770.60	-17.50
WR	Gujarat	5166.42	4981.65	-184.77	-3.58	166.66	160.70	-5.96
	Madhya Pradesh	5084.41	5003.57	-80.84	-1.59	164.01	161.41	-2.61
	Chhattisgarh	1868.98	1861.72	-7.26	-0.39	60.29	60.06	-0.23
	Maharashtra	5971.20	5938.14	-33.06	-0.55	192.62	191.55	-1.07
	Goa	474.38	495.40	21.02	4.43	15.30	15.98	0.68
	DNHDDPDCL	949.32	946.73	-2.59	-0.27	30.62	30.54	-0.08
	AMNSIL	257.73	265.67	7.94	3.08	8.31	8.57	0.26
	BALCO	393.80	394.96	1.16	0.29	12.70	12.74	0.04
	RIL JAMNAGAR*	86.79	86.15	-0.64	-0.74	2.80	2.78	-0.02
	Total	20253.03	19973.98	-279.05	-1.38	653.32	644.32	-9.00
SR	Andhra Pradesh	1983.74	1957.04	-26.70	-1.35	63.99	63.13	-0.86
	Telangana	2580.44	2606.35	25.91	1.00	83.24	84.08	0.84
	Karnataka	2445.04	2409.59	-35.45	-1.45	78.87	77.73	-1.14
	Kerala	1910.26	1902.67	-7.59	-0.40	61.62	61.38	-0.24
	Tamil Nadu	6400.80	6310.81	-89.99	-1.41	206.48	203.57	-2.90
	Puducherry	323.21	315.28	-7.93	-2.45	10.43	10.17	-0.26
	Goa (SR)	73.36	71.99	-1.37	-1.87	2.37	2.32	-0.04
	Total	15716.85	15573.73	-143.12	-0.91	507.00	502.38	-4.62
ER	Bihar	4169.92	4119.81	-50.10	-1.20	134.51	132.90	-1.62
	Jharkhand	1120.85	1103.28	-17.57	-1.57	36.16	35.59	-0.57
	DVC	-911.94	-901.68	10.25	-1.12	-29.42	-29.09	0.33
	Odisha	1646.06	1637.91	-8.15	-0.49	53.10	52.84	-0.26
	West Bengal	2827.08	2744.31	-82.78	-2.93	91.20	88.53	-2.67
	Sikkim	41.66	39.53	-2.13	-5.12	1.34	1.28	-0.07
	Railways_ER ISTS	6.34	6.88	0.55	8.64	0.20	0.22	0.02
	Total	8899.98	8750.04	-149.93	-1.68	287.10	282.26	-4.84
NER	Arunachal Pradesh	92.13	91.81	-0.32	-0.35	2.97	2.96	-0.01
	Assam	871.28	881.66	10.38	1.19	28.11	28.44	0.33
	Manipur	97.40	96.90	-0.50	-0.51	3.14	3.13	-0.02
	Meghalaya	47.19	46.29	-0.90	-1.91	1.52	1.49	-0.03
	Mizoram	56.47	48.78	-7.69	-13.62	1.82	1.57	-0.25
	Nagaland	82.02	78.92	-3.10	-3.78	2.65	2.55	-0.10
	Tripura	139.08	141.32	2.24	1.61	4.49	4.56	0.07
	Total	1385.57	1385.68	0.11	0.01	44.70	44.70	0.00
All India Total		70686.44	69572.07	-1114.36	-1.58	2280.21	2244.26	-35.95

* RIL Jamnagar has been added as new entity wef 01.12.2024

15. INTER REGIONAL EXCHANGES 2025-26

(All figures in MU)

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Import of NR from WR (WR-NR)			
WR - NR HVDC Champa- Kurukshetra	1382.87	2023.40	**3406.27**
WR - NR HVDC Vindhyachal	16.65	119.23	**135.88**
WR - NR HVDC Mundra - M'garh	896.71	1001.79	**1898.50**
WR - NR 765 kV Gwalior - Agra 2xS/C	375.96	961.14	**1337.10**
WR - NR 765 kV Gwalior-Phagi 2xS/C	119.97	290.73	**410.70**
WR - NR 765 kV Jabalpur- Orai D/C	317.58	813.58	**1131.16**
WR - NR 765 kV Satna- Orai	506.38	537.61	**1043.99**
WR - NR 765 kV Gwalior-Orai	0.00	0.00	**0.00**
WR - NR 765 kV Banaskata - Chittorgarh D/C	17.73	226.09	**243.82**
WR - NR 765 kV Vindhyachal - Varanasi	1245.55	1708.13	**2953.68**
WR - NR 765 kV Neemach - Chittorgarh D/C	0.00	36.24	**36.24**
WR - NR 400 kV Zerda- Kankroli	0.50	20.28	**20.78**
WR - NR 400 kV Zerda- Bhinmal	0.00	70.94	**70.94**
WR - NR 400 kV Shujalpur - RAPP C D/C	0.00	32.33	**32.33**
WR - NR 400 KV Vindhyachal - Rihand D/C	0.00	0.00	**0.00**
WR - NR 220 kV Bhanpura - Ranpur	62.23	62.87	**125.10**
WR - NR 220 kV Bhanpura - Modak	70.83	86.49	**157.32**
WR - NR 220 kV Malanpur / Mehgaon - Auraiya	0.00	1.18	**1.18**
Total WR - NR	**5012.96**	**7992.03**	**13004.99**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Export of NR to WR (NR-WR)			
NR - WR HVDC Kurukshetra - Champa	0.00	0.00	**0.00**
NR - WR HVDC Vindhyachal	43.26	29.26	**72.52**
NR - WR HVDC M'garh - Mundra	0.00	0.00	**0.00**
NR - WR 765 kV Agra - Gwalior 2xS/C	6.16	0.00	**6.16**
NR - WR 765 kV Phagi - Gwalior 2xS/C	11.05	2.35	**13.40**
NR - WR 765 kV Orai - Jabalpur D/C	8.98	0.00	**8.98**
NR - WR 765 kV Orai - Satna	0.00	0.00	**0.00**
NR - WR 765 kV Orai - Gwalior	345.16	292.43	**637.59**
NR - WR 765 kV Chittorgarh - Banaskata D/C	330.62	27.29	**357.91**
NR - WR 765 kV Varanasi - Vindhyachal	0.00	0.00	**0.00**
NR - WR 765 kV Chittorgarh - Neemach D/C	192.85	53.22	**246.07**
NR - WR 400 kV Kankroli - Zerda	180.27	34.58	**214.85**
NR - WR 400 kV Bhinmal - Zerda	0.00	1.60	**1.60**
NR - WR 400 kV RAPP C - Shujalpur D/C	179.68	68.92	**248.60**
NR - WR 400 KV Rihand - Vindhyachal D/C	627.94	529.60	**1157.54**
NR - WR 220 kV Ranpur - Bhanpura	0.00	0.00	**0.00**
NR - WR 220 kV Modak - Bhanpura	0.00	0.00	**0.00**
NR - WR 220 kV Auraiya - Malanpur/Mehgaon	66.11	28.64	**94.75**
Total NR - WR	**1992.08**	**1067.89**	**3059.97**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Import of NR from ER (ER-NR)			
ER - NR HVDC Alipurduar - Agra	0.43	0.00	**0.43**
ER - NR 765 kV Sasaram - Fatehpur	77.99	33.39	**111.38**
ER - NR 765 kV Gaya - Varanasi 2*S/C	65.04	56.80	**121.84**
ER - NR 765 kV Gaya - Balia	186.58	263.25	**449.83**
ER - NR 400 kV Patna - Balia D/C	193.76	203.41	**397.17**
ER - NR 400 kV Muzaffarpur - Gorakhpur D/C	11.63	113.13	**124.76**
ER - NR 400 kV Biharshariff - Balia D/C	0.00	12.52	**12.52**
ER - NR 400 kV Motihari - Gorakhpur D/C	62.83	123.33	**186.16**
ER - NR 400 kV Biharshariff - Varanasi D/C	0.00	0.00	**0.00**
ER - NR 400 kV Sasaram - Varanasi	60.82	64.18	**125.00**
ER - NR 400 kV Sasaram - Allahabad	10.62	8.32	**18.94**
ER - NR 400 kV Naubatpur - Balia D/C	45.33	47.32	**92.65**
ER - NR 400 kV Biharshriff - Sahupuri D/C	25.32	33.43	**58.75**
ER - NR 220 kV Sahupuri - Karamnasa	5.66	46.35	**52.01**
ER - NR 132 kV Sahupuri - Karamnasa	0.96	0.48	**1.44**
ER - NR 132 kV Nagar Untari - Rihand	0.05	0.00	**0.05**
ER - NR 132 kV Garhwa - Rihand	0.00	0.00	**0.00**
Total ER-NR	**747.02**	**1005.91**	**1752.93**
Import of NR from NER (NER-NR)			
NER - NR HVDC Biswanath Chariali - Agra	0.00	22.96	**22.96**
Total NER - NR	**0.00**	**22.96**	**22.96**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Export of NR to ER (NR-ER)			
NR - ER HVDC Agra - Alipurduar	0.00	0.00	**0.00**
NR - ER 765 kV Fatehpur - Sasaram	6.26	34.48	**40.74**
NR - ER 765 kV Varanasi - Gaya 2*S/C	56.47	106.17	**162.64**
NR - ER 765 kV Balia - Gaya	0.00	0.00	**0.00**
NR - ER 400 kV Balia - Patna D/C	1.06	0.00	**1.06**
NR - ER 400 kV Gorakhpur - Muzaffarpur D/C	99.75	29.83	**129.58**
NR - ER 400 kV Balia - Biharshariff D/C	162.65	104.51	**267.16**
NR - ER 400 kV Gorakhpur - Motihari D/C	4.85	0.05	**4.90**
NR - ER 400 kV Varanasi - Biharshariff D/C	0.00	0.00	**0.00**
NR - ER 400 kV Varanasi - Sasaram	0.00	0.00	**0.00**
NR - ER 400 kV Allahabad - Sasaram	2.99	6.52	**9.51**
NR - ER 400 kV Balia - Naubatpur D/C	1.90	4.36	**6.26**
NR - ER 400 kV Sahupuri - Biharshriff D/C	25.78	30.77	**56.55**
NR - ER 220 kV Karamnasa - Sahupuri	7.75	1.36	**9.11**
NR - ER 132 kV Karamnasa - Sahupuri	0.20	0.39	**0.59**
NR - ER 132 kV Rihand - Nagar Untari	0.98	0.10	**1.08**
NR - ER 132 kV Rihand - Garhwa	14.20	15.51	**29.71**
Total NR - ER	**384.84**	**334.05**	**718.89**
Export of NR to NER (NER-NR)			
NR - NER HVDC Agra - Biswanath Chariali	587.35	339.01	**926.36**
Total NR - NER	**587.35**	**339.01**	**926.36**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Export of WR to ER (WR-ER)			
WR - ER 765 kV Dharamjaygarh - Ranchi 2xS/C	361.32	847.34	**1208.67**
WR - ER 765 kV Dharamjaygarh - Jharsuguda Q/C	302.38	152.33	**454.71**
WR - ER 765 kV Durg - Jharsuguda D/C	0.00	8.48	**8.48**
WR - ER 400 kV Sipat - Ranchi D/C	44.41	165.08	**209.49**
WR - ER 400 kV Raigarh - Jharsuguda- 2xD/C	0.04	36.04	**36.07**
WR - ER 220 kV Korba - Budhipadar D/C	12.35	33.58	**45.94**
WR - ER 220 kV Raigarh - Budhipadar	0.10	11.59	**11.69**
Total WR - ER	**720.61**	**1254.44**	**1975.05**
Import of WR from ER (ER - WR)			
ER - WR 765 kV Dharamjaygarh - Ranchi 2xS/C	79.61	7.39	**87.00**
ER - WR 765 kV Dharamjaygarh - Jharsuguda D/C	160.09	253.52	**413.61**
ER - WR 765 kV Durg - Jharsuguda D/C	503.09	232.42	**735.51**
ER - WR 400 kV Sipat - Ranchi D/C	55.76	5.53	**61.30**
ER - WR 400 kV Raigarh - Jharsuguda- 2xD/C	325.72	102.70	**428.42**
ER - WR 220 kV Korba - Budhipadar D/C	25.22	2.91	**28.14**
ER - WR 220 kV Raigarh - Budhipadar	50.11	13.49	**63.60**
Total ER - WR	**1199.60**	**617.96**	**1817.56**
Export of ER to NER (ER - NER)			
ER - NER 400 kV Binaguri - Bongaigaon D/C	23.81	14.14	**37.94**
ER - NER 400 kV Alipurduar - Bongaigaon D/C	28.02	45.27	**73.29**
ER - NER 220 kV Birpara - Salakati D/C	3.15	4.51	**7.66**
Total ER - NER	**54.98**	**63.92**	**118.90**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Import of ER from NER (NER - ER)			
NER - ER 400 kV Binaguri - Bongaigaon D/C	86.91	101.88	**188.80**
NER - ER 400 kV Alipurduar - Bongaigaon 2xD/C	133.68	82.82	**216.50**
NER - ER 220 kV Birpara - Salakati D/C	30.05	24.26	**54.31**
Total NER - ER	**250.64**	**208.96**	**459.60**
Export of ER to SR (ER - SR)			
ER - SR HVDC Gazuwaka	64.45	47.26	**111.71**
ER - SR HVDC Talchar -Kolar	1338.63	1181.86	**2520.49**
ER - SR 765 kV Angul- Srikakulam D/C	1591.65	1274.48	**2866.13**
Total ER - SR	**2994.74**	**2503.60**	**5498.34**
Import of ER from SR (SR - ER)			
SR - ER HVDC Gazuwaka	44.04	138.20	**182.24**
SR - ER HVDC Talchar - Kolar	0.00	0.00	**0.00**
SR - ER 765 kV Angul- Srikakulam D/C	0.00	0.00	**0.00**
Total SR - ER	**44.04**	**138.20**	**182.24**
Export of WR to SR (WR-SR)			
WR - SR HVDC Bhadrawati	644.61	220.50	**865.11**
WR - SR 765 kV Sholapur - Raichur 2xS/C	206.88	115.39	**322.27**
WR - SR 765 kV Wardha - Nizamabad D/C	983.94	603.84	**1587.77**
WR - SR 400KV Kolhapur-Kudgi D/C	0.02	0.00	**0.02**
WR - SR HVDC Raigarh-Pugalur	2564.04	1621.30	**4185.34**
WR - SR 220kV Xeldem - Ambewadi S/C	71.04	74.18	**145.22**
WR - SR 220kV Ponda - Ambewadi S/C	0.79	0.09	**0.88**
WR - SR 765 kV Warora - Warangal D/C	1140.34	750.16	**1890.50**
Total WR - SR	**5611.68**	**3385.46**	**8997.13**

	Apr'25	May'25	Fin. Year 2025-26
Name of Line			
Import of WR from SR (SR - WR)			
SR - WR HVDC Bhadrawati	0.00	206.01	**206.01**
SR - WR 765 kV Raichur - Sholapur 2xS/C	134.40	376.02	**510.41**
SR - WR 765 kV Wardha - Nizamabad D/C	0.24	25.72	**25.96**
SR - WR 400KV Kolhapur-Kudgi D/C	657.02	869.48	**1526.50**
SR - WR HVDC Pugalur-Raigarh	0.00	0.00	**0.00**
SR - WR 220kV Xeldem - Ambewadi S/C	0.00	0.00	**0.00**
SR - WR 220kV Ponda - Ambewadi S/C	0.01	0.01	**0.02**
SR - WR 765 kV Warangal - Warora D/C	0.02	17.52	**17.54**
Total SR - WR	**791.68**	**1494.76**	**2286.44**
TOTAL ALL INDIA	**20392**	**20429**	**40821**

***In case of mutiple ckt / DC pole year corres. to the commissioning of final element**

Date	15.1 Import-Export of NR with WR during May 2025																		
	Import of NR from WR (WR-NR)																		
	WR - NR HVDC Champa-Kurukshetra	WR - NR HVDC Vindhyachal	WR - NR HVDC Mundra - M'garh	WR - NR 765 kV Gwalior - Agra 2xS/C	WR - NR 765 kV Gwalior-Phagi 2xS/C	WR - NR 765 kV Jabalpur-Orai D/C	WR - NR 765 kV Satna-Orai	WR - NR 765 kV Gwalior-Orai	WR - NR 765 kV Banaskata - Chittorgarh D/C	WR - NR 765 kV Vindhyachal - Varanasi	WR - NR 765 kV Neemach - Chittorgarh D/C	WR - NR 400 kV Zerda-Kankroli	WR - NR 400 kV Zerda-Bhinmal	WR - NR 400 kV Shujalpur - RAPP C D/C	WR - NR 400 KV Vindhyachal - Rihand D/C	WR - NR 220 kV Bhanpura - Ranpur	WR - NR 220 kV Bhanpura - Modak	WR - NR 220 kV Malanpur / Mehgaon - Auraiya	Total WR - NR
1-May-25	69.00	0.11	35.79	25.00	12.09	23.71	18.30	0.00	11.35	44.50	0.00	0.05		0.00	0.00	2.10	1.36	0.00	**243.36**
2-May-25	26.20	2.42	25.41	13.00	9.71	11.71	14.91	0.00	4.03	35.79	0.00	0.00		0.00	0.00	2.11	1.92	0.00	**147.21**
3-May-25	22.97	2.42	24.25	25.04	14.18	23.08	17.94	0.00	8.00	40.20	0.00	0.00		0.00	0.00	2.01	2.98	0.00	**183.07**
4-May-25	32.60	2.42	27.61	29.20	12.21	26.30	17.50	0.00	8.06	47.60	0.00	0.00		0.00	0.00	2.01	3.03	0.00	**208.54**
5-May-25	46.32	2.42	36.31	21.20	11.90	17.27	17.39	0.00	0.00	45.00	0.00	0.00		0.00	0.00	1.67	2.13	0.00	**201.61**
6-May-25	48.15	2.40	36.30	24.75	9.41	16.83	17.36	0.00	0.00	44.85	0.00	0.00		0.00	0.00	1.58	2.04	0.00	**203.67**
7-May-25	46.72	2.42	31.47	28.95	6.12	22.26	16.78	0.00	0.00	49.20	0.00	0.00	1.11	0.00	0.00	1.56	2.58	0.00	**209.17**
8-May-25	58.80	2.40	29.05	21.90	2.86	16.10	15.88	0.00	1.00	52.60	0.00	0.00	0.70	0.00	0.00	1.63	2.48	0.00	**205.40**
9-May-25	46.70	2.42	29.07	24.30	5.14	18.05	15.99	0.00	0.78	50.00	0.00	0.00	0.40	0.00	0.00	1.57	2.25	0.00	**196.67**
10-May-25	57.90	2.40	29.07	22.90	3.21	18.03	15.98	0.00	3.71	53.50	0.00	0.00	0.00	0.00	0.00	1.74	2.63	0.00	**211.07**
11-May-25	53.80	2.39	20.01	22.63	1.57	17.73	15.45	0.00	4.59	55.23	0.00	0.00	1.20	0.00	0.00	1.72	2.61	0.00	**198.93**
12-May-25	58.03	2.42	19.74	21.45	0.29	19.54	15.40	0.00	4.00	62.43	0.00	0.00	1.53	0.00	0.00	1.71	2.72	0.00	**209.26**
13-May-25	74.00	2.39	36.28	25.08	0.00	18.52	14.89	0.00	0.85	58.00	0.00	0.00	2.30	0.00	0.00	1.82	2.90	0.00	**237.03**
14-May-25	86.91	2.39	36.28	29.30	1.68	22.55	16.21	0.00	1.64	68.84	0.00	0.00	2.75	0.00	0.00	1.96	2.82	0.00	**273.33**
15-May-25	92.77	6.51	36.28	29.62	3.53	23.00	16.87	0.00	1.13	64.01	0.00	0.00	2.85	0.00	0.00	2.00	2.96	0.00	**281.53**
16-May-25	92.03	8.50	36.28	26.85	3.22	19.92	16.45	0.00	4.67	60.73	0.00	0.00	3.10	0.00	0.00	2.06	3.19	0.00	**277.00**
17-May-25	93.80	5.83	33.50	28.56	9.20	23.30	17.69	0.00	5.56	55.60	0.00	0.00	3.57	0.00	0.00	2.19	3.20	0.00	**282.00**
18-May-25	64.57	11.50	37.19	31.23	14.12	31.73	18.21	0.00	0.00	54.61	0.72	0.00	2.75	0.00	0.00	2.16	2.63	0.00	**271.42**
19-May-25	90.89	12.00	40.00	25.24	10.00	21.50	18.05	0.00	0.00	46.32	0.00	0.00	2.20	0.00	0.00	2.20	3.14	0.00	**271.54**
20-May-25	104.93	10.63	40.58	41.04	15.79	36.41	20.22	0.00	8.76	58.83	2.26	0.35	4.04	1.88	0.00	2.19	3.08	0.00	**350.99**
21-May-25	104.00	5.47	44.52	32.00	12.84	31.68	18.66	0.00	0.00	59.38	1.20	0.00	2.50	0.00	0.00	2.15	3.29	0.00	**317.69**
22-May-25	42.21	0.57	28.16	36.95	17.48	27.19	20.37	0.00	0.00	54.33	1.46	0.00	2.85	1.69	0.00	2.14	3.04	0.00	**238.44**
23-May-25	65.48	2.40	24.23	40.54	13.38	34.71	18.78	0.00	2.03	61.35	1.89	0.00	3.30	1.94	0.00	2.05	2.45	0.00	**274.53**
24-May-25	71.93	2.43	27.20	43.43	10.82	34.44	19.18	0.00	16.41	65.09	2.01	1.67	5.45	2.28	0.00	2.38	2.81	0.00	**307.53**
25-May-25	24.60	0.15	24.52	22.70	8.98	22.40	13.20	0.00	3.15	59.98	0.00	0.23	4.26	0.00	0.00	2.25	3.03	0.00	**189.45**
26-May-25	55.15	0.00	25.80	41.80	12.31	34.56	17.42	0.00	14.88	60.19	2.52	5.06	2.30	2.11	0.00	2.34	3.29	0.00	**279.73**
27-May-25	74.25	0.00	36.41	42.54	18.08	40.25	19.65	0.00	20.25	60.48	5.10	2.85	5.85	4.44	0.00	2.37	3.25	0.39	**336.16**
28-May-25	89.69	1.26	38.01	51.80	18.46	44.61	21.25	0.00	24.29	65.21	7.01	2.28	5.23	6.39		2.55	3.10	0.43	**381.57**
29-May-25	87.11	4.77	43.33	47.28	16.02	41.93	16.36	0.00	17.71	54.38	4.43	1.20	1.98	3.70	0.00	2.29	3.16	0.00	**345.65**
30-May-25	78.62	7.25	36.30	41.15	8.55	37.97	18.13	0.00	28.75	55.65	3.63	2.61	3.51	1.98	0.00	2.22	3.26	0.00	**329.58**
31-May-25	63.27	8.54	32.84	43.71	7.58	36.30	17.14	0.00	30.49	64.25	4.01	3.98	5.21	5.92		2.14	3.16	0.36	**328.90**
Total	**2023.40**	**119.23**	**1001.79**	**961.14**	**290.73**	**813.58**	**537.61**	**0.00**	**226.09**	**1708.13**	**36.24**	**20.28**	**70.94**	**32.33**	**0.00**	**62.87**	**86.49**	**1.18**	**7992.03**

Disclaimer:- Blank entry if the line under outage/shutdown on corrosponding day

Date	15.1 Import-Export of NR with WR during May 2025																		
	Export of NR to WR (NR- WR)																		
	NR - WR HVDC Kurukshetra - Champa	NR - WR HVDC Vindhyachal	NR - WR HVDC M'garh - Mundra	NR - WR 765 kV Agra - Gwalior 2xS/C	NR - WR 765 kV Phagi - Gwalior 2xS/C	NR - WR 765 kV Orai - Jabalpur D/C	NR - WR 765 kV Orai - Satna	NR - WR 765 kV Orai - Gwalior	NR - WR 765 kV Chittorgarh - Banaskata D/C	NR - WR 765 kV Varanasi - Vindhyachal	NR - WR 765 kV Chittorgarh - Neemach D/C	NR - WR 400 kV Kankroli - Zerda	NR - WR 400 kV Bhinmal - Zerda	NR - WR 400 kV RAPP C - Shujalpur D/C	NR - WR 400 KV Rihand - Vindhyachal D/C	NR - WR 220 kV Ranpur - Bhanpura	NR - WR 220 kV Modak - Bhanpura	NR - WR 220 kV Auraiya - Malanpur/Mehgaon	Total NR - WR
1-May-25	0.00	2.33	0.00	0.00	0.00	0.00	0.00	11.30	0.00	0.00	1.91	0.00		2.17	19.74	0.00	0.00	1.35	**38.80**
2-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.77	0.00	0.00	3.80	1.45		4.54	19.51	0.00	0.00	2.20	**42.27**
3-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.60	0.00	0.00	1.00	0.31		0.94	20.75	0.00	0.00	1.09	**34.69**
4-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.79	0.00	0.00	1.71	0.52		0.46	19.63	0.00	0.00	0.38	**32.49**
5-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.70	5.30	0.00	2.54	5.33		3.25	20.78	0.00	0.00	0.98	**47.88**
6-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.68	3.94	0.00	0.68	3.20		2.40	20.14	0.00	0.00	0.98	**40.02**
7-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.63	8.07	0.00	1.95	0.46	0.00	2.62	19.50	0.00	0.00	0.74	**41.97**
8-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.76	0.00	0.00	5.09	1.94	0.00	5.41	20.48	0.00	0.00	1.22	**42.90**
9-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.35	0.00	0.00	3.65	1.70	0.00	4.53	20.92	0.00	0.00	1.18	**41.33**
10-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.40	0.00	0.00	5.22	1.75	1.60	5.71	20.91	0.00	0.00	1.37	**45.96**
11-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.80	0.00	0.00	5.50	2.20	0.00	5.87	20.47	0.00	0.00	1.14	**43.98**
12-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.05	0.00	0.00	6.50	2.45	0.00	6.92	21.96	0.00	0.00	1.34	**47.22**
13-May-25	0.00	0.00	0.00	0.00	2.35	0.00	0.00	7.30	0.00	0.00	3.90	1.90	0.00	6.30	20.93	0.00	0.00	1.90	**44.58**
14-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.78	0.00	0.00	2.47	1.40	0.00	4.27	20.33	0.00	0.00	1.88	**38.13**
15-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.13	0.00	0.00	1.80	1.20	0.00	3.51	20.56	0.00	0.00	2.03	**37.23**
16-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.92	0.00	0.00	2.36	0.64	0.00	3.99	19.68	0.00	0.00	2.04	**36.63**
17-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.88	0.00	0.00	1.15	0.30	0.00	2.28	19.96	0.00	0.00	0.95	**33.52**
18-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.83	1.01	0.00	0.00	1.43	0.00	1.01	19.42	0.00	0.00	0.66	**34.36**
19-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.44	3.77	0.00	1.48	2.00	0.00	2.06	20.28	0.00	0.00	1.54	**41.57**
20-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.97	0.00	0.00	0.00	0.00	0.00	0.00	20.14	0.00	0.00	1.05	**32.16**
21-May-25	0.00	0.94	0.00	0.00	0.00	0.00	0.00	11.50	4.05	0.00	0.00	1.90	0.00	0.13	19.99	0.00	0.00	0.70	**39.21**
22-May-25	0.00	9.18	0.00	0.00	0.00	0.00	0.00	10.40	1.15	0.00	0.00	1.54	0.00	0.00	19.06	0.00	0.00	0.25	**41.58**
23-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.65	0.00	0.00	0.00	0.96	0.00	0.00	19.84	0.00	0.00	0.15	**31.60**
24-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.04	0.00	0.00	0.00	0.00	0.00	0.00	19.73	0.00	0.00	0.10	**29.87**
25-May-25	0.00	2.27	0.00	0.00	0.00	0.00	0.00	10.24	0.00	0.00	0.51	0.00	0.00	0.55	17.85	0.00	0.00	0.90	**32.32**
26-May-25	0.00	2.43	0.00	0.00	0.00	0.00	0.00	9.98	0.00	0.00	0.00	0.00	0.00	0.00	19.32	0.00	0.00	0.20	**31.93**
27-May-25	0.00	4.58	0.00	0.00	0.00	0.00	0.00	9.10	0.00	0.00	0.00	0.00	0.00	0.00	7.72	0.00	0.00	0.00	**21.40**
28-May-25	0.00	7.41	0.00	0.00	0.00	0.00	0.00	9.77	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	**17.18**
29-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.19	**9.05**
30-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13	**8.45**
31-May-25	0.00	0.12	0.00	0.00	0.00	0.00	0.00	7.49	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	**7.61**
Total	**0.00**	**29.26**	**0.00**	**0.00**	**2.35**	**0.00**	**0.00**	**292.43**	**27.29**	**0.00**	**53.22**	**34.58**	**1.60**	**68.92**	**529.60**	**0.00**	**0.00**	**28.64**	**1067.89**

Disclaimer:- Blank entry if the line under outage/shutdown on corrosponding day

15.2 Import-Export of NR with ER & NER during May 2025

Date	Import of NR from ER (ER-NR)																		Import of NR from NER (NER-NR)	
	ER - NR HVDC Alipurduar - Agra	ER - NR 765 kV Sasaram - Fatehpur	ER - NR 765 kV Gaya - Varanasi 2*S/C	ER - NR 765 kV Gaya - Balia	ER - NR 400 kV Patna - Balia D/C	ER - NR 400 kV Muzaffarpur - Gorakhpur D/C	ER - NR 400 kV Biharshariff - Balia D/C	ER - NR 400 kV Motihari - Gorakhpur D/C	ER - NR 400 kV Biharshariff - Varanasi D/C	ER - NR 400 kV Sasaram - Varanasi	ER - NR 400 kV Sasaram - Allahabad	ER - NR 400 kV Naubatpur - Balia D/C	ER - NR 400 kV Biharshriff - Sahupuri D/C	ER - NR 220 kV Sahupuri - Karamnasa	ER - NR 132 kV Sahupuri - Karamnasa	ER - NR 132 kV Nagar Untari - Rihand	ER - NR 132 kV Garhwa - Rihand	Total ER -NR	NER - NR HVDC Biswanath Chariali - Agra	Total NER-NR
1-May-25		4.73	8.29	10.61	11.12	4.87	0.40	4.99		1.00	1.35	3.10	3.70	0.18	0.00			**54.34**	0.00	**0.00**
2-May-25		0.60	4.08	6.98	7.87	1.57	0.00	4.10		2.12	0.25	1.92	1.49	0.48	0.00			**31.46**	0.00	**0.00**
3-May-25		2.43	5.79	8.31	7.85	0.87	0.00	3.80		2.01	0.38	1.78	1.57	0.00	0.48			**35.27**	0.00	**0.00**
4-May-25		2.40	3.33	7.52	6.55	0.32	0.00	4.37		1.75	0.60	1.37	0.42	0.48	0.00		0.00	**29.11**	0.00	**0.00**
5-May-25		1.81	0.00	4.57	4.31	0.00	0.00	2.50		2.25	0.10	0.63	0.00	0.60	0.00		0.00	**16.77**	0.00	**0.00**
6-May-25		1.22	0.00	4.39	3.33	0.00	0.00	3.15		1.90	0.36	0.31	0.00	0.00	0.00		0.00	**14.66**	0.00	**0.00**
7-May-25		0.00	0.00	7.75	3.06	0.00	0.00	2.34		2.04	0.24	0.11	0.00		0.00		0.00	**15.54**	0.00	**0.00**
8-May-25		0.00	0.00	3.78	0.75	0.00	0.00	0.90		2.01	0.24	0.00	0.00	0.00			0.00	**7.68**	0.00	**0.00**
9-May-25	0.00	0.00	0.00	5.45	1.00	0.00	0.00	1.17		2.39	0.00	0.00	0.00	0.00			0.00	**10.01**	0.00	**0.00**
10-May-25	0.00	0.00	0.00	5.58	0.88	0.00	0.00	1.12		2.09	0.00	0.00	0.00	1.18			0.00	**10.85**	0.00	**0.00**
11-May-25		0.00	0.00	5.80	1.11	0.00	0.00	1.34		2.11	0.00	0.00	0.00	1.70	0.00		0.00	**12.06**	0.00	**0.00**
12-May-25		0.00	0.00	8.11	3.10	0.00	0.00	1.59		2.40	0.00	0.00	0.00	1.40	0.00		0.00	**16.60**	0.00	**0.00**
13-May-25		0.00	0.00	8.71	3.74	1.10	0.00	2.50		2.56	0.00	0.30	0.00	2.00			0.00	**20.91**	0.00	**0.00**
14-May-25		0.00	0.00	8.77	0.66	0.00	0.00	0.00		3.13	0.00	0.80	0.00	1.65			0.00	**15.01**	0.00	**0.00**
15-May-25		0.00	0.00	9.16	2.91	0.48	0.00	1.62		2.60	0.00	0.00	0.00	1.75			0.00	**18.52**	0.00	**0.00**
16-May-25		0.00	0.00	8.79	5.13	4.21	0.00	3.34		2.65	0.00	1.42	0.00	2.12			0.00	**27.66**	0.00	**0.00**
17-May-25		0.96	3.00	5.50	10.38	7.11	0.33	5.40		2.04	0.34	2.64	3.41	2.25	0.00		0.00	**43.36**	0.00	**0.00**
18-May-25		3.11	6.26	7.15	13.24	8.10	1.08	7.06		1.81	0.45	3.78	2.83	2.35	0.00		0.00	**57.22**	0.00	**0.00**
19-May-25		3.52	8.93	7.25	12.05	8.10	1.42	7.18		1.41	0.00	3.58	2.83	2.10	0.00		0.00	**58.37**	0.00	**0.00**
20-May-25		3.87	5.18	12.00	12.42	9.63	1.88	6.89		1.79	0.45	2.91	2.51	2.13		0.00	0.00	**61.66**	0.00	**0.00**
21-May-25	0.00	2.40	1.41	10.70	9.90	5.35	0.58	6.12		2.01	0.27	2.50	2.03	2.38			0.00	**45.65**	0.00	**0.00**
22-May-25		0.00	0.00	7.67	6.85	3.29	0.00	3.54		2.45	0.00	1.41	0.18	2.05			0.00	**27.44**	0.00	**0.00**
23-May-25		0.75	0.00	10.98	7.94	2.11	0.00	3.87		1.81	0.45	1.84	1.56	2.61			0.00	**33.92**	0.00	**0.00**
24-May-25		0.00	0.00	10.32	5.79	3.07	0.00	3.20		2.11	0.10	0.95		2.39			0.00	**27.93**	0.00	**0.00**
25-May-25		0.00	0.00	6.90	0.25	0.00	0.00	1.10		2.89	0.00	0.65	0.00	2.00			0.00	**13.79**	0.00	**0.00**
26-May-25		0.00	0.00	8.79	4.11	4.13	0.00	4.10		1.60	0.73	0.43	1.00	2.18			0.00	**27.07**	0.00	**0.00**
27-May-25		1.38	2.78	10.10	8.50	7.65	0.00	6.30		1.33	0.98	1.98	1.98	1.75			0.00	**44.73**	0.00	**0.00**
28-May-25		0.31	0.00	16.20	12.39	7.58	1.22	6.97		1.47	0.42	3.30	1.64	1.61			0.00	**53.11**	0.00	**0.00**
29-May-25		2.45	6.60	15.50	17.70	11.62	3.29	9.70		1.99	0.33	5.19	4.80	2.70	0.00		0.00	**81.87**	0.00	**0.00**
30-May-25		1.45	1.15	10.74	11.02	11.77	2.15	7.36		1.98	0.28	2.77	1.15	2.46			0.00	**54.28**	11.95	**11.95**
31-May-25		0.00	0.00	9.17	7.50	10.20	0.17	5.71		2.48	0.00	1.65	0.33	1.85			0.00	**39.06**	11.01	**11.01**
Total	**0.00**	**33.39**	**56.80**	**263.25**	**203.41**	**113.13**	**12.52**	**123.33**	**0.00**	**64.18**	**8.32**	**47.32**	**33.43**	**46.35**	**0.48**	**0.00**	**0.00**	**1005.91**	**22.96**	**22.96**

Disclaimer:- Blank entry if the line under outage/shutdown on corrosponding day

15.2 Import-Export of NR with ER & NER during May 2025

Date	Export of NR to ER (NR- ER)																		Export of NR to NER (NR-NER)	
	NR - ER HVDC Agra - Alipurduar	NR - ER 765 kV Fatehpur - Sasaram	NR - ER 765 kV Varanasi - Gaya 2*S/C	NR - ER 765 kV Balia - Gaya	NR - ER 400 kV Balia - Patna D/C	NR - ER 400 kV Gorakhpur - Muzaffarpur D/C	NR - ER 400 kV Balia - Biharshariff D/C	NR - ER 400 kV Gorakhpur - Motihari D/C	NR - ER 400 kV Varanasi - Biharshariff D/C	NR - ER 400 kV Varanasi - Sasaram	NR - ER 400 kV Allahabad - Sasaram	NR - ER 400 kV Balia - Naubatpur D/C	NR - ER 400 kV Sahupuri - Biharshriff D/C	NR - ER 220 kV Karamnasa - Sahupuri	NR - ER 132 kV Karamnasa - Sahupuri	NR - ER 132 kV Rihand - Nagar Untari	NR - ER 132 kV Rihand - Garhwa	Total NR -ER	NR - NER HVDC Agra - Biswanath Chariali	Total NR-NER
1-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00			**0.00**	12.69	**12.69**
2-May-25		0.00	0.00	0.00	0.00	0.00	3.41	0.00		0.00	0.00	0.00	0.00	0.00	0.00			**3.41**	12.46	**12.46**
3-May-25		0.00	0.00	0.00	0.00	0.00	5.32	0.00		0.00	0.00	0.00	0.00	0.49	0.00			**5.81**	12.09	**12.09**
4-May-25		0.00	0.00	0.00	0.00	0.00	5.67	0.00		0.00	0.00	0.00	0.00	0.00	0.00		0.03	**5.70**	12.39	**12.39**
5-May-25		0.00	2.42	0.00	0.00	2.43	7.15	0.00		0.00	0.00	0.00	1.51	0.00	0.00		0.38	**13.89**	12.55	**12.55**
6-May-25		0.00	2.12	0.00	0.00	0.37	6.20	0.00		0.00	0.00	0.00	0.94	0.47	0.00		0.28	**10.38**	11.10	**11.10**
7-May-25		0.58	5.56	0.00	0.00	2.93	6.98	0.00		0.00	0.00	0.00	1.43		0.39		0.06	**17.93**	11.20	**11.20**
8-May-25		2.47	7.52	0.00	0.00	4.97	9.53	0.00		0.00	0.00	0.74	3.10	0.20			0.64	**29.17**	12.11	**12.11**
9-May-25	0.00	1.63	6.40	0.00	0.00	5.38	9.65	0.00		0.00	0.13	0.71	2.73	0.20			0.62	**27.45**	12.20	**12.20**
10-May-25	0.00	2.07	7.53	0.00	0.00	5.47	10.16	0.00		0.00	0.53	0.89	3.27	0.00			0.58	**30.50**	12.45	**12.45**
11-May-25		2.47	8.40	0.00	0.00	2.38	7.67	0.00		0.00	1.11	0.57	2.95	0.00	0.00		0.59	**26.14**	11.90	**11.90**
12-May-25		3.60	10.45	0.00	0.00	2.82	6.35	0.00		0.00	1.20	1.40	2.15	0.00	0.00		0.72	**28.69**	9.17	**9.17**
13-May-25		3.27	6.60	0.00	0.00	0.00	3.85	0.00		0.00	0.75	0.00	1.60	0.00			0.71	**16.78**	10.73	**10.73**
14-May-25		6.02	11.02	0.00	0.00	2.18	5.72	0.05		0.00	0.71	0.00	3.70	0.00			0.76	**30.16**	10.49	**10.49**
15-May-25		3.03	7.62	0.00	0.00	0.00	4.30	0.00		0.00	0.22	0.05	2.18	0.00			0.73	**18.13**	11.80	**11.80**
16-May-25		2.23	6.22	0.00	0.00	0.00	2.46	0.00		0.00	0.46	0.00	1.25	0.00			0.63	**13.25**	14.35	**14.35**
17-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	1.76	0.00	0.00		0.62	**2.38**	12.20	**12.20**
18-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00		0.68	**0.68**	11.50	**11.50**
19-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.26	0.00	0.00	0.00	0.00		0.56	**0.82**	12.12	**12.12**
20-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00		0.10	0.62	**0.72**	12.03	**12.03**
21-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00			0.48	**0.48**	13.62	**13.62**
22-May-25		0.65	1.52	0.00	0.00	0.00	0.93	0.00		0.00	0.21	0.00	0.00	0.00			0.26	**3.57**	12.05	**12.05**
23-May-25		0.00	0.37	0.00	0.00	0.00	0.56	0.00		0.00	0.00	0.00	0.00	0.00			0.50	**1.43**	11.74	**11.74**
24-May-25		0.32	4.14	0.00	0.00	0.00	1.18	0.00		0.00	0.00	0.00		0.00			0.56	**6.20**	11.82	**11.82**
25-May-25		4.27	11.00	0.00	0.00	0.90	5.02	0.00		0.00	0.65	0.00	2.20	0.00			0.63	**24.67**	12.43	**12.43**
26-May-25		0.28	0.23	0.00	0.00	0.00	2.19	0.00		0.00	0.00	0.00	0.00	0.00			0.60	**3.30**	11.49	**11.49**
27-May-25		0.00	0.00	0.00	0.00	0.00	0.21	0.00		0.00	0.00	0.00	0.00	0.00			0.65	**0.86**	11.93	**11.93**
28-May-25		0.00	1.47	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00			0.71	**2.18**	11.90	**11.90**
29-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00		0.72	**0.72**	4.50	**4.50**
30-May-25		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00			0.64	**0.64**	0.00	**0.00**
31-May-25		1.59	5.58	0.00	0.00	0.00	0.00	0.00		0.00	0.29	0.00	0.00	0.00			0.55	**8.01**	0.00	**0.00**
Total	**0.00**	**34.48**	**106.17**	**0.00**	**0.00**	**29.83**	**104.51**	**0.05**	**0.00**	**0.00**	**6.52**	**4.36**	**30.77**	**1.36**	**0.39**	**0.10**	**15.51**	**334.05**	**339.01**	**339.01**

Disclaimer:- Blank entry if the line under outage/shutdown on corrosponding day

Date	15.3 Import and Export of ER with WR & NER during May 2025																							
	Export of WR to ER (WR-ER)								Import of WR from ER (ER - WR)								Export of ER to NER (ER-NER)				Import of ER from NER (NER-ER)			
	WR - ER 765 kV Dharamjaygarh - Ranchi 2xS/C	WR - ER 765 kV Dharamjaygarh - Jharsuguda Q/C	WR - ER 765 kV Durg - Jharsuguda D/C	WR - ER 400 kV Sipat - Ranchi D/C	WR - ER 400 kV Raigarh - Jharsuguda- 2xD/C	WR - ER 220 kV Korba - Budhipadar D/C	WR - ER 220 kV Raigarh - Budhipadar	Total WR - ER	ER - WR 765 kV Dharamjaygarh - Ranchi 2xS/C	ER-WR 765 kV Dharamjaygarh - Jharsuguda D/C	ER-WR 765 kV Durg - Jharsuguda D/C	ER - WR 400 kV Sipat - Ranchi D/C	ER - WR 400 kV Raigarh - Jharsuguda- 2xD/C	ER - WR 220 kV Korba - Budhipadar D/C	ER - WR 220 kV Raigarh - Budhipadar	Total ER - WR	ER - NER 400 kV Binaguri - Bongaigaon D/C	ER - NER 400 kV Alipurduar - Bongaigaon D/C	ER - NER 220 kV Birpara - Salakati D/C	Total ER - NER	NER - ER 400 kV Binaguri - Bongaigaon D/C	NER - ER 400 kV Alipurduar - Bongaigaon 2xD/C	NER - ER 220 kV Birpara - Salakati D/C	Total NER - ER
1-May-25	8.2	5.9	0.0	1.5	0.0	0.7	0.0	**16.31**	4.4	8.4	17.3	1.4	7.1	0.7	1.7	**40.98**	0.23	1.01	0.02	**1.26**	2.83	3.75	0.93	**7.52**
2-May-25	7.5	8.2	0.0	0.9	0.0	0.6	0.0	**17.22**	1.5	3.3	11.9	0.9	7.0	0.4	1.0	**26.04**	0.01	0.05	0.00	**0.05**	3.55	4.94	1.28	**9.77**
3-May-25	13.3	3.5	0.0	2.0	0.0	0.5	0.0	**19.27**	0.4	6.6	12.1	0.7	8.1	0.4	1.4	**29.67**	0.58	1.00	0.05	**1.63**	1.75	2.44	0.67	**4.86**
4-May-25	18.8	1.6	0.0	3.0	0.0	0.7	0.1	**24.20**	0.3	11.0	12.2	0.3	8.0	0.4	1.2	**33.38**	1.25	2.21	0.23	**3.69**	0.68	0.78	0.25	**1.71**
5-May-25	15.7	1.3	0.0	2.4	0.0	0.5	0.0	**19.91**	0.4	9.7	11.9	0.4	7.1	0.3	1.1	**30.80**	0.95	2.65	0.33	**3.92**	0.76	0.65	0.13	**1.55**
6-May-25	16.0	2.7	0.0	2.9	0.3	1.2	0.0	**23.08**	0.2	5.9	9.7	0.2	3.9	0.0	0.7	**20.67**	0.34	1.03	0.07	**1.44**	0.88	1.17	0.36	**2.41**
7-May-25	24.1	7.1	0.1	4.9	1.4	2.1	0.4	**40.15**	0.0	3.0	6.8	0.1	2.7	0.0	0.0	**12.69**	0.96	1.75	0.09	**2.80**	0.79	0.90	0.35	**2.04**
8-May-25	26.7	8.0	0.1	5.5	1.6	2.5	0.6	**45.06**	0.0	2.0	6.7	0.0	1.3	0.0	0.1	**10.08**	1.28	2.50	0.20	**3.98**	0.82	1.03	0.46	**2.31**
9-May-25	28.0	6.2	0.0	5.8	2.1	2.6	0.2	**44.83**	0.0	3.8	7.1	0.0	1.6	0.0	0.2	**12.69**	2.59	4.33	0.67	**7.59**	0.38	0.32	0.18	**0.87**
10-May-25	28.0	4.4	0.0	5.8	0.9	2.1	0.3	**41.44**	0.0	5.9	7.5	0.0	1.4	0.0	0.2	**14.97**	2.61	4.35	0.63	**7.58**	1.48	2.17	0.61	**4.26**
11-May-25	30.8	6.0	0.1	6.1	0.8	1.2	0.5	**45.49**	0.0	3.4	6.3	0.1	2.2	0.0	0.1	**12.11**	0.00	0.00	0.00	**0.00**	4.48	5.41	1.59	**11.48**
12-May-25	32.1	5.3	0.0	6.9	0.7	1.2	0.5	**46.81**	0.0	7.2	6.8	0.0	2.6	0.0	0.1	**16.71**	1.03	2.19	0.34	**3.56**	1.40	1.35	0.42	**3.17**
13-May-25	29.9	2.2	0.0	5.9	0.1	0.6	0.1	**38.69**	0.0	6.4	7.7	0.0	4.2	0.0	0.3	**18.61**	0.00	1.59	0.13	**1.72**	2.35	1.57	0.37	**4.28**
14-May-25	37.8	2.1	0.0	7.7	0.4	0.7	0.1	**48.76**	0.0	8.9	6.2	0.0	3.1	0.0	0.2	**18.34**	0.18	2.14	0.16	**2.47**	2.52	2.36	0.57	**5.45**
15-May-25	34.1	2.6	0.0	6.1	0.2	0.6	0.2	**43.83**	0.0	9.6	7.0	0.0	3.6	0.0	0.3	**20.56**	0.00	0.22	0.00	**0.22**	4.61	3.44	1.02	**9.08**
16-May-25	32.7	2.8	0.0	5.8	0.4	0.5	0.3	**42.49**	0.0	5.8	6.5	0.0	4.2	0.1	0.2	**16.82**	0.00	0.06	0.00	**0.06**	7.08	5.70	1.54	**14.31**
17-May-25	25.7	1.1	0.0	3.9	0.3	0.4	0.1	**31.47**	0.0	8.0	7.3	0.1	4.8	0.1	0.3	**20.59**	0.00	0.23	0.00	**0.23**	6.46	6.40	1.53	**14.38**
18-May-25	23.5	2.2	0.0	3.3	0.1	0.4	0.2	**29.83**	0.1	9.1	8.0	0.3	6.1	0.1	0.5	**24.24**	0.00	0.36	0.00	**0.36**	5.45	5.75	1.50	**12.70**
19-May-25	16.8	1.8	0.0	2.1	0.0	0.3	0.0	**20.94**	0.2	10.5	9.5	0.7	5.5	0.1	0.6	**27.11**	0.00	0.02	0.00	**0.02**	5.41	5.53	1.36	**12.30**
20-May-25	25.2	0.4	0.0	3.8	0.4	0.3	0.1	**30.21**	0.0	15.7	7.0	0.2	3.4	0.1	0.6	**26.95**	0.00	0.00	0.00	**0.00**	6.09	5.77	1.43	**13.30**
21-May-25	26.6	3.1	0.0	4.4	0.8	0.4	0.1	**35.42**	0.0	13.0	6.8	0.1	2.2	0.0	0.5	**22.61**	0.00	0.00	0.00	**0.00**	5.68	4.02	1.20	**10.89**
22-May-25	28.4	9.5	0.6	5.9	1.6	0.9	0.4	**47.35**	0.0	6.7	6.0	0.0	1.8	0.0	0.5	**14.98**	0.00	0.06	0.00	**0.06**	5.74	5.16	1.27	**12.17**
23-May-25	33.2	4.3	0.3	6.6	1.5	1.2	0.5	**47.68**	0.0	9.7	5.8	0.0	1.7	0.0	0.3	**17.56**	0.09	1.11	0.09	**1.28**	3.10	2.07	0.59	**5.75**
24-May-25	35.5	6.8	0.1	7.5	1.4	1.3	0.8	**53.38**	0.0	9.6	6.1	0.0	2.3	0.0	0.0	**18.11**	0.18	1.47	0.12	**1.77**	2.22	0.58	0.29	**3.09**
25-May-25	40.6	15.3	0.7	8.4	2.0	1.4	1.2	**69.67**	0.0	5.4	4.1	0.0	1.0	0.0	0.0	**10.56**	0.77	3.19	0.42	**4.37**	1.26	0.41	0.19	**1.86**
26-May-25	37.8	8.9	0.5	8.0	2.1	1.2	1.2	**59.60**	0.0	8.6	4.2	0.0	0.7	0.0	0.0	**13.46**	0.73	3.25	0.38	**4.36**	1.34	0.46	0.16	**1.97**
27-May-25	36.7	6.7	0.3	8.1	2.1	1.0	1.0	**55.90**	0.0	11.4	4.7	0.0	0.5	0.0	0.0	**16.59**	0.23	4.29	0.41	**4.94**	1.15	0.01	0.01	**1.17**
28-May-25	38.1	5.0	1.0	8.7	3.3	1.6	1.1	**58.65**	0.0	12.5	5.4	0.0	0.7	0.0	0.0	**18.63**	0.00	1.35	0.01	**1.37**	3.65	1.00	0.53	**5.18**
29-May-25	24.8	0.2	0.5	5.1	1.8	1.0	0.4	**33.82**	0.0	17.1	6.6	0.0	2.4	0.2	0.4	**26.66**	0.07	1.37	0.08	**1.52**	4.29	1.28	0.67	**6.25**
30-May-25	29.7	4.7	1.3	6.3	2.8	1.6	0.4	**46.82**	0.0	9.8	4.7	0.0	1.5	0.1	0.5	**16.66**	0.00	0.00	0.00	**0.00**	7.77	3.32	1.73	**12.82**
31-May-25	41.2	12.6	2.9	9.5	6.9	2.3	0.7	**76.16**	0.0	5.6	2.3	0.0	0.0	0.0	0.3	**8.13**	0.05	1.49	0.09	**1.63**	5.92	3.07	1.08	**10.06**
Total	**847.34**	**152.33**	**8.48**	**165.08**	**36.04**	**33.58**	**11.59**	**1254.44**	**7.39**	**253.52**	**232.42**	**5.53**	**102.70**	**2.91**	**13.49**	**617.96**	**14.14**	**45.27**	**4.51**	**63.92**	**101.88**	**82.82**	**24.26**	**208.96**

Date	15.4 Import and Export of SR with ER & WR during May 2025																							
	Export of ER to SR (ER - SR)				Import of ER from SR (SR - ER)				Export of WR to SR (WR-SR)									Import of WR from SR (SR - WR)								
	ER - SR HVDC Gazuwaka	ER - SR HVDC Talchar - Kolar	ER-SR 765 kV Angul-Srikakulam D/C	Total ER - SR	SR - ER HVDC Gazuwaka	SR - ER HVDC Talchar - Kolar	SR-ER 765 kV Angul-Srikakulam D/C	Total SR - ER	WR - SR HVDC Bhadrawati	WR - SR 765 kV Sholapur - Raichur 2xS/C	WR-SR 765 kV Wardha - Nizamabad D/C	WR-SR 400KV Kolhapur-Kudgi D/C	WR-SR HVDC Raigarh-Puglur	WR-SR 220kV Xeldem - Ambewadi S/C	WR-SR 220kV Ponda - Ambewadi S/C	WR-SR 765 kV Warora - Warangal D/C	Total WR - SR	SR - WR HVDC Bhadrawati	SR - WR 765 kV Raichur - Sholapur 2xS/C	SR-WR 765 kV Wardha - Nizamabad D/C	SR-WR 400KV Kolhapur-Kudgi D/C	SR-WR HVDC Raigarh-Puglur	SR - WR 220kV Xeldem - Ambewadi S/C	SR - WR 220kV Ponda - Ambewadi S/C	SR-WR 765 kV Warangal - Warora D/C	Total SR - WR
1-May-25	0.00	38.03	52.75	**90.78**	4.79	0.00	0.00	**4.79**	18.93	4.46	29.39	0.00	56.53	2.64	0.00	35.49	**147.43**	0.00	4.45	0.00	23.03	0.00	0.00	0.00	0.00	**27.47**
2-May-25	1.68	42.65	53.04	**97.37**	3.14	0.00	0.00	**3.14**	17.05	8.01	33.44	0.00	94.79	2.51	0.00	39.18	**194.97**	0.00	1.30	0.00	22.94	0.00	0.00	0.00	0.00	**24.24**
3-May-25	2.92	40.27	50.06	**93.25**	1.18	0.00	0.00	**1.18**	12.20	4.07	26.08	0.00	82.79	2.72	0.00	30.95	**158.80**	0.00	10.28	0.00	29.59	0.00	0.00	0.00	0.00	**39.87**
4-May-25	2.62	35.26	44.55	**82.42**	0.00	0.00	0.00	**0.00**	12.46	1.69	20.48	0.00	65.11	2.57	0.00	24.23	**126.54**	0.00	13.48	1.15	30.20	0.00	0.00	0.00	0.47	**45.30**
5-May-25	2.79	36.63	51.75	**91.17**	0.00	0.00	0.00	**0.00**	9.76	9.95	29.03	0.00	89.22	2.60	0.00	33.65	**174.22**	0.00	7.41	0.00	23.08	0.00	0.00	0.00	0.00	**30.49**
6-May-25	6.63	40.19	47.28	**94.11**	0.00	0.00	0.00	**0.00**	7.37	6.59	28.85	0.00	105.20	2.68	0.00	33.52	**184.21**	0.00	3.90	0.00	24.31	0.00	0.00	0.00	0.00	**28.22**
7-May-25	7.42	38.24	41.29	**86.94**	0.00	0.00	0.00	**0.00**	8.86	6.52	22.95	0.00	76.77	2.56	0.00	28.28	**145.94**	0.00	4.46	0.00	23.48	0.00	0.00	0.00	0.00	**27.94**
8-May-25	7.42	39.86	42.73	**90.01**	0.00	0.00	0.00	**0.00**	7.36	11.49	26.06	0.00	67.75	2.61	0.00	32.76	**148.03**	0.00	3.52	0.00	22.84	0.00	0.00	0.00	0.00	**26.37**
9-May-25	5.17	42.90	42.77	**90.84**	0.00	0.00	0.00	**0.00**	7.37	8.22	22.86	0.00	88.92	2.59	0.00	31.23	**161.17**	0.00	4.62	0.00	25.24	0.00	0.00	0.00	0.00	**29.87**
10-May-25	2.66	39.60	43.09	**85.35**	0.00	0.00	0.00	**0.00**	7.36	4.43	22.98	0.00	102.92	2.71	0.00	30.54	**170.94**	0.00	4.82	0.00	24.83	0.00	0.00	0.00	0.00	**29.65**
11-May-25	2.66	33.67	38.86	**75.19**	0.00	0.00	0.00	**0.00**	7.37	2.41	17.68	0.00	84.20	2.52	0.00	23.96	**138.16**	0.00	12.84	0.16	29.04	0.00	0.00	0.00	0.00	**42.04**
12-May-25	1.18	45.10	41.87	**88.16**	4.57	0.00	0.00	**4.57**	11.87	1.18	19.00	0.00	91.35	2.44	0.00	25.15	**150.99**	0.00	13.45	0.16	27.65	0.00	0.00	0.00	0.00	**41.26**
13-May-25	0.00	43.00	48.39	**91.39**	8.52	0.00	0.00	**8.52**	19.47	4.79	24.57	0.00	75.36	2.65	0.00	30.87	**157.70**	0.00	7.66	0.00	24.59	0.00	0.00	0.00	0.00	**32.24**
14-May-25	0.76	40.40	41.63	**82.79**	5.05	0.00	0.00	**5.05**	24.15	3.38	18.66	0.00	72.26	2.65	0.00	23.92	**145.01**	0.00	9.26	0.00	26.00	0.00	0.00	0.00	0.00	**35.26**
15-May-25	1.85	39.04	40.97	**81.86**	1.30	0.00	0.00	**1.30**	16.17	6.09	18.40	0.00	52.60	2.59	0.00	24.23	**120.07**	0.00	10.34	0.32	24.20	0.00	0.00	0.00	0.01	**34.87**
16-May-25	1.52	44.02	44.72	**90.25**	1.11	0.00	0.00	**1.11**	7.38	7.96	24.26	0.00	36.21	2.49	0.00	30.37	**108.68**	0.00	5.20	0.00	22.25	0.00	0.00	0.00	0.00	**27.45**
17-May-25	0.00	38.88	46.40	**85.28**	2.59	0.00	0.00	**2.59**	7.39	4.15	20.57	0.00	28.62	2.53	0.00	28.06	**91.33**	0.00	6.06	0.00	23.84	0.00	0.00	0.00	0.00	**29.90**
18-May-25	0.00	32.40	41.71	**74.11**	2.59	0.00	0.00	**2.59**	7.38	1.05	15.70	0.00	20.88	2.34	0.00	20.43	**67.78**	0.00	15.65	1.53	26.30	0.00	0.00	0.00	0.78	**44.25**
19-May-25	0.00	38.78	49.88	**88.66**	2.59	0.00	0.00	**2.59**	7.36	8.49	29.67	0.00	26.61	2.57	0.00	34.65	**109.35**	0.00	3.91	0.00	18.89	0.00	0.00	0.00	0.00	**22.80**
20-May-25	0.00	40.05	35.61	**75.66**	5.64	0.00	0.00	**5.64**	3.25	1.30	13.79	0.00	22.81	1.98	0.00	16.95	**60.08**	8.27	19.79	1.50	23.47	0.00	0.00	0.00	1.43	**54.46**
21-May-25	0.00	41.90	39.33	**81.24**	11.94	0.00	0.00	**11.94**	0.00	1.82	15.72	0.00	25.01	1.93	0.01	19.59	**64.08**	13.88	15.26	1.56	33.18	0.00	0.00	0.00	1.24	**65.13**
22-May-25	0.00	40.63	39.99	**80.62**	11.73	0.00	0.00	**11.73**	0.00	1.00	16.69	0.00	47.10	1.98	0.01	22.80	**89.57**	11.13	14.83	1.29	33.46	0.00	0.00	0.00	0.53	**61.24**
23-May-25	0.00	35.82	39.05	**74.87**	2.65	0.00	0.00	**2.65**	0.00	1.47	17.12	0.00	26.22	2.15	0.01	22.37	**69.33**	16.72	12.52	0.52	32.93	0.00	0.00	0.00	0.08	**62.77**
24-May-25	0.00	33.53	37.41	**70.94**	7.23	0.00	0.00	**7.23**	0.00	0.21	17.68	0.00	20.90	2.08	0.00	14.41	**55.28**	23.95	13.39	1.64	31.42	0.00	0.00	0.00	0.80	**71.19**
25-May-25	0.00	29.67	29.50	**59.17**	7.11	0.00	0.00	**7.11**	0.00	0.07	10.86	0.00	19.39	2.01	0.00	14.68	**47.01**	23.96	19.58	2.32	34.51	0.00	0.00	0.00	1.11	**81.48**
26-May-25	0.00	35.02	28.36	**63.38**	7.11	0.00	0.00	**7.11**	0.00	0.03	7.76	0.00	17.40	2.00	0.00	10.10	**37.29**	23.99	21.54	1.33	39.18	0.00	0.00	0.00	1.17	**87.21**
27-May-25	0.00	32.32	27.10	**59.42**	9.93	0.00	0.00	**9.93**	0.00	0.00	5.81	0.00	25.11	2.04	0.00	7.54	**40.51**	23.98	25.75	4.76	40.98	0.00	0.00	0.00	4.13	**99.60**
28-May-25	0.00	36.14	28.67	**64.81**	11.05	0.00	0.00	**11.05**	0.00	0.20	7.86	0.00	18.43	2.23	0.00	9.53	**38.26**	17.30	28.17	4.48	35.04	0.00	0.00	0.00	3.94	**88.93**
29-May-25	0.00	36.15	36.54	**72.69**	9.48	0.00	0.00	**9.48**	0.00	0.42	11.05	0.00	30.95	2.15	0.00	14.72	**59.29**	15.02	22.73	0.55	30.89	0.00	0.00	0.00	0.19	**69.38**
30-May-25	0.00	33.38	38.04	**71.42**	8.43	0.00	0.00	**8.43**	0.00	1.32	15.81	0.00	24.26	2.27	0.00	19.78	**63.44**	12.08	17.34	0.57	31.06	0.00	0.00	0.00	0.26	**61.32**
31-May-25	0.00	38.35	31.13	**69.48**	8.46	0.00	0.00	**8.46**	0.00	2.62	13.06	0.00	25.65	2.41	0.00	16.25	**59.98**	15.74	22.50	1.87	31.06	0.00	0.00	0.00	1.38	**72.55**
TOTAL	**47.26**	**1181.86**	**1274.48**	**2503.60**	**138.20**	**0.00**	**0.00**	**138.20**	**220.50**	**115.39**	**603.84**	**0.00**	**1621.30**	**74.18**	**0.09**	**750.16**	**3385.46**	**206.01**	**376.02**	**25.72**	**869.48**	**0.00**	**0.00**	**0.01**	**17.52**	**1494.76**

16. भूटान , नेपाल, बांग्लादेश एवं म्यान्मार के साथ अंतरराष्ट्रीय विद्युत विनिमय
INTERNATIONAL EXCHANGE WITH BHUTAN, NEPAL BANGLADESH AND MYANMAR

अप्रैल 2025 से मार्च 2026 April 2025 to March 2026

अंतरराष्ट्रीय विद्युत विनिमय [भारत 'से निर्यात'/ 'को आयात']
Transnational Exchange ('Export from'/'Import to' India)

माह MONTH	भूटान BHUTAN		नेपाल NEPAL		बांग्लादेश BANGLADESH		म्यान्मार MYANMAR	
	Energy Exported (In MU)	Energy Imported (In MU)	Energy Exported (In MU)	Energy Imported (In MU)	Energy Exported (In MU)	Energy Imported (In MU)	Energy Exported (In MU)	Energy Imported (In MU)
अप्रैल 2025 APR'25	72.61	27.18	365.47	0.00	684.92	0.00	0.70	0.00
मई 2025 MAY'25	0.00	553.50	203.10	9.50	707.90	0.00	0.70	0.00
कुल Total	**72.61**	**580.68**	**568.57**	**9.50**	**1392.82**	**0.00**	**1.40**	**0.00**

* Based on daily operational data

16.1 Import from neighbouring countries during Apr 2025

(All figures in MU)

Date	Import from Bhutan								Import from Bangladesh		Import from Nepal				Import from Myanmar
	400 kV Tala-Binaguri I,II & IV	400 kV Binaguri-Malbase	220 kV Birpara-Chuka D/C	220 kV Birpara-Malbase	400 kV Punatsanchu-Alipurdwar D/C*	400 kV Jigmeling-Alipurdwar D/C	132 kV Rangia-Motanga	132 kV Salakati-Gelephu	400 kV Behrampur-Bheramara 1,2,3&4	132 kV Surjyamaninagar-Comilla D/C	132 kV Tanakpur-Mahendranagar	From UP Source	400 kV Muzaffarpur-Dhalkebar	From BIHAR Source	11 kV Moreh-Tamu
1-May-25	2.41	0.54	0.00	0.00	0.00	8.76	0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2-May-25	1.18	0.00	0.00	0.00	0.00	7.54	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3-May-25	1.21	0.00	0.00	0.00	0.00	6.87	0.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4-May-25	0.44	0.00	0.00	0.00	0.00	7.00	0.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5-May-25	1.06	0.00	0.00	0.00	0.00	10.48	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6-May-25	1.22	0.00	0.00	0.00	0.00	6.68	0.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7-May-25	0.44	0.00	0.00	0.00	0.00	7.25	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8-May-25	0.39	0.00	0.00	0.00	0.00	7.73	0.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9-May-25	0.38	0.00	0.00	0.00	0.00	7.06	0.11	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10-May-25	0.94	0.00	0.00	0.00	0.00	6.65	0.28	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11-May-25	0.96	0.00	0.00	0.00	0.00	10.24	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12-May-25	1.00	0.00	0.00	0.00	0.00	9.05	0.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13-May-25	3.74	2.33	0.00	0.00	0.00	15.36	0.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14-May-25	3.28	1.94	0.00	0.00	0.00	14.41	0.79	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15-May-25	4.67	2.40	0.00	0.00	0.00	16.11	0.61	0.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16-May-25	6.42	2.08	0.00	0.00	0.00	21.08	0.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17-May-25	4.63	1.23	0.00	0.00	0.00	16.44	0.76	0.00	0.00	0.00	0.00	0.00	0.99	0.00	0.00
18-May-25	3.01	0.45	0.00	0.00	0.00	13.99	0.62	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19-May-25	2.57	0.22	0.00	0.00	0.00	13.62	0.52	0.00	0.00	0.00	0.00	0.00	0.20	0.00	0.00
20-May-25	3.65	0.78	0.00	0.00	0.00	15.77	0.55	0.23	0.00	0.00	0.00	0.00	2.47	0.00	0.00
21-May-25	3.97	0.95	0.00	0.00	0.00	19.40	0.72	0.12	0.00	0.00	0.00	0.00	1.20	0.00	0.00
22-May-25	5.06	1.48	0.00	0.00	0.00	16.38	0.63	0.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23-May-25	3.47	0.67	0.00	0.00	0.00	16.22	0.74	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24-May-25	2.79	0.30	0.00	0.00	0.00	17.41	0.79	0.26	0.00	0.00	0.00	0.00	1.32	0.00	0.00
25-May-25	3.49	0.62	0.00	0.00	0.00	15.60	0.82	0.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26-May-25	3.89	0.80	0.00	0.00	0.00	15.71	0.66	0.26	0.00	0.00	0.00	0.00	0.38	0.00	0.00
27-May-25	7.53	2.61	0.00	0.00	0.00	21.88	0.75	0.54	0.00	0.00	0.00	0.00	4.50	0.00	0.00
28-May-25	7.29	2.42	0.00	0.00	0.00	23.42	0.78	0.65	0.00	0.00	0.00	0.00	2.39	0.00	0.00
29-May-25	7.83	2.88	0.68	0.00	0.00	23.77	0.62	0.48	0.00	0.00	0.00	0.00	3.02	0.00	0.00
30-May-25	13.06	5.43	1.68	0.00	0.00	29.35	0.42	0.74	0.00	0.00	0.00	0.00	5.19	0.00	0.00
31-May-25	14.16	5.88	1.41	0.58	0.00	26.53	0.66	0.65	0.00	0.00	0.00	0.00	6.41	0.00	0.00
Total	**116.14**	**36.02**	**3.77**	**0.58**	**0.00**	**447.78**	**15.50**	**5.05**	**0.00**	**0.00**	**0.00**	**0.00**	**28.07**	**0.00**	**0.00**

Based on SEM/Energy meter data for links where available (*Mangdechu generation reciept at APD through a bypassed arrangement at 400kV Punatsanchu station)

16.2 Export to neighbouring countries during Apr 2025

(All figures in MU)

Date	Export to Bhutan								Export to Bangladesh		Export to Nepal				Export to Myanmar
	400 kV Tala-Binaguri I,II & IV	400 kV Binaguri-Malbase	220 kV Birpara-Chuka D/C	220 kV Birpara-Malbase	400 kV Punatsanchu-Alipurdwar D/C*	400 kV Jigmeling-Alipurdwar D/C	132 kV Rangia-Motanga	132 kV Salakati-Gelephu	400 kV Behrampur-Bheramara 1,2,3&4	132 kV Surjyamaninagar-Comilla D/C	132 kV Tanakpur-Mahendranagar	From UP Source	400 kV Muzaffarpur-Dhalkebar	From BIHAR Source	11 kV Moreh-Tamu
1-May-25	0.00	0.00	1.84	0.93	0.00	0.00	0.00	0.28	22.07	0.00	1.09	0.86	3.74	3.28	0.02
2-May-25	0.00	0.54	2.12	1.09	0.00	0.00	0.00	0.24	22.15	0.00	1.14	0.95	6.74	3.05	0.02
3-May-25	0.00	0.48	1.98	0.90	0.00	0.00	0.00	0.17	22.22	0.00	1.19	0.95	6.55	2.94	0.02
4-May-25	0.00	0.80	2.20	1.02	0.00	0.00	0.00	0.12	22.32	0.00	0.96	0.86	4.83	3.09	0.02
5-May-25	0.00	0.24	2.51	0.93	0.00	0.00	0.00	0.45	22.10	0.00	1.08	0.85	5.47	3.17	0.03
6-May-25	0.00	0.06	2.03	1.05	0.00	0.00	0.00	0.17	22.23	0.00	0.98	0.94	4.61	3.15	0.03
7-May-25	0.00	0.82	2.15	1.03	0.00	0.00	0.00	0.11	22.31	0.00	1.25	1.25	6.64	2.17	0.02
8-May-25	0.00	0.87	2.11	0.95	0.00	0.00	0.00	0.13	22.41	0.00	1.33	1.07	7.81	2.76	0.03
9-May-25	0.00	0.82	1.92	0.82	0.00	0.00	0.00	0.00	22.08	0.00	0.94	1.02	7.75	2.94	0.03
10-May-25	0.00	0.74	1.70	0.69	0.00	0.00	0.00	0.13	21.77	0.00	1.16	1.01	7.30	2.57	0.03
11-May-25	0.00	0.19	2.01	1.27	0.00	0.00	0.00	0.21	22.29	0.00	1.04	0.85	7.43	2.09	0.03
12-May-25	0.00	0.23	2.04	1.20	0.00	0.00	0.00	0.33	21.69	0.00	1.20	0.93	6.39	2.18	0.02
13-May-25	0.00	0.00	0.77	0.64	0.00	0.00	0.00	0.18	22.29	0.00	1.05	0.98	5.83	2.98	0.03
14-May-25	0.00	0.00	0.98	0.77	0.00	0.00	0.00	0.10	22.12	0.00	1.36	1.05	5.04	2.23	0.03
15-May-25	0.00	0.00	0.40	0.64	0.00	0.00	0.00	0.00	22.18	0.00	1.27	1.29	5.67	2.64	0.03
16-May-25	0.00	0.00	0.38	0.70	0.00	0.00	0.00	0.02	22.11	0.00	1.12	1.04	0.80	2.75	0.02
17-May-25	0.00	0.00	0.94	1.14	0.00	0.00	0.00	0.09	22.36	0.00	0.82	0.83	0.00	1.72	0.02
18-May-25	0.00	0.00	1.60	1.39	0.00	0.00	0.00	0.00	22.32	0.00	0.97	1.03	1.16	1.92	0.03
19-May-25	0.00	0.00	1.94	1.50	0.00	0.00	0.00	0.30	22.39	0.00	0.92	0.00	0.00	1.73	0.02
20-May-25	0.00	0.00	0.45	1.59	0.00	0.00	0.00	0.00	22.41	0.00	0.63	0.00	0.00	1.69	0.02
21-May-25	0.00	0.00	0.94	1.18	0.00	0.00	0.00	0.00	22.41	0.00	0.16	0.00	0.00	0.00	0.03
22-May-25	0.00	0.00	0.48	0.91	0.00	0.00	0.00	0.00	22.12	0.00	1.06	0.00	0.29	0.77	0.02
23-May-25	0.00	0.00	0.82	0.86	0.00	0.00	0.00	0.00	22.00	0.00	1.11	0.00	2.86	1.69	0.03
24-May-25	0.00	0.00	1.12	0.99	0.00	0.00	0.00	0.00	22.05	0.00	1.00	0.00	0.00	1.11	0.03
25-May-25	0.00	0.00	0.81	0.76	0.00	0.00	0.00	0.00	22.22	0.00	1.34	0.00	1.35	1.56	0.02
26-May-25	0.00	0.00	0.49	1.11	0.00	0.00	0.00	0.00	17.96	0.00	1.14	0.71	0.00	1.68	0.02
27-May-25	0.00	0.00	0.13	0.07	0.00	0.00	0.00	0.00	21.81	0.00	1.21	0.69	0.00	1.61	0.02
28-May-25	0.00	0.00	0.12	0.47	0.00	0.00	0.00	0.00	22.33	0.00	1.04	0.71	0.00	0.32	0.02
29-May-25	0.00	0.00	0.00	0.51	0.00	0.00	0.00	0.00	22.50	0.00	1.09	0.70	0.00	0.37	0.02
30-May-25	0.00	0.00	0.00	0.13	0.00	0.00	0.00	0.00	17.73	0.00	1.19	1.01	0.00	0.39	0.02
31-May-25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.12	0.00	1.20	0.20	0.00	0.00	0.03
Total	**0.00**	**5.79**	**36.96**	**27.26**	**0.00**	**0.00**	**0.00**	**3.03**	**678.06**	**0.03**	**33.05**	**21.77**	**98.25**	**60.51**	**0.74**

Based on SEM/Energy meter data for links where available (*Mangdechu generation reciept at APD through a bypassed arrangement at 400kV Punatsanchu station)

17. एसटीओए (द्विपक्षीय एवं सामूहिक) एवं डी एस एम बिलिंग का ब्योरा – मई 2025

STOA (BILATERAL AND COLLECTIVE) & DSM BILLING DETAILS - MAY 2025

द्विपक्षीय एसटीओए BILATERAL SHORT TERM OPEN ACCESS

मई 2025 MAY 2025			Apr'25- Mar'26	
नोडल क्षे.भा.प्रे.के. का नाम Name of Nodal RLDC	अनुमोदित लेन – देनों की संख्या No. of Approved Transactions	अनुमोदित ऊर्जा (मि.यु.) Energy Approved(MU)	अनुमोदित लेन – देनों की संख्या No. of Approved Transactions	अनुमोदित ऊर्जा (मि.यु.) Energy Approved (MU)
ऊ. क्षे. NR	1339	2030	1822	2508
प.क्षे. WR	1067	868	2304	2030
द.क्षे. SR	416	3036	829	7184
पू.क्षे. ER	572	1362	1185	2545
पूर्वोत्तर क्षे. NER	78	250	136	417
कुल TOTAL	3472	7546	6276	14684

एसटीओए SHORT TERM OPEN ACCESS

	सामूहिक एसटीओए Collective STOA		द्विपक्षीय एसटीओए Bilateral STOA	
माह MONTH	क्रेताओं / विक्रेताओं की स. NO. of Buyers/Sellers	अनुमोदित ऊर्जा (मि.यु.) Approved Energy (MU)	अनुमोदित लेन – देनों की संख्या No. of Approved Transactions	अनुमोदित ऊर्जा (मि.यु.) Approved Energy (MU)
अप्रैल 2025 Apr'25	13712	9041	2804	7138
मई 2025 May'25	14344	9129	3472	7546
कुल TOTAL	28056	18170	6276	14684

मासिक डी एस एम बिलिंग का ब्योरा* 2025-26
MONTHLY DSM BILLING DETAILS* 2025-26

अनंतिम आँकड़े
Provisional data subject to change

करोड़ रु. मे (RS. IN CRORES)

क्षेत्र REGION → / सप्ताह WEEK ↓	उत्तरी क्षेत्र NORTH	पश्चिमी क्षेत्र WEST	दक्षिणी क्षेत्र SOUTH	पूर्वी क्षेत्र EAST	पूर्वोत्तर क्षेत्र NORTH EAST
05.05.25 to 11.05.25	309.83	327.94	21.11	303.19	43.45
12.05.25 to 18.05.25	337.92	380.59	78.38	340.43	42.78
19.05.25 to 25.05.25	238.96	295.72	30.09	219.70	37.08
26.05.25 to 01.06.25	136.65	247.86	16.86	142.92	5.55

* Amount shown is Payble to DSM pool ^Provisional Data

18. पावर मार्केट की सूचना (स्रोत : आई.ई.एक्स. एवं पी.एक्स.आई.एल.)
POWER MARKET INFORMATION (Source IEX & PXIL)

पावर एक्स्चेंज के माध्यम से विनिमय – माह:- मई 2025
EXCHANGES THROUGH POWER EXCHANGES -MAY 2025

क्र. स. S. No.	क्षेत्रीय इकाई Regional Entity	क्षेत्र Region	पावर एक्स्चेंज के माध्यम से (मि.यु. मे) Through Power Exchange in MU	
			(DAM+HP DAM+RTM)	
1	ACME SIKAR SOLAR PRIVATE LIMITED		10.65	0.00
2	ACME SIKAR SOLAR PRIVATE LIMITED_INFIRM		0.73	0.00
3	AD HYDRO POWER LIMITED		73.06	0.00
4	ADANI GREEN ENERGY TWENTY FIVE LIMITED		122.06	0.00
5	ADANI GREEN ENERGY TWENTY FOUR LIMITED		108.01	0.00
6	ADANI SOLAR ENERGY JAISALMER TWO PRIVATE LIMITED(Project-2)		24.12	0.00
7	ADANI SOLAR ENERGY JODHPUR TWO LIMITED		10.69	0.00
8	AMP Energy Green Four Private Limited		21.25	0.00
9	Adept Renewable Technologies Private Limited		27.93	0.00
10	Amp Energy Green Six Private Limited		26.34	0.00
11	Amplus Ages Private Limited		3.00	0.00
12	Budhil HEP (Greenko Budhil Hydro Power Pvt. Ltd.)		6.08	0.00
13	Chandigarh (UT)		43.23	15.34
14	Delhi		406.79	106.01
15	Gorbea Solar Private Limited_Infirm		0.58	0.00
16	Government of Himachal Pradesh _ Chamera1HEP		12.62	2.47
17	Government of Himachal Pradesh _ Chamera3HEP		12.68	1.10
18	Government of Himachal Pradesh_ CHAMERA2HEP		14.17	1.95
19	Government of Himachal Pradesh_BairasuilHEP		7.55	1.09
20	Government of Himachal Pradesh_Koldam HEP		18.42	2.61
21	Government of Himachal Pradesh_NJHPS		47.28	3.27
22	Government of Himachal Pradesh_Parbati2HEP		21.95	3.67
23	Government of Himachal Pradesh_Parbati3HEP		13.79	3.11
24	Government of Himachal Pradesh_RampurHEP		20.00	0.67
25	Grian Energy Private Limited		4.55	0.00
26	Haryana		301.76	138.82
27	Himachal Pradesh		262.19	32.33
28	IGSTPS JHAJJAR		11.13	0.00
29	JUNIPER GREEN COSMIC PRIVATE LIMITED		19.05	0.00
30	JUNIPER NIRJARA ENERGY PRIVATE LIMITED		4.72	0.00
31	Jammu Kashmir		323.84	68.36
32	KARCHAM WANGTOO HYDRO ELECTRIC PLANT.		83.13	0.00
33	NEA - UP STU		0.00	16.77
34	NEA Nepal Upper Chameliya Hydropower Project		0.26	0.00
35	NEPAL ELECTRICITY AUTHORITY TANAKPUR	उत्तरी क्षेत्र NR	0.00	16.01
36	NTPC Dadri Stage I		4.76	0.00
37	NTPC Dadri Stage II		22.40	0.00
38	NTPC Rihand stage I		13.02	0.00
39	NTPC Rihand stage II		11.70	0.00
40	NTPC Rihand stage III		16.27	0.00
41	NTPC Singrauli		20.93	0.00
42	NTPC Tanda Stage II		7.81	0.00
43	NTPC Unchahar Stage I		3.03	0.00
44	NTPC Unchahar Stage II		3.10	0.00

18. पावर मार्केट की सूचना (स्रोत : आई.ई.एक्स. एवं पी.एक्स.आई.एल.) POWER MARKET INFORMATION (Source IEX & PXIL)				
पावर एक्स्चेंज के माध्यम से विनिमय – माह:- मई 2025 EXCHANGES THROUGH POWER EXCHANGES -MAY 2025				
क्र. स. S. No.	क्षेत्रीय इकाई Regional Entity	क्षेत्र Region	पावर एक्स्चेंज के माध्यम से (मि.यु. मे) Through Power Exchange in MU	
			(DAM+HP DAM+RTM)	
45	NTPC Unchahar Stage III		1.52	0.00
46	NTPC Unchahar Stage IV		6.52	0.00
47	Neemba Solar Plant Renew Surya Vihaan Private Limited(NSPRVPL)		12.45	0.00
48	North Central Railway Prayagraj		0.00	26.23
49	Onevolt Energy Private Limited		3.90	0.00
50	Punjab		95.81	1058.35
51	RENEW SURYA PRATAP PRIVATE LIMITED		48.45	0.00
52	RENEW SURYA ROSHNI PRIVATE LIMITED-Fatehgarh-III PS		0.10	0.00
53	Rajasthan		237.39	328.11
54	ReNew Surya Ravi Private Limited		49.21	0.00
55	Renew Surya Jyoti Private Limited		8.80	0.00
56	SHREE CEMENT LIMITED TPS		30.76	5.86
57	Sainj HEP		20.72	1.40
58	Serentica Renewables India 4 Private Limited		2.05	0.00
59	Serentica Renewables India 5 Private Limited		8.30	0.00
60	Singoli Bhatwari HEP		21.66	0.00
61	Sorang HEP (Himachal Sorang Power Pvt. Ltd.))		17.92	0.00
62	TPSL 200MW TPTCL Banderwala		22.10	0.00
63	TPSL Banderwala SECI 100_INF		3.28	0.00
64	Transition Cleantech Services Private Limited		2.34	0.00
65	Transition Energy Services Private Limited		12.91	0.00
66	Transition Green Energy Private Limited		2.15	0.00
67	Transition Sustainable Energy Services One Private Limited		14.26	0.00
68	Uttar Pradesh		275.99	756.37
69	Uttarakhand		71.92	146.70
70	ACB (INDIA) LIMITED		24.30	0.13
71	ADANI GREEN ENERGY TWENTY FOUR LIMITED_PSS4		28.62	0.00
72	ADANI GREEN ENERGY TWENTY SIX A LIMITED_PSS-3		2.55	0.00
73	ADANI HYBRID ENERGY JAISALMER FIVE LIMITED_PSS4		11.46	0.00
74	ADANI HYBRID ENERGY JAISALMER FIVE LIMITED_PSS5_Solar		21.67	0.00
75	ADANI PORTS AND SPECIAL ECONOMIC ZONE LIMITED (PSS-3)		35.49	0.00
76	ADANI RENEWABLE ENERGY FIFTY FIVE LIMITED_PSS-3 (162.5 MW Hybrid Solar of 187.5MW HPD)		33.48	0.00
77	ADANI RENEWABLE ENERGY FIFTY FIVE LIMITED_PSS3 (20.8 MW Hybrid Wind of 25 MW of 187.5MW HPD)		1.63	0.00
78	ADANI RENEWABLE ENERGY FIFTY FIVE LIMITED_PSS3 (25 MW Hybrid Solar of 25 MW of 187.5MW HPD)		0.54	0.00
79	ADANI RENEWABLE ENERGY FIFTY SEVEN LIMITED_PSS13		82.38	0.00
80	ADANI RENEWABLE ENERGY FIFTY SEVEN LIMITED_PSS13_infirm		0.03	0.00
81	ADANI RENEWABLE ENERGY FIFTY SIX LIMITED_PSS4		44.33	0.00
82	ADANI RENEWABLE ENERGY FIFTY SIX LIMITED_PSS9		35.16	0.00
83	ADANI RENEWABLE ENERGY FORTY FIVE LIMITED_PSS5		10.22	0.00
84	ADANI RENEWABLE ENERGY FORTY ONE LIMITED_PSS-3		13.66	0.00
85	ADANI RENEWABLE ENERGY FORTY ONE LIMITED_PSS13		11.34	0.00
86	ADANI RENEWABLE ENERGY FORTY ONE LIMITED_PSS4		14.30	0.00
87	ADANI RENEWABLE ENERGY HOLDING FOUR LIMITED_PSS-1		190.91	0.00
88	ADANI WIND ENERGY KUTCHH FOUR Ltd. Nakhatrana		45.34	0.00
89	AMBUJA CEMENTS LIMITED_PSS3		4.42	0.00
90	AMBUJA CEMENTS LIMITED_PSS4_Hybrid Wind		27.81	0.00
91	Adani Green Energy Twenty Five A Limited_PSS-2		97.34	0.00
92	Adani Green Energy Twenty Five B Limited_PSS-2		105.95	0.00
93	Adani Green Energy Twenty Four A Limited_PSS-3		77.17	0.00
94	Adani Green Energy Twenty Six B Limited_PSS-2		36.26	0.00
95	Adani Ports and Special Economic Zone Limited_PSS4_Wind		16.08	0.00

18. पावर मार्केट की सूचना (स्रोत : आई.ई.एक्स. एवं पी.एक्स.आई.एल.) POWER MARKET INFORMATION (Source IEX & PXIL)				
पावर एक्स्चेंज के माध्यम से विनिमय – माह:- मई 2025 EXCHANGES THROUGH POWER EXCHANGES -MAY 2025				
क्र. स. S. No.	क्षेत्रीय इकाई Regional Entity	क्षेत्र Region	पावर एक्स्चेंज के माध्यम से (मि.यु. मे) Through Power Exchange in MU	
			(DAM+HP DAM+RTM)	
96	Adani Power Limited - Raigarh TPP	पश्चिमी क्षेत्र WR	18.42	35.08
97	Adani Power Limited-Raipur TPP		24.93	94.38
98	Adani Renewable Energy Fifty Six Limited_PSS10		19.50	0.00
99	Adani Renewable Energy Forty Eight Limited (Wind)_PSS-9		18.54	0.00
100	ArcelorMittal Nippon Steel India Private Limited		0.00	121.92
101	BHARAT ALUMINIUM COMPANY LTD		32.39	0.00
102	CONTINUUM POWER TRADING (TN) PRIVATE LIMITED		5.17	0.00
103	Chhattisgarh		256.02	15.41
104	D B Power Limited		25.75	0.00
105	DGEN MEGA POWER PROJECT		21.66	0.91
106	Daman and Diu - Dadra and Nagar Haveli		0.44	114.60
107	Dhariwal ISTS		3.61	0.00
108	GMR Warora Energy Limited		0.42	0.00
109	Goa WR		25.85	4.37
110	Gujarat		60.89	606.17
111	Jaypee Nigrie Super Thermal Power Plant		20.83	0.00
112	Jhabua Power Limited		2.19	13.84
113	Jindal Power Limited, Stage-1		66.06	0.00
114	Jindal Power Limited, Stage-2		136.40	11.66
115	Jindal Steel & Power Ltd , DCPP		25.60	2.51
116	KSK MAHANADI POWER COMPANY LIMITED		15.98	0.00
117	LANCO AMARKANTAK POWER LIMITED		2.41	0.00
118	MAHAN ENERGEN LIMITED U#1		0.00	3.38
119	MAHAN ENERGEN LIMITED U#2		12.37	4.49
120	MB POWER (MADHYA PRADESH) LIMITED		87.36	5.85
121	Madhya Pradesh		167.73	324.49
122	Maharashtra		225.11	729.93
123	Maruti Clean Coal and Power Limited		5.32	1.27
124	NTPC Gadarwara		19.56	0.00
125	NTPC Jhanor Gandhar GPS		0.00	0.73
126	NTPC Kawas GPS		0.00	0.54
127	NTPC Korba Stage I &II		38.81	0.00
128	NTPC Korba Stage III		12.79	0.00
129	NTPC Lara Stage I		30.39	0.00
130	NTPC Mouda Stage I		15.70	0.00
131	NTPC Mouda Stage II		20.44	0.00
132	NTPC SAIL POWER COMPANY LIMITED		0.45	0.00
133	NTPC Sipat Stage I		47.61	0.00
134	NTPC Sipat Stage II		26.43	0.00
135	NTPC Solapur		7.73	0.00
136	NTPC Vindhyachal Stage I		27.80	0.00
137	NTPC Vindhyachal Stage II		18.41	0.00
138	NTPC Vindhyachal Stage III		22.56	0.00
139	NTPC Vindhyachal Stage IV		11.61	0.00
140	NTPC Vindhyachal Stage V		12.45	0.00
141	NTPC khargone		10.71	0.00
142	Nani Virani Wind Energy Private Limited		1.68	0.00
143	R.K.M POWERGEN PRIVATE LIMITED		1.78	0.00
144	RENEW GREEN (MHS ONE) PRIVATE LIMITED_SOLAR_HYBRID		2.12	0.00
145	Ratnagiri Gas & Power Private Limited		0.16	2.27
146	Reliance Industries Limited Jamnagar		0.00	89.53

18. पावर मार्केट की सूचना (स्रोत : आई.ई.एक्स. एवं पी.एक्स.आई.एल.) POWER MARKET INFORMATION (Source IEX & PXIL)				
पावर एक्स्चेंज के माध्यम से विनिमय – माह:- मई 2025 EXCHANGES THROUGH POWER EXCHANGES -MAY 2025				
क्र. स. S. No.	क्षेत्रीय इकाई Regional Entity	क्षेत्र Region	पावर एक्स्चेंज के माध्यम से (मि.यु. मे) Through Power Exchange in MU (DAM+HP DAM+RTM)	
147	SKS Power Generation Chhattisgarh Limited		17.35	47.09
148	Sasan Power Limited		27.66	0.00
149	TRN ENERGY PRIVATE LIMITED		17.20	0.00
150	The Tata Power Co Ltd (MTPS)		8.10	0.00
151	WIND FIVE RENERGY LIMITED		7.43	0.00
152	AM GREEN ENERGY PRIVATE LIMITED Solar		24.76	0.00
153	AM GREEN ENERGY PRIVATE LIMITED Wind		2.24	0.00
154	Andhra Pradesh		113.27	467.32
155	COASTAL ENERGEN PRIVATE LIMITED		2.04	21.50
156	Goa SR		0.57	2.99
157	Greenko AP01 IREP Private Limited_Start UP		0.00	4.21
158	IL&FS TAMIL NADU POWER COMPANY LIMITED		9.92	0.00
159	JINDAL POWER LIMITED SIMHAPURI		1.77	9.55
160	Karnataka		462.47	48.69
161	Kerala		71.95	141.54
162	Lanco Kondapalli Power Limited STG2		2.45	0.00
163	MEENAKSHI ENERGY LIMITED		0.17	26.44
164	NLC INDIA LIMITED NEYVELI NEW THERMAL POWER STATION		24.08	0.00
165	NLC INDIA LIMITED THERMAL POWER STATION I EXPANSION		8.40	0.00
166	NLC INDIA LIMITED THERMAL POWER STATION II EXPANSION		1.96	0.00
167	NLC INDIA LIMITED THERMAL POWER STATION II STAGE I		3.94	0.00
168	NLC INDIA LIMITED THERMAL POWER STATION II STAGE II		5.22	0.00
169	NLC Tamilnadu Power Limited		7.18	0.00
170	NTECL VALLUR	दक्षिणी क्षेत्र SR	4.51	0.00
171	NTPC KUDGI		8.85	0.00
172	NTPC Ramagundam Stage I &II		12.67	0.00
173	NTPC Ramagundam Stage III		2.90	0.00
174	NTPC Simhadri Stage I		2.12	0.00
175	NTPC Simhadri Stage II		4.99	0.00
176	NTPC Talcher Super Thermal Power Station Stage II		35.18	0.00
177	NTPC Telangana		1.22	0.00
178	OSTRO KANNADA POWER PRIVATE LIMITED		16.39	0.00
179	Pondicherry UT		17.66	1.61
180	RENEW SURYA ROSHNI PRIVATE LIMITED Koppal PS		6.46	0.00
181	Ramagundam Floating solar		9.57	0.00
182	ReNew Surya Roshni Private Limited_Gadag		0.16	0.00
183	SEIL ENERGY INDIA LIMITED		40.95	0.00
184	SEIL Energy India Limited Project II		1.27	0.00
185	Serentica Renewables India 1 Private Limited		0.29	0.00
186	Simhadri FSP 15 MW		1.81	0.00
187	Tamil Nadu		794.69	386.42
188	Telangana		34.48	955.73
189	Zenataris Renewable Energy Private Limited		9.19	0.00
190	ADHUNIK POWER & NATURAL RESOURCES LIMITED		2.46	0.00
191	Basochhu Hydropower Plant Bhutan		4.62	0.00
192	Bihar		383.91	104.18
193	Chuzachen HEP		0.07	0.00
194	Damodar Valley Corporation		26.59	291.85
195	Dikchu Hydro Electric Project (Sneha Kinetic Power Projects Pvt. Ltd.)		27.56	0.00
196	GMR KAMALANGA ENERGY LTD-CTU		2.00	0.00
197	IND BARATH ENERGY UTKAL LIMITED		0.20	29.14

18. पावर मार्केट की सूचना (स्रोत : आई.ई.एक्स. एवं पी.एक्स.आई.एल.) POWER MARKET INFORMATION (Source IEX & PXIL)				
पावर एक्स्चेंज के माध्यम से विनिमय – माह:- मई 2025 EXCHANGES THROUGH POWER EXCHANGES -MAY 2025				
क्र. स. S. No.	क्षेत्रीय इकाई Regional Entity	क्षेत्र Region	पावर एक्स्चेंज के माध्यम से (मि.यु. मे) Through Power Exchange in MU	
			(DAM+HP DAM+RTM)	
198	JORETHANG LOOP HEP, DANS ENERGY PRIVATE LIMITED	पूर्वी क्षेत्र ER	0.08	0.00
199	Jharkhand		53.99	96.62
200	Jindal India Power Limited		11.31	0.00
201	KALI GANDAKI NEPAL ELECTRICITY AUTHORITY		11.66	0.00
202	KANTI BIJLEE UTPADAN NIGAM LIMITED		4.53	0.00
203	LIKHU-iV NEA		0.03	0.00
204	Lower Modi Hydro Power Project NEPAL ELECTRICITY AUTHORITY		0.81	0.00
205	MAITHON POWER LIMITED		5.49	0.00
206	MARSYANGDI NEPAL ELECTRICITY AUTHORITY		2.55	0.00
207	NABINAGAR POWER GENERATING COMPANY LIMITED		27.79	0.00
208	NEA - Bihar STU		0.00	50.64
209	NEA Nepal Dordi Khola Hydropower Project		1.28	0.00
210	NEA Nepal Solu Khola (Dudhkoshi) Hydropower Project		9.75	0.00
211	NEA Nepal Upper Balephi A Hydropower Project1		1.31	0.00
212	NEA Nepal Upper Dordi A Hydropower Project		0.94	0.00
213	NEPAL ELECTRICITY AUTHORITY MUZAFFARPUR		0.00	99.20
214	NEPAL ELECTRICITY AUTHORITY-MIDDLE MARSYANGDI		2.28	0.00
215	NTPC BARH Stage I		5.32	0.00
216	NTPC BARH Stage II		6.25	0.00
217	NTPC Darlipali		9.15	0.00
218	NTPC Farakka stage I		24.84	0.00
219	NTPC Farakka stage III		7.84	0.00
220	NTPC Kahalgaon stage I		11.66	0.00
221	NTPC Kahalgaon stage II		21.20	0.00
222	NTPC North Karanpura STPS		10.90	0.00
223	NTPC Talcher Stage I		7.98	0.00
224	NTPP BRBCL		7.06	0.00
225	Nikachhu Hydropower Project		3.07	0.00
226	Odisha		248.82	400.70
227	Sikkim		2.93	14.72
228	Suchhu HEP		0.01	0.00
229	Tashiding HEP, Shiga Energy Private Limited		0.03	0.00
230	West Bengal		161.35	901.64
231	AGARTALA GAS BASED POWER STATION	पूर्वोत्तर क्षेत्र NER	7.00	0.00
232	ASSAM GAS BASED POWER STATION		0.96	0.00
233	Arunachal Pradesh		20.52	6.58
234	Assam		357.97	10.28
235	Bongaigaon Thermal Power Station NTPC		3.75	0.00
236	KAMENG HYDRO POWER STATION		25.06	0.00
237	Manipur		2.97	24.66
238	Meghalaya		27.58	45.11
239	Mizoram		6.73	0.00
240	Nagaland		5.13	7.61
241	Palatana Plant		1.47	0.00
242	Tripura		14.59	12.46
	Total		**9129**	**9129**

19. INFORMATION ABOUT RENEWABLE ENERGY CERTIFICATE MECHANISM

MONTH : MAY 2025

RE Source & Unit wise break up (01.05.2025-31.05.2025)

Sr.No	Source Wise	Accreditation		Registration	
		Capacity (MW)	Unit	Capacity (MW)	Unit
1	Wind	3	1	17	8
2	Urban or Municipal Waste	0	0	0	0
3	Solar Thermal	0	0	0	0
4	Solar PV	303	2	163	1
5	Small Hydro	0	0	0	0
6	Others	0	0	0	0
7	Geothermal	0	0	0	0
8	Biomass	0	0	0	0
9	Bio-fuel cogeneration	0	0	0	0
	Total	**306**	**3**	**180**	**9**

RECs Issued (01.05.2025-31.05.2025)

Sr.No.	Non Solar	Solar	Total
1	666242	114276	780518

Redemption of REC (01.05.2025-31.05.2025)

Sr.No.	Non Solar	Solar	Total
1	2281571	47086	2328657

19. INFORMATION ABOUT RENEWABLE ENERGY CERTIFICATE MECHANISM

MONTH : MAY 2025

RE Source & Unit wise break up (Apr'25-Mar'26)

Sr.No	Source Wise	Accreditation		Registration	
		Capacity (MW)	Unit	Capacity (MW)	Unit
1	Wind	3	1	17	8
2	Urban or Municipal Waste	0	0	0	0
3	Solar Thermal	0	0	0	0
4	Solar PV	646	4	1213	4
5	Small Hydro	0	0	14	1
6	Others	0	0	0	0
7	Geothermal	0	0	0	0
8	Biomass	0	0	0	0
9	Bio-fuel cogeneration	0	0	0	0
	Total	**649**	**5**	**1244**	**13**

RECs Issued (Apr'25-Mar'26)

Sr.No.	Non Solar	Solar	Total
1	2635022	165204	2800226

Redemption of REC (Apr'25-Mar'26)

Sr.No.	Non Solar	Solar	Total
1	2909046	65958	2975004

19. INFORMATION ABOUT RENEWABLE ENERGY CERTIFICATE MECHANISM

MONTH : MAY 2025

RE Source & Unit wise break up Since Inception to May'25

Sr.No	Source Wise	Accreditation		Registration	
		Capacity (MW)	Unit	Capacity (MW)	Unit
1	Wind	3348	543	3164	539
2	Urban or Municipal Waste	12	1	12	1
3	Solar Thermal	0	0	0	0
4	Solar PV	6180	596	3925	504
5	Small Hydro	883	44	895	46
6	Others	4	2	3	1
7	Geothermal	0	0	0	0
8	Biomass	402	37	378	35
9	Bio-fuel cogeneration	823	91	383	55
	Total	**11652**	**1314**	**8760**	**1181**

RECs Issued since Inception to May'25

Sr.No.	Non Solar	Solar	Total
1	158579102	14914042	173493144

Redemption of REC since Inception to May'25

Sr.No.	Non Solar	Solar	Total
1	110928822	13072774	124001596

REC Closing balance as on 31.05.2025

Sr.No.	Non Solar	Solar	Total
1	37621329	1524842	39146171

20.Details of Grid Events during the Month of May 2025

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
1	GI-2	Punjab	02-05-2025 00:00	02-05-2025 01:29	01:29	0	110	0.000	0.180	47275	61029	i)400/220KV Ludhiana has one and half breaker scheme at 400KV level and has double main transfer scheme at 220KV level. ii)As reported, at 00:00hrs, due to operation of 220KV Bus Bar 2 protection 220KV Bus 2 at Ludhiana(PG) tripped. The tripping details for the exact cause of Bus Bar protection are still awaited. iii)Due to the bus bar protection operation, 400/220 kV 500 MVA ICT 1 & 4 at Ludhiana(PG) and 220 KV feeders to Pakowal, Jagraon, Dandhari Kalan-I and Lalto kaalan-II tripped. iv)As per PMU at Malerkotla(PG), R-N phase to earth fault with delayed fault clearance time of respectively 320ms is observed. v)As per SCADA, change in demand of approx. 110MW is observed in Punjab control area.	i)220 KV Ludhiana(PG)-Laltokalan(PS) (PSTCL) Ckt-2 ii)400/220 kV 500 MVA ICT 4 at Ludhiana(PG) iii)400/220 kV 500 MVA ICT 1 at Ludhiana(PG) iv)220 KV Pakhowal(PS)-Ludhiana(PG) (PSTCL) Ckt-1 v)220KV Bus 2 at Ludhiana(PG)
2	GD-1	Haryana	02-05-2025 04:25	02-05-2025 07:32	03:07	0	167	0.000	0.331	41911	50452	i)400/220/132kV Kabulpur sub-station has one and half breaker arrangement at 400kV side and double main and transfer bus scheme in 220KV side . ii)During antecedent condition, 400 KV Bhiwani(PG)-Kabulpur(HV) (PG) was out of service along with 400/220 KV 315MVA ICT-1. iii)As reported, at 04:25 hrs, 400 KV CLP Jhajjar(CLP)-Kabulpur(HV) (HVPNL) Ckt-2 tripped on R-N phase to earth fault. As per DR, Z-2 distance protection operated, with fault current of 5.06 KA and the fault distance was 60.9KM from Jhajjar end. iv)At the same time, 400 KV CLP Jhajjar(CLP)-Kabulpur(HV) (HVPNL) Ckt-1 tripped on R-N phase to earth fault. As per DR, Z-2 distance protection operated, with fault current of 5.23 KA the fault distance was 58.23KM from Jhajjar end. v)During the same time, 400 KV Deepalpur(JHKT)-Kabulpur(HV) (HVPNL) Ckt-1, Ckt-2, 400 KV Bahadurgarh(PG)- Kabulpur(HV) (PG) Ckt-1 and 400/220 KV ICT-2 at Kabulpur(HV) tripped (tripping details awaited). vi)Since the fault was not cleared at 400KV, it led to subsequent complete tripping of all transmission elements at 220KV and 132KV voltage level. This led to blackout of 400/220/132KV station. (Details of protection operation and sequence of tripping not received yet from Haryana) vii)As per PMU at Gurgaon(PG), R-N phase to earth fault is observed with delayed fault clearance of 480msec. viii)As per SCADA, change in demand of approx. 167MW in Haryana controlled area are observed.	i)400 KV Deepalpur(JHKT)-Kabulpur(HV) (HVPNL) Ckt-1 ii)400 KV Deepalpur(JHKT)-Kabulpur(HV) (HVPNL) Ckt-2 iii)400 KV CLP Jhajjar(CLP)-Kabulpur(HV) (HVPNL) Ckt-1 iv)400 KV CLP Jhajjar(CLP)-Kabulpur(HV) (HVPNL) Ckt-2 v)400 KV Bahadurgarh(PG)- Kabulpur(HV) (PG) Ckt-1 vi)400/220 KV ICT-2 at Kabulpur(HV)
3	GD-1	Haryana	02-05-2025 05:22	02-05-2025 08:00	02:38	763	0	1.936	0.000	39417	45990	i)400kV Jhajjar(APCPL) has one and half breaker arrangement at 400kV side. ii)During antecedent condition, 660MW Unit 1, 2 at Jhajjar(CLP) were generating approx. 374MW and 390MW each. Unit 3 was under shutdown and 400 KV CLP Jhajjar(CLP)-Kabulpur(HV) (HVPNL) Ckt-1 and Ckt-2 were already under tripped condition. iii)As reported, at 05:22 hrs, Jhajjar(CLP)(end)-Dhanoda(HV) (HVPNL) Ckt-1 & 2 tripped (exact reason of tripping yet to be received). As per DR of 400 KV CLP Jhajjar (CLP)(end)-Dhanoda (HV) (HVPNL) Ckt-1 & 2 submitted, there was a momentary loss of current in all the 3 phases. However, no fault was observed in the DR. iv)Following this, 660 MW JHAJJAR(CLP) - UNIT 1 and 2 also tripped due to loss of evacuation path. This led to complete blackout of 400KV Jhajjar sub-station. v)As per PMU at Gurgaon(PG), no fault in system is observed. vi)As per SCADA, generation loss of 763MW (at Jhajjar CLP) in Haryana controlled area are observed.	ii)400 KV CLP Jhajjar(CLP)-Dhanoda(HV) (HVPNL) Ckt-1 iii)400 KV CLP Jhajjar(CLP)-Dhanoda(HV) (HVPNL) Ckt-2 iv)660 MW JHAJJAR(CLP) - UNIT 2 v)660 MW JHAJJAR(CLP) - UNIT 1
4	GD-1	Haryana	02-05-2025 05:22	02-05-2025 08:00	02:38	0	288	0.000	0.626	39417	45990	i)400kV Dhanoda has one and half breaker scheme in 400KV voltage level. ii)During antecedent condition, 400 KV Gurgaon(PG)-Daulatabad(HV) (HV) Ckt-1, Ckt-2, 400 KV JHAJJAR(APCL)-DAULATABAD(HV) (HV) CKT-1 and Ckt2 and 400KV Dhanoda-Daulatabad (HV) Ckt-1 were already in tripped condition. 400KV Dhanoda-Daulatabad (HV) Ckt-2 (carrying ~409MW) and 400/220kV ICT-1,2,3&4 were under running condition. iii)As reported, at 05:23 hrs, 400 KV Dhanoda-Daulatabad (HV) Ckt-2 tripped. The tripping details are yet to be received from Haryana. iv)As per PMU at Gurgaon(PG), B-N phase to earth fault with delayed fault clearance of 600msec is observed. v)As 400 KV Dhanoda-Daulatabad (HV) Ckt-2 was the only element which was catering power to the 220KV side, loss of the aforementioned line caused tripping of 400KV Bus1 along 400/220 KV ICT 1,2,3 &4. vi)Loss of all transmission elements in 400KV system, resulted in Blackout of 400KV Daulatabad Sub station. vii)As per SCADA, change in demand of approx. 288MW in Haryana controlled area are observed.	i) 400 KV Dhanoda-Daulatabad (HV) Ckt-2
5	GD-1	Uttar pradesh	03-05-2025 15:32	03-05-2025 16:18	00:46	1040	90	1.919	0.158	54189	56830	i)765/220KV Lalitpur Sub-station has one and half breaker scheme at 765kV level and double main transfer bus scheme at 220kV level. ii)During antecedent condition, 765/220kV 315MVA ICT-1, 220kV feeders to Jhansi, Lalitpur220-I and 100MVA ST-2 were on 220kV Bus-1 at Lalitpur(UP). Remaining elements were on 220kV Bus-2. iii)Supply to motor driven Boiler Feed Pump(BFP) for 660 MW Unit-1 was fed from 100MVA ST-1 and BFP for Unit-2&3 were being fed from 100 MVA ST-2. Motor driven BFP are being used for speed control operation of unit during house load operation. At a time, only one unit is selected for house load operation in case of SPS operation. During the event, 660MW unit-3 was in selection for house load operation on SPS operation. iv)At 15:19:50 hrs, 220KV Lalitpur-Babina Ckt tripped on R-N fault, Fault was in Z-1 from Lalitpur end (Ir=10.7kA). Line tripped on fault in reclaim time. v)Further at 15:26:11hrs, B-N fault (Ib=2.7kA, Z-1 from Lalitpur) occurred on 220 KV Lalitpur –Jhansi (UP) Ckt and A/R started. During Auto reclosing condition, the LBB relay of Jhansi bay sensed the pickup current in B-ph and initiated tripping of 220kV Bus-1 leading to tripping of all the elements connected to 220kV Bus-1 at Lalitpur(UP) i.e., 765/220kV 315MVA ICT-1, 220kV feeders to Jhansi, Lalitpur220-I and 100MVA ST-2. vi) Further at 15:32:37 hrs, B-N fault occurred on 765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-1 and A/R started. At the same instant, 765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-2 tripped on operation of OV stage-2 protection. As per DR of line, voltage of R-ph of 765kV Lalitpur-Agra Fatehabad line-II increased from 441kV to ~845kV for ~140msec. vii)Further, after dead time of A/R operation, 765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-1 also tripped due to permanent nature of fault. viii)As per PMU at Agra765(PG), B-N phase to earth fault with delayed clearance of ~560msec is observed.ix)Due to tripping of both the 765kV evacuating lines, case-4 for SPS for safe evacuation of Lalitpur generation operated. As per SPS case-4, in case of tripping of both the 765kV lines, one 660MW unit (in this case unit-30 shall come to house load and remaining unit shall trip. 220kV lines to Lalitpur and Jhansi shall also trip.x)However, as 100MVA ST-2 already tripped at 15:26 hrs during LBB operation of 220kV Bus-1, BFP for Unit-3 was not available and therefore, 660MW Unit-3 also tripped along with 660MW Unit-1&2. 220kV line to Lalitpur(2nd ckt) also tripped on SPS operation.xi)Due to tripping of both the units and all the 220kV feeders on loss of evacuation path and SPS operation, complete 765/220kV Lalitpur S/s got blackout. xii) As per SCADA, generation loss of 1040MW at Lalitpur TPS (UP) and change in UP demand of ~90MW is observed.	i)220 KV Lalitpur –Babina (UP) CKT ii)220 KV Lalitpur –Jhansi (UP) CKT iii)220kV Bus-1 at Lalitpur iv)765/220kV 315MVA ICT-1 at Lalitpur(UP) v)220kV Lalitpur-Lalitpur220 ckt-1 vi)100MVA ST-2 at Lalitpur(UP) vii)765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-1 viii)765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-2 ix)660 MW Lalitpur Unit-1 x)660 MW Lalitpur Unit-2 xi)660 MW Lalitpur Unit-3 xii)220kV Lalitpur-Lalitpur220 ckt-2

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
6	GD-1	Uttar pradesh	03-05-2025 15:47	03-05-2025 16:30	00:43	1068	0	1.949	0.000	54796	55690	i)400 and 220kV side of 400/220/132kV Gr.Noida(UP) has double main & transfer bus scheme. ii)As reported, at 15:47 hrs, 400 KV Gr.Noida_2(UPC)(end)-Gr.Noida(UPC) (UP) Ckt-1 tripped on R-N phase to earth fault. The fault distance is 54.96KM and Zone 2 from 765/400KV Greater Noida s/stn and the fault current observed was Ir= 6.2KA. iii)400 KV Gr.Noida_2(UPC)(end)-Gr.Noida(UPC) (UP) Ckt-2 also tripped at same time on R phase to ground fault. The fault distance is 53.75KM and Zone 2 from 765/400KV Greater Noida s/stn and the fault current observed was Ir= 6.1KA . iv)At the same time both 400 KV Gr.Noida_2(UPC) - Bus 1 and Bus-2 tripped due to Bus Bar Z1, Z2 operation. As a result, all the transmission elements connected to 400KV tripped. As reported by SLDC UP, fault occurred due to String fail of R Phase of 400 kV Dadri-Nawada section of 400 kV Main Bus 1. (exact sequence of tripping of element and protection operation details not received yet) v)This led to blackout of 400/220/132KV Greater Noida sub-station. vi)As per PMU at Bassi(PG), R-N fault which cleared within 100msec is observed. vii)As per SCADA, change in demand of approx. 1068MW in Uttar Pradesh controlled area are observed.	i)400 KV Gr.Noida_2(UPC)-Gr.Noida(UPC) (UP) Ckt-2 ii)400 KV Gr.Noida_2(UPC)-Gr.Noida(UPC) (UP) Ckt-1 iii)400 KV Gr.Noida(UPC)-Nawada(HV) (PG) Ckt-1 iv)400 KV Dadri(NT)-Gr.Noida(UPC) (PG) Ckt-1 v)400/220 kV 315 MVA ICT 1 at Gr.Noida(UPC) vi)400/220 kV 315 MVA ICT 2 at Gr.Noida(UPC) vii)400/220 kV 500 MVA ICT 5 at Gr.Noida(UPC) viii)400/220 kV 500 MVA ICT 6 at Gr.Noida(UPC) ix)400 KV Gr.Noida_2(UPC) - Bus 2 x)400 KV Gr.Noida_2(UPC) - Bus 1
7	GI-2	Rajasthan	05-05-2025 11:53	05-05-2025 12:53	01:00	1050	0	1.978	0.000	53092	52225	i)400/220KV Jaisalmer(RS) has one and half breaker bus scheme at 400kV level and double main and transfer bus scheme at 220kV level. ii)During antecedent condition, 400/220kV 500MVA ICT-3 & 4 and 220kV line to NTPC solar, ACME solar, Infra Green Solar and Akal-I were connected at 220kV Bus-2. 400/220kV ICT-1,2&5 and 220kV lines to Akal-II, Green Power solar, Renew Power solar and O2 Power solar were connected at 220kV Bus-1. iii)As reported, at 11:53 hrs, R-N fault occurred on 220KV NTPC_Solar – Jaisalmer line due to snapping of tripped at Jaisalmer end. The fault was converted into a bus fault leading to operation of bus bar of 220kV bus-2. iv)All the elements connected at 220kV bus-2 i.e., 400/220kV 500MVA ICT-3 & 4 and 220kV line to NTPC solar, ACME solar, Infra Green Solar and Akal-I were tripped on bus bar protection operation. v)At the same time, 400/220kV 500MVA ICT-1 also tripped from both HV & LV side and 400kV Akal-Jaisalmer line tripped from Akal end only. As reported, line tripped on R-Y fault in Z-2 from Akal end. vi)As per PMU at Fatehgarh3(PG), R-N phase to earth fault converted into R-Y fault with delayed clearance of ~800msec is observed. vii)As per SCADA replay of Jaisalmer S/s, power flow in all the remaining ICTs (ICT-2 & 5) and other 220kV feeders also became zero. (reason of the same yet to be received.) viii)As per SCADA, total drop in NR solar generation of ~1050MW is observed out of which ~890MW solar generation drop observed in Rajasthan solar.	i)220KV Jaisalmer- NTPC Solar ckt ii)400/220 kV 500 MVA ICT 3 at Jaisalmer(RS) iii)400/220 kV 500 MVA ICT 4 at Jaisalmer(RS) iv)220kV Jaisalmer-ACME ckt v)220kv Jaisalmer-Green Infra ckt vi)220KV Jaisalmer-Akal Ckt 1 vii)400/220 kV 500 MVA ICT 1 at Jaisalmer(RS) viii)400 KV Akal-Jaisalmer (RS) Ckt-1
8	GI-2	Uttar Pradesh	08-05-2025 06:56	08-05-2025 08:42	01:46	184	69	0.416	0.135	44202	51156	i)400/220kV Obra-B(UP) has double main and transfer bus scheme at both 400kV and 220kV level. ii)During antecedent condition, 200 MW Obra TPS - UNIT 10 and 11 were generating approx. 108 MW and 86 MW respectively. 400/220 kV 315 MVA ICT 1 at Obra_B(UP), 400/220 KV 315 MVA ICT 2 AT OBRA_B(UP), 200 MW OBRA TPS - UNIT 10, 400 KV OBRA_B-SULTANPUR (UP) CKT-1 and 400 KV ANPARA-OBRA_B (UP) CKT-1 were connected to 400KV Bus 2 at Obra-B(UP) and rest of the elements were connected to 400KV Bus 1 at Obra-B(UP). iii)As reported, at 06:56 hrs, transformer differential protection operated for 400/220 KV 315 MVA ICT 1 & 2 AT OBRA_B(UP) This led to tripping of both ICTs. However, at the same time 400KV Bus-Bar 2 protection also operated. iv)Due to busbar protection operation, all the elements connected to 400kV Bus-2 at Obra-B(UP) tripped and Bus-2 became dead. v)At 06:58 hrs, 200 MW OBRA TPS - UNIT 11 also tripped. Details of tripping is still awaited. vi)As per PMU at Anpara-TH(UP), no fault was observed. vii)As per SCADA, 69MW change in demand is observed in UP control area. However, generation loss of approx. 184 MW occurred at Obra-B(UP).	i)400/220 KV 315 MVA ICT 1 AT OBRA_B(UP) ii)400/220 KV 315 MVA ICT 2 AT OBRA_B(UP) iii)200 MW OBRA TPS - UNIT 10 iv)400KV BUS 2 AT OBRA_B(UP) v)400 KV OBRA_B-SULTANPUR (UP) CKT-1 vi)400 KV ANPARA-OBRA_B (UP) CKT-1 vii)200 MW OBRA TPS - UNIT 11
9	GI-2	Uttar Pradesh	11-05-2025 13:49	11-05-2025 15:24	01:35	1040	0	1.753	0.000	59315	59296	i)765/220KV Lalitpur Sub-station has one and half breaker scheme at 765kV level and double main transfer bus scheme at 220kV level. ii)At 13:49 hrs, 765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-2 tripped on R-B phase to phase fault. Z-1 distance protection operated and the fault current was Iy = 3.98KA, Ib= 4.33KA. The fault distance is 121KM from Agra end. iii)During antecedent condition, 100MVA ST-2 was on 220kV Bus-1 and 100MVA ST1 was on 220KV Bus-2 at Lalitpur(UP). iv)Supply to motor driven Boiler Feed Pump(BFP) for 660 MW Unit-1 was fed from 100MVA ST-1 and BFP for Unit-2&3 were being fed from 100 MVA ST-2. Motor driven BFP are being used for speed control operation of unit during house load operation. At a time, only one unit is selected for house load operation in case of SPS operation. During the event, 660MW unit-3 was in selection for house load operation on SPS operation. v)At 13:56hrs, 765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-1 tripped on R-N phase to earth fault. Z-1 distance protection operated and the fault current was Ir = 3.68KA. As per DR, due to consecutive R-N fault during the reclaim time, the line tripped. The fault distance is 108KM from Agra end. vi)Due to tripping of both the 765kV evacuating lines, case-4 for SPS for safe evacuation of Lalitpur generation operated. As per SPS case-4, in case of tripping of both the 765kV lines, one 660MW unit (in this case unit-30 shall come to house load and remaining unit shall trip. 220kV lines to Lalitpur and Jhansi shall also trip. vii)As a result, 660 MW Lalitpur Unit-1 & Unit-2 tripped alongwith, 220 KV Lalitpur –Jhansi (UP) CKT, 220kV Lalitpur-Lalitpur220 ckt-2, 220kV Lalitpur-Lalitpur220 ckt-1 and 220 KV Lalitpur –Babina (UP) CKT tripped on SPS. viii)As per SPS, the generation of 660MW Unit-3 reduced to 70MW for house load operation. ix)As per PMU at 765KV Agra(PG), two consecutive R-N phase to phase faults with fault clearing time of 120ms is observed. x)As per SCADA, generation loss of 1040MW at Lalitpur TPS (UP) and no change in demand in SLDC UP control area is observed.	i)765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-2 ii)220 KV Lalitpur –Jhansi (UP) CKT iii)220kV Lalitpur-Lalitpur220 ckt-2 iv)220kV Lalitpur-Lalitpur220 ckt-1 v)660 MW Lalitpur Unit-1 vi)660 MW Lalitpur Unit-2 vii)220 KV Lalitpur –Babina (UP) CKT viii)765 KV Agra Fatehabad(UP)-Lalitpur(LPG) (UP) Ckt-1

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
10	GD-1	Rajasthan	11-05-2025 12:31	11-05-2025 13:17	00:46	2215	0	3.683	0.000	60137	59672	i)Generation of 220kV Nokhra (IP) and 220kV RSDCL-2(IP) stations evacuate through 220 KV Nokhra SL_BHD2 (NTPC)-Bhadla_2 (PG) (NTPC_NOKHRA) Ckt and 220 KV BHADLA_2 (PG)-RSDCL(PSS2) _SL_BHD2_PG (RSDCL) CKT-1 , 220 KV RSDCL(PSS2) _SL_BHD2_PG (RSDCL) – RSDCL 1 & 220 KV RSDCL(PSS2) _SL_BHD2_PG (RSDCL)-RSDCLP3 Ckt respectively. ii)During antecedent condition, 220kV Nokhra (IP) and 220kV RSDCL-2(IP) were generating approx. 242 MW and 218 MW respectively (as per PMU). iii)As reported, at 12:31hrs, 220 KV Bhadla_2 (PG)-RSDCL (PSS4) _SL_BHD2_PG (RSDCL) Ckt tripped (Tripping Details awaited) iv)During the same time, 220 KV NOKHRA SL_BHD2 (NTPC)-BHADLA_2 (PG) (NTPC_NOKHRA) CKT-1 along with STATCOM NO 2(-425/+550MVAR) AT 400 KV BHADLA_2 (PG) also tripped. v)PowerGrid informed that Statcom No2 tripped due to the operation of cooling system protection operation. Due to huge voltage fluctuation the above protection operated and the Statcom tripped (details awaited). vi)At the same time, 400 KV BIKANER(RS)-DEEDWANA(MTS) (RS) CKT-1 also tripped. The tripping details for the said line is still awaited. vii)As per PMU at 400KV, 3 phase fault (voltage dipped upto 0.87 p.u.) is observed with fault clearing time of 80ms. viii)As per PMU, solar generation loss of approx. 143 MW at Avada, and 242 MW at Nokhra(IP) were observed. ix)As per PMU at Azure Maple, fluctuation in power generation was also observed.	i)220 KV BHADLA_2 (PG)-RSDCL(PSS2) _SL_BHD2_PG (RSDCL) CKT-1 ii)220 KV NOKHRA SL_BHD2 (NTPC)-BHADLA_2 (PG) (NTPC_NOKHRA) CKT-1 iii)400 KV BIKANER(RS)-DEEDWANA(MTS) (RS) CKT-1 iv)STATCOM NO 2(-425/+550MVAR) AT 400 KV BHADLA_2 (PG)
11	GI-2	J&K	13-05-2025 16:15	13-05-2025 16:46	00:31	238	0	0.400	0.000	59537	64057	i)400kV Uri-1 S/s have double main bus system. There are 4, 120MW Units at Uri-I HEP and the power evacuates through 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1 & 2. ii)During antecedent condition, 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1 & 2 was carrying 262 MW each and feeding 400/220KV Amargarh. Unit 2 was on 400KV Bus-1 and Unit 3 along with 400 KV URI_1(NH)-AMARGARH(INDIGRID) (INDIGRID) CKT-2 were at 400KV Bus-2. iii)As reported, at 16:15 hrs, 400 KV URI_1(NH)-AMARGARH(INDIGRID) (INDIGRID) CKT-2 tripped from both ends on B-N phase to earth fault. As per DR at Uri-1 end, B-N fault, Z-1 protection operated, fault current was ~3.6KA. The fault distance was 39.35KM from Uri end. Line tripped on fault in reclaim time after successful A/R operation (within 100msec of A/R operation). iv)At the same time, both 120MW Unit 2 and Unit 3 tripped on Y-B Generator differential protection operation. NHPC stated that during the line fault, Main 2 CT of B phase got saturated for Unit 2 and 3. The relay operated due to wrong current sensed by Generator Differential relays. v)As per SCADA, Generation loss of 238MW in Uri-1 HEP is observed.	i)120 MW URI-1 HPS - UNIT 2 ii)120 MW URI-1 HPS - UNIT 3 iii)400 KV URI_1(NH)-AMARGARH(INDIGRID) (INDIGRID) CKT-2
12	GD-1	HP	16-05-2025 15:25	18-05-2025 16:01	48:36	87	0	0.132	0.000	65848	71439	i)Generation of AD Hydro HEP (2*96 MW) evacuates through 220kV AD Hydro-Nallagarh line (~175km) and 220kV AD Hydro-Phozal line(~14km)--> 220kV Phozal-Nallagarh Line. Both the lines are on same tower. There is LILO portion at 220/33kV Phozal in second line. ii)During antecedent condition, 96 MW Unit-1 at AD Hydro HEP(IP) was generating approx. 87MW and Unit-2 was under shutdown. iii)As reported, at 15:25 hrs, 220 KV Phozal(HP)-Nallagarh(PG) (ADHPL) line and 220kV AD Hydro-Nallagarh line tripped on R-Y phase to phase fault. Fault occurred due to tree fell on both the lines between tower location no 174-175. Conductor of all three phase between tower location 174-175 snapped and two crossarm of tower location no 175 also damaged. (~47km from AD Hydro end). iv)As per SCADA SOE (recorded at NRLDC), voltage plot of PMU (at Nallagarh(PG)) and DR file of AD Hydro end (of 220kV AD Hydro-Nallagarh line), at 15:25:32:240 hrs, 220kV Phozal-Nallagarh Line tripped on R-Y fault followed by tripping of 220kV AD Hydro-Nallagarh line at 15:25:32:960 hrs on R-Y fault (Z-1 from AD Hydro end). Both the faults cleared within 120msec. v)At the same time, 96 MW Unit-1 at AD Hydro HEP (generating ~87MW) also tripped due to loss of evacuation path. 220kV AD Hydro-Phozal line remained charged from AD Hydro end and details of Phozal end not received. vi)As per SCADA plot of AD Hydro HEP generation, loss of ~87 MW is observed and as per SCADA plot of HP demand, no change in HP demand is observed during the event time. vii)Further at 13:30hrs, R-N phase to earth fault occurred on 220 KV AD hydro(AD)-Nallagarh(PG) (ADHPL) Ckt with fault current of ~6.07kA from Nallagarh(PG) end and ~1.164kA from AD hydro end (as per DR). As reported, there was forest fire near 400/220kV Nallagarh(PG) S/s. viii)Further, as reported, after repair and restringing work between tower location 174-175, the 220 kV AD Hydro (AD) – Nallagarh (PG) (ADHPL) line was successfully energized on May 18, 2025, at 16:01 Hrs. Restoration work for 220 KV Phozal (HP)-Nallagarh (PG) (ADHPL) line is currently in progress	i)220 KV Phozal(HP)-Nallagarh(PG) (ADHPL) Ckt ii)220 KV AD hydro(AD)-Nallagarh(PG) (ADHPL) Ckt iii)96 MW Unit-1 at AD Hydro HEP
13	GD-1	J&K	16-05-2025 20:10	16-05-2025 21:59	01:49	710	0	1.235	0.000	57486	69317	i)400kV Uri-1 & 2 S/s have double main bus system. There are 4, 120MW Units at Uri-I HEP and 4, 60 MW Units at Uri-2 HEP. Power of Uri-1&2 evacuates through 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1 & and 400kV Uri-2-Wagoora line. ii)During antecedent condition, 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-2 was under tripped condition (tripped at 16:48hrs on B-N fault), 400kV Uri-2-Wagoora line. was under shutdown and 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1 was carrying 716 MW. Complete power of Uri-1 & Uri-2 HEP was evacuating through 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1. iii)As reported, at 20:10 hrs, 400 KV URI_1(NH)-AMARGARH(INDIGRID) (INDIGRID) CKT-1 tripped from both ends on B-N phase to earth fault. As per DR at Uri-1 end, B-N fault, Z-1 protection operated, fault current was ~2.3KA. iv)As per PMU at Amargarh end, B-N phase to earth fault cleared within 100msec is observed. As per phase current data of 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1, A/R in B-ph observed however 3-ph trip after ~1.8sec is observed. Reason of the same yet to be received. v)After tripping of 400 KV URI_1(NH)-AMARGARH (INDIGRID) CKT-1, complete generation of Uri-1&2 HEP tripped due to loss of evacuation path and Uri-1&2 S/s got blackout. vi) As per SCADA, total generation loss of ~710MW (470MW at Uri-1 HEP and 240MW at Uri-2 HEP) is observed.	i)120 MW URI-1 HPS - UNIT 1 ii) 120 MW URI-1 HPS - UNIT 2 iii)120 MW URI-1 HPS - UNIT 3 iv) 120 MW URI-1 HPS - UNIT 4 v)60 MW URI-2 HPS - UNIT 1 vi) 60 MW URI-2 HPS - UNIT 2 vii)60 MW URI-2 HPS - UNIT 3 viii) 60 MW URI-2 HPS - UNIT 4 ix) 400 KV URI_1(NH)-AMARGARH(INDIGRID) (INDIGRID) CKT-2

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event (GI 1or GI 2/ GD-1 to GD-5)	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
						Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
14	GD-1	J&K	18-05-2025 21:35	18-05-2025 22:59	01:24	244	0	0.417	0.000	58477	76787	i)400kV Uri-2 S/s have double main bus system. There are 4, 60MW Units at Uri-2 HEP and power evacuates through 400 KV URI_2(NH)-WAGOORA (PG) (PG) CKT and 400 KV URI_2(NH)-URI_1(NH) (PG) CKT. ii)During antecedent condition, 400 KV URI_2(NH)-WAGOORA (PG) (PG) CKT and 400 KV URI_2(NH)-URI_1(NH) (PG) CKT were carrying ~195 MW and 47 MW respectively. All the 4 units were generating 60MW each. iii)As reported, at 21:35 hrs, 400 KV URI_2(NH)-WAGOORA (PG) (PG) CKT tripped from both ends on R-N phase to earth fault. As per DR at Uri-2 end, R-N fault, Z-1 protection operated, fault current was 2.8KA. The fault distance was 26.40KM from Uri_2 end. A/R was successful from Uri_2 end. However, line tripped on SOTF on persisted fault. iv)At the same time, 400 KV URI_2(NH)-URI_1(NH) (PG) CKT also tripped on R-N phase to earth fault. As per DR at Uri-2 end, R-N fault, Z-1 protection operated, fault current was 3.1KA. /R was successful from Uri_2 end. However, line tripped on SOTF on persisted fault v)At the same time, all the 4 X 60 MW units atUri-2 HEP tripped due to loss of evacuation path. This led to complete blackout of 400KV Uri-2 sub-station. vi)As per PMU at Amargarh(PG), R-N phase to earth fault which cleared with delayed fault clearance of 400 msec is observed. vii)As per SCADA, Generation loss of 244MW at Uri-2 HEP is observed. No load loss in J&K control area observed.	i)400 KV URI_2(NH)-WAGOORA(PG) (PG) CKT ii)400 KV URI_2(NH)-URI_1(NH) (PG) CKT iii)60 MW URI-II HPS - UNIT 1 iv)60 MW URI-II HPS - UNIT 2 v)60 MW URI-II HPS - UNIT 3 vi)60 MW URI-II HPS - UNIT 4
15	GD-1	J&K	18-05-2025 22:57	19-05-2025 00:57	02:00	0	85	0.000	0.109	59370	78090	i)220/132kV Ziankote S/s have two bus at 220kV side i.e., main bus & reserve bus. 220kV Amargarh-Ziankote ckt-1&2 are on the same tower (D/C tower) and line length is ~21.4km. ii)During antecedent condition, 220kV Amargarh (INDIGRID) –Ziankote (JK) D/C were carrying 19 MW each and feeding Ziankote load. 220kV Wagoora-Ziankote D/C were already under tripped condition (tripped at22:44 hrs & 22:54 hrs on same day). iii)As reported, at 22:57 hrs 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1 and Ckt-2 tripped on R-Y fault. iv)As per DR at Amargarh end, 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1 tripped on R-Y phase to phase fault. The fault current Ir = 3.7KA, Ib= 3.6KA, Z1 protection operated and the fault distance was 12.13KM from Amargarh end. v)As per DR at Amargarh end, 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-2 tripped on R-Y phase to phase fault. The fault current Ir = 1.8KA, Ib= 1.7KA, Z2 protection operated and the fault distance was 26KM from Amargarh end. vi)As per PMU at Amargarh (INDIGRID), R-Y phase to phase was observed in system. vii)As per SCADA, change in demand of approx. 85 MW is observed in J&K control area.	i)220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1 ii)220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-2
16	GD-1	UP	21-05-2025 20:00	21-05-2025 22:43	02:43	975	0	2.056	0.000	47427	56188	i)400/220kV Dadri Stage I has one and half breaker scheme in 400KV and Double main transfer system in 220KV system. 400KV Dadri stage 2 has one and half breaker scheme. Stage 1 has 4 X 210 Generating units while Stage 2 has 2 X 490 MW Generating units. ii)During antecedent condition, Unit 1,2,3 and 4 of Stage 1 Dadri was generating 131MW, 121 MW, 117MW and 109MW respectively. While Unit 1 of Dadri Stage 2 was generating 264MW while Unit 2 already tripped at 20:17 hrs. iii)The lines 400KV Dadri – Muradnagar, 400KV Dadri – Panipat Ckt -1 & 2 were already tripped during to inclement weather conditions. Whole power of Dadri Stage-1 (~475 MW was evacuating through 400kV Dadri-Harshvihar ckt-1. The Dadri Stage 1 and Stage 2 were running in split bus arrangement. iv)As reported, at 20:00 hrs, 400 KV Dadri(NT)-Loni Harsh Vihar(DV) (NT) Ckt-1 tripped on R-N phase to earth fault. Z-1 distance protection operated; fault distance was 15.3 KM from Harsh Vihar end. During patrolling the tower at location no. 24 found collapsed. v)As per PMU at Dadri TPS, R-N phase to earth fault cleared within 100msec is observed. vi)Following the tripping of 400 KV Dadri(NT)-Loni Harsh Vihar(DV) (NT) Ckt-1, all the 4 generating units and 3X 210MW ICT 1,2 & 5 tripped due to loss of evacuation path. vii)Again at 20:20 hrs, only 490 MW Unit-1 at Dadri-II TPS was running and 400KV Dadri – Mandaula Ckt-2 was the only operational ckt in Dadri Stage 2. 400KV Dadri- Kaithal Ckt, 400KV Dadri – Gr. Noida, 400KV Dadri – Harsh Vihar Ckt-2, 400KV Dadri – Mandaula Ckt-1 were already under tripped condition on line faults during inclement weather conditions. viii)As reported at 20:21 hrs, 400 KV Mandola(PG)- Dadri (PG)(DTL) Ckt-2 tripped during power swing. ix)At the same time, 490 MW Unit-1 at Dadri-II TPS along with 2X500 MVA ICT 3 and 4 tripped due to loss of evacuation path. This led to complete blackout of 400KV Dadri Substation. x)As per PMU at Dadri TPS, R-N phase to earth fault cleared within 100msec followed by fluctuation in voltage is observed. xi)At the same time, 500 kV HVDC Rihand-Dadri (PG) Ckt-1 and Ckt-2 tripped due to commutation failure. At the time of tripping 500 kV HVDC Rihand-Dadri (PG) Ckt-1 and Ckt-2 were carrying total ~1150 MW. As a result of tripping of both the ckt, SPS condition 2 operated. xii)As per details received from POWERGRID, as per logic if commutation failure persists for more than 2600 ms then the Protection shall issue a Y Trip to the converters. Since starting from 20:20:58:2785 Hrs. 12 successive commutation failures were detected at a gap of less than 500ms, at 20:21:00:8782 both Poles of the Rihand Dadri HVDC Link tripped on Commutation failure protection from HVDC Dadri S/s. i)As per SPS case-2 operation, there should load shed in load group-A, B, C & D and generation back down of total ~500 MW at Rihand & Singrauli TPS. ii)As per SCADA data, generation backdown of ~335MW is observed in Rihand Stage I and Stage II. However, However, there wasn't any significant generation back down (only ~30MW) in Singrauli observed. iii)As per SCADA, generation loss of total ~975 MW is observed at Dadri TPS, ~475 MW at 20:00 hrs at Dadri Stage-1 TPS and ~254 MW at 20:17 hrs due to tripping of Unit-2 at Dadri stage-II TPS and ~240 MW at 20:21 hrs due to tripping of Unit-1 at Dadri stage-II TP	i)400 KV Dadri(NT)-Loni Harsh Vihar(DV) (NT) Ckt-1 ii)210 MW Unit-1 at Dadri-I TPS iii)210 MW Unit-2 at Dadri-I TPS iv)210 MW Unit-3 at Dadri-I TPS v)210 MW Unit-4 at Dadri-I TPS vi)400 KV Mandola(PG)- Dadri (PG) (DTL) Ckt-2 vii)490 MW Unit-1 at Dadri-II TPS viii)500 kV HVDC Rihand- Dadri (PG) Ckt-1 ix)500 kV HVDC Rihand- Dadri (PG) Ckt-2

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
17	GD-1	UP & UK	21-05-2025 19:55	22-05-2025 06:35	10:40	645	150	1.281	0.241	50335	62295	i)400KV Tehri has double main, 400KV Koteshwar (THDC) has double main and transfer, 765/400KV Koteshwar(PG) has one & half breaker scheme in 765KV and double main bus scheme in 400KV and 765/400/220KV Meerut substation has one and half breaker scheme in 765KV and 400KV system. ii)During antecedent condition, at 400KV Tehri HEP, 250 MW Unit 1, 3 & 4 were in service generating 124MW, 119MW and 118MW (total ~360MW). At 400KV Koteshwar HEP (THDC), 100 MW Unit 1, 2 & 3 were in service generating 95MW each (total ~285 MW). 765 KV Moga-Meerut (PG) Ckt-1 was under tripped condition (tripped at 18:11:47 hrs on permanent R-N fault). There was inclement weather condition (heavy windstorm, rain and thunderstorm). iii)As reported, at 19:55:21 hrs, R-N fault occurred on 765 KV Koteshwar- Meerut (PG) Ckt-2 due to earth wire broken during inclement weather condition at ~1km from Meerut end. Line tripped from Koteshwar end in Z-2 but didn't trip from Meerut end due to non-operation of Distance Protection. During investigation it was found that R-ph jumper of CVT at Meerut end of 765 KV Koteshwar- Meerut (PG) Ckt-2 snapped ~10sec before the fault incident leading to VT fuse fail and loss of R-ph voltage. Due to this, distance protection at Meerut end didn't operate. iv)As fault was still persisting, 765kV Meerut-Bhiwani ckt and 765kV Meerut-Gr. Noida ckt tripped from remote end in Z-2. At ~19:55:22:000 hrs, all three 1500 MVA ICT at Meerut tripped on operation of back up impedance protection operation (Z-2). v)Further at 19:55:22:600 hrs, 400kV Tehri-Koteshwar ckt-1, 2 & 3 along with 765kV Meerut-Koteshwar (PG) ckt-1 tripped from Tehri and Koteshwar(PG) end respectively on O/C E/F protection (67N relay). vi)With the tripping of above mentioned elements, supply to 765kV part of Meerut(PG), 765/400kV Koteshwar(PG), 400kV Tehri HEP & Koteshwar HEP lost and these stations got blackout. vii)At the same time, 250MW Unit-1, 3 & 4 at Tehri HEP and 100 MW Unit 1, 2 & 3 at Koteshwar HEP tripped due to loss of evacuation path leading to generation loss of ~360MW at Tehri HEP and ~285MW at Koteshwar HEP. viii)Further within further few seconds, 400kV Meerut-Bareilly D/C, 400kV Meerut-Baghpat D/C, 400kV Meerut-Muzaffarnagar ckt and 400kV Meerut-Manolda ckt-1 also tripped on line faults during inclement weather condition. Muzaffarnagar and Mandola line tripped from remote end only (exact reason yet to be received). ix)At the same time, power flow of 220KV lines Gajrala, Shatabdinagar, Simbholi, Charla and Partappur from Meerut became NIL. x)As per PMU at Meerut(PG), B-N fault at 19:55:19 hrs (cleared within 100msec) and R-N fault with delayed clearance of ~1640msec is observed. xi)As per SCADA, generation loss of ~360MW at Tehri HEP, ~285MW at Koteshwar and change in demand of ~150 MW in UP control area is observed. xii)Remaining elements at Koteshwar(PG) and 765kV part of Meerut(PG) were hand tripped due to loss of voltage. xiii)Further at 06:35 hrs, 765kV Meerut-Koteshwar ckt-1 was charger and subsequently supply to Tehri HEP, Koteshwar HEP was restored.	i)765 KV Koteshwar-Meerut (PG) Ckt-2 ii)765 KV Bhiwani- Meerut (PG) Ckt iii)765 KV Meerut -Gr Noida (PG) Ckt iv)765/400kV 1500 MVA ICT-1 at Meerut(PG) v)765/400kV 1500 MVA ICT-2 at Meerut(PG) vi)765/400kV 1500 MVA ICT-3 at Meerut(PG) vii)765 KV Koteshwar- Meerut (PG) Ckt-1 viii)400 KV Tehri(THDC)- Koteshwar(PG) (PG) Ckt-1 ix)400 KV Tehri(THDC)- Koteshwar(PG) (PG) Ckt-2 x)400 KV Tehri(THDC)- Koteshwar(PG) (PG) Ckt-3 xi)100 MW Unit-1 at Koteshwar HPS xii)100 MW Unit-2 at Koteshwar HPS xiii)100 MW Unit-3 at Koteshwar HPS xiv)250 MW Unit-1 at TEHRI HPS xv)250 MW Unit-3 at TEHRI HPS xvi)250 MW Unit-4 at TEHRI HPS xvii)765/400 kV 800 MVA ICT 1 at Koteshwar(PG) xviii)7765/400 kV 800 MVA ICT 2 at Koteshwar(PG) xix)765/400 kV 800 MVA ICT 3 at Koteshwar(PG) xx)765/400 kV 800 MVA ICT 4 at Koteshwar(PG) xxi)240 MVAR Bus Reactor No 1 at 765 KV Koteshwar (PG) xxii)765KV Bus 1 at Meerut(PG) xxiii)400 KV Koteshwar(TH)- Koteshwar(PG) (PG) Ckt-1 xxiv)400 KV Koteshwar(TH)- Koteshwar(PG) (PG) Ckt-2 xxv)400 KV Meerut- Baghpat (PG) Ckt-1 xxvi)400 KV Meerut- Baghpat (PG) Ckt-2 xxvii)400 KV Meerut- Bareilly (PG) Ckt-1 xxviii)400 KV Meerut- Bareilly (PG) Ckt-2 xxix)400 KV Meerut- Muzaffarnagar (PG) Ckt xxx)400 KV Meerut- Mandola (PG) Ckt-1
18	GI-2	Haryana	21-05-2025 22:50	22-05-2025 01:42	02:52	0	0	0.000	0.000	55334	57854	i)During antecedent condition, 800kV HVDC Champa-Kurukshetra was carrying total 3000MW power from Champa to Kurukshetra (Pole-1=958MW, Pole-2=613MW, Pole-3=603MW & Pole-4= 283MW). The weather condition at the time of incident was very worse accompanying thunderstorms & very heavy lightning along with wind was prevailing at Kurukshetra. ii)As reported, at 22:50 hrs, 800 kV HVDC Kurukshetra (PG) Pole-02 and Pole 4 tripped due to transient earth fault. The fault distance was 438.1KM from Kurukshetra end and 849.21KM from Champa end. iii)As per details received from POWERGRID sequence of event was as follows: a.At 22:50:20:517 hrs, DC line fault sequence started in Pole-2 and Pole-4. Again, at 22:50:25:130 hrs another DC line fault sequence started in Pole-2 and Pole-4. b.Following this at 22:50:25:169 hrs, an attempt was made to run Pole-2 and Pole-4 in reduced voltage mode. c.At 22:50:25:229 hrs, Pole 2 was blocked from Champa end due to subsequent DC line fault. d.At 22:50:26:055 hrs, Pole-4 was blocked due to CAT-B protection operation in Pole-2. iv)The power order reduced from 2457MW to 1317MW. Pole-1 = 657MW and Pole-3=660MW. v)As per PMU at Kurukshetra(PG), fluctuation in voltage was observed. vi)As per SCADA, no change in demand is observed in Haryana control area.	i)800 kV HVDC Kurukshetra (PG) Pole-02 ii)800 kV HVDC Kurukshetra (PG) Pole-04

Details of Grid Events during the Month of May 2025 in Northern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
19	GD-1	Himachal Pradesh	21-05-2025 21:05	21-05-2025 22:41	01:36	192	26	0.414	0.048	46432	53991	i)Total generated power of Sainj HEP(HP) and Parbati_2(NH) and evacuates through 400 kV Parbati_2(NH)- Banala(PG) (PKTCL) Ckt and 400 kV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt, 400 KV Parbati_3(NH)-Sainj(HP) (PKTCL) Ckt and 400 KV Parbati_2(NH)-Parbati Pooling Banala (PG) (PKTCL) Ckt-1. ii)During antecedent condition, 50MW Unit-1 and Unit-2 at Sainj HEP(HP) were running and generating 49MW each respectively, all four units (4*250MW) at Parbati_2(NH) in service (SCADA data unavailable before tripping). 400KV Bus 2 at Parbati_2 was under shutdown condition. iii)As reported, at 21:05 hrs, 400 KV Parbati_2 (NH)- Parbati Pooling Banala (PG) (PKTCL) Ckt-1 tripped due to 400KV Bus-Bar 1 protection operation. iv)As per DR of 400 KV Parbati_2 (NH)(end)- Parbati Pooling Banala (PG) (PKTCL) Ckt-1, tripped on 400KV Bus-Bar 1 protection operation due to external fault. The Bus-Bar protection operated due to triggering of LBB protection relay of Unit-3 at Parbati_2. v)At the same time, 400 KV Parbati_2(NH)- Sainj(HP) (PKTCL) Ckt-1 along with all 4X200 MW Units at Parbati_2 HEP also tripped on 400KV Bus-Bar 1 protection operation. The Bus-Bar protection operation was due to triggering of LBB protection relay of Unit-3 at Parbati_2 vi)Parbati_2 informed that the reason for triggering LBB protection was on account of improper implementation of AND function logic for non-electric faults in Unit-3. vii)This led to complete blackout of Parbati_2 HEP. viii)As per PMU at Banala(PG), no fault signature was observed. ix)As per SCADA, Generation loss of 192MW in Parbati_2. Change in demand of 26MW in HP control area observed.	i)400 KV Parbati_2(NH)- Parbati Pooling Banala(PG) (PKTCL) Ckt-1 ii)400 KV Parbati_2(NH)- Sainj(HP) (PKTCL) Ckt-1 iii)200 MW Unit-1 at Parbati II HEP iv)200 MW Unit-2 at Parbati II HEP v)200 MW Unit-3 at Parbati II HEP vi)200 MW Unit-4 at Parbati II HEP
20	GD-1	Himachal Pradesh	23-05-2025 10:37	23-05-2025 12:04	01:27	505	0	0.802	0.000	63001	65531	i)Total generated power of Sainj HEP(HP) and Parbati_2(NH) and evacuates through 400 kV Parbati_2(NH)- Banala(PG) (PKTCL) Ckt and 400 kV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt, 400 KV Parbati_3(NH)-Sainj(HP) (PKTCL) Ckt. ii)During antecedent condition, 50MW Unit-1 and Unit-2 at Sainj HEP(HP) were running and generating 49MW each respectively, three units (4*250MW) at Parbati_2(NH) in service generating 189MW(Unit-1), 187MW(Unit-2), 129MW(Unit-4). 400KV Bus 2 and Unit-3 at Parbati_2 were under shutdown. iii)As reported, at 10:37 hrs, 400 KV Parbati_2 (NH)- Parbati Pooling Banala (PG) (PKTCL) Ckt-1 tripped due to 400KV Bus-Bar 1 protection operation. The Bus-Bar protection operated due to triggering of LBB protection relay of Unit-4 at Parbati_2. iv)At the same time, 400 KV Parbati_2(NH)- Sainj(HP) (PKTCL) Ckt-1 along with all 3X200 MW Units at Parbati_2 HEP also tripped on 400KV Bus-Bar 1 protection operation. The Bus-Bar protection operation was due to triggering of LBB protection relay of Unit-4 at Parbati_2 v)Parbati_2 informed that the reason for triggering LBB protection was on account of improper implementation of AND function logic for non-electric faults in Unit-4. vi)This led to complete blackout of Parbati_2 HEP. vii)As per PMU at Banala(PG), no fault signature was observed. viii)As per SCADA, Generation loss of 505MW in Parbati_2. No Change in demand in HP control area observed.	i)400 KV Parbati_2(NH)- Parbati Pooling Banala(PG) (PKTCL) Ckt-1 ii)400 KV Parbati_2(NH)- Sainj(HP) (PKTCL) Ckt-1 iii)200 MW Unit-1 at Parbati II HEP iv)200 MW Unit-2 at Parbati II HEP v)200 MW Unit-3 at Parbati II HEP vi)200 MW Unit-4 at Parbati II HEP
21	GD-1	UP and Uttarakhand	23-05-2025 20:24	23-05-2025 20:42	00:18	38	533	0.080	0.818	47565	65173	i)Total generated power of Tanakpur evacuates through 220 KV Tanakpur (NH)-CBGanj(UP) (PG) Ckt-1, 220 KV Tanakpur(NH)-Sitarganj(PG) (PG) Ckt-1 and 132 KV Mahendra Nagar (PG)-Tanakpur(NH) (PG) Ckt-1. During the antecedent condition, 3X40 MW Tanakpur was generating 46MW. ii)400/220KV Bareilly(UP) has double main and transfer bus-scheme in both 400KV and 220KV system. 315MVA, 400/220KV ICT 2 was in shutdown condition. The 315MVA, 400/220KV ICT 1 and 3, were loaded 311MW and 315 MW respectively. iii)As reported, at 20:24 hrs, an attempt was made to charge 315MVA, 400/220KV ICT 2. After ~15 sec of ICT charging, 220KV Bus-Bar Zone 2 (Y-ph differential) protection operated. As per PMU, there was no fault in system during bus bar operation. Exact reason of bus bar protection yet to be received. iv)Subsequently 220KV lines to Pantnagar, CB Ganj-II, Dohna-II, Pilibhit-II and ICT-3 tripped due to 220KV Bus-Bar II protection operation at Bareilly. At the same time, 315MVA, 400/220KV ICT 1 was hand-tripped for equipment safety. v)As per PMU at Bareilly(PG), R-Y phase to phase fault observed was observed with delayed fault clearance of 440msec. As reported, 220kV Bareilly-Faridpur line tripped on fault occurred due to snapping of line side jumper (after CT). vi)After tripping of ICTs at 400/220 kV Bareilly (UP), line loading of 220KV CB Ganj-Sitarganj ckt reached up to the level of 270MW, it leads to voltage oscillation/ fluctuation in the Tanakpur-Sitarganj-Cbganj complex. Voltage fluctuation was in the range of 125kV to 218kV on 220KV bus voltage and at the same time, two units at Tanakpur HEP (Unit-1 and Unit-2) also tripped. As a result, 533 MW load loss was observed in UP and approx. 38 MW of generation loss was observed in Tanakpur HEP. vii)At 20:42 hrs, 315MVA, 400/220KV ICT 1 was revived. viii)As reported at 20:51 hrs, 315MVA, 400/220KV ICT 1 loading increase to 347MW. As a result, the ICT tripped on Overcurrent protection. This again led to voltage fluctuations in the Tanakpur-Sitarganj-CBH Ganj complex as a result 220 KV Tanakpur (NH)-CBGanj(UP) (PG) Ckt-1, 220 KV Tanakpur(NH)-Sitarganj(PG) (PG) Ckt-1 and 132 KV Mahendra Nagar (PG)-Tanakpur(NH) (PG) Ckt-1 (Affected the power supply to Nepal) tripped simultaneously, which further led to 138 MW load loss in UP and approx. 31 MW of generation loss in Tanakpur HEP (Unit-3 tripped, Unit-1 and Unit-2 were already out). ix)As per PMU at Barilly(PG), R-Y phase to phase fault was observed at 20:24hrs with delayed fault clearance of 440msec. x)This led to complete blackout of Tanakpur HEP. xi)As per SCADA, at 20:24 Hrs, as per SCADA approx. 533MW load loss was observed in UP and approx. 38 MW of generation loss was observed at Tanakpur HEP. xii)At 20:51 Hrs, as per SCADA approx. 138MW load loss was observed in UP and approx. 31 MW of generation loss was observed at Tanakpur HEP.	i)400/220 kV 315 MVA ICT 3 at Bareilly (UP) ii)400/220 kV 315 MVA ICT 1 at Bareilly (UP) iii)31.42 MW Tanakpur HPS - UNIT 1 iv)31.42 MW Tanakpur HPS - UNIT 2 v)220KV Bareilly(UP) – Pant Nagar vi)220KV Bareilly(UP) – Pilibhit Ckt-1 vii)220KV Bareilly(UP) – Pilibhit Ckt-2 viii)220KV Bareilly(UP) – Dohna Ckt-2 ix)220KV Bus-1 at Bareilly (UP) x)220KV Bareilly – Faridpur Ckt xi)400/220 kV 315 MVA ICT 1 at Bareilly (UP) xii)220 KV Bus-2 at Bareilly(UP) xiii)220KV Bareilly(UP) – Dohna Ckt-1 xiv)220KV Bareilly(UP) – CB Ganj2 Ckt-1 xv)132 KV Mahendra Nagar (PG)-Tanakpur(NH) (PG) Ckt-1 xvi)220 KV Tanakpur (NH)-CB Ganj(UP) (PG) Ckt-1 xvii)220 KV Tanakpur(NH)-Sitarganj(PG) (PG) Ckt-1 xviii)31.42 MW Tanakpur HPS - UNIT 3

Details of Grid Events during the Month of May 2025 in Western Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
1	GD-1	WR	01-05-2025 16:38	01-05-2025 18:06	01:28	600	-	0.70%	-	86103	68833	At 16:38 Hrs / 01-05-2025, 400kV REL Raipur PS (Durg) – 1 & 2 tripped on R-E fault and Y-E fault respectively resulted in blackout of 400KV APL Raipur/REL Substation due to loss of evacuation path.Heavy rains and windstorms with thunderstorms are reported in the area at the time of event. Generation loss of 600 MW at REL occurred due to the event. Loss supply at 400kV APL Raipur SS	1. 400KV REL Raipur PS (Durg)-1 2. 400KV REL Raipur PS (Durg)-2 3. APL Raipur Unit-2
2	GD-1	WR	03-05-2025 15:11	03-05-2025 16:13	01:02	464	-	0.54%	-	85511	71639	At 15:11 Hrs / 03-05-2025, 400kV-ACBIL-Bilaspur & 400kV-MCCPL-Bilaspur lines tripped on B-E fault. Inclement weather conditions reported at the time of event. Total 464 MW generation loss occured at ACBIL and MCCPL due to the loss of evacuation path. Loss supply at 400kV ACBIL and MCCPL	1. 400kV-ACBIL-Bilaspur-1 2. 400KV-ACBIL-MCCPL-1 3. ACBIL Unit 1 (135 MW) 4. ACBIL Unit 2 (135 MW) 5. ACBIL Unit 3 (50 MW) 6. ACBIL Unit 4 (50 MW) 7. ACBIL Unit 5 (30 MW) 8. ACBIL Unit 7 (63 MW) 9. MCCPL Unit 1(300 MW)
3	GI-2	WR	03-05-2025 15:17	03-05-2025 16:24	01:07	910	-	1.07%	-	85023	71297	At 15:17 Hrs / 03-05-2025, 400KV-KORBA-NTPC-RAIPUR-3 two phases (R&Y) of line isolator got opened on load, which led to KSTPS - 400KV - Bus 4 bus bar protection operation resulting in tripping of all connected units and lines. Heavy wind and rain reported during the event. Generation loss of 910 MW reported at Korba NTPC.	1. 400KV-KORBA-NTPC-SIPAT-1 2. 400KV-KORBA-NTPC-BHATAPARA-1 3. 400KV-KORBA-NTPC-VINDHYACHAL-2 4. 400KV-KORBA-NTPC-RAIPUR-3 5. 400KV-KORBA-NTPC-RAIPUR-4 6. 400KV-BALCO (MRSDS)-KORBA-NTPC-1 7. KSTPS - 400KV - Bus 8. KSTPS1&2 Unit-5 (500 MW) 9. KSTPS1&2 Unit-6 (500 MW)
4	GD-1	WR	03-05-2025 15:13	03-05-2025 18:34	03:21	0	-	0.00%	-	85184	71544	At 15:13 Hrs / 03-05-2025, 220 kV Sherisha-Raipur-1 tripped. Heavy rain reported at the time of event. No Generation loss occurred due to the event. Loss supply at 220 kV Sherisha SS	1. 220 kV Sherisha-Raipur-1
5	GD-1	WR	05-05-2025 14:16	05-05-2025 15:33	01:17	283	-	0.35%	-	80629	68160	At 14:16 Hrs/05.05.2025 400 KV JP Bina- Bina (PG) line tripped due to B-G fault. 400 KV JP Bina- Bina (MP) line was already under planned outage. Due to tripping of 400 KV JP Bina- Bina (PG) line, both units of JP Bina got tripped due to loss of evacuation path. Generation loss of 283 MW occurred at JP Bina. Loss supply at 400kV JP Bina SS	1. 400 KV JP Bina- Bina (PG) 2. JP BINA Unit 1 (250 MW) 3. JP BINA Unit 2 (250 MW)
6	GI-2	WR	06-05-2025 02:03	06-05-2025 03:48	01:45	43	-	0.06%	-	69291	53781	At 02:03 Hrs/06.05.2025, 400KV/220KV SSP-ICT-1 tripped on overflux protection operation. 400KV/220KV SSP-ICT-2 was already under planned outage since 01.05.2025 for Conservator air cell checking & replacement work. Due to tripping of 400KV/220KV SSP-ICT-1, SSP (CHPH) Unit 2 (63MW) tripped due to loss of evacuation path. Generation loss of 43 MW occurred at (CHPH). Later, due to heavy rain and thunderstorm, 400kV SSP- Rajgarh-2 tripped at 02:13Hrs on Zone 1, Y-G ph fault, and 400kV SSP- Rajgarh-1 tripped at 02:15 Hrs on Zone 1, B-G ph fault. There is supply at 220kV SSP(CHPH), however 400kV SSP is intact.	1. 400KV/220KV SSP-ICT-1 2. SSP (CHPH) Unit 2 (63MW) 3. 400kV SSP- Rajgarh-2 4. 400kV SSP- Rajgarh-1

Details of Grid Events during the Month of May 2025 in Western Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
7	GI-2	WR	06-05-2025 12:02	09-05-2025 16:34	76:32	-	-	-	-	68454	59423	At 12:02 Hrs/06.05.2025, 765kV-Vadoara Bus -1 & 2 tripped due to bus fault took place during opening of 712-89A isolator connected with 765KV Bus 1 along with 765KV-VADODARA-LAKADIA-1 & ICT-3. 765 kV Vadodara Lakadiya-2 was under planned outage prior to the event. No load loss reported as all other elements were intact. Remaining transmission lines are in service through Tie breakers and 400kV system is in service.	1. 765 kV Bus-1&2 2. 765 kV Vadodara Lakadiya-1&2
8	GD-1	WR	06-05-2025 13:29	06-05-2025 14:17	00:48	198	-	0.28%	-	70882	58202	At 13:29Hrs/06-05-2025, 220 kV Bhuj PS- Kotda Madh single circuit tripped Tripped on Bph-E fault with Generation loss of 56 MW occurred at Kotda Madh (Netra). Along with that 220kV-Bhuj- Nanavalka(Alfanar) tripped on Bph-E fault with generation loss of 30MW at Nanavalka(Alfanar) . At the same time, 220kV-Bhuj-Ghadsisa opened from Gadhsisa end only due to fault sensed in Zone-3 with 112MW generation loss at Gadhsisa. there is loss supply at 220kV Kotda Madh (Netra),220kV Nanavalka(Alfanar), 220kV Ghadsisa SS	1. 220kV Bhuj- Kotda Madh (Netra) 2. 220kV-Bhuj- Alfanar Valkanana 3. 220kV-Bhuj-Ghadsisa
9	GI-2	WR	07-05-2025 16:56	07-05-2025 18:08	01:12	0	-	0.00%	-	73488	56469	At 16:56 Hrs/07-05-2025, 400 kV Kharghar Bus 2 tripped on Bus bar protection operation due to HV side B phase LA blasted in 400/220 kV 315 MVA Kharghar ICT2. At the same time, 400 kV Bus 1 & all the elements connected tripped (suspected mal-operation). 400 kV Kharghar- Kalwa, 400 kV Kharghar- Pune, 400 kV Kharghar- Padghe(PG), 400 kV Kharghar- Vikhroli & 400/220 kV Kharghar ICTs 1,2,3&4 tripped during the event. As reported by site, heavy rains and thunderstorms reported during the event. As reportedby MSLDC, no load loss reported during the event as 220 kV side of the station was in live condition.	1 400/220 kV 315 MVA Kharghar ICT 2 2 400 kV Kharghar- Kalwa 3 400 kV Kharghar- Pune 4 400 kV Kharghar- Padghe(PG) 5 400 kV Kharghar- Vikhroli 6 400/220 kV Kharghar 315 MVA ICT 1 7 400/220 kV Kharghar 315 MVA ICT 3 8 400/220 kV Kharghar 501 MVA ICT 4 9 400 KV Kharghar Bus Coupler
10	GD-1	WR	08-05-2025 17:40	09-05-2025 15:06	21:26	0	-	0.00%	-	76041	59965	At 17:40 Hrs/08.05.2025 400kV KPS1-PSS5 line tripped and 400 kV PSS-5 got dead due to water ingress in GIS Gas density-Model which led to false SF6 low signal amid inclement weather conditions. 400 kV PTR-2 also tripped at 17:44 Hrs due to the same reason. At the time of event generation was NIL at PSS-5.	1. 400 kV Khavda PS1-Khavda PSS5
11	GD-1	WR	08-05-2025 18:16	08-05-2025 21:18	03:02	271	-	0.36%	-	74857	59130	At 18:16 Hrs/ 08.05.2025, 220kV Bhuj- Alfanar Valkanana, 220 Bhuj- Netra Kotda Madh, 220kV Bhuj-Gadhsisa tripped on B-N fault amid inclement weather condition. All generators have only one evacuation path, therefore, these stations became dead during line trippings. Total generation loss of 271 MW reported as per the following- 220kV Alfanar Valkanana (51 MW), 220kV Netra Kotda Madh (100 MW), 220kV Gadhsisa (110 MW).	1. 220 kV Bhuj-Alfanar 2. 220 kV Bhuj-Netra Kotda Madh 3. 220 kV Bhuj-Gadhsisa
12	GD-1	WR	08-05-2025 18:37	08-05-2025 20:22	01:45	18	-	0.02%	-	75042	59789	At 18:37 Hrs/ 08.05.2025, 220 kV Morjar Srijan-Bhuj-II tripped on B-N fault amid inclement weather condition. Total generation loss of 18 MW reported at Srijan Morjhar due to loss of evacuation path. There is supply loss at 220kV Srijan Morjar	1. 220 kV Morjar Srijan-Bhuj-II
13	GD-1	WR	11-05-2025 11:32	11-05-2025 13:35	02:03	500	-	0.73%	-	68496	59758	At 11:32 Hrs on 11-05-2025, the 220kV Radhanesda–Vav double circuit (DC) line tripped, resulting in the loss of a key evacuation path and a consequent solar generation loss of approximately 500 MW at Radhanesda (GETCO). No other elements were affected. There is supply loss at 220kV Radhanesda (GETCO)	1. 220kV Radhanesda-Vav-1 2. 220kV Radhanesda-Vav-2
14	GD-1	WR	11-05-2025 16:52	11-05-2025 18:08	01:16	2770	-	4.05%	-	68350	59678	At 16:52 Hrs/11.05.2025, 400KV-APL-MUNDRA-VARSANA-1 tripped due to Yph-Bph fault. At the same time, 400KV-APL-MUNDRA-SAMI-1 tripped due to overloading, HVDC Mundra Pole – 1&2 tripped due to under voltage protection operation and APL unit-3 to unit-9 (7 units) tripped due to SPS operation. Prior to the event, following lines tripped at APL Mundra Substation due to inclement weather: 1. 400KV-APL-MUNDRA-CHARANKA-1 tripped at 16:18 Hrs. 2. 400KV-APL-MUNDRA-MANSAR-1 tripped at 16:30 Hrs. 3. 400KV-APL-MUNDRA-SAMI-2 tripped at 16:35 Hrs. 4. 400KV-APL-MUNDRA-VARSANA-2 tripped at 16:35 Hrs Generation loss of 2770 MW occurred as per SCADA at APL Mundra.	1.400KV-APL-MUNDRA-SAMI-1 2. HVDC 500KV APL Pole 1 3. HVDC 500KV APL Pole 2 4. 400KV-APL-MUNDRA-SAMI-2 5. 400KV-APL-MUNDRA-VARSANA-1 6. 400KV-APL-MUNDRA-VARSANA-2 7. 400KV-APL-MUNDRA-CHARANKA-1 8. 400KV-APL-MUNDRA-MANSAR (HALVAD)-1 9. APL Mundra unit - 3 10. APL Mundra unit - 4 11. APL Mundra unit - 5 12. APL Mundra unit - 6 13. APL Mundra unit - 7 14. APL Mundra unit - 8 15. APL Mundra unit - 9 16. 220KV / 400KV APL ICT-1 17. 220KV / 400KV APL ICT-2 18. 400KV APL BUS-1 19. 400KV APL BUS-2
15	GD-1	WR	11-05-2025 16:24	11-05-2025 17:41	01:17	280	-	0.41%	-	76018	61049	1. At 16:24 Hrs /11-05-2025, 220 kV Bachau-Ostro Line-1 tripped due to B-E Fault. Prior to the event, 220KV-BACHAU-NARANPAR(OSTRO)-2 line was under forced outage from 21:39 Hrs./ 03.05.2025 due to Y-B fault. Generation loss of 180 MW is reported at 220 kV Ostro due to loss of evacuation path. 2. At the same time i.e. at 16:24 Hrs /11-05-2025, 220 kV Bachau-Bhuvad Line-1 & Line -2 tripped due to RYB-E Fault. Generation loss of 100 MW is reported by Bhuvad due to loss of evacuation path.	1.220 kV Bachau-Ostro-1 2. 220 kV Ostro BUS-1 3. 220 kV Ostro BUS-2 4. 220KV/33KV NARANPAR(OSTRO)-ICT-1 5. 220KV/33KV NARANPAR(OSTRO)-ICT-2 6. 220KV-BHUVAD-BACHAU-1 7. 220KV-BHUVAD-BACHAU-2 8. BHUVAD - 220KV - Bus 1 9. 220KV/33KV BHUVAD-ICT-1 10. 220KV/33KV BHUVAD-ICT-2
16	GD-1	WR	11-05-2025 15:54	11-05-2025 17:27	01:33	559	-	0.73%	-	76966	61706	At 15:54 Hrs/11.05.2025, 400kV Mahan-Bilaspur-1 also got tripped due to R-B fault. Prior to this, 400kV Mahan-Bilaspur-2 tripped on R-E fault at 15:42 Hrs. Due to loss of evacuation path MEL, Unit-2 (600 MW) tripped. This caused generation loss of ~559 MW at Mahan.	1. 400KV-APL-MUNDRA-SAMI-1 2. 400 kV Mahan Energen-Bilaspur 1 3.400 kV Mahan Energen-Bilaspur 2 4.600 MW MEL Unit 2 5. 600 MW MEL Unit 1

Details of Grid Events during the Month of May 2025 in Western Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
17	GD-1	WR	15-05-2025 15:08	15-05-2025 17:02	01:54	210	-	0.25%	-	83779	68136	At 15:08 Hrs/15-05-2025, B phase CT of 33 kV chokar feeder blasted at Jagdalpur end, As the fault was not cleared by main protection (fault duration: 1.480 sec as per PMU), 220 kV Jagdalpur- Barsoor D/C (tripped at Barsoor end only on Z3 protectopn) & 400/220 kV Jagdalpur ICTs tripped on Backup protection operation. Due to the tripping of the above-mentioned elements, 220 kV Jagdalpur- Nagarnar D/C became dead and resulted in blackout of 220 kV Nagarnar substation. As reported by Chhatisgarh SLDC, 210 MW load loss ocurred at Jagdalpur & Nagarnar.	1. 400/220 kV Jagdalpur ICT 1 2. 400/220 kV Jagdalpur ICT 2 3. 220 kV Jagdalpur- Barsoor 1 4. 220 kV Jagdalpur- Barsoor 2
18	GD-1	WR	16-05-2025 10:22	16-05-2025 10:41	00:19	250	-	0.32%	-	78311	64987	At 10:22 Hrs/ 16.02.2025, 220 kV Gurur- Barsoor tripped on B-E fault and resulted in blackout of 400/220 kV Jagdalpur, 220 kV Barsoor, 220 kV Nagarnar & 220 kV Narayanpur. Prior to the event, 400 kV Kurud- Jagdalpur was under planned shutdown and 400 kV Raita- Jagdalpur tripped on R-E fault at 10:02 Hrs. Test charge attempt of 400 kV Raita- Jagdalpur attempted at 10:17 Hrs but line tripped on SOTF with same relay indications. The entire load of Jagdalpur, Nagarnar, Narayanpur & Barsoor was fed from 220 kV Gurur- Barsoor, therefore tripping of this line caused disturbane resulted in Blackout at 400 kV Jagdalpur, 400/220 kV Jagdalpur, 220 kV Barsoor, 220 kV Nagarnar & 220 kV Narayanpur. As reported by Chhatisgarh SLDC, 250 MW (Jagdalpur- 60 MW, Nagarnar- 40 MW, Narayanpur- 50 MW & Barsoor-100 MW) load loss occurred due to the event.	Tripping of following Elements: 1. 400 kV Raita- Jagdalpur 2. 220 kV Gurur- Barsoor 3. 400/220 kV Jagdalpur ICT 2 4.400/220 kV Jagdalpur ICT 1 5. 220kV Jagdalpur Barsoor 1 6. 220kV Jagdalpur Barsoor 2 7.220kV Jagdalpur Nagarnar 1 8.220kV Jagdalpur Nagarnar 2 9. 220kV Narayanpur Barsoor
19	GD-1	WR	16-05-2025 12:10	16-05-2025 12:38	00:28	168	-	0.21%	-	79522	64393	At 12:10 Hrs/16-05-2025, 220 KV Pachora- Shajapur U7 ckt tripped on Y-E fault at Shajapur U7 end only & A/R successful at Pachora end. Due to tripping of this line, Shajapur U7 & Shajapur U6 (radially connected with Unit 7) went into dark. Generation loss of 168 MW reported at Shajpur due to loss of evacuation path.	1. 220kV Pachora-Shajapur U7 2. 220kV Shajapur U7-Shajapur U6
20	GD-1	WR	18-05-2025 23:59	28-05-2025 01:14	217:15	59	-	0.07%	-	79938	64490	At 23:59 Hrs/18-05-2025, 220kV Bhuj- Gadhsisa tripped on Y-B phase fault. Due to loss of evacuation path, 59 MW generation loss occurred at 220 kV Gadhsisa (Renew Power) WPP. As reported by Renew Power, Tower No.:- 21/7 damaged from top section due to conductor theft incident (conductor theft in spare line above Gadhsisa line).	1.220kV Bhuj-Gadhsisa S/C
21	GD-1	WR	24-05-2025 09:08	24-05-2025 12:42	03:34	50		0.07%		69727	58993	At 09:08 Hrs/24-05-25, During execution of planned shutdown of Bus-1 at 220kV Sidhpur S/S, LBB mal-operated during shifting of line from bus-1 to bus-2. Due to this Bus-1 and bus-2 tripped. Due to loss of evacuation path, generation loss of around 50 MW reported at Sidhpur.	1. 220kV Bus-1 2. 220kV Bus-2 3. 220/33 KV ICT-1 4. 220 KV Jamkambaliya-Sidhpur
	GD-1	WR	23-05-2025 12:02	23-05-2025 13:48	01:46	163	-	0.23%	-	69434	60237	At 12:02 Hrs/23-05-2025, 220 KV Pachora- Shajapur U7 ckt tripped on Yph - Bph fault. Due to tripping of this line, Shajapur U7 & Shajapur U6 (radially connected with Unit 7) went into dark. Solar RE generation loss of 163 MW (U6-81.24MW & U7-81.55MW) reported at Shajpur due to loss of evacuation path.	1. 220kV Pachora-Shajapur U7 2. 220kV Shajapur U7-Shajapur U6
	GD-1	WR	27-05-2025 16:27	27-05-2025 17:44	01:17	180	-	0.24%		74993	60665	At 16:27 Hrs / 27-05-25, 400KV IEPL- Koradi tripped on R-E fault. At the same time, 400 KV IEPL- Warora line tripped on over voltage protection operation at IEPL end and Z-2 R-N fault indication at Warora end. IEPL Unit-1(270 MW) tripped due to loss of evacuation path & led to generation loss of 180 MW.	1. 400KV IEPL- Koradi 2. 400KV IEPL- Warora 3. IEPL Unit-1 (270 MW)

Details of Grid Events during the Month of May 2025 in Southern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
1	GD - 1	KARNATAKA	02-05-2025 16:11	02-05-2025 16:19	00:08	1074	423	2.24%	0.74%	47923.0	57059.89	Complete outage of 220kV/110kV Kavoor SS, 220kV/110kV MSEZ(Bajpe) SS, and 400kV/220kV UPCL of Adani and Tripping of 220kV Bus-1 of 220kV/110kV Kemar SS of KPTCL on 02-05-2025 at 16:11hrs: The triggering incident was BN fault in 400kV UPCL Hebbanahalli line-1 and 2. Due to tripping of these lines, running U#2 at UPCL got tripped on operation of SPS at 16:11.48 hrs. Since there was split bus operation at 220kV Kemar SS during antecedent condition, an island was formed consisting of 220kV Kemar Bus-1 connected loads and U#1 generation at UPCL. Due to variation in the load generation balance in the island, U#1 UPCL got tripped at 16:12:02hrs (island operation for 14 sec) on operation of UF protection resulting in the complete outage of 400kV/220kV UPCL, 220kV/110kV Kavoor SS, 220kV/110kV MSEZ(Bajpe) SS and de-energization of 220kV Bus-1 of 220kV/110kV Kemar SS.	400KV-HEBBANAHALLI-UPCL-1, 400KV-HEBBANAHALLI-UPCL-2, UPCL UNIT 2, UPCL - UNIT 1
2	GD - 1	ANDHRA PRADESH	02-05-2025 18:32	02-05-2025 21:10	02:38	0	0	0.00%	0.00%	39953.35	48900.74	Complete outage of 400kV AMGEPL_Solar: As per the reports submitted, the triggering incident was B-N fault in 400kV Greenko AMGEPL line. At both ends, the fault was sensed in differnetial protection. A/R operated and the line tripped on persistant fault. Tripping of the only connected line led to complete outage of 400kV AMGEPL_Solar.	400KV-GREENKO_CPSS-AMGEPL_SOLAR-1, AMGEPL_SOLAR - 400KV
3	GD - 1	KARNATAKA	05-05-2025 20:12	06-05-2025 08:39	12:27	0	0	0.00%	0.00%	40267.16	50912.0	Complete Outage of 220kV Hiriyur Ostro Wind Station: Triggering incident was RN fault in 220KV-HIRIYUR_OSTRO-HIRIYUR-1 due to failure of suspension pilot insulator. Tripping of the only connected line resulted in the complete outage of 220kV Hiriyur Ostro Wind Station.	220KV-HIRIYUR_OSTRO-HIRIYUR-1
4	GD - 1	KARNATAKA	13-05-2025 15:00	Not restored yet	NA	116	0	0.22%	0.00%	51812.1	60401.98	Complete Outage of 400kV/220kV Gadag_PSS, 220kV Veena_GadagPS, 220kV RSRPL_GadagPS, and 220kV Green Infra_GadagPS: As per the reports submitted, the triggering incident was Tower collapse at a distance of 16km from Kudgi end causing multiple faults in 400kV Gadag Kudgi Line-1&2 and the line tripped. Tripping of both lines led to complete outage of 400kV/220kV Gadag PS. Since 220kV Greeninfra_GadagPS, 220kV RSRPL GadagPS, 220kV Veena GadaPS, 220kV Serentica are being radially Connected to 400kV/220kV Gadag Pooling station, Complete outage of 400kV/220kV Gadag PS led to complete outage of radial connected stations too.	400KV-GADAG_PSS-KUDGI_PG-1, 400KV-GADAG_PSS-KUDGI_PG-2
5	GD - 1	KARNATAKA	14-05-2025 12:11	14-05-2025 12:32	00:21	0	131	0.00%	0.23%	51661.04	56041.39	Complete outage of 220kV/66kV HBR Layout SS of KPTCL: During antecedent conditions, 220kV Manyata HBR layout was under outage. As per the reports submitted, the triggering incident was R-N fault in the UG cable of 220kV Hoody HBR Layout line and the line tripped. Tripping of the only connected line led to complete outage of 220kV HBR Layout SS.	220KV-HOODY-HBR_LAYOUT-1

Details of Grid Events during the Month of May 2025 in Southern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
6	GD - 1	ANDHRA PRADESH	19-05-2025 13:52	19-05-2025 14:09	00:17	121	0	0.28%	0.00%	43485.7	47300.41	Complete outage of 220kV Upper Sileru PH: During antecedent conditions, 220kV Upper Sileru Balimela was idle charged from Upper Sileru end. The triggering incident was R-N fault in 220kV Donkarai Upper Sileru Line. At Donkarayi end, E/F start was observed in EL and DR and the line tripped but E/F trip was not observed . However, the line was not tripped at Upper Sileru end but the fault was cleared by tripping of 220kV Upper Sileru Pendurthy Line at Pendurthy end on zone-3 protection. At the same time, Lower Sileru Unit-1 and Donkarayi Units tripped. This led to complete outage of 220kV Upper Sileru PH.	220KV-DONKARAYI-UPPER_SILERU-1, 220KV-PENDURTHI-UPPER_SILERU-1, UPPER_SILERU - 220KV
7	GD - 1	PONDICHERRY	21-05-2025 07:36	21-05-2025 08:55	01:19	0	153	0.00%	0.36%	40740.85	42651.92	Complete Outage of 230kV/110kV/22kV Bahoor SS and 230kV/110kV Karaikal SS: During antecedent conditions, 230kV Karaikal NLC TS-2 line was under outage to control the overloading of 400kV/230kV NLC TS-2 ICTs. Hence, 230kV/110kV/22kV Bahoor SS and 230kV/110kV Karaikal SS were radially fed from 400kV/230kV Pondy SS. The triggering incident was RN fault in 230kV Pondy Bahoor line. Tripping of 230kV Pondy Bahoor line resulted in complete outage of 230kV/110kV/22kV Bahoor SS and 230kV/110kV Karaikal SS.	230KV-PUDUCHERRY-BAHOOR-1
8	GD - 1	KARNATAKA	22-05-2025 11:22	22-05-2025 11:36	00:14	600	200	1.25%	0.45%	47922.67	43987.69	Complete Outage of 220kV/66kV Neelagunda SS, 220kV/66kV Kudligi SS, 220kV/66kV Tallak SS, 220kV BARC SS, 220kV Sagitur SS and 220kV Bus-2 of 220kV/66kV Ittagi SS: During antecedent conditions, 220kV Neelagunda Guttur and 220kV Jagalur Tallak Line-&2 were under outage. 220kV Itagi SS was operating with Bus split condition with 220kV Itagi Neelagunda and 220kV Itagi Kudlagi Line-1&2 on 220kV Bus-1. As per the reports submitted, the triggering incident was Y-N fault in 220kV Hiriyur Talak line and B-N fault in 220kV Guttur Chitradurga Line-1. At the same time, 220kV Hiriyur Chitradurga Line tripped only at Chitradurga end on	220KV-HIRIYUR-TALLAK-1, 220KV-GUTTUR-Chitradurga-1, 220KV-HIRIYUR-Chitradurga-1, 400KV/220KV JAGALUR-ICT-1, 400KV/220KV JAGALUR-ICT-2
9	GI-1	KARNATAKA	01-05-2025 17:59	01-05-2025 18:30	00:31	0	20	0.00%	0.04%	37411.06	47410.33	Tripping of 220kV Bus-1 of 220kV/110kV Narendra_KP SS of KPTCL: As per the reports submitted, the triggering incident was R- phase CVT failure in 220kV Narendra Ambewadi Line-2 at Narendra_KA SS. At the same time, 220kV Bus-1 BBP operated and all elements connected to 220kV Bus-1 tripped.	220KV-AMBEWADI-NARENDRA_KP-2, 220KV-BIDNAL-NARENDRA_KP-1, 220KV-HUBLI-NARENDRA_KP-2, 220KV-KANABARGI-NARENDRA_KP-1, NARENDRA_KP - 220KV - Bus 1, 220KV-AMBEWADI-NARENDRA-1
10	GI-2	ANDHRA PRADESH	03-05-2025 11:34	03-05-2025 15:02	03:28	0	0	0.00%	0.00%	50208.45	53185.69	Tripping of 765kV Bus-2 of 765kV/400kV Kurnool_PG SS: As per the reports submitted, the triggering incident was maloperation of PUA of 709 bay(Main bay of 765kV Kurnool Cuddapah Line-2). The BBP operation of Bus-2 was extended to 765kV Kurnool Bus-2. All main breakers connected to 765kV Bus-2 tripped. This led to loss of power supply to 765kV Bus-2 of 765kV/400kV Kurnool SS.	-
11	GI-2	ANDHRA PRADESH	15-05-2025 17:19	15-05-2025 18:18	00:59	0	0	0.00%	0.00%	42863.38	52353.84	De-energization of 400kV Gazuwaka East Bus: During deblocking of BTB HVDC Gazuwaka bipoles, over votages were observed in 400kV Gazuwaka East Bus. Triggering incident was tripping of 400kV Gazuwaka Jeypore line-1 on operation of DT Receive at Gazuwaka end due to OV St-1 protection operation at Jeypore end at 17:19:34hrs. Subsequently, 400kV Gazuwaka Jeypore line-2 tripped at 17:19:36hrs on operation of OV St-1 protection at Gazuwaka end and DT was sent to Jeypore end. Due to tripping of 400kV Gazuwaka Jeypore line-1 and 2, 400kV Gazuwaka East Bus got de-energised. Subsequently, BTB HVDC Gazuwaka bipoles got blocked on loss of AC voltage.	400kV Gazuwaka Jeypore line-1 and 2
12	GI-1	TAMILNADU	23-05-2025 13:52	23-05-2025 14:46	00:54	0	0	0.00%	0.00%	50055.72	45736.81	Tripping of 230kV Bus-1 and Bus-2 of 230kV/110kV Gobi SS: Triggering incident was failure of B-phase CT of 230kV Bus Coupler at 230kV/110kV Gobi SS. BBP protection of 230kV Bus-1 and Bus-2 operated resulting in the tripping of all connected elements at 230kV/110kV Gobi SS. 110kV Bus was intact during the event.	230KV-ARASUR-GOBI-1, 230KV-ARASUR_PG-GOBI-1, 230KV-GOBI-ANTHIYUR-1, 230KV-GOBI-MTPS_ST_III-1, 230KV-GOBI-PALKAPALYAM-1
13	GI-1	ANDHRA PRADESH	24-05-2025 03:37	24-05-2025 05:37	02:00	0	0	0.00%	0.00%	37262.97	38252.05	Tripping of 220kV Bus-2 of 220kV/132kV Chillakallu SS of APTRANSCO: As per the reports submitted, the triggering incident was R-N fault in 220kV Chillakallu VTPS Line-2. At Chillakallu end, the breaker failed to open and LBB operated. All elements connected to 220kV Chillakallu Bus-2 tripped.	220KV-CHILLAKALLU-PULICHINTALA-1, 220KV-CHILLAKALLU-SURYAPET-1, 220KV-VTPS-CHILLAKALLU-2

Details of Grid Events during the Month of May 2025 in Eastern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid[a]		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
1	GD-I	CHATRA	01.05.2025 13:04	01.05.2025 13:57	00:53	00:00	30	0.00%	0.14%	22325	20741	220kV Chatra S/s connected via S/c from Daltongunj & Latehar each S/s. At 13:04 Hrs, 220 kV Daltongunj-Chatra line tripped from Daltonganj end in Z-3 distance protection and simultaneously, 220 kV Latehar–Chatra line also tripped from Latehar end in Z-3 distance protection. 220kV Chatra S/s became dead. Total load loss of 30 MW occurred at Chatra. Power was extended through 220kV Latehar-Chatra S/C at 13:57 Hrs.	220kV Latehar-Chatra S/C 220kV Daltongunj-Chatra S/C
2	GD-I	GARHWA	04.05.2025 15:36	04.05.2025 18:30	02:54	00:00	80	0.00%	0.34%	24113	23260	220Kv Garhwa S/s radially connected through 220kV-Daltongunj-Garhwa D/C. Prior to disturbance 220kV Datongunj-Garhwa #2 was under tripped condition from 16:25 Hrs of 03/05/2025 due to snapping of conductor. At 15:36 Hrs, 220kV Datongunj-Garhwa #1 tripped on R-Earth fault. Due to tripping of this element, 220kV Garhwa S/s became dead. Total load loss of 80 MW occurred at Garhwa S/s. Power restored through 220 KV Daltonganj (PG) –Garhwa #2 at 18:30 Hrs.	220kV-Daltongunj-Garhwa #1 220kV-Daltongunj-Garhwa #2
3	GD-I	DIKCHU	10.05.2025 11:35	10.05.2025 12:57	01:22	0	0	0.00%	0.00%	24876	28056	At 11:35 Hrs, high resistive fault occurred in 400 kV Rangpo-Dikchu line and line tripped on B-Earth fault from both ends. As Dikchu was radially connected to Rangpo, 400kV Dikchu S/s became dead. During disturbance schedule of Dikchu was Zero so no generation loss reported. 400 kV Rangpo-Dikchu charged at 12:57 Hrs.	400 kV Rangpo-Dikchu
4	GI-II	DIKCHU	22.05.2025 12:52	22.05.2025 13:26	00:32	103	0	0.48%	0.00%	21277	25452	At 12:51 Hrs, high resistive fault occurred in 400kV Dikchu-Rangpo CKT-II (Bypassing Teesta-III) and same fault was sensed by Dikchu 400/132kV ICT and ICT got tripped on O/C earth fault. Further faulty line tripped from both end after 3 sec. Due to tripping of 400/132kV ICT both units at Dikchu tripped on over frequency due to loss of evacuation path. Generation loss of 103 MW was reported. Dikchu Unit#1 & 2 synchronized at 13:26 Hrs and 13:27 Hrs respectively.	400kV Dikchu-Rangpo CKT-II (Bypassing Teesta-III) 400/132 kV Dikchu ICT Dikchu Unit-1 Dikchu Unit-2
5	GD-I	MEJIA	23.05.2025 20:09	23.05.2025 21:46	01:37	962	0	2.97%	0.00%	32408	27015	At 20:09 Hrs on 23-05-2025, Total Power Failure occurred at 400KV Mejia due to operation of bus differential protection of both the 400kV main buses while performing bus change operation on GT 8. Total generation loss of 962 MW occurred at Mejia S/s. 400kV Main bus #1 was restored at 21:46 hrs on 23/05/25 after extending power through 400 KV Mejia Maithon ckt 1.	400KV MAIN BUS - 1 AT MEJIA-B 400KV MAIN BUS - 2 AT MEJIA-B 400KV-MAITHON-MEJIA-1 400KV-MAITHON-MEJIA-2 400KV-MAITHON-MEJIA-3 400KV-JAMSHEDPUR-MEJIA-1 MEJIA -UNIT 7 MEJIA -UNIT 8
6	GD-I	JODA	31.05.2025 12:07	31.05.2025 12:38	00:31	0	213	0.00%	0.77%	21986	27490	Prior to the disturbance 220kV Joda-TTPS #2 and 220/132kV ICT#3 under breakdown condition and Joda load feeding through Ramchandrapur S/c and TTPS #1(LILO at Telkoi). During shifting of 220/132kV ICT#1(220/132kV ICT #1 & 2 connected through 220kV main bus#1) to 220kV main bus #2 heavy sparking observed while isolator opening of ICT #1 and create a three-phase bus fault at Joda S/s. 220kV Ramchandrapur & TTPS circuit tripped in Z-4 protection. 220kV Joda S/s became dead. Total 213 MW load loss occurred at Joda S/s. Power extended through 220kV-Joda Ramchandrapur at 12:38 Hrs.	220kv Joda –Ramachandrapur 220kv Joda –Telkoi 220kv Joda –TSIL 220kv Joda –TTPS 220kv Joda –JSPL 220/132 kV ICT 1,2,3

Details of Grid Events during the Month of May 2025 in North Eastern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
1	GD I	Pasighat, Napit, Niglok areas of Arunachal Pradesh	03-05-2025 16:01	03-05-2025 17:06	01:05	0	17	0.00%	0.71%	1713	2404	Pasighat, Napit & Niglok areas of Arunachal Pradesh Power System were connected with rest of NER Grid through 132 kV Along-Pasighat & 132 kV Roing - Pasighat lines. At 16:01 Hrs of 03-05-2025, 132 kV Along-Pasighat & 132 kV Roing - Pasighat lines tripped. Due to tripping of these elements, Pasighat and radially connected Napit & Niglok areas of Arunachal Pradesh Power System got isolated from NER Grid and collapsed due to no source available in these areas. Power supply was extended to Pasighat area and radially connected Napit & Niglok by charging 132 kV Along-Pasighat line at 17:06 Hrs of 03-05-2025 & 132 kV Roing –Pasighat line at 17:14 Hrs of 03-05-2025.	132 kV Along-Pasighat & 132 kV Roing - Pasighat lines
2	GD I	Umrangsho and Haflong(AS) areas of Assam Power System & Haflong(PG) S/S	04-05-2025 17:40	04-05-2025 19:47	02:07	0	11	0.00%	0.44%	2418	2519	Umrangsho and Haflong(AS) areas of Assam Power System & Haflong(PG) S/S was radially connected with rest of NER Grid via 132 kV Khandong-Umrangsho line. Prior to the event, 132 kV Haflong(PG)-Jiribam line was under planned continuous shutdown since 21-04-2025. At 17:40 Hrs of 04-05-2025, 132 kV Khandong-Umrangsho line tripped. Due to tripping of these elements, Haflong(PG), Umrangsho and Haflong(AS) areas of Assam Power system got isolated from NER Grid and collapsed due to no source available in these areas. Power supply was extended to Umrangsho area of Assam Power System by charging 132 kV Khandong-Umrangsho line at 19:21 Hrs of 04.05.2025. Subsequently, power restoration at Haflong(PG) and Haflong(AS) were done by charging 132 kV Umrangsho-Haflong(PG) and 132 kV Haflong(PG)-Haflong(AS) at 19:40 Hrs and 19:47 Hrs of 04-05-2025 respectively.	132 kV Khandong-Umrangsho line
3	GD I	Umrangsho and Haflong(AS) areas of Assam Power System & Haflong(PG)	06-05-2025 17:56	06-05-2025 18:03	00:07	0	11	0.00%	0.41%	2475	2678	Umrangsho and Haflong(AS) areas of Assam Power System & Haflong(PG) S/S was radially connected with rest of NER Grid via 132 kV Khandong-Umrangsho line. Prior to the event, 132 kV Haflong(PG)-Jiribam line was under planned continuous shutdown since 21-04-2025. At 17:56 Hrs of 06-05-2025, 132 kV Khandong-Umrangsho line was hand tripped. Due to tripping of these elements, Haflong(PG), Umrangsho and Haflong(AS) areas of Assam Power system got isolated from NER Grid and collapsed due to no source available in these areas. Power supply was extended to Umrangsho and Haflong area of Assam Power System by charging 132kV Khandong-Umrangsho line at 18:03 Hrs of 06-05-2025.	132 kV Khandong-Umrangsho line
4	GD I	Rengpang area of Manipur Power System	08-05-2025 06:54	08-05-2025 07:30	00:36	0	2.4	0.00%	0.10%	1743	2309	Rengpang area of Manipur Power System was connected with rest of NER Grid through 132 kV Loktak-Rengpang line. Prior to the event, 132 kV-Jiribam-Rengpang line was under long outage since 18:18 Hrs of 17.11.2023. At 06:54 Hrs of 08-05-2025, 132 kV Loktak-Rengpang line tripped. Due to tripping of this element, Rengpang area of Manipur Power System was isolated from NER Grid and collapsed due to no source available in this area. Power supply was extended to Rengpang area of Manipur Power System by charging 132 kV Loktak-Rengpang line at 07:30 Hrs of 08-05-2025.	132 kV Loktak-Rengpang line
5	GD I	Amrit area of Meghalaya Power System	08-05-2025 14:30	08-05-2025 14:50	00:20	0	2	0.00%	0.08%	1594	2623	Amrit area of Meghalaya Power System was connected with rest of NER Grid through 132 kV Lumshnong-Amrit line. At 14:30 Hrs of 08-05-2025, 132 kV Lumshnong-Amrit line tripped. Due to tripping of this element, Amrit area of Meghalaya Power System was isolated from NER Grid and collapsed due to no source available in this area. Power supply was extended to Amrit area of Meghalaya Power System by charging 132 kV Lumshnong-Amrit line at 14:50 Hrs of 08-05-2025.	132 kV Lumshnong-Amrit line
6	GD I	Haflong(AS) area of Assam Power System	10-05-2025 12:39	10-05-2025 13:16	00:37	0	3.3	0.00%	0.12%	1452	2680	Haflong(AS) area of Assam Power System was radially connected with rest of NER Grid via 132 kV Haflong(AS)-Haflong(PG) line. At 12:39 Hrs of 10-05-2025, 132 kV Haflong(AS)-Haflong(PG) line tripped. Due to tripping of these elements, Haflong(AS) area of Assam Power system got isolated from NER Grid and collapsed due to no source available in this area. Power supply was extended to Haflong(AS) area of Assam Power System by charging 132 kV Haflong (AS) – Haflong(PG) line at 13:16 Hrs of 10-05-2025.	132 kV Haflong(AS)-Haflong(PG) line
7	GD I	Cherrapunji area of Meghalaya power system	11-05-2025 11:33	11-05-2025 13:40	02:07	0	1.8	0.00%	0.10%	1709	1748	Cherrapunji area of Meghalaya Power System is connected with rest of NER Grid by 132 kV Mawlai-Cherrapunji line. At 11:33 Hrs of 11-05-2025, 132 kV Mawlai-Cherrapunji line tripped. Due to the tripping, Cherrapunji area of Meghalaya Power System got isolated from NER Grid and collapsed due to no source available in this area. Power Suppy was extended to Cherrapunji area of Meghalaya Power system by charging 132 kV Mawlai-Cherrapunji line at 13:40 Hrs of 11-05-2025.	132 kV Mawlai-Cherrapunji line

Details of Grid Events during the Month of May 2025 in North Eastern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
8	GD I	Rongkhon and Ampati areas of Meghalaya Power system & Hatsingimari area of Assam Power system	11-05-2025 14:24	11-05-2025 15:06	00:42	0	41	0.00%	2.03%	1839	2024	Rongkhon and Ampati areas of Meghalaya Power system & Hatsingimari area of Assam were connected with rest of NER Grid by 132 kV Nangalbibra-Rongkhon line & 132 kV Agia-Hatsingimari line. At 14:24 Hrs of 11-05-2025, 132 kV Nangalbibra-Rongkhon and 132 kV Agia – Hatsingimari lines tripped. Due to tripping of these elements, Rongkhon and Ampati areas of Meghalaya Power System and Hatsingimari area of Assam power system got isolated from NER Grid and collapsed due to no source available in these areas. Power was extended to Ronkhon, Ampati & Hatsingimari areas by charging 132 kV Nangalbibra-Ronkhon-Ampati link at 15:06 Hrs of 11-05-2025.	132 kV Nangalbibra-Rongkhon and 132 kV Agia – Hatsingimari lines
9	GD I	Rongkhon, Ampati and Ganol areas of Meghalaya Power system & Hatsingimari area of Assam power system	12-05-2025 04:59	12-05-2025 05:43	00:44	0	11	4.46%	0.67%	1705	1630	Rongkhon, Ampati areas of Meghalaya Power system and Hatsingimari area of Assam were connected with rest of NER Grid by 132 kV Nangalbibra-Rongkhon and 132 kV Agia-Hatsingimari lines. Prior to the event, 132 kV Agia – Hatsingimari line was under outage since 15:14 Hrs of 11-05-2025. At 04:59 Hrs of 12-05-2025, 132 kV Nangalbibra-Rongkhon line tripped. Due to this tripping, Rongkhon Ganol, Ampati substations of Meghalaya Power System and Hatsingimari area of Assam power system got isolated from NER Grid and collapsed due to no source available in these areas. Power was extended to Ronghon, Ampati, Ganol and Hatsingimari areas by charging 132 kV Nangalbibra-Rongkhon line at 05:43 Hrs of 12-05-2025.	132 kV Nangalbibra-Rongkhon line
10	GD I	Kolasib, Bairabi and Turial area of Mizoram Power System	12-05-2025 05:52	12-05-2025 07:01	01:09	0	1	0.00%	0.06%	1716	1670	Kolasib area of the Mizoram Power system is connected to the rest of the NER grid through 132 kV Kolasib-Badarpur and 132 kV Kolasib - Aizawl lines. Turial and Bairabi are connected with Kolasib via 132 kV Kolasib - Turial and 132 kV Kolasib-Bairabi lines respectively. At 05:52 Hrs of 12-05-2025, 132 kV Aizawl-Kolasib and 132 kV Badarpur-Kolasib lines tripped leading to loss of power in Kolasib, Turial and Bairabi area of Mizoram Power system. Power supply was restored in Kolasib area at 07:01 Hrs of 12-05-2025 by charging 132 kV Aizawl - Kolasib line.	132 kV Aizawl-Kolasib and 132 kV Badarpur-Kolasib lines
11	GD I	Tezu and Namsai areas of Arunachal Pradesh Power System	20-05-2025 07:45	20-05-2025 12:31	04:46	0	12	0.00%	1.52%	2046	2165	Tezu and Namsai areas of Arunachal Pradesh Power System were connected with rest of NER Grid via 132 kV Roing – Tezu line. At 07:45 Hrs of 20-05-2025, 132 kV Roing – Tezu line tripped leading to blackout of Tezu and Namsai areas of Arunachal Pradesh Power System. Power was extended to Tezu and Namsai areas of Arunachal Pradesh by charging 132 kV Roing-Tezu line at 12:31 Hrs of 20-05-2025.	132 kV Roing – Tezu line
12	GD I	Chiephobozou area of Nagaland power system	22-05-2025 16:42	22-05-2025 18:09	01:27	0	1.2	0.00%	0.05%	2326	2652	Chiephobozou areas of Nagaland Power System was connected with rest of NER Grid through 132 kV Wokha - Chiephobozou and 132kV Zhadima - Chiephobozou line. At 16:42 Hrs of 22-05-2025, 132 kV Wokha - Chiephobozou and 132 kV Zhadima - Chiephobozou lines tripped. Due to tripping of these elements, Chiephobozou area of Nagaland Power System was isolated from NER Grid and collapsed due to no source available in this area. Power supply restored to Chiephobozou area of Nagaland Power System at 18:09 Hrs by charging 132 kV Chiephobozou-Zhadima line.	132 kV Wokha - Chiephobozou and 132 kV Zhadima - Chiephobozou lines
13	GD I	Along and Pasighat areas of Arunachal Pradesh Power System	23-05-2025 14:01	23-05-2025 15:04	01:03	0	11	0.00%	0.40%	2132	2770	Along and Pasighat areas of Arunachal Pradesh Power System were connected with rest of NER Grid through 132 kV Along-Basar and 132 kV Roing-Pasighat Line. At 14:01 Hrs of 23-05-2025, 132 kV Basar - Along and 132 kV Pasighat - Roing line tripped. Due to tripping of these elements, Along and Pasighat areas of Arunachal Pradesh Power System were isolated from NER Grid and collapsed due to no source available in these areas. Power supply was extended to Pasighat area by charging 132 kV Roing –Pasighat line at 14:46 Hrs of 23-05-2025 and to Along area by charging 132 kV Along – Pasighat line at 15:04 Hrs of 23-05-2025.	132 kV Basar - Along and 132 kV Pasighat - Roing lines
14	GD I	Sihhmui area of Mizoram Power System	26-05-2025 17:21	29-05-2025 19:34	74:13	0	8	0.00%	0.29%	2063	2714	Sihhmui area of Mizoram Power System was connected with rest of NER Grid through 132 kV Sihhmui-Melriat(PG) D/C lines. Prior to the event, 132 kV Zuangtui-Sihhmui line was under outage. At 17:21 Hrs of 26-05-2025, 132 kV Sihhmui-Melriat(PG) D/C lines tripped. Due to tripping of this element, Sihhmui area of Mizoram Power System was isolated from NER Grid and collapsed due to no source available in this area. Power was exended to Sihhmui area of Mizoram power system by charging 132 kV Zuangtui-Sihhmui line (charged as 33 kV as informed by Mizoram) at 17:21 Hrs of 26-05-2025.	132 kV Sihhmui-Melriat(PG) D/C lines

Details of Grid Events during the Month of May 2025 in North Eastern Region

Sl No.	Category of Grid Event	Affected Area	Time and Date of occurrence of Grid Event	Time and Date of Restoration	Duration (HH:MM)	Loss of generation / loss of load during the Grid Event		% Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Event		Antecedent Generation/Load in the Regional Grid*		Brief details of the event (pre fault and post fault system conditions)	Elements Tripped
	(GI 1or GI 2/ GD-1 to GD-5)					Generation Loss(MW)	Load Loss (MW)	% Generation Loss (MW)	% Load Loss (MW)	Antecedent Generation (MW)	Antecedent Load (MW)		
15	GD I	Rengpang area of Manipur Power System	26-05-2025 13:47	28-05-2025 13:50	48:03	0	1	0.00%	0.04%	1622	2545	Rengpang area of Manipur Power System was connected with rest of NER Grid through 132 kV Loktak Rengpang line. Prior to the event, 132 kV-Jiribam-Rengpang line was under long outage since 18:18 Hrs of 17.11.2023. At 13:47 Hrs of 26-05-2025, 132 kV Loktak-Rengpang line tripped. Due to tripping of this element, Rengpang area of Manipur Power System was isolated from NER Grid and collapsed due to no source available in this area. Power was extended to Rengpang area by charging 132 kV Loktak-Rengpang Line at 13:50 Hrs of 28-05-2025.	132 kV Loktak-Rengpang line
16	GD I	Ziro area of Arunachal Pradesh Power System	30-05-2025 22:06	30-05-2025 22:36	00:30	0	4	0.00%	0.21%	3153	1912	Ziro area of Arunachal Pradesh Power System was only connected with rest of NER Grid through 132 kV Ranganadi - Ziro Line and 132 kV Ziro-Daporizo Line. Prior to the event, 132 kV Ziro-Daporizo line was under tripped condition since 18:15 Hrs of 30-05-2025. At 22:06 Hrs of 30-05-2025, 132 kV Ranganadi – Ziro Line tripped. Due to tripping of this line, Ziro area of Arunachal Pradesh Power System was isolated from NER Grid and collapsed due to no source available in this area. Power was extended to Ziro area by charging 132 kV Ranganadi-Ziro line at 22:36 Hrs of 30-05-2025.	132 kV Ranganadi – Ziro Line
17	GD I	Zhadima, Chiephobozou, Wokha and Sanis areas of Nagaland Power System	31-05-2025 01:32	31-05-2025 03:05	01:33	0	2	0.00%	0.14%	2912	1459	Zhadima, Chiephobozou, Wokha and Sanis areas of Nagaland Power System are connected with rest of NER Grid through 132 kV Zhadima - Kohima line and 132 kV Doyang-Sanis line. At 01:32 Hrs of 31-05-2025, 132 kV Zhadima – Kohima, 132 kV Doyang-Sanis and 132 kV Sanis-Wokha lines tripped. Due to tripping of these elements, Zhadima, Chiephobozou, Wokha and Sanis areas of Nagaland Power System were isolated from NER Grid and collapsed due to no source available in these areas. Power supply was restored to Zhadima, Chiephobozou, Wokha and Sanis areas of Nagaland Power System by charging 132 kV Zadhima-Kohima line at 02:19 Hrs of 31-05-2025 and at 03:05 Hrs of 31-05-2025 by charging 132 kV Doyang - Sanis line.	132 kV Zhadima – Kohima, 132 kV Doyang-Sanis and 132 kV Sanis-Wokha lines

21. NEW ELEMENTS CHARGED IN MAY 2025

GENERATING UNITS

REGION	S. NO.	Location	Owner/Unit Name	Unit No/Source	Capacity added (MW)	Total/Installed Capacity (MW)	DATE
WR	1	400 kV Vedanta	Vedanta Private Ltd.	**Thermal**	600	600/600	24.05.2025
	2	NTPC REL Khavda PSS-2	NTPC REL Khavda PSS2 (NREL)	**Solar**	450.84	539/1555	08.05.2025
	3	Khavda PSS-5	Adani Renewable Energy Forty Five Ltd. (ARE45L)	**Solar**	75	125/250	13.05.2025
	4	Khavda PSS-13	Adani Renewable Energy Fifty Seven Ltd. (ARE57L)	**Solar**	75	650/1100	13.05.2025
	5	Khavda PSS-10	Adani Renewable Energy Fifty Six Ltd. (ARE56L)	**Solar**	75	250/500	14.05.2025
	6	Konhali RGESPL PSS-4	Renew Green (MHS Three) Private Ltd.	**Solar**	50.1	50.1/100	29.05.2025
	7	Akkalkot RGESPL PSS-5	Renew Green (MHS Three) Private Ltd.	**Solar**	100.5	100/100	29.05.2025
	8	Akkalkot RGESPL PSS-5	Renew Green (TN Three) Private Ltd.	**Solar**	99.6	99.6/100	29.05.2025
NR	9	Bikaner-II	SJVN Green Energy Ltd	**Solar**	64.01	320	01.05.2025
	10	Bikaner-II	ACME Sikar Solar Private Limited(ASSPL_BKN2)	**Solar**	75	300	03.05.2025
	11	Bhadla_2	Nokh Solar Power Plant NTPC Limited	**Solar**	237.57	735	23.05.2025
	12	Bikaner-II	Juna Renewable Energy Private Limited(JREPL)	**Solar**	335	335	24.05.2025
	13	Bhadla_2	GORBEA SOLAR PRIVATE LIMITED(GSPL)	**Solar**	100	300	25.05.2025
	14	Bikaner-II	ACME Sikar Solar Private Limited(ASSPL_BKN2)	**Solar**	60	300	27.05.2025
	15	Bikaner-II	Karinsar Solar Plant NHPC Ltd(KSP_NHPC)	**Solar**	53.57	300	27.05.2025
SR	16	230KV/33KV Generation Pooling S/S 220KV KOPPAL S/S	KLEIO SOLAR POWER Pvt. Ltd.	**Solar Generation (Lot-1)**	105	105	09.05.2025
	17	400KV GREENKO CPSS	GREENKO AP01 IREP	**Hydro/PSP Generation(Unit-6)**	240	1200	13.05.2025
	18	400KV GREENKO CPSS	GREENKO AP01 IREP	**Hydro/PSP Generation(Unit-7)**	120	1320	12.05.2025
	19	400KV GREENKO CPSS	GREENKO AP01 IREP	**Hydro/PSP Generation(Unit-8)**	120	1440	09.05.2025
	20	Nellore, Andhra Pradesh	Meenakshi Energy Limited (MEPL) - UNIT-3	**UNIT-3**	350	1000	21.05.2025
				Total Solar Generation addition	**2513**		
				Total Wind Generation addition	**634**		

Interconnecting/Generator/Station Transformers

REGION	S.NO.	Agency/Owner	Sub-Station	ICT No.	Voltage Level (kV)	Capacity (MVA)	DATE
WR	1	Renew Green Energy Solutions Pvt. Ltd.	Akkalkot RGESPL PSS5	ICT-1	400/33	100	28.05.2025
	2	NTPC REL Khavda PSS2	NTPC REL Khavda PSS2	ICT-5	400/33	315	26.05.2025
	3	Renew Green Energy Solutions Pvt. Ltd.	Tuljapur RGESPL PSS1	ICT-2	400/33	200	24.05.2025
	4	Renew Green Energy Solutions Pvt. Ltd.	Tuljapur RGESPL PSS1	ICT-1	400/33	200	24.05.2025
NR	5	Tehri PSP	Tehri(THDC)	GT-7	420/15.75	306	03.05.2025
	6	RSDCL	RSDCL(PSS3)_SL_BHD2_PG	ICT-1	220/33	100	05.05.2025
	7	RSDCL	RSDCL(PSS3)_SL_BHD2_PG	ICT-2	220/33	100	05.05.2025
	8	RSDCL	RSDCL(PSS3)_SL_BHD2_PG	ICT-3	220/33	100	05.05.2025
NER	9	POWERGRID ER NER Transmission Limited	Namsai	ICT-4	220/132	160	31.05.2025
	10	POWERGRID ER NER Transmission Limited	Namsai	ICT-3	220/132	160	31.05.2025
ER	11	WBSETCL	Jeerat	ICT-5	400/220	315	26.05.2025
	12	WBSETCL	SATGACHIA	ICT-1	400/220	500	11.05.2025
	13	WBSETCL	SATGACHIA	ICT-2	400/220	500	13.05.2025
SR	14	GREENKO AP01 IREP	400KV/18KV GREENKO_PSP	GT-6	400KV/18KV	300	13.05.2025
	15	GREENKO AP01 IREP	400KV/18KV GREENKO_PSP	GT-7	400KV/18KV	150	12.05.2025
	16	GREENKO AP01 IREP	400KV/18KV GREENKO_PSP	GT-8	400KV/18KV	150	09.05.2025
	17	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV/33KV Serentica_RI3PL_Gadag_S-ICT-1	ICT-1	220KV/33KV	150	10.05.2025
	18	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV/33KV Serentica_RI3PL_Gadag_S-ICT-2	ICT-2	220KV/33KV	150	10.05.2025
	19	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV/33KV Serentica_RI3PL_Gadag_W-ICT-1	ICT-1	220KV/33KV	150	12.05.2025
	20	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV/33KV Serentica_RI3PL_Gadag_W-ICT-2	ICT-2	220KV/33KV	150	12.05.2025
					Total (MVA)	**4256**	

NEW TRANSMISSION LINES

REGION	S.NO.	Agency/Owner	Line Name	Length (KM)	Conductor Type	DATE
WR	1	Goa Tamnar Transmission Projects Ltd.	220 kV Xeldem (GTTPL) - Xeldem (GED)-1	22.2	ACSS HTLS	29.05.2025
	2	Goa Tamnar Transmission Projects Ltd.	220 kV Xeldem (GTTPL) - Xeldem (GED)-1	22.2	ACSS HTLS	29.05.2025
	3	Renew Green Energy Solutions Pvt. Ltd.	400 kV Konhali RGESPL PSS4 - Tuljapur RGESPL PSS1	45.3	AL59	15.05.2025
NR	4	XL_XPPL	220kV Bhadla_2 (PG)-RSDCL(PSS3)_SL_BHD2_PG-1	31.1	AL59 Moose	04.05.2025
	5	ASSPL_BKN2	220kV Bikaner_2 (PBTSL)-Juna_REPL_SL_BKN2-1	16.2	AL59 Moose	21.05.2025
ER	6	Aditya Aluminium	400 kV Lapanga-Aditya Aluminium Ckt-1	5.4	AAAC MOOSE	23.05.2025
	7	Aditya Aluminium	400 kV Lapanga-Aditya Aluminium Ckt-2	5.4	AAAC MOOSE	23.05.2025
SR	8	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV-GADAG_PSS-Serentica_RI3PL_Gadag_S-1	11.4	ACSS 378	10.05.2025
	9	SERENTICA RENEWABLES INDIA 3 Pvt. Ltd.	220KV-Serentica_RI3PL_Gadag_S-Serentica_RI3PL_Gadag_W-1	22.6	AL59 MOOSE	12.05.2025
			Total length (km)	**181.7**		

ANTI-THEFT CHARGING OF NEW TRANSMISSION LINES

REGION	S.NO.	Agency/Owner	Line Name	Length (KM)	Conductor Type	DATE
WR	1	POWERGRID ER-WR Transmission Ltd.	400 kV Jeypore - Jagdalpur - 2 (from CSPTCL Jagdalpur end up to Jeypore gantry in ER)	68.81	Quad moose	22.05.2025
NR	2	UPPTCL	132kV Nanpara(UP)-Kohalpur(Nepal) CKT-1 from Nanpara(UP) Upto Tower no.98 (upto Indian border)	32.072	Panther	30.05.2025
	3	UPPTCL	132kV Nanpara(UP)-Kohalpur(Nepal) CKT-2 from Nanpara(UP) Upto Tower no.98 (upto Indian border)	32.072	Panther	30.05.2025
NER	4	DoP, AP	132kV Ziro (PG) - Yachuli (New Ziro) Line 2	12.221	ACSR Panther	14.05.2025

LILO/RE-ARRANGEMENT OF EXISTING TRANSMISSION LINES

REGION	S.NO.	Agency/Owner	Line Name/LILO at	Length (KM)	Conductor Type	DATE
WR	1	MPPTCL	220 kV Datia - Gwalior PG	55.18	ACSR Zebra 45	29.05.2025
	2	MPPTCL	220 kV Gwalior PG - Mahalgaon ckt III	10.205	ACSR Zebra 45	29.05.2025
	3	WRTS2, POWERGRID	400 kV Veloda - Kansari ckt II (Formed by 400 kV Veloda - Banaskantha & 400 kV Banaskantha - Kansari bypass at Banaskantha)	52.28	ACSR Twin Moose 85C	29.05.2025
NR	4	HVPNL	220kV Kadarpur (GPTL)-Palli(HV)-1	19.195	AL59 Zebra	15.05.2025
	5		220kV Kadarpur (GPTL)-Palli(HV)-2	19.195	AL59 Zebra	15.05.2025
	6		220kV Kadarpur (GPTL)-Gurugram_sec65 (HVPNL)-1	14.927	AL59 Zebra	15.05.2025
	7		220kV Kadarpur (GPTL)-Gurugram_sec65 (HVPNL)-2	14.927	AL59 Zebra	15.05.2025
ER	8	WBSETCL	400KV-NEW CHANDITALA-SATGACHIA-2	88	ACSR MOOSE	09.05.2025
	9	WBSETCL	400KV-GOKARNA-SATGACHIA-2	98	ACSR MOOSE	09.05.2025
	10	WBSETCL	400KV-NEW CHANDITALA-SATGACHIA-1	88	ACSR MOOSE	09.05.2025
	11	WBSETCL	400KV-GOKARNA-SATGACHIA-1	98	ACSR MOOSE	09.05.2025
	12	SPTL	400KV-DIKCHU-RANGPO-2	71.482	QUAD MOOSE	10.05.2025

BUS/LINE REACTORS

REGION	S.NO.	Agency/Owner	Element Name	Voltage Level (kV)	Rating (MVAr)	DATE
WR	1	Khavda II-A Transmission Ltd.	330 MVAR, Line reactor of 765 kV KPS2 - Lakadia line 2 at KPS2	765	330	24.05.2025
NR	2	UPRVUNL	330 MVAR Switchable Convertable LR of 765kV Bhadla-II Sikar-II Ckt-4 at Sikar_2(PSTL)	765	330	14.05.2025
ER	3	WBSETCL	125MVAR 400KV B/R-1 AT SATGACHIA	400	125	11.05.2025
				Total (MVAr)	**785**	

HVDC /AC Filter bank / FACTS DEVICE associated System

REGION	S.NO.	Agency/Owner	Element Name	SUB-STATION	Voltage Level (kV)	DATE
NIL						

Voltage Profile

विद्युत विभव रूपरेखा माह - मई 2025 VOLTAGE PROFILE - May 2025

क्र.स. Sl. No.	क्षेत्र REGION	उपकेंद्र SUBSTATION	VOLTAGE < V(lower)* (V=380,728 kV)	V(lower) < VOLTAGE < V(upper)*	VOLTAGE > V(upper)* (V=420,800 kV)	Voltage Deviation Index (%age of time voltage is outside range)	Number of hours voltage was outside IEGC band during month	उच्चतम (कि.वो.) Maximum(kV)	निम्नतम(कि.वो.) Minimum(kV)	औसत (कि.वो.) Average(kV)
1		अंगुल ANGUL	0%	100%	0%	0%	0	789	749	771
2		दार्लिपली DARLIPALI	0%	100%	0%	0%	0	787	764	774
3		गया GAYA	0%	100%	0%	0%	0	787	741	766
4	पूर्वी क्षेत्र ER	जीरत JEERAT	0%	100%	0%	0%	0	799	728	765
5		झारसगड़ा JHARSUGUDA	0%	100%	0%	0%	0	796	756	782
6		मिदनापुर MEDINIPUR	0%	100%	0%	0%	0	797	740	769
7		रांची RANCHI	0%	100%	0%	0%	0	793	756	778
8		सासाराम SASARAM	0%	100%	0%	0%	0	796	743	767
1		आगरा AGRA	0%	99%	0%	0%	3	808	739	777
2		आगरा (फ़तेहाबाद) AGRA (FATEHABAD)	0%	99%	1%	1%	7	808	746	773
3		अजमेर AJMER	0%	98%	2%	2%	12	804	744	784
4		अलीगढ़ ALIGARH	0%	100%	0%	0%	1	802	742	773
5		अनपरा सी ANPARA-C	0%	100%	0%	0%	0	784	756	768
6		अनपरा डी ANPARA-D	0%	100%	0%	0%	0	781	751	764
7		अंता ANTA	0%	100%	0%	0%	0	803	755	780
8		बलिया BALLIA	0%	100%	0%	0%	0	793	733	765
9		बारा BARA	0%	100%	0%	0%	0	800	753	771
10		भाडला BHADLA	0%	100%	0%	0%	0	806	733	781
11		भाडला-2 BHADLA-2	0%	100%	0%	0%	0	798	710	778
12		भिवानी BHIWANI	0%	100%	0%	0%	2	804	747	780
13		बीकानेर BIKANER	0%	100%	0%	0%	1	803	730	780
14		बरेली BAREILLY	0%	100%	0%	0%	2	806	737	772
15		चित्तौड़गढ़ CHITTORGARH	0%	99%	1%	1%	10	806	757	785
16		फतेहगढ़-2 FATEHGARH-2	0%	100%	0%	0%	0	821	712	775
17		फ़तेहपुर FATEHPUR	0%	100%	0%	0%	1	802	739	771
18		घाटमपुर GHATAMPUR	0%	100%	0%	0%	0	797	739	764
19	उत्तरी क्षेत्र NR	ग्रेटर नोएडा GREATER NOIDA	0%	99%	1%	1%	10	806	746	776
20		हापुड़ HAPUR	0%	100%	0%	0%	3	804	742	771
21		जवाहरपुर JAWAHARPUR	0%	100%	0%	0%	1	803	740	768
22		झटिकरा JHATIKARA	0%	100%	0%	0%	1	802	738	773
23		कानपुर जीआईएस KANPUR GIS	0%	100%	0%	0%	0	805	742	770
24		खेतरी KHETRI	0%	98%	2%	2%	13	804	735	778
25		कोटेश्वर KOTESHWAR	0%	100%	0%	0%	0	802	744	771
26		ललितपुर LALITPUR	0%	100%	0%	0%	3	786	708	758
27		लखनऊ LUCKNOW	0%	100%	0%	0%	0	798	732	765
28		मैनपुरी MAINPURI	0%	100%	0%	0%	0	799	735	763
29		मेरठ MEERUT	0%	99%	1%	1%	6	807	746	776
30		मेरठ(UP) MEERUT (UP)	0%	100%	0%	0%	2	805	743	771
31		मोगा MOGA	0%	100%	0%	0%	2	802	740	779
32		ओबरा सी OBRA C	0%	100%	0%	0%	0	778	746	761
33		उरई ORAI	0%	97%	3%	3%	26	812	749	784
34		फागी PHAGI	0%	100%	0%	0%	2	802	739	781
35		रामपुर RAMPUR	0%	98%	2%	2%	12	812	749	776
36		उन्नाव UNNAO	0%	100%	0%	0%	0	789	731	761
37		वाराणसी VARANASI	0%	100%	0%	0%	0	797	749	773
1		अकोला AKOLA	0%	100%	0%	0%	0	796	751	775
2		औरंगाबाद AURANGABAD	0%	100%	0%	0%	0	799	753	778
3		भोपाल (बीडीटीसीएल) BHOPAL (BDTCL)	0%	100%	0%	0%	0	793	749	771
4		भुज BHUJ	0%	100%	0%	0%	0	794	745	775
5		भुज-2 BHUJ-II	0%	100%	0%	0%	0	789	744	769
6		बिलासपुर BILASPUR	0%	100%	0%	0%	0	793	759	774
7		बीना BINA	0%	99%	1%	1%	4	806	754	780
8		बनसकंठा BANASKANTHA	0%	98%	2%	2%	13	807	751	781
9		चांपा CHAMPA	0%	96%	4%	4%	29	809	761	786
10		धले (बीडीटीसीएल) DHULE (BDTCL)	0%	100%	0%	0%	0	795	756	777
11		धर्मजयगढ़ DHARAMJAIGARH	0%	100%	0%	0%	0	789	756	772
12		रायपुर पूलिंग RAIPUR POOLING	0%	100%	0%	0%	0	798	762	780
13		एकतनी EKTUNI	0%	100%	0%	0%	0	795	743	772
14		गदरवाड़ा GADARWARA	0%	99%	1%	1%	6	806	761	784
15		ग्वालियर GWALIOR	0%	99%	1%	1%	9	809	749	781
16		इंदौर INDORE	0%	100%	0%	0%	0	791	749	772
17		जबलपुर JABALPUR	0%	98%	2%	2%	13	809	758	785
18	पश्चिमी क्षेत्र WR	खंडवा KHANDWA	0%	100%	0%	0%	0	789	755	769
19		कोरडी KORADI	0%	100%	0%	0%	0	786	750	771
20		लकाडिया LAKADIYA	0%	100%	0%	0%	3	803	752	781
21		रायगढ़ पूलिंग RAIGARH POOLING	0%	100%	0%	0%	0	796	767	780
22		पडघे PADGHE	0%	100%	0%	0%	0	803	750	777
23		परली PARLI	0%	99%	1%	1%	8	809	762	785
24		पुणे PUNE	0%	99%	1%	1%	6	804	756	782
25		राजनन्दगांव RAJNANDGAON	0%	97%	3%	3%	21	808	734	788
26		सासन SASAN	0%	100%	0%	0%	0	797	762	778
27		सतना SATNA	0%	99%	1%	1%	7	808	761	784
28		सिवनी SEONI	0%	100%	0%	0%	1	803	762	782
29		सीपत SIPAT	0%	100%	0%	0%	0	790	760	775
30		सोलापुर SOLAPUR	0%	98%	2%	2%	17	809	765	786
31		तिरोड़ा TIRORA	0%	100%	0%	0%	0	782	752	768
32		तामनार TAMNAR	0%	100%	0%	0%	0	795	768	779
33		वड़ोदरा VADODARA	0%	100%	0%	0%	3	807	754	782
34		विंध्याचल पूलिंग VINDHYACHAL PS	0%	100%	0%	0%	0	801	764	781
35		वर्धा WARDHA	0%	100%	0%	0%	2	807	758	782
36		वरोरा WARORA	0%	99%	1%	1%	5	806	755	783
1		अरियलूर ARIYALUR	0%	99%	1%	1%	10	805	761	785
2		कड़पा CUDDAPAH	0%	96%	4%	4%	31	816	760	784
3		चिल्कलूरीपेट CHILAKALURIPETA	0%	99%	1%	1%	4	805	749	773
4		कर्नूल KURNOOL	0%	100%	0%	0%	0	798	757	779
5		महेश्वरम MAHESWARAM	0%	98%	2%	2%	14	804	761	785
6	दक्षिणी क्षेत्र SR	निज़ामाबाद NIZAMABAD	0%	93%	7%	7%	54	809	769	791
7		नेल्लूर पूलिंग NELLORE PS	0%	100%	0%	0%	0	789	756	774
8		नॉर्थ चेन्नै पूलिंग NORTH CHENNAI PS	0%	100%	0%	0%	2	807	752	780
9		रायचर RAICHUR	0%	100%	0%	0%	2	802	757	783
10		श्रीकाकुलम SRIKAKULAM	0%	100%	0%	0%	0	801	742	774
11		तिरुवलम THIRUVALEM	0%	100%	0%	0%	0	801	750	777
12		वेमगिरी VEMAGIRI	0%	99%	1%	1%	5	807	750	776
13		वारंगल WARANGAL	0%	100%	0%	0%	2	805	754	778
1		बालिपारा BALIPARA (400 kV)	0%	100%	0%	0%	0	413	395	403
2		बिस्वनाथ चरिआलि BISWANATH CHARIALI (400 kV)	0%	100%	0%	0%	0	413	385	401
3		बोंगाईगांव BONGAIGAON (400 kV)	0%	100%	0%	0%	0	414	399	407
4		बोंगाईगांव टीपीएस BONGAIGAON TPS (400 kV)	0%	100%	0%	0%	0	415	398	408
5		इम्फ़ाल IMPHAL (400 kV)	0%	100%	0%	0%	0	415	394	403
6		बर्निहाट BYRNIHAT (400 kV)	0%	100%	0%	0%	0	417	399	407
7		कामेंग KAMENG (400 kV)	0%	100%	0%	0%	0	416	390	403
8	पूर्वोत्तर क्षेत्र NER	अज़ारा AZARA (400 kV)	0%	100%	0%	0%	0	413	401	406
9		मीसा MISA (400 kV)	0%	100%	0%	0%	0	412	393	401
10		न्यू मरियानी NEW MARIANI (400 kV)	0%	100%	0%	0%	0	415	391	405
11		न्यू कोहिमा NEW KOHIMA (400 kV)	0%	100%	0%	0%	0	417	393	404
12		पालाटाना PALATANA (400 kV)	0%	100%	0%	0%	0	414	401	406
13		पुर्बकचनबारी PK BARI (400 kV)	0%	100%	0%	0%	0	415	394	403
14		रंगानदी RANGANADI (400 kV)	0%	100%	0%	0%	0	419	387	405
15		सिलचर SILCHAR (400 kV)	0%	100%	0%	0%	0	418	387	407
16		सुर्ज्यामणिनगर SURJYAMANINAGAR (400 kV)	0%	100%	0%	0%	0	413	394	402
17		थौबाल THOUBAL (400 kV)	0%	100%	0%	0%	0	412	390	398

All listed stations are 765 kV stations unless otherwise mentioned

***Percentage is calculated w.r.t. Time of one month.**

ALL TIME HIGHEST

31-05-2025

	Maximum Demand Met during the day (MW)	Demand Met during Evening Peak hrs(MW)	Energy Met (MU)	Hydro Gen. (MU)	Wind Gen. (MU)	Solar Gen. (MU)
NR	91215 19-06-2024	82312 23-07-2024	1990 18-06-2024	443 01-08-2023	86 07-08-2023	228 22-04-2025
WR	80000 08-02-2025	71713 24-04-2025	1742 25-04-2025	167 18-12-2014	315 31-05-2025	160.2 24-04-2025
SR	69942 21-03-2025	55925 28-03-2025	1458 28-03-2025	208 31-08-2018	323 26-07-2024	155.5 06-03-2025
ER	32531 10-06-2024	31898 14-05-2025	692 10-06-2024	157 14-09-2022	-	4.76 02-05-2025
NER	3905 19-09-2024	3787 19-09-2024	80 20-09-2024	43 27-06-2024	-	2.4 22-06-2022
All India	250070 30-05-2024	227354 29-05-2024	5466 30-05-2024	877 30-08-2022	640 31-05-2025	534 23-04-2025

Regions	States	Max. Demand Met during the day (MW)		Energy Consumption (MU)	
			As on date		As on date
NR	Punjab	15980	29-06-2024	366.8	21-07-2024
	Haryana	14524	31-07-2024	293.4	19-06-2024
	Rajasthan	18985	12-02-2025	379.1	30-05-2024
	Delhi	8568	18-06-2024	177.7	18-06-2024
	UP	30032	13-06-2024	658.8	17-06-2024
	Uttarakhand	2863	14-06-2024	62.1	14-06-2024
	HP	2273	17-01-2025	41.3	20-12-2024
	J&K(UT) and Ladakh(UT)	3200	07-01-2025	70.3	04-02-2025
	Chandigarh	443	13-06-2024	9.1	18-06-2024
	Railways_NR_ISTS	-	-	-	-
WR	Chhattisgarh	6798	25-04-2025	153.3	25-04-2025
	Gujarat	26421	28-04-2025	519.1	29-04-2025
	MP	18888	20-12-2024	353.8	14-02-2025
	Maharashtra	30675	13-03-2025	689.0	24-04-2025
	Goa	864	14-05-2025	18.4	06-05-2025
	DD & DNH	1390	23-10-2024	32.6	16-10-2024
	AMNSIL	1083	10-01-2024	21.0	31-05-2022
	Balco	-	-	-	-
SR	Andhra Pradesh*	13712	04-05-2024	263.8	16-06-2023
	Telangana*	17162	20-03-2025	339.2	18-03-2025
	Karnataka	18395	07-03-2025	359.2	19-03-2025
	Kerala	5797	02-05-2024	116.1	03-05-2024
	Tamil Nadu	20830	02-05-2024	443.6	30-04-2024
	Pondy	545	03-05-2025	11.8	31-05-2024
ER	Bihar	8001	23-09-2024	172.8	30-07-2024
	DVC	3674	14-06-2024	81.2	22-04-2022
	Jharkhand	2351	09-07-2024	50.4	10-06-2024
	Odisha	7104	13-07-2023	148.5	19-04-2024
	West Bengal	12781	10-05-2025	264.0	30-04-2024
	Sikkim	137	11-01-2024	2.5	28-01-2020
	Railways_ER_ISTS	-	-	-	-
NER	Arunachal Pradesh	198	26-05-2024	3.9	18-06-2024
	Assam	2687	20-09-2024	55.8	20-09-2024
	Manipur	271	16-01-2025	4.2	10-01-2025
	Meghalaya	415	09-02-2022	7.8	31-01-2022
	Mizoram	167	29-01-2025	2.6	02-03-2024
	Nagaland	188	22-07-2024	3.4	29-07-2024
	Tripura	386	04-05-2024	7.3	02-06-2024
*SR	Andhra Pradesh (Undivided)	13162	23-03-2014	284.8	22-03-2014

24. System Reliability Indices Report for the month of May 2024

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	5	1.25	0.17
2	ER-NR	13	3.25	0.45
3	Import of NR	37	9.25	1.28
4	NEW-SR	1	0.25	0.03
5	NER Import	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	1	0.25	0.03
2	ER-NR	7	1.75	0.24
3	Import of NR	7	1.75	0.24
4	NEW-SR	2	0.50	0.07
4	NER Import	2	0.50	0.07

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.