

RESIDENTIAL FIRE DRILL / EVACUATION RECORD

Site Address: *164 Oak St*

DDSO / Provider Agency: *Hudson Valley DDSO*

Date: *10/01/2026*

Time Evacuation Started: *2:55 AM*

Part of Day: *Overnight*

Total time to evacuate to ground: *2 min 40 sec*

Total time for all to reach safe area: *4 min*

Centrally Monitored Fire Alarm Station: *No*

Time Monitoring Station Notified of Drill: *10:23 PM*

Time Monitoring Station Reactivated: *2:07 PM*

Time Monitoring Station Received Alarm: *8:30 PM*

Weather Conditions: *Cold and windy*

Method of Alarm Activation ☒ Pull Station ☐ Smoke Detector ☐ Other

Evacuation Type ☒ Full Evacuation to Outside ☐ Other

Type of Evacuation ☐ Announced ☐ Unannounced ☒ Supervised

Location of Simulated Fire: *Garage*

Blocked Exits by Simulated Fire: *Front door*

Location: *Whole house*

RESIDENTS & EVACUATION DETAIL

Name	Away?	To Evacuate	At Safe Area	Details
M. Singh	N	2:30	3:33	Independent
A. Cole	N	3:10	4:09	Used main exit
D. Okafor	Y	3:01	2:48	Independent

Description of evacuation: *Drill proceeded without incident.*

Problems noted / actions: *Exit light was dim; bulb replaced.*

Did Evacuation proceed per plan: *Yes*

Were all exits/routes clear: *No*

Did alarms/strobes function: *Yes*

Was drill observed: *Yes*

Did evacuation time meet requirement ☐ Yes ☒ No