

E-301 SINGLE-LINE DIAGRAM

13.8 kV UTILITY DISTRIBUTION SOURCE

EXISTING PADMOUNT

TRANSFORMER TX-01

13.8 kV / 600 V

600 V, 3-PHASE SECONDARY SERVICE

4 x 100 mm PVC DUCT BANK

ROUTE LENGTH: 85 m

CUSTOMER METER

400 A MAIN DISCONNECT

CUSTOMER DISTRIBUTION

PANEL

COMMERCIAL LOAD

250 kVA

GENERAL NOTES

- Single-line diagram is fictional and for academic portfolio use only.
- Final protection, grounding, and metering requirements require utility/code review.
- Service voltage assumed as 600 V, 3-phase.
- Customer load assumed as 250 kVA.
- Drawing is not for construction.

Project: Electrical Distribution Design Package

Site: 1234 Rexdale Industrial Road, Toronto, ON

Drawing: Single-Line Diagram

Drawing No.: E-301

Revision: 0

Date: 2026-06-10

Designer: Vivek Aruja

Status: Academic Portfolio Project

Note: Not For Construction