

S. No.	Test (with unit of measurement)	Test Result	Test Method	Requirements as per IS 1077:1992 (Non - Modular) for CD
1.	Compressive Strength (N/mm ²) Individual (i) (ii) (iii) (iv) (v) (vi) Average		IS 3495(P-1):2019	<div> </div> Any Individual brick shall not fall below by more than 10% of 10 N/mm ²
2.	Water Absorption, (%) by wt. Individual (i) (ii) (iii) (iv) (v) (vi) Average		IS 3495(P-2):2019	Up to Class 12.5 – Not more than 20% Higher than Class 12.5 – Not more than 15 %
3.	Efflorescence Test		IS 3495(P-3):2019	Up to Class 12.5 – Not More than (Moderate) Higher than Class 12.5 – Not more than (Slight)
4.	Dimension Length Width Height		IS 1077:1992/R2016	4600±80 mm 2200±40 mm 1400±40 mm

D.O.S.:

D.O.C.:

- *Indicates information provided by the customer
- **Note:** - The test Results given above pertains to the sample as received.

*****End of Report*****
(Jai Hind)

REVIEWED BY
Er.YOGINDER CHAUHAN
(SENIOR ANALYST)

AUTHORISED BY
Er.VISHAL ACHARYA
(TECHNICAL MANAGER)