



200 E. 7th Street Suite 204
Loveland, CO 80537
(970) 612-1970

Sample ID: 55740
Cody Drug
1505 S. Broadway St.
Sulphur Springs, TX 75482

Air Impaction Sampling Final Report

LAB 797 is a microbiology laboratory that specializes in USP<797> environmental and personnel monitoring. Samples from the facility listed above were submitted either directly from the facility or through a certification company working with the facility. The samples taken 4/1/2026 have been analyzed and the results are summarized below.

After incubation, no growth was recovered on any sample submissions.

If further action is required at your facility, please reference USP<797> for guidelines on the documentation, remediation, and re-testing required for the noncompliant sample area. A glossary of any organisms recovered in this sample set can be found on the third page of this report. Additional information explaining USP<797> can also be found on our website at Lab797.com. Please contact us with any questions you may have in regards to these results.

Note: It is ultimately the responsibility of the compounder to determine which laboratory results and organisms recovered warrant corrective action.

Sincerely,

LAB 797
200 E. 7th Street Suite 204
Loveland, CO 80537
970-612-1970

Respectfully Submitted by,

REVIEWED

By A. Fiscus at 10:16 am, Apr 13, 2026

REVIEWED

By N. Ulibarri at 10:28 am, Apr 13, 2026



Air Impaction Sampling Final Report

Sample ID 55740
Work Order J124747
Account No. 20605

Certification Company:
Medical Technology Associates, Inc.
6651 102nd Ave. N
Pinellas Park, FL 33782

Sampling Location:
Cody Drug
1505 S. Broadway St.
Sulphur Springs, TX 75482

Sampling Date:	4/1/2026	Incubation 1	30-35C		
Date Received:	4/3/2026	Start Date	4/3/2026	Start Time:	1:48 pm
No. Plates Received:	4	End Date:	4/6/2026	End Time:	8:43 am
Media Type:	TSA Air	Incubation 2	20-25C		
Media Lot/Expiry:	375530 x 5/10/2026	Start Date	4/6/2026	Start Time:	9:07 am
Sampler:	John Lillich	End Date:	4/13/2026	End Time:	7:35 am
				Start Temp(C):	33.1
				End Temp(C):	33.1
				Start Temp(C):	22.6
				End Temp(C):	22.5

Location Reference	ISO	Bacterial		Fungal		Microbial Analysis	Evaluation
		CFUs/ Morphs		CFUs/ Morphs			
1- Negative Control						Negative	Pass
2- Powder Room	8	0	0	0	0		Pass
3- Gowning Room	8	0	0	0	0		Pass
4- IV Room	7	0	0	0	0		Pass

Notes:

Results reported are applicable to the sample set and information provided by customer

All samples are processed and tested following current USP standards unless otherwise stated. Statements of conformity are based upon current USP standards unless otherwise stated. Any non-standard methods requested by the client or deviations from a standard method are noted above. All samples arrived in acceptable condition unless otherwise noted. All testing processes, including interpretations and opinions, are done by authorized laboratory personnel. Client-provided information such as sample volume and ISO classifications may affect the validity of the results. All testing is conducted within LAB 797's permanent facility. Methods of samples analysis may include SOP L906, L907, L909, L910, L911, L912, and L913.

Microbe Glossary

Fungal IDs

Intentionally Left Blank

Bacterial IDs

Intentionally Left Blank