

SANDY BROWN

Consultants in Acoustics, Noise & Vibration

17470-R04-B

17 April 2018

Greenwich Millennium Village, Phases 3, 4 & 5 Buildings 302, 303 & 304

Buildings 303 facade sound insulation mark ups – balconies and windows

55 Charterhouse Street, London EC1M 6HA
68 Sackville Street, Manchester M1 3NJ
2 Walker Street, Edinburgh EH3 7LA
87 Caroline Street, Birmingham B3 1UP

Sandy Brown Associates LLP
Registered in England & Wales No. OC 307504

T: +44 (0)20 7549 3500
T: +44 (0)161 771 2020
T: +44 (0)131 235 2020
T: +44 (0)121 227 5020

Registered Office: 55 Charterhouse Street, London EC1M 6HA

post@sandybrown.com
www.sandybrown.com

Version	Date	Comments	Author	Reviewer
A	14 Mar 18		Gareth Wells	Jason Swan
B	17 Apr 18	Includes updated GAs	Gareth Wells	Jason Swan

Contents

1 Building 303 facade sound insulation mark ups – balconies and windows..... 4

2 Building 303 Block E – Ground level 5

3 Building 303 Block F – Ground level 6

4 Building 303 Block G – Ground level..... 7

5 Building 303 Block E – Level 1..... 9

6 Building 303 Block F – Level 1..... 10

7 Building 303 Block G – Level 1 11

8 Building 303 Block H – Level 1 12

9 Building 303 Block E – Level 2..... 13

10 Building 303 Block F – Level 2..... 14

11 Building 303 Block H – Level 2 15

12 Building 303 Block E – Level 3..... 16

13 Building 303 Block F – Level 3..... 17

14 Building 303 Block H – Level 3 18

15 Building 303 Block E – Level 4..... 19

16 Building 303 Block H – Level 4 20

17 Building 303 Block E – Level 5..... 21

18 Building 303 Block H – Level 5 22

1 Building 303 facade sound insulation mark ups – balconies and windows

The following pages contain marked up floor plans for buildings 303 demonstrating how the design principles for opening windows and partially enclosed balconies can be applied. The minimum sound insulation performances for doors and windows on the various facades of the building are also provided.

The mark ups are based on the latest internal layouts issued by Jestico + Whiles for the building.

Table 1 provides a key to the tables for each facade mark-up in the following pages of this document.

Table 1 Key to facade mark-up table

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz} *)		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
XX	XX	XX	XX	XX	XX	XX	XX	XX	XX%	XX%	Yes / No	Yes / No	XX	XX	

Window / door reference number

Criterion 1: *L*_{Aeq} ≥ 45 dB - window fixed closed unless adequately shrouded

Criterion 2: *L*_{A63Hz} ≥ 40 dB - window recommended to be closed unless shrouded; predicted levels compared to Acoustic Report to determine required *D*_{63Hz} for window / door

Criteria 3 & 4: predicted levels which are compared to Acoustic Report to determine required window / door sound insulation performance

* This number is approximated from the broadband models of dredger noise, which dominates at 63 Hz. The actual level at 63 Hz is either equal to this number or as much as 3 dB lower. See discussion in cover report (17470-R02-C GMV3 Buildings 302, 303 & 304 -Internal and facade levels- acoustic Cond 87 Report, dated 17 April 2018).

All levels given are A-weighted facade noise levels in dB.

- The first level in each column (AO) is the noise level predicted with just the buildings existing ‘At Occupation’ of Buildings 303, namely Buildings 101 to 109, 201, 204 to 210 and 504.
- The second level in each column (MP) is the noise levels predicted with all the buildings of the masterplan in place – including all later parcels.

The percentages of allowable open areas are based on balcony/ shroud’s frontage only. The ends, top and floor may need to be solid, as noted herein.

Where no balcony / shroud is present, the percentage of allowable open area and the decision on whether a window may open will require further measures as noted herein. The additional screening required will be designed so that the openings are shielded from the wharf / dredger noise to ensure the internal noise levels can still be met. Please refer to the architectural drawings for more details on this.

The window / door sound insulation values given (ie, *D*_w + *C*_{tr} and *D*_{63Hz}) assume the window / door is more than 50% of the facade of the room and the remaining solid portion has at least the same performance. Where windows are a small portion of the facade and the surrounding solid part of the facade is at least 5 dB better than the windows, a slight relaxation in the requirement for the window / door as shown in Table 2 is then possible.

Table 2 Composite facade sound insulation performance, solid v glazed

Sound insulation required (from Figures on the following pages)	Minimum sound insulation of solid portion	Minimum sound insulation of fenestration if less than 20%/30%/50% of room facade
<i>D</i> _w + <i>C</i> _{tr} ≥ 30 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 35 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 27/28/29 dB
<i>D</i> _w + <i>C</i> _{tr} ≥ 25 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 30 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 22/23/24 dB
<i>D</i> _w + <i>C</i> _{tr} ≥ 20 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 25 dB	<i>D</i> _w + <i>C</i> _{tr} ≥ 17/18/19 dB

2 Building 303 Block E – Ground level




Figure 1 Building 303 Block E– Ground floor plan

Table 3 Building 303 Block E – Ground level predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area	Window/ door openable	Window/door sound insulation (dB)	Notes			
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP					AO	MP	<i>D</i> _w + <i>C</i> _{tr}
G.1	35	36	32	32	58	58	60	59	100%	100%	YES	YES	29	15	
G.2	35	36	32	32	58	58	60	59	100%	100%	YES	YES	29	15	
G.3	41	41	34	34	61	61	62	62	100%	100%	YES	YES	32	15	
G.4	41	41	34	34	61	61	62	62	100%	100%	YES	YES	32	15	
G.5	41	41	34	35	61	61	62	62	100%	100%	YES	YES	32	15	
G.6	41	41	35	35	61	61	62	62	100%	100%	YES	YES	32	15	
G.7	41	41	35	34	61	61	62	62	100%	100%	YES	YES	32	15	
G.8	40	41	34	34	61	61	62	61	100%	100%	YES	YES	32	15	
G.9	41	41	34	34	58	58	59	59	100%	100%	YES	YES	29	15	

3 Building 303 Block F – Ground level




Figure 2 Building 303 Block F– Ground floor plan

Table 4 Building 303 Block F – Ground level predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
G.1	38	39	31	31	47	44	53	49	100%	100%	YES	YES	13	15	
G.2	38	40	31	31	47	44	53	49	100%	100%	YES	YES	13	15	
G.3	38	40	31	31	48	44	54	49	100%	100%	YES	YES	14	15	
G.4	39	39	31	31	48	43	55	48	100%	100%	YES	YES	14	15	
G.5	43	43	36	35	45	45	49	49	100%	100%	YES	YES	16	15	
G.6	43	44	35	35	45	44	49	48	100%	100%	YES	YES	16	15	
G.7	43	44	35	35	45	44	49	48	100%	100%	YES	YES	16	15	
G.8	43	43	35	35	45	44	50	48	100%	100%	YES	YES	16	15	

4 Building 303 Block G – Ground level




Figure 3 Building 303 Block G – Ground floor plan

Table 5 Building 303 Block G – Ground level predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
G.1	42	42	33	33	48	46	54	52	100%	100%	YES	YES	19	15	
G.2	42	43	30	30	46	45	50	49	100%	100%	YES	YES	17	15	
G.3	42	43	30	30	46	45	50	49	100%	100%	YES	YES	17	15	
G.4	42	42	33	33	48	45	54	51	100%	100%	YES	YES	19	15	
G.5	43	43	34	34	46	45	50	50	100%	100%	YES	YES	17	15	
G.6	43	43	34	34	46	45	50	50	100%	100%	YES	YES	17	15	

5 Building 303 Block H – Ground level




Figure 4 Building 303 Block H – Ground floor plan

Table 6 Building 303 Block H – Ground level predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
G.1	38	41	29	33	51	44	59	49	100%	100%	n/a	n/a	22	15	
G.2	43	43	29	35	55	49	65	64	100%	100%	n/a	n/a	26	15	
G.3	42	43	29	35	55	49	65	64	100%	100%	n/a	n/a	26	15	
G.4	42	43	29	35	55	49	66	65	100%	100%	n/a	n/a	27	15	
G.5	42	43	29	33	55	48	66	65	100%	100%	n/a	n/a	27	15	
G.6	42	44	29	33	55	49	65	63	100%	100%	n/a	n/a	26	15	
G.7	42	44	29	33	55	49	63	63	100%	100%	n/a	n/a	26	15	
G.8	41	43	34	35	52	49	59	58	100%	100%	n/a	n/a	23	15	

6 Building 303 Block E – Level 1




Figure 5 Building 303 Block E – Level 1 floor plan

Table 7 Building 303 Block E – Level 1 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
1.1	41	42	34	35	61	61	62	61	100%	100%	YES	YES	32	15	
1.2	41	42	34	35	61	61	62	61	100%	100%	YES	YES	32	15	
1.3	41	42	34	35	61	61	62	61	100%	100%	YES	YES	32	15	
1.4	41	42	35	35	61	61	62	61	100%	100%	YES	YES	32	15	
1.5	41	41	36	36	61	61	62	61	100%	100%	YES	YES	32	15	
1.6	41	41	35	35	61	51	62	61	100%	100%	YES	YES	32	15	
1.7	41	41	35	35	61	61	62	61	100%	100%	YES	YES	32	15	
1.8	41	41	34	34	57	57	58	58	100%	100%	YES	YES	28	15	
1.9	40	41	34	34	55	54	56	55	100%	100%	YES	YES	26	15	
1.10	40	40	34	34	55	54	56	55	100%	100%	YES	YES	26	15	
1.11	39	42	31	31	47	46	54	52	100%	100%	YES	YES	18	15	
1.12	39	41	30	30	47	46	53	52	100%	100%	YES	YES	18	15	
1.13	40	41	30	30	46	46	53	52	100%	100%	YES	YES	19	15	
1.14	40	41	33	33	46	46	52	51	100%	100%	YES	YES	17	15	
1.15	40	42	33	34	46	45	52	50	100%	100%	YES	YES	17	15	
1.16	39	42	36	36	46	45	52	50	100%	100%	YES	YES	18	15	
1.17	39	42	34	34	44	45	52	50	100%	100%	YES	YES	18	15	
1.18	40	41	36	34	45	45	52	50	100%	100%	YES	YES	18	15	
1.19	39	41	34	34	46	45	52	49	100%	100%	YES	YES	18	15	
1.20	39	41	34	34	48	45	54	49	100%	100%	YES	YES	20	15	
1.21	39	39	33	32	54	55	56	54	100%	100%	YES	YES	26	15	
1.22	36	37	34	33	57	57	59	58	100%	100%	YES	YES	28	15	

7 Building 303 Block F – Level 1



Figure 6 Building 303 Block F – Level 1 floor plan

Table 8 Building 303 Block F – Level 1 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
1.1	39	41	33	33	48	45	54	50	100%	100%	YES	YES	19	15	
1.2	39	41	33	33	48	45	54	50	100%	100%	YES	YES	19	15	
1.3	39	41	32	32	48	45	55	50	100%	100%	YES	YES	19	15	
1.4	39	41	32	32	48	45	55	50	100%	100%	YES	YES	19	15	
1.5	39	41	32	32	49	45	55	49	100%	100%	YES	YES	20	15	
1.6	39	41	32	32	49	45	55	49	100%	100%	YES	YES	20	15	
1.7	40	41	32	32	49	44	55	49	100%	100%	YES	YES	20	15	
1.8	40	41	32	32	49	44	55	49	100%	100%	YES	YES	20	15	
1.9	43	44	36	36	45	45	50	49	100%	100%	YES	YES	16	15	
1.10	43	44	36	36	45	45	49	49	100%	100%	YES	YES	16	15	
1.11	43	44	36	36	45	45	49	49	100%	100%	YES	YES	16	15	
1.12	43	44	36	36	45	45	49	49	100%	100%	YES	YES	16	15	
1.13	43	44	35	35	45	45	49	49	100%	100%	YES	YES	16	15	
1.14	43	43	35	35	45	45	49	49	100%	100%	YES	YES	16	15	
1.15	43	44	37	37	46	45	50	50	100%	100%	YES	YES	17	15	
1.16	43	44	37	37	46	45	51	50	100%	100%	YES	YES	17	15	

8 Building 303 Block G – Level 1




Figure 7 Building 303 Block G – Level 1 floor plan

Table 9 Building 303 Block G – Level 1 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
1.1	41	42	33	34	50	48	56	54	100%	100%	YES	YES	22	15	
1.2	42	43	33	34	49	47	55	53	100%	100%	YES	YES	21	15	
1.3	42	43	32	32	48	48	53	51	100%	100%	YES	YES	14	15	
1.4	42	43	32	32	48	47	52	51	100%	100%	YES	YES	19	15	
1.5	43	43	34	34	49	46	53	51	100%	100%	YES	YES	20	15	
1.6	43	43	36	36	49	47	53	52	100%	100%	YES	YES	20	15	
1.7	43	44	33	34	49	47	53	51	100%	100%	YES	YES	15	15	
1.8	43	44	34	34	49	45	55	49	100%	100%	YES	YES	21	15	

9 Building 303 Block H – Level 1




Figure 8 Building 303 Block H – Level 1 floor plan

Table 10 Building 303 Block H – Level 1 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
1.1	42	43	34	34	45	45	53	49	100%	100%	YES	YES	16	15	Juliet screening arrangement Juliet screening arrangement Seal and ventilate via balcony or provide Juliet screening arrangement
1.2	42	43	34	34	46	45	52	48	100%	100%	YES	YES	17	15	
1.3	42	43	35	34	46	45	52	48	100%	100%	YES	YES	18	15	
1.4	42	43	35	35	46	45	52	48	100%	100%	YES	YES	18	15	
1.5	43	45	37	35	46	46	51	49	100%	85%	YES	YES	17	15	
1.6	43	45	37	35	46	46	51	50	100%	85%	YES	YES	17	15	
1.7	43	45	36	36	46	46	52	50	100%	85%	YES	NO	17	15	
1.8	43	44	36	36	46	47	52	51	100%	100%	YES	YES	18	15	
1.9	43	44	34	33	53	49	59	56	100%	100%	YES	YES	24	15	
1.10	43	44	35	36	53	49	59	55	100%	100%	YES	YES	25	15	
1.11	42	43	35	36	53	48	59	55	100%	100%	YES	YES	24	15	
1.12	42	44	35	36	53	49	60	57	100%	100%	YES	YES	24	15	
1.13	40	44	29	36	55	50	63	59	100%	100%	YES	YES	26	15	
1.14	40	44	29	36	55	49	63	60	100%	100%	YES	YES	29	15	
1.15	40	44	29	36	55	49	65	63	100%	100%	YES	YES	31	15	
1.16	40	44	29	36	55	49	65	65	100%	100%	YES	YES	26	15	
1.17	41	44	29	36	55	49	66	65	100%	100%	YES	YES	32	15	
1.18	42	44	29	36	55	49	66	65	100%	100%	YES	YES	27	15	
1.19	42	43	29	36	55	49	66	65	100%	100%	YES	YES	32	15	
1.20	43	43	29	35	55	49	66	65	100%	100%	YES	YES	32	15	
1.21	44	43	29	34	55	49	66	64	100%	100%	YES	YES	27	15	
1.22	42	40	30	29	52	45	59	50	100%	100%	YES	YES	23	15	
1.23	42	39	29	30	51	45	62	51	100%	100%	YES	YES	23	15	
1.24	40	40	30	29	50	44	62	50	100%	100%	YES	YES	23	15	

10 Building 303 Block E – Level 2




Figure 9 Building 303 Block E – Level 2 floor plan

Table 11 Building 303 Block E – Level 2 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
2.1	42	42	35	35	60	60	61	61	100%	100%	YES	YES	31	15	
2.2	42	42	35	35	60	60	61	61	100%	100%	YES	YES	31	15	
2.3	42	42	35	36	60	60	61	61	100%	100%	YES	YES	31	15	
2.4	42	42	35	36	60	60	61	61	100%	100%	YES	YES	31	15	
2.5	42	43	36	36	60	60	61	61	100%	100%	YES	YES	31	15	
2.6	43	44	38	36	60	60	61	61	100%	100%	YES	YES	31	15	
2.7	42	42	36	36	60	60	61	61	100%	100%	YES	YES	31	15	
2.8	42	43	35	35	57	56	59	59	100%	100%	YES	YES	28	15	
2.9	42	42	35	35	56	56	57	56	100%	100%	YES	YES	27	15	
2.10	41	42	35	35	55	55	56	55	100%	100%	YES	YES	26	15	
2.11	42	43	31	31	49	49	55	52	100%	100%	YES	YES	20	15	
2.12	40	42	31	31	48	48	54	52	100%	100%	YES	YES	20	15	
2.13	39	41	30	33	47	47	53	52	100%	100%	YES	YES	19	15	
2.14	41	41	37	37	47	47	53	51	100%	100%	YES	YES	18	15	
2.15	41	43	34	34	47	47	53	50	100%	100%	YES	YES	19	15	
2.16	41	43	34	34	47	47	53	50	100%	100%	YES	YES	19	15	
2.17	40	42	34	34	49	49	54	51	100%	100%	YES	YES	20	15	
2.18	39	40	32	32	54	54	56	54	100%	100%	YES	YES	25	15	
2.19	39	39	30	30	55	55	57	55	100%	100%	YES	YES	26	15	
2.20	39	38	30	30	56	57	57	57	100%	100%	YES	YES	28	15	
2.21	38	37	32	32	57	57	59	58	100%	100%	YES	YES	28	15	

11 Building 303 Block F – Level 2




Figure 10 Building 303 Block F – Level 2 plan

Table 12 Building 303 Block F – Level 2 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
2.1	38	42	33	33	49	46	55	51	100%	100%	YES	YES	21	15	Juliet screening arrangement
2.2	37	42	33	33	49	45	55	51	100%	100%	YES	YES	21	15	
2.3	37	42	33	33	50	45	56	50	100%	100%	YES	YES	22	15	
2.4	38	42	34	34	50	45	57	50	100%	100%	YES	YES	22	15	
2.5	42	43	36	37	49	45	55	50	100%	100%	YES	YES	21	15	
2.5	44	45	37	37	47	46	51	50	100%	85%	YES	YES	18	15	
2.6	44	45	37	37	47	46	51	50	100%	85%	YES	YES	18	15	
2.7	44	45	37	37	47	46	51	50	100%	85%	YES	YES	18	15	
2.8	43	44	36	36	47	46	51	50	100%	100%	YES	YES	18	15	
2.9	44	44	36	36	47	46	51	50	100%	100%	YES	YES	18	15	
2.10	43	44	36	36	47	46	52	51	100%	100%	YES	YES	18	15	
2.11	43	44	36	36	47	46	52	51	100%	100%	YES	YES	18	15	
2.12	43	44	38	38	47	46	52	51	100%	100%	YES	YES	18	15	

12 Building 303 Block H – Level 2




Figure 11 Building 303 Block H – Level 2 floor plan

Table 13 Building 303 Block H – Level 2 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
2.1	43	44	36	36	47	46	53	50	100%	100%	YES	YES	18	15	Juliet screening arrangement
2.2	43	44	36	36	47	46	53	50	100%	100%	YES	YES	18	15	
2.3	43	44	37	37	47	46	53	49	100%	100%	YES	YES	18	15	
2.4	43	44	37	37	47	47	52	48	100%	100%	YES	YES	18	15	
2.5	43	45	36	36	47	47	52	50	100%	85%	YES	YES	18	15	
2.6	43	45	36	36	47	47	52	50	100%	85%	YES	YES	18	15	
2.7	43	45	36	36	48	48	52	52	100%	85%	YES	YES	19	15	
2.8	43	44	36	36	48	48	53	53	100%	100%	YES	YES	19	15	Seal and ventilate via balcony or provide Juliet screening arrangement
2.9	44	44	35	34	53	50	59	56	100%	100%	YES	YES	24	15	
2.10	44	44	35	36	53	49	59	55	100%	100%	YES	YES	24	15	
2.11	43	44	38	36	53	49	60	56	100%	100%	YES	YES	24	15	
2.12	43	45	38	37	53	50	60	57	100%	85%	YES	YES	24	15	
2.13	40	45	29	30	55	50	63	60	100%	85%	YES	YES	26	15	Juliet screening arrangement
2.14	40	45	29	30	55	50	65	63	100%	85%	YES	YES	31	15	
2.15	40	45	29	34	55	50	65	63	100%	85%	YES	YES	31	15	
2.16	40	45	29	37	55	50	66	65	100%	85%	YES	YES	27	15	Juliet screening arrangement
2.17	41	45	29	39	55	50	66	65	100%	85%	YES	YES	27	16	
2.18	42	45	29	39	55	50	66	65	100%	85%	YES	YES	27	16	
2.19	43	44	29	36	55	50	66	65	100%	100%	YES	YES	32	15	Seal and ventilate via balcony or provide Juliet screening arrangement
2.20	43	44	29	36	55	50	66	65	100%	100%	YES	YES	32	15	
2.21	44	44	29	36	55	50	66	65	100%	100%	YES	YES	27	15	
2.22	42	40	30	37	52	45	59	51	100%	100%	YES	YES	23	15	
2.23	42	40	29	29	51	45	62	51	100%	100%	YES	YES	23	15	
2.24	40	41	32	32	51	44	57	51	100%	100%	YES	YES	22	15	

13 Building 303 Block E – Level 3




Figure 12 Building 303 Block E – Level 3 floor plan

Table 14 Building 303 Block E – Level 3 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
3.1	42	43	36	36	59	59	60	60	100%	100%	YES	YES	30	15	*Window can be openable taking 1 dB low frequency allowance
3.2	42	43	36	37	59	59	61	60	100%	100%	YES	YES	30	15	
3.3	42	43	36	37	59	59	61	60	100%	100%	YES	YES	30	15	
3.4	42	43	36	37	59	59	61	60	100%	100%	YES	YES	30	15	
3.5	44	44	40	40	59	59	61	60	0%*	0%*	NO*	NO*	30	17	
3.6	43	44	39	40	59	59	61	60	100%	0%*	YES	NO*	30	17	*Window can be openable taking 1 dB low frequency allowance
3.7	44	43	36	37	59	59	61	60	100%	100%	YES	YES	30	15	
3.8	42	43	36	36	56	55	58	57	100%	100%	YES	YES	27	15	
3.9	42	42	36	36	56	54	57	56	100%	100%	YES	YES	27	15	
3.10	42	43	36	37	55	52	56	55	100%	100%	YES	YES	26	15	
3.11	40	44	31	38	49	48	56	53	100%	100%	YES	YES	20	15	
3.12	40	42	30	29	48	47	55	52	100%	100%	YES	YES	21	15	
3.13	40	42	33	33	47	47	54	52	100%	100%	YES	YES	20	15	
3.14	40	42	35	35	47	46	54	51	100%	100%	YES	YES	18	15	
3.15	40	42	35	39	47	46	54	51	100%	100%	YES	YES	20	16	
3.16	43	43	40	39	48	46	54	51	0%	100%	NO	YES	20	17	*Window can be openable taking 1 dB low frequency allowance
3.17	42	43	38	39	49	46	55	52	100%	100%	YES	YES	20	16	
3.18	40	42	33	37	54	53	56	54	100%	100%	YES	YES	25	15	
3.19	39	40	29	29	55	54	57	55	100%	100%	YES	YES	26	15	
3.20	38	41	30	30	56	55	58	56	100%	100%	YES	YES	27	15	
3.21	37	39	34	33	57	56	59	58	100%	100%	YES	YES	28	15	

14 Building 303 Block F – Level 3




Figure 13 Building 303 Block F – Level 3 floor plan

Table 15 Building 303 Block F – Level 3 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
3.1	39	43	35	35	49	47	56	52	100%	100%	YES	YES	22	15	Non-habitable room
3.2	39	44	35	35	50	47	57	51	100%	100%	YES	YES	23	15	
3.3	39	43	35	36	50	46	57	51	100%	100%	YES	YES	23	15	
3.4	40	43	36	36	51	46	57	50	100%	100%	YES	YES	23	15	
3.5	44	45	37	37	48	47	53	51	n/a	n/a	YES	YES	14	15	
3.6	44	45	38	38	48	47	53	51	n/a	n/a	YES	YES	14	15	
3.7	44	45	38	38	48	47	53	51	n/a	n/a	YES	YES	14	15	
3.8	44	45	38	37	48	47	54	52	n/a	n/a	YES	YES	14	15	

15 Building 303 Block H – Level 3




Figure 14 Building 303 Block H– Level 3 floor plan

Table 16 Building 303 Block H – Level 3 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}			
3.1	44	45	37	37	48	46	54	51	100%	85%	YES	YES	19	15	Seal and ventilate via balcony or provide Juliet screening arrangement
3.2	44	45	37	37	48	46	54	50	100%	85%	YES	YES	19	15	Seal and ventilate via balcony or provide Juliet screening arrangement
3.3	44	45	39	37	48	46	54	49	100%	85%	YES	YES	20	16	Juliet screening arrangement
3.4	44	45	39	37	48	46	54	50	100%	85%	YES	YES	20	16	Juliet screening arrangement
3.5	44	46	38	37	48	47	54	50	100%	70%	YES	YES	20	15	Juliet screening arrangement
3.6	44	46	38	37	48	47	54	51	100%	70%	YES	YES	19	15	Juliet screening arrangement

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
3.7	44	46	40	37	49	48	54	52	85%	70%	YES	YES	20	17	Seal and ventilate via balcony or provide Juliet screening arrangement
3.8	44	45	39	37	49	48	54	53	100%	85%	YES	YES	20	16	
3.9	45	45	39	40	53	49	60	55	85%	85%	YES	YES	24	17	
3.10	45	45	39	40	54	49	60	56	85%	85%	YES	YES	26	17	Juliet screening arrangement
3.11	45	45	39	40	54	50	60	58	85%	85%	YES	YES	25	17	Juliet screening arrangement
3.12	44	45	39	40	54	50	60	65	100%	85%	YES	YES	26	17	Seal and ventilate via balcony or provide Juliet screening arrangement
3.13	44	46	29	39	56	50	63	65	100%	70%	YES	YES	27	16	Juliet screening arrangement
3.14	42	46	29	41	56	50	63	65	100%	70%	YES	YES	31	18	
3.15	42	46	29	41	56	50	65	65	100%	70%	YES	YES	31	18	
3.16	42	46	29	41	56	50	67	65	100%	70%	YES	YES	33	18	Juliet screening arrangement
3.17	42	46	29	41	56	51	66	65	100%	70%	YES	YES	32	18	Seal and ventilate via balcony or provide Juliet screening arrangement
3.18	42	45	29	41	56	51	66	65	100%	70%	YES	YES	27	18	
3.19	42	46	29	41	56	51	66	65	100%	70%	YES	YES	32	18	
3.20	43	45	29	39	56	50	66	63	100%	70%	YES	YES	32	16	Juliet screening arrangement
3.21	33	45	29	39	56	50	66	60	100%	85%	YES	YES	27	16	Seal and ventilate via balcony or provide Juliet screening arrangement
3.22	40	41	29	29	52	45	60	51	100%	100%	YES	YES	23	15	Seal and ventilate via balcony or provide Juliet screening arrangement
3.23	43	41	29	29	52	44	62	50	100%	100%	YES	YES	23	15	
3.24	42	42	29	33	51	44	62	50	100%	100%	YES	YES	23	15	

16 Building 303 Block E – Level 4




Figure 15 Building 303 Block E– Level 4 floor plan

Table 17 Building 303 Block E – Level 4 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})		AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
4.1	43	44	37	37	58	59	61	60	100%	100%	YES	YES	29	15	*Window can be openable taking 1 dB low frequency allowance
4.2	43	44	37	37	59	59	61	60	100%	100%	YES	YES	30	15	
4.3	43	44	37	37	59	59	61	60	100%	100%	YES	YES	30	15	
4.4	43	44	37	40	59	59	61	60	100%	0%*	YES	NO*	30	17	
4.5	44	44	39	39	59	59	61	60	100%	100%	YES	YES	30	16	Seal and ventilate via balcony or provide Juliet screening arrangement
4.6	44	45	39	37	59	58	61	60	100%	100%	YES	YES	30	16	
4.7	43	44	37	37	58	58	61	60	100%	100%	YES	YES	29	15	
4.8	43	44	36	36	56	56	58	57	100%	100%	YES	YES	27	16	
4.9	43	44	37	37	55	54	57	56	100%	100%	YES	YES	26	17	Juliet screening arrangement
4.10	43	44	38	38	54	53	56	56	100%	100%	YES	YES	25	17	
4.11	42	43	32	32	50	48	57	53	100%	100%	YES	YES	21	15	
4.12	40	42	31	32	50	47	56	53	100%	100%	YES	YES	22	15	
4.13	42	42	37	37	50	47	56	53	100%	100%	YES	YES	22	16	
4.14	43	44	39	39	50	47	56	52	100%	100%	YES	YES	21	16	
4.15	43	44	39	39	50	47	56	52	100%	100%	YES	YES	22	16	
4.16	43	44	39	39	50	47	56	52	100%	100%	YES	YES	22	16	
4.17	43	45	41	41	50	47	56	52	70%	70%	YES	YES	22	19	
4.18	44	45	41	41	50	47	57	52	70%	70%	YES	YES	21	19	
4.19	42	43	37	37	55	51	57	54	100%	100%	YES	YES	26	16	
4.20	39	40	31	31	56	54	58	56	100%	100%	YES	YES	27	15	
4.21	39	40	35	35	56	55	59	58	100%	100%	YES	YES	27	15	

17 Building 303 Block H – Level 4




Figure 16 Building 303 Block H– Level 4 floor plan

Table 18 Building 303 Block H – Level 4 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (L_{Aeq})		Dredgers (L_{A63Hz})		All sources night (L_{Aeq})		All sources day (L_{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	D_w+C_{tr}	D_{63Hz}			
4.1	45	46	40	40	50	48	55	52	85%	70%	YES	YES	21	17	Seal and ventilate via balcony or provide Juliet screening arrangement
4.2	45	46	40	40	50	48	55	51	85%	70%	YES	YES	21	17	Seal and ventilate via balcony or provide Juliet screening arrangement
4.3	45	46	41	40	50	48	55	51	70%	70%	YES	YES	21	18	Juliet screening arrangement
4.4	45	46	40	41	50	48	55	51	85%	70%	YES	YES	21	18	Juliet screening arrangement
4.5	46	46	42	40	50	48	55	52	45%	70%	YES	YES	21	19	Juliet screening arrangement 70% open area with 1 dB low frequency allowance

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
4.6	45	47	40	43	49	48	55	52	85%	45%	YES	YES	20	20	Seal and ventilate via balcony or provide Juliet screening arrangement
4.7	45	47	40	43	49	49	55	53	85%	45%	YES	YES	20	20	Seal and ventilate via balcony or provide Juliet screening arrangement
4.8	44	46	40	43	50	49	55	54	85%	30%	YES	YES	21	20	70% open area with 2 dB low frequency allowance
4.9	45	46	41	41	54	50	60	56	70%	70%	YES	YES	25	18	
4.10	46	46	41	41	54	49	60	56	70%	70%	YES	YES	26	18	Juliet screening arrangement
4.11	46	46	41	41	54	50	60	58	70%	70%	YES	YES	25	18	Seal and ventilate via balcony or provide Juliet screening arrangement
4.12	46	47	41	41	54	51	61	65	70%	45%	YES	YES	26	18	Seal and ventilate via balcony or provide Juliet screening arrangement
4.13	44	46	30	31	56	51	64	65	100%	70%	YES	YES	27	8	Juliet screening arrangement
4.14	43	47	30	38	56	51	65	65	100%	45%	YES	YES	31	15	
4.15	42	46	30	39	56	51	67	65	100%	70%	YES	YES	33	16	Juliet screening arrangement
4.16	42	46	30	40	56	51	67	65	100%	70%	YES	YES	33	17	Juliet screening arrangement
4.17	43	46	30	41	56	51	67	65	100%	70%	YES	YES	33	18	Seal and ventilate via balcony or provide Juliet screening arrangement
4.18	43	47	30	42	56	51	66	65	100%	45%	YES	YES	27	19	
4.29	43	46	30	42	56	51	66	63	100%	70%	YES	YES	32	19	Juliet screening arrangement
4.20	43	46	30	41	56	51	66	63	100%	70%	YES	YES	32	18	Juliet screening arrangement
4.21	44	46	30	40	56	51	66	60	100%	70%	YES	YES	27	17	Seal and ventilate via balcony or provide Juliet screening arrangement
4.22	41	45	31	31	52	46	60	53	100%	85%	YES	YES	23	15	
4.23	43	43	31	31	52	45	63	54	100%	100%	YES	YES	24	15	
4.24	42	43	31	31	52	45	62	53	100%	100%	YES	YES	23	15	

18 Building 303 Block E – Level 5




Figure 17 Building 303 Block E– Level 5 floor plan

Table 19 Building 303 Block E – Level 5 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
5.1	45	46	41	41	58	58	60	60	70%	70%	YES	YES	29	18	Seal and ventilate via balcony or provide Juliet screening arrangement
5.2	45	46	41	41	58	58	60	60	70%	70%	YES	YES	29	18	
5.3	45	46	41	41	58	58	60	60	70%	70%	YES	YES	29	18	Juliet screening arrangement
5.4	45	45	41	41	58	58	60	60	70%	70%	YES	YES	29	18	Juliet screening arrangement
5.5	46	46	41	43	58	58	60	60	70%	30%	YES	YES	29	20	Juliet screening arrangement. 70% open area with 2 dB low frequency allowance

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
5.6	46	46	43	43	58	58	60	60	30%	30%	YES	YES	29	20	Juliet screening arrangement. 70% open area with 2 dB low frequency allowance
5.7	46	46	43	43	58	58	60	60	30%	30%	YES	YES	29	20	
5.8	45	45	41	41	58	58	60	60	70%	70%	YES	YES	29	18	
5.9	45	45	40	40	55	55	58	57	85%	85%	YES	YES	26	17	Seal and ventilate via balcony or provide Juliet screening arrangement. 70% open area with 2 dB low frequency allowance
5.10	45	45	40	40	54	54	58	56	85%	85%	YES	YES	25	17	
5.11	45	46	42	41	54	52	57	55	45%	70%	YES	YES	25	19	
5.12	43	44	33	34	51	48	57	53	100%	100%	YES	YES	22	15	Seal and ventilate via balcony or provide Juliet screening arrangement
5.13	42	43	33	33	51	47	57	53	100%	100%	YES	YES	23	15	
5.14	41	43	33	33	51	47	57	52	100%	100%	YES	YES	22	15	
5.15	41	43	33	33	51	47	57	52	100%	100%	YES	YES	23	15	
5.16	41	43	33	33	51	47	57	52	100%	100%	YES	YES	23	15	
5.17	41	43	33	33	51	47	57	52	100%	100%	YES	YES	23	15	
5.18	41	43	33	33	51	47	57	52	100%	100%	YES	YES	22	15	
5.19	44	45	33	33	51	47	57	51	100%	85%	YES	YES	22	15	
5.20	45	45	33	33	55	51	58	54	85%	85%	YES	YES	26	15	Juliet screening arrangement
5.21	45	45	33	33	55	54	58	55	85%	85%	YES	YES	26	15	
5.22	41	41	38	33	55	55	59	58	100%	100%	YES	YES	26	15	

19 Building 303 Block H – Level 5




Figure 18 Building 303 Block H – Level 5 floor plan

Table 20 Building 303 Block H – Level 5 floor predicted noise levels and required mitigation measures

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
5.1	47	47	43	43	51	49	57	55	30%	30%	YES	YES	22	20	45% open area with 1 dB low frequency allowance
5.2	47	47	43	43	51	49	57	53	30%	30%	YES	YES	23	20	Seal and ventilate via balcony or provide Juliet screening arrangement. 45% open area with 1 dB low frequency allowance
5.3	47	47	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement. 45% open area with 1 dB low frequency allowance
5.4	47	47	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement. 45% open area with 1 dB low frequency allowance

Ref.	Noise levels (dB)								Balcony/ shroud open area		Window/ door openable		Window/door sound insulation (dB)		Notes
	Wharf & dredgers (<i>L</i> _{Aeq})		Dredgers (<i>L</i> _{A63Hz})		All sources night (<i>L</i> _{Aeq})		All sources day (<i>L</i> _{Aeq})								
	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	AO	MP	<i>D</i> _w + <i>C</i> _{tr}	<i>D</i> _{63Hz}	
5.5	47	47	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement. 45% open area with 1 dB low frequency allowance
5.6	47	48	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement
5.7	47	48	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement
5.8	47	48	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Juliet screening arrangement
5.9	47	48	43	43	51	50	56	54	30%	30%	YES	YES	22	20	Seal and ventilate via balcony or provide Juliet screening arrangement
5.10	47	47	43	43	51	50	56	55	30%	30%	YES	YES	22	20	Roof required. 45% open area with 1 dB low frequency allowance
5.11	47	47	42	42	54	51	60	57	45%	45%	YES	YES	25	19	Roof required
5.12	47	47	42	42	54	51	60	57	45%	45%	YES	YES	25	19	Seal and ventilate via balcony or provide Juliet screening arrangement
5.13	47	47	42	42	54	51	61	57	45%	45%	YES	YES	27	19	Seal and ventilate via balcony or provide Juliet screening arrangement
5.14	47	48	42	42	54	52	61	58	45%	30%	YES	YES	27	19	Roof required
5.15	45	47	33	33	56	51	64	61	85%	45%	YES	YES	30	15	Roof required
5.16	43	46	34	33	56	51	65	64	100%	70%	YES	YES	27	15	Juliet screening arrangement
5.17	43	46	34	33	56	51	65	65	100%	70%	YES	YES	27	15	Seal and ventilate via balcony or provide Juliet screening arrangement
5.18	43	46	34	33	56	50	67	65	100%	70%	YES	YES	28	15	
5.19	43	47	34	33	56	51	67	65	100%	45%	YES	YES	28	15	
5.20	43	47	33	33	56	51	66	65	100%	45%	YES	YES	27	15	Juliet screening arrangement
5.21	44	47	33	33	56	51	66	65	100%	45%	YES	YES	27	15	Juliet screening arrangement
5.22	45	47	33	33	56	51	66	65	85%	45%	YES	YES	27	15	Roof required
5.23	45	47	33	33	56	51	66	65	85%	45%	YES	YES	27	15	Roof required
5.24	43	48	33	33	53	49	60	54	100%	30%	YES	YES	24	15	Roof required
5.25	43	48	33	33	53	49	60	54	100%	30%	YES	YES	24	15	Seal and ventilate via balcony or provide Juliet screening arrangement
5.26	43	44	33	33	53	48	63	55	100%	100%	YES	YES	29	15	
5.27	44	44	33	33	53	47	63	55	100%	100%	YES	YES	29	15	