

Positive Unknown Input Observer for Fault Detection of Positive Distributed Systems

Sam Nazari and Bahram Shafai

Department of Electrical Engineering, Northeastern University, Boston MA
nazari@ece.neu.edu

Abstract—We consider robust fault detection in distributed systems with first and second order agent models. In such systems, we show that a ubiquitous class of consensus protocols leads to collective dynamics that lie in a nonnegative invariant set. Based on this, we derive LMI conditions for residual generators to sense faults in the nonnegative invariant set. An illustrative example is provided to highlight our approach and to show that it can reduce the time interval between fault occurrence and fault detection.

I. INTRODUCTION

Society relies on large, complex systems that are fundamentally networked [1], [2]. Many of these systems constitute the critical infrastructures that modernity depends on. Typically, these complex infrastructures are made up of smaller sub-systems, sometimes called agents, that interact locally with neighbors through information pathways. Examples of these infrastructures include financial transaction networks, information bearing networks, and energy production networks [3]. A distributed system is a system wherein such agents interactions are constrained to a local set of neighboring agents.

It is well known that the design of distributed systems is a multidisciplinary endeavor. Currently, there is major emphasis on development of rigorous design tools in order to assist system architecture planners in designing networked control systems (NCS) and Cyber-Physical Systems (CPS) [3], [4]. To address these demands, investigators have recently approached the design of distributed systems from a system theoretic perspective [3]. In particular linear observers have been formulated to address a variety of problems (delay, robust, singular, positive) [5], [6] as well as a variety of applications (fault detection, cyberphysical security, etc) [7], [8].

Due to its robust disturbance decoupling properties, the Unknown Input Observer (UIO) plays a central role in the analysis and design of observers for systems subject to unknown disturbance inputs [9], [10]. Recently, the authors of [11] reported the conditions that must be satisfied in order to design a positive UIO (PUIO) for a positive linear dynamical systems in terms of LMIs. This development is important since many physical systems may be modeled as positive linear systems [12]–[14]. In the distributed setting, however, no equivalent results have been reported in the literature. Furthermore, distributed systems are frequently plagued by actuator and sensor faults. If such faults are not adequately addressed, they may lead to biases in the overall consensus solution of the network or unexpected system

behavior. Consequently, there is a growing need to formulate positive observers for distributed positive systems.

To that end, fault detection in distributed systems has received notable attention from researchers recently. In [15], the authors address the problem of distributed reconfiguration of networked control systems. Various decentralized observer structures are surveyed in [6] for fault detection in distributed systems. In [8] and [16] the authors consider distributed fault detection and isolation with imprecise network models. The authors of [17] consider the consensus dynamics of a specific fault that leads to positive feedback in the distributed system. Many of the distributed systems that are addressed by the aforementioned approaches can be classified as positive linear systems. A positive linear system is a linear system whose state trajectories are confined to lie in the positive orthant [12]–[14], [18], [19]. Fault detection for such systems involves designing residual generators with internally positive state observers. In this paper we show that two popular linear consensus protocols lead to collective dynamics that can naturally be modeled as positive linear systems. After establishing this, we introduce distributed positive unknown input observers (D-PUIOs) using an LMI formulation to robustly estimate the states of individual agents, decoupled from unknown external disturbances, so that they can be processed by a residual generator to sense faults in distributed topologies. In doing this, we address the problem of designing positive residual generators to sense faults in a networked or distributed system with first or second order agent dynamics that are confined to the nonnegative orthant using an LMI formulation.

Section II provides background on systems theory, section III introduces PUIO and show how to formulate PUIO based residual generators, section IV shows that the distributed systems in this paper are positive systems and the D-PUIO for robust residual generation is introduced. An illustrative example is provided in Section V with concluding remarks in Section VI.

II. BACKGROUND

A. Notation

We denote the set of all positive real numbers including zero with the symbol $\mathbb{R}_+ = \{x \in \mathbb{R} : x \geq 0\}$. For convenience, nonnegative matrices are denoted by $M \geq 0$. We use similar notation for vectors and scalars. Relatedly, we use the notation $M > 0$ to mean the matrix M with entries that are strictly positive. We reserve the symbol \succeq refer to

positive semi-definite matrices, e.g. $P \succeq 0$. Graph theory has proven to be useful in a variety of diverse applications. We denote a graph by $\mathcal{G} = (\mathcal{V}, \mathcal{E})$. We assume all graphs are simple, finite, and undirected. The set of *neighbors* of the vertex $v \in \mathcal{V}$ is denoted by \mathcal{N}_v . The notation $|\mathcal{N}_v| = m$ denotes the cardinality of the set of neighbors of v , in this case m .

B. Positive Systems

Consider the general linear, time invariant system

$$\begin{aligned} \dot{x}(t) &= Ax(t) + Bu(t) + Ef(t) \\ y(t) &= Cx(t) + Du(t) \end{aligned} \quad (1)$$

where $x \in \mathbb{R}^n$, $u \in \mathbb{R}^m$, $y \in \mathbb{R}^p$, $f \in \mathbb{R}^r$ are state, input, output and fault vectors, respectively, and $A \in \mathbb{R}^{n \times n}$, $B \in \mathbb{R}^{n \times m}$, $C \in \mathbb{R}^{p \times n}$, $D \in \mathbb{R}^{p \times m}$ and $E \in \mathbb{R}^{n \times r}$ are associated system matrices. Let us further assume the system is in minimal representation meaning that the pair $\{A, B\}$ and $\{A, C\}$ are controllable and observable respectively. Note that the following definitions and lemmas are standard and can be found in [12].

Definition 1: A general linear system with initial condition $x_0 \geq 0$ is said to be internally positive if $u(t), f(t) \geq 0$ implies $x(t), y(t) \geq 0 \forall t \geq 0$.

Definition 2: A matrix $A = [a_{ij}] \in \mathbb{R}^{n \times n}$ is called a Metzler matrix if all of its off-diagonal elements are nonnegative, i.e., $a_{ij} \geq 0, \forall i \neq j, i, j = 1, \dots, n$.

Remark 1: Furthermore, a Metzler matrix is called strictly Metzler if in addition the condition in definition 1 we have $a_{ii} < 0 \forall i = 1, \dots, n$.

Remark 2: Throughout the paper, we shall denote the space of Metzler matrices with the symbol \mathbb{M} .

Remark 3: Every Metzler matrix A has a real eigenvalue $\mu = \lambda_{\max}(A) = \max \text{Re}(\lambda_i) \forall i = 1, \dots, n$ and a corresponding eigenvector $v_{\max} \geq 0$. If $\mu < 0$ then $\text{Re}(\lambda_i) < 0 \forall i = 1, \dots, n$ where λ_i are the eigenvalues of A [12], [14].

Definition 3: A positive system is said to be *reducible* if and only if the free evolution of a set of n_1 state variables is independent of the free evolution of the remaining $n_2 = n - n_1$ state variables. A system that is not reducible is said to be *irreducible*.

Lemma 1: The system in (1) is internally positive if and only if $A \in \mathbb{M}$ and $B \geq 0, C \geq 0$, and $E \geq 0$.

Lemma 2: A positive system (A, B, E, C) is irreducible if and only if its influence graph \mathcal{G} is connected, or, equivalently, if and only if

$$I + A + A^2 + \dots + A^{n-1}$$

is a strictly positive matrix, where A is the adjacency matrix of \mathcal{G} .

C. Distributed Systems

1) First-Order Dynamics: Consider a group of n agents with state $\psi_i(t)$ having single integrator dynamics

$$\begin{aligned} \dot{\psi}_i(t) &= u_i(t), \\ y_i(t) &= \psi_i(t) \end{aligned}$$

starting with initial condition $\psi_i(0) = \psi_{i0} \in \mathbb{R}$. The underlying interactions of such a interconnected system can be modeled by an undirected graph, $\mathcal{G} = (\mathcal{V}, \mathcal{E})$. Let the first-order consensus law $u_i(t) = \sum_{j \in \mathcal{N}_i} (\psi_j(t) - \psi_i(t))$ be assumed; where $u_i(t)$ is the control input to agent $i \in \mathcal{V}$, $x_i(t) \in \mathbb{R}$ is the state of agent i and $\psi_j(t) \in \mathbb{R}$ is the state of one of agent i 's neighbors. In the case where there are no faults or disturbances, the model

$$\begin{aligned} \dot{\psi}_i(t) &= \sum_{j \in \mathcal{N}_i} (\psi_j(t) - \psi_i(t)) \\ y_i(t) &= \psi_i(t) \end{aligned}$$

is valid for each agent $i \in \mathcal{V}$. Under these assumptions, the collective dynamics of the entire network are given by [20]:

$$\dot{\mathbf{x}}(t) = -\mathcal{L}\mathbf{x}(t) \quad (2)$$

where $\mathcal{L} \in \mathbb{R}^{n \times n}$ is the graph Laplacian of \mathcal{G} and $\mathbf{x}(t) \in \mathbb{R}^n$ is the state vector. In a distributed system, each agent $i \in \mathcal{V}$ only has access to the states of the m agents in its local neighborhood, \mathcal{N}_i . Let the set of states available to agent $i \in \mathcal{V}$ be defined by: $w_i(t) = [\psi(t)_{i_1}, \dots, \psi(t)_{i_{|\mathcal{N}_i|}}]^\top = C_i \mathbf{x}(t)$ where $C_i \in \mathbb{R}^{m \times n}$ encodes the interconnection topology of agent $i \in \mathcal{V}$. In the presence of faults, the system model for the agent that is subject to the fault must be modified since it no longer updates its state according to the consensus protocol. Instead, if agent $j \in \mathcal{N}_i$ experiences an fault, then it may update its state according to:

$$\begin{aligned} \dot{\psi}_j(t) &= \sum_{i \in \mathcal{N}_j} (\psi_i(t) - \psi_j(t)) + f_j(t) \\ y_j(t) &= \psi_j(t) \end{aligned}$$

where $f_j(t)$ is a function of time that is due to the fault signal. The network dynamics become [21]:

$$\begin{aligned} \dot{\mathbf{x}}(t) &= -\mathcal{L}\mathbf{x}(t) + Ef(t) \\ \mathbf{y}(t) &= \mathbf{x}(t) \end{aligned} \quad (3)$$

where $E \in \mathbb{R}^{n \times r}$ is the fault distribution matrix.

2) Second-Order Dynamics: Consider a group of n agents with state $x(t) = [\psi(t) \omega(t)]^\top$ having double integrator dynamics

$$\begin{aligned} \dot{\psi}_i(t) &= \omega_i(t), \\ \dot{\omega}_i(t) &= u_i(t) + v_i(t) \end{aligned}$$

with $v_i(t)$ being a known external input and $u_i(t)$ given by the linear consensus protocol

$$\begin{aligned} u_i(t) &= -\kappa_i \omega_i(t) \\ &+ \sum_{j \in \mathcal{N}_i} w_{ij} [(\psi_j(t) - \psi_i(t)) + \gamma(\omega_j(t) - \omega_i(t))] \end{aligned}$$

where $w_{ij} > 0$ is the edge weight and $\kappa_i, \gamma \geq 0$ for $i, j = 1, \dots, n$ are scalar coefficients. The subscript i and j denote the agent and its neighbor, respectively. The collective

dynamics of the distributed system are then modeled by [21], [22]

$$\begin{aligned}\dot{\mathbf{x}}(t) &= A_G \mathbf{x}(t) + Bv(t) \\ \mathbf{y}(t) &= \mathbf{x}(t)\end{aligned}\quad (4)$$

where

$$A_G = \begin{bmatrix} 0 & I \\ -\mathcal{L} & -\gamma\mathcal{L} - \bar{K} \end{bmatrix}, \quad B = \begin{bmatrix} 0 \\ I \end{bmatrix} \quad (5)$$

where $\mathcal{L} \in \mathbb{R}^{2n \times 2n}$ is the graph Laplacian of \mathcal{G} and $\bar{K} = \text{diag}(\kappa_1, \dots, \kappa_n)$. In the presence of faults, the system model for the agent that is subject to the fault must be modified since it no longer updates its state according to the consensus protocol. Instead, if agent $j \in \mathcal{N}_i$ experiences a fault, then it may update its state according to $\dot{\psi}_j(t) = \omega_j(t) + f_j(t)$, or, if the fault is imparted on the second state variable

$$\begin{aligned}\dot{\psi}_j(t) &= \omega_j(t) \\ \dot{\omega}_j(t) &= u_j(t) + v_j(t) + f_j(t)\end{aligned}$$

where $f_j(t)$ is a function of time that is due to the fault signal. The network dynamics become:

$$\begin{aligned}\dot{\mathbf{x}}(t) &= A_G \mathbf{x}(t) + Bv(t) + Ef(t) \\ \mathbf{y}(t) &= \mathbf{x}(t).\end{aligned}\quad (6)$$

III. POSITIVE UNKNOWN INPUT OBSERVERS FOR FAULT DETECTION & ISOLATION

A. Positive Unknown Input Observer Structure

An unknown input observer for the system in (1) has the following structure

$$\begin{aligned}\dot{z}(t) &= Fz(t) + Gy(t) + Hu(t) \\ \hat{x}(t) &= Mz(t) + Ny(t).\end{aligned}\quad (7)$$

For simplicity we assume $M = I$, $G = G_1 + G_2$ and $H = TB$. In fault detection and isolation, residual signals are processed in order to determine if a fault has occurred. Based on the PUIO in (7), the residual generator is given by

$$r(t) = (I - CH)y(t) - Cz(t). \quad (8)$$

Related to (7) we have the following lemma.

Lemma 3: The UIO (7) is an internally positive unknown input observer if and only if $F \in \mathbb{M}$, $G \geq 0$, $H \geq 0$, $N \geq 0$ and $u(t) \geq 0$ implies that $z(t) \geq 0$, $\hat{x}(t) \geq 0$, $y(t) \geq 0$, $\forall t \geq 0$.

Proof: This is a consequence of definition (1) and lemma (1). ■

B. Generalized Inverse of a Nonnegative Matrix

The generalized inverse of a nonnegative matrix is needed to design a PUIO. The Moore-Penrose generalized inverse of $\tilde{A} \in \mathbb{R}^{m \times n}$ is the unique matrix $\tilde{A}^g \in \mathbb{R}^{m \times n}$, satisfying the equalities (i) $\tilde{A}^g = \tilde{A}^g \tilde{A} \tilde{A}^g$, (ii) $\tilde{A} = \tilde{A} \tilde{A}^g \tilde{A}$, (iii) $(\tilde{A} \tilde{A}^g)^T = \tilde{A} \tilde{A}^g$, and $(\tilde{A}^g \tilde{A})^T = \tilde{A}^g \tilde{A}$.

In general the existence of $\tilde{A} \geq 0$ does not imply $\tilde{A}^g \geq 0$. For $\tilde{A} \geq 0$ square and invertible we have $\tilde{A}^g = \tilde{A}^{-1} \geq 0$ iff \tilde{A} is monomial. A monomial matrix is a generalized permutation

matrix. We can express a monomial matrix as a product of a diagonal matrix and permutation matrix. Similarly, its inverse can be expressed as $\tilde{A}^{-1} = D\tilde{A}^T$ for some diagonal matrix D with positive diagonal elements. Our goal is to provide the necessary and sufficient conditions on $\tilde{A} \geq 0$ so that $\tilde{A}^g \geq 0$. To accomplish this, we use the following result from [14] which characterizes $\tilde{A} \geq 0$ so that $\tilde{A}^g \geq 0$.

Lemma 4: Let $\tilde{A} \geq 0$ with rank r . Then the following statements are equivalent:

- 1) $\tilde{A}^g \geq 0$.
- 2) There exists a permutation matrix \tilde{P} such that $\tilde{P}\tilde{A}$ has the form $\tilde{P}\tilde{A} = \begin{bmatrix} \tilde{B}_1^T & \dots & \tilde{B}_r^T & 0 \end{bmatrix}^T$, where each \tilde{B}_i has rank 1 and the rows of \tilde{B}_i are orthogonal to the rows of \tilde{B}_j for $i \neq j$.
- 3) $\tilde{A}^g = D\tilde{A}^T$ for some diagonal matrix D with positive diagonal elements.

The interested reader may find the proof of lemma 4 in [14]. We now construct \tilde{A}^g . Under statement 2 in lemma 4, we let $\tilde{B} = \tilde{P}\tilde{A}$. Then $\forall i = 1 \dots r$, there exist column vectors x_i, y_i such that $\tilde{B}_i = x_i y_i^T$. Furthermore, \tilde{B}_i^g is the nonnegative matrix $\tilde{B}_i^g = (\|x_i\|^2 \|y_i\|^2)^{-1} \tilde{B}_i^T$ and moreover $\tilde{B}^g = (\tilde{B}_1^g, \dots, \tilde{B}_r^g, 0)$, since $\tilde{B}_i \tilde{B}_j = 0$ for $i \neq j$. In particular, $\tilde{B}^g = D\tilde{B}^T$ where D is a diagonal matrix with positive diagonal elements and thus $\tilde{A}^g = D\tilde{A}^T$.

C. Design of PUIO Based Residual Generators

The following result is important in designing PUIOs that can be used to produce residual signals for fault detection in positive dynamic systems.

Theorem 1: Consider a positive system defined by (1) with the fault term $f(t) \neq 0$ such that $\text{rank}(CE) = \text{rank}(E) = r$ and the generalized left inverse of CE is nonnegative. Then there exists a PUIO of the form (7) if and only if the following extended LMI has a feasible solution for Y and a symmetric positive definite matrix P

$$\begin{cases} A_1^T P + P A_1 - C^T Y^T - Y C \prec 0 \\ A_1^T P - C^T Y^T + I \geq 0 \\ Y + P A_1 N - Y C N \geq 0 \\ P \succ 0 \end{cases} \quad (9)$$

where

$$F = A - NCA - G_1 C \quad (10)$$

$$T = I - NC \geq 0 \quad (11)$$

$$G_2 = FN \quad (12)$$

$$G = G_1 + G_2 \geq 0 \quad (13)$$

$$H = TB \quad (14)$$

$$(NC - I)E = 0, \quad N \geq 0 \quad (15)$$

Proof: The reader is referred to [11] for the proof of this theorem. ■

The existence conditions of the PUIO depends on the positive solution of (15). This equation has a solution if and only if the rank condition $\text{rank}(CE) = \text{rank}(E) = r$ is satisfied

and that a nonnegative left inverse of CE exists. As can be seen from

$$N = E(CE)^g + S[I - (CE)(CE)^g] \quad (16)$$

a nonnegative CE leads to a nonnegative N , where $S \in \mathbb{R}^{n \times p}$ is an arbitrary matrix that can be used as a design parameter. We may assume $S = 0$ for simplicity and require that

$$N = E(CE)^g \geq 0 \quad (17)$$

Since it is assumed that $(CE)^g \geq 0$, the matrix N is nonnegative. Furthermore, it is required that N satisfies the nonnegativity of T in (11). If (17) fails to achieve this, (16) can be used with the aid of free parameter matrix S . Accordingly, the design of PUIO amounts to solving for the remaining unknown matrices F , G , and H . This can be done based on a design procedure outlined below.

PUIO Design Procedure:

- 1) Check if $\text{rank}(CE) = \text{rank}(E) = r$. If not, then an unknown input observer does not exist.
- 2) Check the condition of Lemma (4). If a nonnegative left inverse of CE exists, then compute N from (16) or (17) such that (11) is satisfied and continue to the next step, otherwise stop.
- 3) Compute $T = I - NC$ and define $A_1 = TA$ such that $\{A_1, C\}$ is observable.
- 4) Solve the LMI (9) for the variable P and Y , and compute $G_1 = P^{-1}Y$.
- 5) Obtain the parameter matrices of PUIO from

$$\begin{aligned} F &= A_1 - G_1 C, & H &= TB \\ G &= G_1 + A_1 N - G_1 C N \end{aligned}$$

Note that $M = I$ and N is specified by (16) or (17).

Remark 4: The above design procedure can be modified by avoiding the nonnegativity constraint in (11) and (13) and replaced by the following conditions:

$$H = TB \geq 0 \quad (18)$$

$$NCA - FNC + GC \geq 0 \quad (19)$$

which provides us with additional design freedom. Consequently step 4 of the PUIO design procedure can be adjusted so that the third condition of (8) is replaced with the inequality:

$$PNCA + YC \geq 0 \quad (20)$$

This allows to preserve the positivity of PUIO through the dynamics of the state estimate

$$\begin{aligned} \hat{x}(t) &= F\hat{x}(t) + (NCA - FNC + GC)\hat{x}(t) \\ &\quad + (NCB + H)u(t) + NCEd(t) \end{aligned} \quad (21)$$

For more details of the derivation, see [23].

Remark 5: In order to detect and isolate faults based on the PUIO design procedure above, it necessary to design a residual generator based on (8). Since the PUIO is an

internally positive observer and the system in (1) is a positive system, the residual will also be a signal in the positive orthant.

IV. DISTRIBUTED FAULT DETECTION & ISOLATION IN POSITIVE SYSTEMS

A. Positive Linear Consensus Laws

This section establishes the connection between collective dynamics of distributed systems under consensus protocols and positive linear systems. First we show that distributed systems which can be modeled by (2-4) exhibit positive collective dynamics.

Theorem 2: A distributed system with consensus dynamics given by (3), (6), with $-\mathcal{L} \in \mathbb{M}$ and $A_G, B, E, \bar{K} \geq 0$ is internally positive.

Proof: We prove this result directly. First, from lemma (1) we note that any system with $-\mathcal{L} \in \mathbb{M}$, and $B, E \geq 0$ is an internally positive system. What remains to be shown is that A_G is nonnegative. To see this, we partition the state vector into $X(t) = [\Psi(t) \Omega(t)]^T = [\Psi_1(t) \dots \Psi_n(t), \Omega_1(t) \dots \Omega_n(t)]^T$. Then by (5) we have $\dot{\Psi}(t) = I\Psi(t)$ and $\dot{\Omega}(t) = -\mathcal{L}\Psi(t) - \gamma\mathcal{L}\Omega(t) - \bar{K}I\Omega(t)$. At the boundary of the positive cone for $\Psi(t) = 0$, we must have $\dot{\Psi}(t) \geq 0$ i.e., $I\Omega(t) \geq 0$ which is trivially satisfied provided that the initial condition of the state is nonnegative. For $\Omega(t) = 0$, we require $\dot{\Omega}(t) \geq 0$, or equivalently that $-\mathcal{L}\Psi(t) \geq 0$. Since $-\mathcal{L} \in \mathbb{M}$ this condition is also met. This completes the proof. ■

Lemma 5: The positive system (6) is irreducible and primitive.

Proof: Irreducibility can be proved by direct application of lemma 2. ■

B. Distributed PUIO Design (D-PUIO)

Now we consider the design of the observer for the positive system of Theorem (2). The following theorem extends the PUIO observer to the distributed positive case.

Theorem 3: The dynamic system:

$$\begin{aligned} \dot{z}_i &= F_i z_i + G_i y_i + H_i u_i \\ \hat{x}_i &= M_i z_i + N_i y_i \end{aligned} \quad (22)$$

is an internally positive unknown input observer, i.e., it is a distributed positive unknown input observer, for a distributed positive system modeled by (3 -6) if and only if a) $(\widetilde{C_i E_i})^{-1} \geq 0$, b) $\text{rank}(C_i E_i) = \text{rank}(E_i) = r$ and the following LMI has a feasible solution for Y_i and symmetric positive definite P_i

$$\begin{cases} A_i^{(1)T} P_i + P_i A_i^{(1)} - C_i^T Y_i^T - Y_i C_i \prec 0 \\ A_i^{(1)T} P_i - C_i^T Y_i^T + I \geq 0 \\ Y_i + P_i A_i^{(1)T} N_i - Y_i C_i N_i \geq 0 \\ P_i \succ 0. \end{cases} \quad (23)$$

where

$$\begin{aligned} F_i &= A_i^{(1)} - G_i^{(1)} C_i, \quad H_i = T_i B_i \\ G_i &= G_i^{(1)} + A_i N_i - G_i^{(1)} C_i N_i \\ N_i &= E_i (C_i E_i)^g \geq 0, \quad A_i^{(1)} = T_i A_i, \quad T_i = I - N_i C_i \end{aligned}$$

Proof: Using (3) or (6) and (22) we may write the error dynamics of the D-PUIO

$$\begin{aligned} \dot{e}_i &= (A_i^{(1)} - N_i C_i A_i^{(1)} - G_i^{(1)} C_i) e_i \\ &\quad + [F_i - (A_i - N_i C_i A_i - G_i^{(1)} C_i)] z_i \\ &\quad + [G_i^{(2)} - (A_i - N_i C_i A_i - G_i^{(1)} C_i) N_i] y_i \\ &\quad + (N_i C_i - I) E_i d_i \end{aligned}$$

In order to satisfy the positivity constraint and the disturbance decoupling properties together, we must have $\dot{e}_i = F_i e_i$ and $\lim_{t \rightarrow \infty} e_i(t) = 0$. Choosing a Lyapunov function $V(t) = e_i(t)^T P_i e_i(t)$ so that we have $\dot{V}(t) = e_i^T Q e_i$ and $Q = F_i^T P_i + P_i F_i \prec 0$ implies that $e(t)_i$ approaches zero asymptotically $\forall e(0)$. When F_i is a stable Metzler matrix, then $\exists P_i \succ 0$, which positive, satisfying the Lyapunov inequality. ■

We also provide the following design procedure for distributed systems in order to complement the PUIO design procedure of section III

D-PUIO Design Procedure:

- 1) Check if $\text{rank}(C_i E_i) = \text{rank}(E_i) = r$. If not, then an unknown input observer does not exist.
- 2) Check the condition of Lemma (4). If a nonnegative left inverse of $C_i E_i$ exists, then compute N_i from $N_i = E_i (C_i E_i)^g \geq 0$ and continue to the next step, otherwise stop.
- 3) Compute $T_i = I - N_i C_i$ and define $A_i^{(1)} = T_i A_i$ such that $\{A_i^{(1)}, C_i\}$ is observable.
- 4) Solve the LMI (23) for the variable P_i and Y_i , and compute $G_i^{(1)} = P_i^{-1} Y_i$. Alternatively, as noted in Remark 4, one can replace condition 3 of (23) by the following inequality

$$P_i N_i C_i A_i^{(1)} + Y_i C_i \geq 0. \quad (24)$$

- 5) Obtain the parameter matrices of D-PUIO from

$$\begin{aligned} F_i &= A_i^{(1)} - G_i^{(1)} C_i, \quad H_i = T_i B_i \\ G_i &= G_i^{(1)} + A_i N_i - G_i^{(1)} C_i N_i \\ N_i &= E_i (C_i E_i)^g \geq 0, \quad A_i^{(1)} = T_i A_i, \quad T_i = I - N_i C_i \end{aligned}$$

As noted above in section III, we may set $M_i = I$ and we must have N_i specified by (16) or (17). By using the D-PUIO design procedure, it is possible to form a residual generator for the distributed fault detection system. Using the D-PUIO, the residual signal for the i th agent monitoring the j th agent for a fault is given by:

$$r_i^j(t) = (I - C_i H_i) y_i(t) - C_i z_i(t). \quad (25)$$

We now illustrate this approach with the following example.




Fig. 1: Distributed system with fault detection system embedded in agent 1.

V. ILLUSTRATIVE EXAMPLE

We provide an example to illustrate our approach. The system we consider is shown in Figure 1 and is assumed to be under consensus using (2) with the following Laplacian matrix:

$$-\mathcal{L} = \begin{bmatrix} -3 & 1 & 1 & 1 & 0 & 0 & 0 \\ 1 & -4 & 1 & 1 & 1 & 0 & 0 \\ 1 & 1 & -3 & 0 & 0 & 1 & 0 \\ 1 & 1 & 0 & -3 & 0 & 0 & 1 \\ 0 & 1 & 0 & 0 & -2 & 0 & 1 \\ 0 & 0 & 1 & 0 & 0 & -2 & 1 \\ 0 & 0 & 0 & 1 & 1 & 1 & -3 \end{bmatrix}.$$

At $t = 2$ sec we introduce fault signal $f(t) = 10u(t - 2)$ where $u(t)$ is the step function. By definition 1 this system is a positive system and we may design a positive residual generator to be embedded in agent 1. This agent's residual generator will be monitoring for faults in agents 2, 3 and 4. However, our design will choose to make the PUIO insensitive to faults from agent 3, therefore we will only be able to detect faults in agents 2 and 4. A separate UIO can be used to detect faults in agent 3. The PUIO for agent 1 is designed to be insensitive to all faults in agent 3 and sensitive to any fault imparted on to agents 2 and 4.

$$F_1 = \begin{bmatrix} -3 & 0.87 & 0.91 & 0.49 & 0 & 0 & 0 \\ 1 & -4.16 & 0.81 & 0.95 & 1 & 0 & 0 \\ 1 & 0.80 & -3.18 & 0.02 & 0 & 1 & 0 \\ 0 & 0.95 & 0.01 & -3.35 & 0 & 0 & 0 \\ 0 & 0.88 & -0.10 & 0.01 & -2 & 0 & 1 \\ 0 & -0.09 & 0.88 & 0.02 & 0 & -2 & 1 \\ 0 & -0.11 & -0.07 & 0.54 & 1 & 1 & -3 \end{bmatrix},$$

$$G_1 = \begin{bmatrix} 0.13 & 0.09 & 1 \\ 0.16 & 0.18 & 1 \\ 0.19 & 0.18 & 0 \\ -0.94 & -0.01 & 0 \\ 0.11 & 0.10 & 0 \\ 0.08 & 0.11 & 0 \\ 0.11 & 0.07 & 1 \end{bmatrix}$$

$T_1 \in \mathbb{R}^{7 \times 7}$ identity matrix with $T_{1,4,4} = 0$, $N \in \mathbb{R}^{7 \times 4}$ with only $n_{4,3} = 1$. As shown in figure 2, the residual generator for D-PUIO is able to exceed the threshold and detect the fault in agent 4. Furthermore, as shown in figure 3, the estimate of the fault signal $\hat{f}(t)$ is much better using D-PUIO.




Fig. 2: A time series plot of the residual generator signal for D-UIO (black) and D-PUIO (blue). The fault occurs in Agent 4 at $t = 2$ seconds. A threshold value of 2.0 (red) was selected as the fault detection threshold that must be exceeded in order for the fault detection system to declare a fault in Agent 4. As shown in the figure, the time-to-detection, *i.e.*, the time interval between fault occurrence and fault detection is $\Delta T = 0.22$ seconds in D-PUIO. The D-UIO observer does not reach this value and consequently does not trigger the fault detection system.




Fig. 3: Estimates of the fault signal $\hat{f}(t)$ with D-UIO (red) and D-PUIO (blue). The fault signal was introduced at 2 seconds as $f(t) = 10u(t - 2)$. As can be seen, the fault estimate produced by D-PUIO converges to the correct value.

VI. CONCLUSION

In this paper, we considered robust fault detection in distributed systems with first and second order agent models. We showed that a ubiquitous class of consensus protocols leads to collective dynamics that lie in a nonnegative invariant set. Based on this, we derived LMI conditions for residual generators to sense faults in the nonnegative invariant set. We highlighted the advantages of our approach through an illustrative example.

REFERENCES

- [1] M. Wolf and D. Serpanos, "Safety and Security in Cyber-Physical Systems and Internet-of-Things Systems," *Proceedings of the IEEE*, vol. 106, no. 1, pp. 9–20, Jan. 2018.
- [2] S. Nazari and B. Shafai, "Distributed detection filter design for intruder identification," in *2016 American Control Conference (ACC)*, Jul. 2016, pp. 5581–5586.

- [3] F. Pasqualetti, F. Dorfler, and F. Bullo, "Control-Theoretic Methods for Cyberphysical Security: Geometric Principles for Optimal Cross-Layer Resilient Control Systems," *IEEE Control Systems*, vol. 35, no. 1, pp. 110–127, 2015.
- [4] A. Teixeira, D. Prez, H. Sandberg, and K. H. Johansson, "Attack Models and Scenarios for Networked Control Systems," in *Proceedings of the 1st International Conference on High Confidence Networked Systems*, ser. HiCoNS '12. Beijing, China: ACM, 2012, pp. 55–64.
- [5] J. O'Reilly, *Observers for Linear Systems*, ser. Mathematics in Science and Engineering. Elsevier Science, 1983.
- [6] B. Shafai and M. Saif, *Proportional-Integral Observer in Robust Control, Fault Detection, and Decentralized Control of Dynamic Systems*, ser. Studies in Systems, Decision and Control, A. El-Osery and J. Prevost, Eds. Springer, 2015.
- [7] J. Chen and R. J. Patton, *Robust Model-Based Fault Diagnosis for Dynamic Systems*, ser. The International Series on Asian Studies in Computer and Information Science, K.-Y. Cai, Ed. Boston, MA: Springer US, 1999, vol. 3, doi: 10.1007/978-1-4615-5149-2.
- [8] A. Teixeira, I. Shames, H. Sandberg, and K. Johansson, "Distributed Fault Detection and Isolation Resilient to Network Model Uncertainties," *IEEE Transactions on Cybernetics*, vol. 44, no. 11, pp. 2024–2037, Nov. 2014.
- [9] P. Kudva, N. Viswanadham, A. Ramakrishna, "Observers for linear systems with unknown inputs," *IEEE Transactions on Automatic Control*, 1980.
- [10] M. Hou, P. Muller, "Design of observers for linear systems with unknown inputs," *IEEE Transactions on Automatic Control*, 1992.
- [11] B. Shafai, S. Nazari, and A. Oghbaee, "Positive unknown input observer design for positive linear systems," in *2015 19th International Conference on System Theory, Control and Computing (ICSTCC)*, Oct. 2015, pp. 360–365.
- [12] L. Farina and S. Rinaldi, *Positive Linear Systems: Theory and Applications*. Wiley, 2000.
- [13] T. Kaczorek, *Positive 1D and 2D systems*. Springer, 2002.
- [14] A. Berman, M. Neumann, and R. J. Stern, *Nonnegative Matrices in Dynamic Systems*. Wiley, 1989.
- [15] A. M. H. Teixeira, J. Arajo, H. Sandberg, and K. H. Johansson, "Distributed sensor and actuator reconfiguration for fault-tolerant networked control systems," *IEEE Transactions on Control of Network Systems*, vol. PP, no. 99, pp. 1–1, 2017.
- [16] I. Shames, A. M. Teixeira, H. Sandberg, and K. H. Johansson, "Distributed fault detection and isolation with imprecise network models," in *American Control Conference (ACC)*, 2012. IEEE, 2012, pp. 5906–5911.
- [17] H. Terelius, G. Shi, and K. H. Johansson, "Consensus Control for Multi-agent Systems with a Faulty Node," *IFAC Proceedings Volumes*, vol. 46, no. 27, pp. 425 – 432, 2013.
- [18] N. Dautrebande and G. Bastin, "Positive linear observers for positive linear systems," in *1999 European Control Conference (ECC)*, Aug. 1999, pp. 1092–1095.
- [19] B. Shafai, A. Oghbaee, and S. Nazari, "Robust fault detection for positive systems," in *2016 IEEE 55th Conference on Decision and Control (CDC)*, Dec. 2016, pp. 6470–6476.
- [20] R. Olfati-Saber, J. Fax, and R. Murray, "Consensus and Cooperation in Networked Multi-Agent Systems," *Proceedings of the IEEE*, vol. 95, no. 1, pp. 215–233, Jan. 2007.
- [21] A. Teixeira, "Toward cyber-secure and resilient networked control systems," PhD Dissertation, KTH Royal Institute of Technology, 2014.
- [22] W. Ren and E. Atkins, "Distributed multi-vehicle coordinated control via local information exchange," *International Journal of Robust and Nonlinear Control*, vol. 17, no. 10–11, pp. 1002–1033, Jul. 2007.
- [23] A. Oghbaee, B. Shafai, and S. Nazari, "Complete characterisation of disturbance estimation and fault detection for positive systems," *IET Control Theory & Applications*, Jan. 2018.