

## TEST REPORT

**Product family** WXT530 series  
**Product type** WXT536  
**Order code** 6B1B2A1C1A1B  
**Serial number** T4150412  
**Manufacturer** Vaisala Oyj, Finland  
**Test date** 15 October 2021

This test report certifies that the product was thoroughly tested and inspected, and found to meet its published test limits when it was shipped from Vaisala.

### Test results

Test	Result	Lower limit	Upper limit	Unit
Rain response	380	345	575	mV
Zero wind speed	0	0	0.4	m/s
Pressure difference	0.03	-1	1	hPa
Temperature difference	-0.08	-2	2	°C
Humidity difference	0.14	-10	10	%RH
Heating current	0.75	0.6	0.8	A
Current (service port)	4.33	0.5	6	mA
Communication (service port)	pass	PASS	PASS	-
Current (main port)	3.8	0.5	6	mA
Communication (main port)	pass	PASS	PASS	-

**Ambient conditions** / Humidity 36.17 ±5 %RH, Temperature 23.73 ±1 °C, Pressure 994.14 ±1 hPa.

Signature



Technician