

A

B

C


D

E

F


ITEM NUMBERS IN THIS BLOCK ARE IDENTICAL TO THE ITEM NUMBERS  
USED ON THE SCHEMATIC FLOW DIAGRAM

ITEM	QTY.	DESCRIPTION	KEMCO #	MANUFACTURER
1	1	9.9 x 10 <sup>6</sup> BTU WATER HEATER A, NSF	42-2760	KEMCO MODEL TE-100+
2	1	9.9 x 10 <sup>6</sup> BTU WATER HEATER B, NSF	42-2761	KEMCO MODEL TE-100+
3	1	HEATER A CONTROL PANEL	42-2762	KEMCO
4	1	HEATER B CONTROL PANEL	42-2763	KEMCO
5	4	HEATER DISCHARGE PUMP (3600RPM, 300GPM, 7.5HP, 460V)	651-04-1007	PACO LC25707(3" x 2.5", 4.91" IMP.)



NOTE:  
REFERENCE SCHEMATIC FLOW DIAGRAM  
DRAWING NUMBER 42-2759.

LET.	CHANGE	DATE	BY
A	WAS PRELIMINARY	3/19/24	MK



11500 47th Street N | Clearwater, FL 33762  
800-633-7033 | [www.kemcosystems.com](http://www.kemcosystems.com)

EQUIPMENT LAYOUT

JOB # 34278	WAYNE FARMS UNION SPRINGS, AL
DR. MK	
SCALE 1' = 1/4"	THIS DRAWING IS THE PROPERTY OF KEMCO SYSTEMS ALL RIGHTS OF DESIGN ARE RESERVED. DRAWING IS TO BE RETURNED UPON REQUEST.
DATE 1/22/24	
ENG. B PENDER	
APP. BP 3/25/24	
APP.	
APP.	DWG. NO. 21-2489A