



PHOENIX INNOVATIONS INC.

479-219-9100
Phoenix314.com
Page | 1

User Manual for Phoenix Innovations Chiller SANDERSON UNION SPRINGS, AL



Serial # 241039
Model # P515

Phoenix Innovations
4254 S Arkansas Avenue
Russellville, AR 72802
(479)219-9100
Sales@phoenix314.com

**PHOENIX INNOVATIONS
INC.**

Contents

Letter of Conformity -----	4
RMA Procedures -----	4
Safety -----	5
The Control of Hazardous Energy (Lockout/Tagout)-----	5
Lockout/Tagout Procedure-----	5
OBJECTIVE -----	5
ASSIGNMENT OF RESPONSIBILITY -----	5
PROCEDURES -----	5
ELECTRICAL-----	6
HYDRAULIC / PNEUMATIC -----	6
MECHANICAL ENERGY -----	6
Release from Lockout/Tagout-----	6
Service or Maintenance Involving More than One Person-----	7
Removal of an Authorized Employee's Lockout/Tagout by the Company -----	7
Shift or Personnel Changes -----	7
Procedures for Outside Personnel/Contractors -----	7
Training and Communication -----	7
Periodic Inspection-----	8
Attachments: -----	8
ATTACHMENT A -----	9
ATTACHMENT B -----	10
ATTACHMENT C -----	11
ATTACHMENT D -----	12
ATTACHMENT E-----	13
Energy Sources -----	15
Preventative Maintenance -----	16
Weekly-----	16
Monthly-----	17
Machine Operation -----	18
Start Up-----	18
Notes -----	18
Shut Down -----	18
Filter System (If installed) -----	Error! Bookmark not defined.
Emergency Shutdown -----	18
Controls -----	20
PLC (Programmable Logic Controller) -----	20

**PHOENIX INNOVATIONS
INC.**

479-219-9100
Phoenix314.com
Page | 3

Programming -----	20
Programming a new Micro800 with Backup Card -----	20
Programming With Connected Components Workbench -----	20
Device Configuration -----	21
Controller-----	21
Serial Port -----	22
USB Port -----	22
Ethernet-----	22
Plug-in Modules -----	23
2080-SDMEMRTC-SC -----	23
2080-RTD2 -----	23
2080-IF4-----	23
HMI (Human Machine Interface)-----	25
Configuration-----	25
Home Screen -----	26
Heat Exchanger Monitor -----	27
Drive Configuration -----	28
System Configuration-----	29
Dwell Time Calculations -----	30
Dwell Time Calculations-----	30
Keyence GC100 Safety Controller -----	32
Drives-----	35
Auger-----	35
Commissioning -----	35
Unload -----	36
Commissioning -----	36
Recirc Pump -----	37
Commissioning -----	37
Electrical Schematics -----	38
Mechanical Layouts -----	39

**PHOENIX INNOVATIONS
INC.**

Letter of Conformity

Phoenix Innovations manufactures, sells, and services food processing equipment to exact customer specifications. Our equipment is designed and manufactured to meet or exceed both safety, hygiene, and environmental standards that will be present in the food processing industry. Equipment is manufactured using stainless steel, or other acceptable plastic components in food contact areas and uses corrosion resistant materials throughout the machine when possible. Equipment is designed and built with hygiene in mind and ease of both cleaning and maintaining.

RMA Procedures

- A. When you receive your merchandise:
 - a. Please open all boxes immediately and check contents. We must be notified of any damaged or defective products within 2 business days of you receiving your products. We also request that you also inspect all of your products for obvious defects/blemishes within 2 days of receiving them.
- B. If you receive the incorrect product:
 - a. It is very rare that you will receive an incorrect product; we double-check *all* orders before we ship them. However, if we made a mistake/error in shipping (it does rarely happen), please contact us. We will issue an RMA Number and return instructions on how and where to return the product. After receipt of the incorrect part we will then ship you the correct product and *pay the shipping costs both ways*. In some instances we may choose to ship a replacement overnight providing we receive another purchase order for the replacement. If you ordered the incorrect product and would like to return it, then please see the "Returns" section.
- C. Shipping Damage:
 - a. If the packaging appears damaged on the outside, *please refuse to accept it from the carrier*; or please make sure when signing the shipper's proof-of-delivery slip, you include a note stating the package is or appears damaged. If you do accept a damaged shipment, please contact us immediately. Depending on the product and where/how it was shipped, it may be necessary for you to deal with the carrier. Also, if there was any internal (non-visible) damage, this will need to be reported to us or the carrier within two days of receiving the product.
- D. Returns:
 - a. CRITERIA REQUIRED FOR RETURNING ITEM(S)
 - i. Must be within 30 days from the day you received the item
 - ii. Item must not have been installed
 - iii. The item must be in perfect resalable condition in the original packaging
 - iv. Custom orders or quoted items are non-returnable
 - v. Item must have been shipped by a Common Carrier (UPS/FedEx/USPS) If the above criteria is met, then we will issue an RMA Number
 - b. If you ordered the wrong products and wish to return the product, you will need to contact us to request an RMA Number. Returns will be subject to a 20% Restocking fee.
 - c. Please do NOT return any product that you have ordered without contacting us for an RMA Number first. This will make processing your credit very difficult and may delay your credit.
- E. Returned Materials Authorization:
 - a. When it is necessary to return a product, please contact us to request an RMA Number. All returns, regardless of how they were shipped or where they were shipped from must be referenced by an RMA Number. Packages returned to us without an RMA number will not be returned to you. Handling returns in the manner that we do is necessary to ensure that you receive proper credit in a timely fashion.
 - b. When you request an RMA Number to return a product, we will either issue the RMA at that time, or contact the warehouse that it shipped from and request that one be issued. If we need to receive the RMA from another warehouse, we will let you know by forwarding the information to you along with shipping instructions as soon as we receive it. The instructions for return must be followed carefully.
 - c. Once the product has been received at our warehouse, it will be inspected and you will be credited for the returned product less the applicable Restocking Fee and original shipping and processing charges.
 - d. If the product is returning to another warehouse, they will contact us once they have received the product, inspected it, and we have been issued credit. Once we have been credited for the return, your credit will be issued less the Restocking Fee and original shipping and processing charges.

Safety

The Control of Hazardous Energy (Lockout/Tagout)

The following lockout/tagout program is provided only as a guide to assist employers and employees in complying with the requirements of 29 CFR 1910.147, as well as to provide other helpful information. It is not intended to supersede the requirements of the standard. An employer should review the standard for particular requirements which are applicable to their individual situation and make adjustments to this program that are specific to their company. An employer will need to add information relevant to their particular facility in order to develop an effective, comprehensive program.

Lockout/Tagout Procedure

OBJECTIVE

The objective of this procedure is to establish a means of positive control to prevent the accidental starting or activating of machinery or systems while they are being repaired, cleaned and/or serviced. This program serves to:

- A. Establish a safe and positive means of shutting down machinery, equipment and systems.
- B. Prohibit unauthorized personnel or remote control systems from starting machinery or equipment while it is being serviced.
- C. Provide a secondary control system (tagout) when it is impossible to positively lockout the machinery or equipment.
- D. Establish responsibility for implementing and controlling lockout/tagout procedures.
- E. Ensure that only approved locks, standardized tags and fastening devices provided by the company will be utilized in the lockout/tagout procedures.

ASSIGNMENT OF RESPONSIBILITY

- A. Responsible Person will be responsible for implementing the lockout/tagout program.
- B. Responsible Persons are responsible for enforcing the program and insuring compliance with the procedures in their departments.
- C. Responsible Person is responsible for monitoring the compliance of this procedure and will conduct the annual inspection and certification of the authorized employees.
- D. Authorized employees (those listed in Attachment A) are responsible for following established lockout/tagout procedures. An authorized employee is defined as a person who locks out or tags out machines or equipment in order to perform servicing or maintenance on that machine or equipment. An affected employee becomes an authorized employee when that employee's duties include performing servicing or maintenance covered under 1910.147, The Control of Hazardous Energy (lockout/tagout).
- E. Affected employees (all other employees in the facility) are responsible for insuring they do not attempt to restart or re-energize machines or equipment that are locked out or tagged out. An affected employee is defined as a person whose job requires him/her to operate or use a machine or equipment on which servicing or maintenance is being performed under lockout or tagout, or whose job requires him/her to work in an area in which such servicing or maintenance is being performed.

PROCEDURES

The ensuing items are to be followed to ensure both compliance with the OSHA Control of Hazardous Energy Standard and the safety of our employees.

Employees who are required to utilize the lockout/tagout procedure (see Attachment A) must be knowledgeable of the different energy sources and the proper sequence of shutting off or disconnecting energy means. The four types of energy sources are:

1. electrical (most common form);
2. hydraulic or pneumatic;
3. mechanical (including gravity).

**PHOENIX INNOVATIONS
INC.**

More than one energy source may be utilized on some equipment and the proper procedure must be followed in order to identify energy sources and lockout/tagout accordingly. See Attachment F for specific procedure format.

ELECTRICAL

1. Shut off power at machine and disconnect.
2. Disconnecting means must be locked or tagged.
3. All controls must be returned to their safest position.
4. Points to remember:
 - a. If a machine or piece of equipment contains capacitors, they must be drained of stored energy.
 - b. Possible disconnecting means include the power cord, power panels (look for primary and secondary voltage), breakers, the operator's station, motor circuit, relays, limit switches, and electrical interlocks.
 - c. Some equipment may have a motor isolating shut-off and a control isolating shut-off.
 - d. If the electrical energy is disconnected by simply unplugging the power cord, the cord must be kept under the control of the authorized employee or the plug end of the cord must be locked out or tagged out.

HYDRAULIC / PNEUMATIC

1. Shut off all energy sources (pumps and compressors). If the pumps and compressors supply energy to more than one piece of equipment, lockout or tagout the valve supplying energy to the piece of equipment being serviced.
2. Stored pressure from hydraulic/pneumatic lines shall be drained/bled when release of stored energy could cause injury to employees.
3. Make sure controls are returned to their safest position (off, stop, standby, inch, jog, etc.).

MECHANICAL ENERGY

Mechanical energy includes gravity activation, energy stored in springs, etc.

1. Block out or use die ram safety chain.
2. Lockout or tagout safety device.
3. Shut off, lockout or tagout electrical system.
4. Check for zero energy state.
5. Return controls to safest position.

Release from Lockout/Tagout

1. **Inspection:** Make certain the work is completed and inventory the tools and equipment that were used.
2. **Clean-up:** Remove all towels, rags, work-aids, etc.
3. **Replace guards:** Replace all guards possible. Sometimes a particular guard may have to be left off until the start sequence is over due to possible adjustments. However, all other guards should be put back into place.
4. **Check controls:** All controls should be in their safest position.
5. **Check the Work Area:** The work area shall be checked to ensure that all employees have been safely positioned or removed and notified that the lockout/tagout devices are being removed.
6. **Remove locks/tags:** Remove only your lock and / or tag.

**PHOENIX INNOVATIONS
INC.**

Service or Maintenance Involving More than One Person

When servicing and/or maintenance is performed by more than one person, each authorized employee shall place his own lock or tag on the energy isolating source. This shall be done by utilizing a multiple lock scissors clamp if the equipment is capable of being locked out. If the equipment cannot be locked out, then each authorized employee must place his tag on the equipment.

Removal of an Authorized Employee's Lockout/Tagout by the Company

Each location must develop written emergency procedures that comply with 1910.147(e)(3) to be utilized at that location. Emergency procedures for removing lockout/tagout should include the following:

1. Verification by employer that the authorized employee who applied the device is not in the facility.
2. Make reasonable efforts to advise the employee that his/her device has been removed. (This can be done when he/she returns to the facility).
3. Ensure that the authorized employee has this knowledge before he/she resumes work at the facility.
4. **Shift or Personnel Changes**

Shift or Personnel Changes

Each facility must develop written procedures based on specific needs and capabilities. Each procedure must specify how the continuity of lockout or tagout protection will be ensured at all times. See 1910.147(f)(4).

Procedures for Outside Personnel/Contractors

Outside personnel/contractors shall be advised that the company has and enforces the use of lockout/tagout procedures. They will be informed of the use of locks and tags and notified about the prohibition of attempts to restart or re-energize machines or equipment that are locked out or tagged out.

The company will obtain information from the outside personnel/contractor about their lockout/tagout procedures and advise affected employees of this information.

The outside personnel/contractor will be required to sign a certification form (see Attachment E). If outside personnel/contractor has previously signed a certification that is on file, additional signed certification is not necessary.

Training and Communication

Each authorized employee who will be utilizing the lockout/tagout procedure will be trained in the recognition of applicable hazardous energy sources, type and magnitude of energy available in the work place, and the methods and means necessary for energy isolation and control.

Each affected employee (all employees other than authorized employees utilizing the lockout/tagout procedure) shall be instructed in the purpose and use of the lockout/tagout procedure, and the prohibition of attempts to restart or re-energize machines or equipment that are locked out or tagged out.

**PHOENIX INNOVATIONS
INC.**

Training will be certified using Attachment B (Authorized Personnel) or Attachment C (Affected Personnel). The certifications will be retained in the employee personnel files.

Periodic Inspection

A periodic inspection (at least annually) will be conducted of each authorized employee under the lockout/tagout procedure. This inspection shall be performed by the (Responsible person). If (Responsible person) is also using the energy control procedure being inspected, then the inspection shall be performed by another party.

The inspection will include a review between the inspector and each authorized employee of that employee's responsibilities under the energy control (lockout/tagout) procedure. The inspection will also consist of a physical inspection of the authorized employee while performing work under the procedures.

The (Responsible person) shall certify in writing that the inspection has been performed. The written certification (Attachment D) shall be retained in the individual's personnel file.

Attachments:

ATTACHMENT A

List of Authorized Personnel
For Lockout/Tagout Procedures

**PHOENIX INNOVATIONS
INC.**

ATTACHMENT B

**Certification of Training
(Authorized Personnel)**

I certify that I received training as an authorized employer under Company Name Lockout/Tagout program. I further certify that I understand the procedures and will abide by those procedures.

AUTHORIZED EMPLOYEE SIGNATURE

DATE

**PHOENIX INNOVATIONS
INC.**

ATTACHMENT C

**Certification of Training
(Affected Personnel)**

I certify that I received training as an Affected Employee under
Company Name Lockout/Tagout Program. I further certify and understand that I am prohibited
from attempting to restart or re-energize machines or equipment that are locked out or tagged out.

AUTHORIZED EMPLOYEE SIGNATURE

DATE

**PHOENIX INNOVATIONS
INC.**

ATTACHMENT D

Lockout/Tagout Inspection Certification

I certify that *Equipment* was inspected on this date utilizing lockout/tagout procedures.
The inspection was performed while working on
Equipment.

AUTHORIZED EMPLOYEE SIGNATURE

DATE

INSPECTOR SIGNATURE

DATE

**PHOENIX INNOVATIONS
INC.**

ATTACHMENT E

Outside Personnel/Contractor Certification

I certify that _____ and _____ (outside personnel/contractor) have informed each other of our respective lockout/tagout procedures.

AUTHORIZED EMPLOYEE SIGNATURE

DATE

INSPECTOR SIGNATURE

DATE

**PHOENIX INNOVATIONS
INC.**

ATTACHMENT F

**Equipment Specific Procedure
for**

Date: _____

Machine Identification

General Description:

Manufacturer:

Model Number:

Serial Number:

* If more than one piece of same equipment, list all serial numbers.

Location of equipment:

Operator Controls

The types of controls available to the operator need to be determined. This should help identify energy sources and lockout capacity for the equipment.

List types of operator controls:

PHOENIX INNOVATIONS INC.

Energy Sources

The energy sources, such as electrical, steam, hydraulic, pneumatic, natural gas, stored energy, etc.) present on this equipment are:

**PHOENIX INNOVATIONS
INC.**

**Preventative Maintenance
Weekly**

	Date	Initial
1. Check belt tension (Unload End)	/	
2. Check chain tension (Unload End).....	/	
3. Check auto lube	/	
a. Verify no red light	/	
b. Verify contains grease	/	
4. Check belt tension (Drive End)	/	
5. Check chain tension (Drive End)	/	
6. Check auto lube	/	
a. Verify no red light	/	
b. Verify contains grease	/	
7. Check electrical panels for moisture	/	
8. Verify all Estops, Pull Cords, and Safety Switches function	/	
a. Panel Estop	/	
b. Near Side Pull Cord.....	/	
c. Far Side Pull Cord	/	
d. Drive End Cover.....	/	
e. Drive End Door	/	
f. Unload End Cover.....	/	
g. Unload End Door.....	/	
9. Run all motors and check for vibration.....	/	

Signed

Date

**PHOENIX INNOVATIONS
INC.**

**Preventative Maintenance
Monthly**

	Date	Initial
1. Check belt tension (Unload End)	/	
a. Inspect for wear. Replace if needed.	/	
2. Check chain tension (Unload End).....	/	
a. Inspect for wear. Replace if needed.	/	
b. Lube chain with food safe spray grease.	/	
3. Check auto lube (Unload End)	/	
a. Verify no red light	/	
b. Verify contains grease. Change if needed.	/	
4. Check belt tension (Drive End).....	/	
a. Inspect for wear. Replace if Needed	/	
5. Check chain tension (Drive End)	/	
a. Inspect for wear. Replace if needed.	/	
b. Lube chain with food safe spray grease.	/	
6. Check auto lube (Drive End).....	/	
a. Verify no red light	/	
b. Verify contains grease	/	
7. Check electrical panels for moisture	/	
8. Verify all Estops, Pull Cords, and Safety Switches function	/	
a. Panel Estop	/	
b. Near Side Pull Cord.....	/	
c. Far Side Pull Cord	/	
d. Drive End Cover.....	/	
e. Drive End Door	/	
f. Unload End Cover	/	
g. Unload End Door.....	/	
9. Run all motors and check for vibration	/	

Signed

Date

Machine Operation

Start Up

- Close both drains on the chiller.
- Fill system to operating level.
- Turn electrical disconnect on for auger, unloader, and recirculation pump to the closed / on position.
- Install both auger covers.
- Make sure all safeties are made and in a safe position.
- Enter a dwell time in the Dwell Time box. This should be in decimal minutes. (*ie. 20:30 is 20.5*)
- Enter the Unload paddles per minute in the Unload (PPM) box.
 - paddles per minute – how many paddles pass the exit ramp per minute.
- Press the start button.
 - The Auger, Unload, Recirc Pump and Blower motor will start up.
 - The Auger, Unload and Recirc Pump will (by default) take ten seconds to get to speed.
 - The Auto Cycle Start button will illuminate on the HMI to a bright red.

Notes

- If the need arises to run one of the motors separately from the others this can be done by taking the system out of Auto. Then in the lower left-hand corner of the home screen you will find toggle button for the following motors.
 - Auger
 - Unload
 - Recirc Pump
 - Blower
- If the flow from the recirc pump is too high or too low the speed of the pump can be changed in the System Configuration screen.

Shut Down

- Press the Auto Cycle Stop button.
- The Auger and Unload ramp down to stopped.
- The Blower and Recirc Pump will continue to run.
 - To shut down the Blower and Pump press the individual buttons for those motors on the home screen.

Emergency Shutdown

In the case of an emergency the machine is equipped with two pull cords. One on either side of the machine. Pulling either of these or pushing the Estop on the panel will put the machine into Emergency Stop. The machine will immediately stop applying power to all motors and not allow you to start back up until the safety controller has been reset.

Chiller Sanitation CIP Operation

Step 1

Get with the Refrigeration maintenance dept and make sure refrigeration has been turned off to the heat exchanger.

Turn off the Chiller panel.

Lock out panel

Open both drains that are located at each end of the chiller.

**PHOENIX INNOVATIONS
INC.**

Rinse the chiller body out.

Step 2

Turn the Chiller control panel on

Reset all e-stops and touch reset button on front of control panel

On the side of the chiller, the CIP box and the water recirculation box turn the valve handle to CIP.

Turn on water, then fill the CIP side tank with water.

Go to the touch screen and turn on the recirculation pump. Watch the water level in the CIP tank; you might have to stop the pump and restart the pump a couple of times. Once water returns into the CIP tank then the heat exchanger is full of water. Then let the tank fill back up, then turn the water off. Recirculate water to clean piping once completed.

Turn the recirculation pump off on the screen.

Drain Cip tank

Step 3

Refill CIP tank with hot water, pour chemical into side tank, follow step 2 to fill heat exchanger back up and when water recirculates back into CIP tank, then start your time for the cleaning chemicals to clean.

Once completed, drain the CIP tank.

Refill the CIP tank with clean hot water and flush the system until all chemicals have been flushed out of the system.

Once completed, turn all 3 valves back to production mode

Step 4

Turn power off on panel and release to QA dept.

**PHOENIX INNOVATIONS
INC.**

Controls

PLC (Programmable Logic Controller)

Micro 800 PLC

Programming

Programming a new Micro800 with Backup Card


Our programs are set to “Load On Startup”, so every time power is applied to the PLC, the program will be pulled from the memory card and saved to the PLC. After installing the new Micro800, the memory card adapter should be in the first expansion port on the front of the PLC. Once power is applied, the program should be pulled from the memory card.

Programming With Connected Components Workbench

The Micro800 series of PLC's are programmed with the program Connected Components Workbench (CCW). This can be downloaded for free on Rockwell Automation's website. These instructions show how to connect via an ethernet cord.

1. Configure the ethernet adapter settings on the computer you will be using to communicate with the Micro800.
 - a. On Windows 10, right click the windows icon and select “Network Connections”, then click “Ethernet”.
 - b. On the right side of the window, select “Change Adapter Options”.
 - c. Right click on the ethernet adapter you will be using, then click “Properties”.
 - d. Select “Internet Protocol Version 4” and click “Properties”.
 - e. Change the settings to match the picture below.

PHOENIX INNOVATIONS INC.



(These changes can be undone to restore normal functionality of your ethernet port)

2. Connect an ethernet cord between the PLC and computer, and apply power to the PLC.
3. If you intend to alter the program, switch the Run/Program switch to program on the bottom left corner of the PLC.
4. You can use RSLinx (part of the CCW install) to browse the PLC's in the range you configured in step 1.e. to confirm communication between the PLC and computer.


(The default IP of our PLC is 10.5.97.5, and the HMI is 10.5.97.10)

If you have experience with Studio 5000, follow this link for help with Connected Components Workbench
https://literature.rockwellautomation.com/idc/groups/literature/documents/qr/9328-qr001_en-e.pdf

Device Configuration

Controller

Overview



PHOENIX INNOVATIONS INC.

479-219-9100
Phoenix314.com
Page | 22

General

Name	Description	Vendor Name	Catalog ID	Controller Project Version	Download Source Code
Micro850		Allen-Bradley	2080-L50E-48QBB	12	Yes

Plug-in Modules

Physical Slot	Catalog ID	When module is not present
1	2080-SDMEMRTC-SC	Do not fault controller (optional module)
4	2080-RTD2	Fault controller (required module)
5	2080-IF4	Fault controller (required module)

Startup/Faults

Mode Behavior	Fault Override	Memory Module	Hard Fault
Remote run mode	Clear Fault	2080-SDMEMRTC-SC	Stop controller

Serial Port

Common Settings

Driver	Baud Rate	Parity	Station Address
CIP Serial	38400	None	1

Protocol Control

DF1 Mode	Media	Control Line	Error Detection
Full Duplex	RS232	No Handshake	CRC

Embedded Responses	Duplicate Packet Detection	ACK Timeout	NAK Retries
After One Received	Enabled	50	3

ENQ Retries
3

USB Port

Status	Suspend State	Bus Speed	Mode	State
Enabled	Not Suspended	Full Speed	Slave Mode	Ready

Ethernet

Port Settings

Port State: Enabled

Auto-Negotiate Speed and Duplex Mode: Enabled

Internet Protocol (IP) Settings

Startup Configuration	IP Address	Subnet Mask	Gateway Address	Detect duplicate IP address
Static	10.5.97.5	255.255.255.0	0.0.0.0	Enabled

EtherNet/IP

Inactivity Timeout: 120 sec

Modbus TCP

Modbus TCP Server state: Disabled

PHOENIX INNOVATIONS INC.

Plug-in Modules

2080-SDMEMRTC-SC

General

Catalog ID	Vendor Name	Description	Product Type	Slot	Revision
<u>2080-SDMEMRTC-SC</u>	Spectrum Controls	microSD card and high accuracy RTC	Specialty plug-in	1	1

Configuration

Memory Card Settings

Load on power up	Overwrite Ethernet Settings	Include Project & Logical values upon Backup/Restore
Load Always	True	True

2080-RTD2

General

Catalog ID	Vendor Name	Description	Product Type	Slot	Revision
<u>2080-RTD2</u>	Allen-Bradley	2-channel, non-isolated RTD module	Analog plug-in	4	1

Input

Label	Variable Name
Input 0	IO_P4_AI_00
Input 1	IO_P4_AI_01
Input 2	IO_P4_AI_02
Input 3	IO_P4_AI_03
Input 4	IO_P4_AI_04

Configuration

Channel	RTD Type	Data Update Rate
0	100 Pt 385	16.7 Hz
1	100 Pt 385	16.7 Hz

2080-IF4

General

Catalog ID	Vendor Name	Description	Product Type	Slot	Revision
<u>2080-IF4</u>	Allen-Bradley	4-channel, Non-isolated unipolar voltage/current analog input	Analog plug-in	5	1

Input

Label	Variable Name
Input 0	IO_P5_AI_00
Input 1	IO_P5_AI_01
Input 2	IO_P5_AI_02
Input 3	IO_P5_AI_03

Configuration


Channel	Input Type	Frequency	Input State
0	Current	50 Hz	Enabled
1	Current	50 Hz	Enabled
2	Current	50 Hz	Enabled
3	Current	50 Hz	Enabled

479-219-9100
Phoenix314.com
Page | 24

**PHOENIX INNOVATIONS
INC.**

**PHOENIX INNOVATIONS
INC.**

HMI (Human Machine Interface)



Configuration

General

Name	Description	Vendor Name	Catalog ID	Controller Project Version	Download Source Code
PanelView 800		Allen-Bradley	271R-T10T	8	Yes

Ethernet

Port Settings

Port State: Enabled

Auto-Negotiate Speed and Duplex Mode: Enabled

Internet Protocol (IP) Settings

Startup Configuration	IP Address	Subnet Mask	Gateway Address	Detect duplicate IP address
Static	10.5.97.10	255.255.255.0	0.0.0.0	Enabled

PHOENIX INNOVATIONS INC.

Home Screen




Figure 1 Home Screen Preview

Auger, Unload and Recirc Pump will illuminate green when each are running.

- **HEX Inlet Temp** – Readout – Displays the water temperature at the outlet of the Heat Exchanger. (IF USING A PHOENIX HEAT EXCHANGER)
- **Motor Indicators** – Indicates that the respective motor is running.
- **Dwell Time** – Input – Controls the time the product will dwell in the Chiller. Input in minutes. *ie. 2:30 is 2.5*
- **Unload** – Input – controls the speed of the unloader. Input in Paddles Per Minute.
- **Hex Return Temp** – Readout – Shows the temperature of the water that is supplied to the Chiller.
- **Overflow Temp** – Readout - Shows the temperature of the water that is leaving the Chiller.
- **Air Header Pressure** – Readout – Shows the air pressure at the air Header.
- **Auto Cycle** – Contain the start stop button for the chiller.
- **Navigation** – This panel is for navigating to the different screens.
 - **Hex Details** – navigates to a screen that you can use to monitor the Heat Exchanger.
 - **Drives Configuration** – LOGIN REQ. – Navigates to the first drive configuration page.
 - **System Setup** – LOGIN REQ. – Navigates to the first configuration page.

PHOENIX INNOVATIONS INC.

Heat Exchanger Monitor




Figure 2 Heat Exchanger Monitor Preview (Login Required)

This screen only available on systems with Phoenix Innovations Heat Exchanger.

- **Liq. Ammonia Level** – Displays the level of liquid ammonia in the vessel of the heat exchanger.
- **Suction valve** – Displays the status of the suction valve. OPEN/CLOSED
- **Liquid Valve** – Displays the status of the liquid valve. OPEN/CLOSED
- **Pump Inlet PSI** – Displays the pressure at the inlet of the Heat Exchanger.
- **Vessel PSI** – Displays the ammonia pressure of the vessel.
- **Outlet Temp** – Shows the water temperature at the outlet of the Heat Exchanger. This is the water temperature the HEX is supplying to the Process.
- **Inlet Temp** – Shows the water temperature at the inlet of the Heat Exchanger. This is the water temperature the HEX is receiving from the Process.
- **Setpoint** – Display Only – Shows setpoint of the Heat Exchanger. Cannot be changed from the Chiller Control Panel.
- **Hot Gas Valve** – Displays the status of the hot gas valve. OPEN/CLOSED
- **Navigation** – This panel is for navigating to the different screens.
 - **Home** – Returns to the home screen.
 - **System Setup** – LOGIN REQ. – Navigates to the first configuration page.
 - **Screen Configuration** – LOGIN REQ. – Navigates to the built in terminal settings workspace.

**PHOENIX INNOVATIONS
 INC.**

Drive Configuration




Figure 3 Drive Configuration Preview (Login Required)

- **IP Address** – Tells the PLC what address to use to control the drive.
- **CMD Freq** – The frequency the plc is telling the Drive to go.
- **Jog Motor Forward** – Turns the motor at 10 Hz.
- **Clear Drive Fault** – Will clear a dive fault.
- **Accel / Decell Time** – Sets the time it takes for the drive to get to full speed / zero speed.
- **Toggle Direction** – Sets the rotation direction of the motor.
- **Drive Comms** – Displays if the PLC has communication with the Drive.
- **Output Freq** – The frequency the drive is applying to the motor.
- **Output Current** – The current that the motor is drawing.
- **Navigation** – This panel is for navigating to the different screens.
 - **Home** – Returns to the home screen.
 - **Next Drive** – Navigates to the next Drive.
 - **System Config** – Navigates to the first configuration page.

**PHOENIX INNOVATIONS
INC.**

System Configuration




Figure 4 System Configuration Screen (Login Required)

- **Toggle °F/°C** – Configures the system to use Fahrenheit or Celsius.
- **Analog In FSH** – Sets the Full-Scale High of the Blower Pressure Transducer.
- **Analog In FSL** – Sets the Full-Scale Low of the Blower Pressure Transducer.
- **Pump Speed** – Sets the Speed of the Recirc Pump 0 – 100%
- **Paddles Per Min FSH** – Sets the scaling of the unload speed reference.
- **Navigation** – This panel is for navigating to the different screens.
 - **Dwell Time Calcs** – Navigates to the screen to calculate the dwell time scaling.
 - **Drive Configuration** - LOGIN REQ. – Navigates to the first drive configuration page.
 - **Home** – Returns to the home screen.
 - **System Config** – Navigates to the first configuration page.

PHOENIX INNOVATIONS INC.

Dwell Time Calculations

Motor Speed	Drive Sheave Datum	Driven Sheave Datum	Gearbox Ratio
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Drive Sprocket Tooth Count	Driven Sprocket Tooth Count	Auger Pitch (In.)	Chiller Length (Ft.)
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Minimum Freq. (Hz.)	Minimum Dwell Time	Maximum Dwell Time	Total Ratio
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

PHOENIX
INNOVATIONS
5244 S. Arkansas ave.
Russellville, AR 72802
1 (479) 219-9100

DWELL TIME
CALCULATION

1/10/2024
5:35:50 PM
0

Login
Logout

Sheave Ratio * Gearbox Ratio *
Sprocket Ratio = Total Ratio
Motor Speed / Total Ratio = Auger
Speed
Chiller Length (in.)(Auger Speed *
Auger Pitch) = Dwell Time

Navigation
System Setup

Figure 5 Dwell Time Calculation Screen Preview (Eng Level Login Required)

This screen is for calculating the dwell time of the auger. Enter all the relevant data and the system will automatically calculate the minimum dwell, maximum dwell, and total reduction ration.

These values are used to scale the speed of the auger to achieve the appropriate dwell time.

This screen requires Engineering Level logon to access.

Dwell Time Calculations

The target Motor RPM (X) is given by:

$$X = \frac{L \times 12}{T \times P} \times \left(\frac{B}{A} \times \frac{s}{S} \times G \right)$$

where:

- N = Motor Nominal Speed (RPM)
- F = Nominal Frequency (Hz)
- L = Chiller Length (ft.)
- T = Dwell Time (min.)
- P = Auger Pitch (in.)
- A = Drive Sheave (datum)
- B = Driven Sheave (datum)
- G = Gear Box Ratio
- s = Driven Sprocket (teeth)
- S = Drive Sprocket (teeth)

The PLC computes the constant (K) as follows:

$$K = \frac{L \times 12}{P} \times \left(\frac{B}{A} \times \frac{s}{S} \times G \right) \times \frac{F_{\text{nom}}}{N}$$

The dwell times corresponding to the nominal and minimum frequencies are computed as:


**PHOENIX INNOVATIONS
INC.**

$$T_{\text{nom}} = \frac{K}{F_{\text{nom}}} \quad \text{and} \quad T_{\min} = \frac{K}{F_{\min}}$$

The frequency at any dwell time (T) is given by:


$$F(T) = \frac{K}{T}$$

Below is a sample plot of the Frequency / Dwell Time plot for a chiller:



**PHOENIX INNOVATIONS
INC.**

Keyence GC100 Safety Controller



**PHOENIX INNOVATIONS
 INC.**

Keyence GC100 Safety Controller

The Keyence Safety Controller controls a safety contactor, which supplies power to all controls when energized. If the safety relays are not functioning, follow these steps to troubleshoot.

1. Verify all doors are closed and all E-Stops are pulled out.
2. Verify the Safety Controller is on and does not have an error.
 - a. If an error has occurred, follow on-screen diagnostics.
3. Verify all Safety Inputs (SI) are solid Green.
 - a. If a channel is not on refer to the safety cheat sheet (on the Panduit cover next to the controller and included here) to determine which device is open or faulty.
 - b. Verify wiring harness is secure to the controller.
4. Replacing the Safety Controller.
 - a. If the controller will not turn on or has a memory failure, it may be necessary to replace it.
 - b. Follow LOTO procedures.
 - c. Remove wiring harness from controller.
 - d. Remove controller from din rail.
 - e. Remove the cover on the left side of the controller.
 - f. Remove memory module and install in new controller.
 - g. Install new controller on din rail and reattach wiring harness.

Si		
0	1	Panel Estop
2	3	Pull Cord One
4	5	Pull Cord Two
6	7	Cover One Interlock Switch
8	9	Cover Two Interlock Switch
10	11	Cover Three Interlock Switch
12	13	Cover Two Interlock Switch
14	15	SAFETY RESET BUTTON
So		
0	1	SAFETY OUTPUT
2	3	Safe Torque Off
4	5	
Ao		
0	1	0=Panel Estop OK 1=Pull Cord 1 OK
2	3	2= Pull Cord 1 OK 3= All Guards OK

**PHOENIX INNOVATIONS
INC.**

Apply power and controller will automatically boot within 30 seconds.


For more information, follow this link:

<https://www.keyence.com/mykeyence/?ptn=001&dlLangId=&dlLangType=en-GB>

PHOENIX INNOVATIONS INC.

Drives

Auger




#	Name	Value	Internal	Default	Min	Max
P046	Start Source 1	EtherNet/IP	5	Keypad	1	5
P047	Speed Reference1	EtherNet/IP	15	Drive Pot	1	16
P050	Start Source 3	Keypad	1	EtherNet/IP	1	5
P051	Speed Reference3	Drive Pot	1	EtherNet/IP	1	16
T105	Safety Open En	FaultDisable	1	FaultEnable	0	1
T106	SafetyFlt RstCfg	FltClr Reset	1	PwrCycleRset	0	1
C128	EN Addr Sel	Parameters	1	BOOTP	1	2
C129	EN IP Addr Cfg 1	10	10	0	0	255
C130	EN IP Addr Cfg 2	5	5	0	0	255
C131	EN IP Addr Cfg 3	97	97	0	0	255
C132	EN IP Addr Cfg 4	20	20	0	0	255
C133	EN Subnet Cfg 1	255	255	0	0	255
C134	EN Subnet Cfg 2	255	255	0	0	255
C135	EN Subnet Cfg 3	255	255	0	0	255

Commissioning

- Lockout the High Voltage Panel
- Un-wire the old drive and remove.
- Mount the new drive.
- Wire in the drive as shown in the Schematics.
- Apply power.
- Change the Parameters shown above to the values in the value column.
- Cycle Power Being sure to allow the drive to fully shut down.

PHOENIX INNOVATIONS INC.

Unload




#	Name	Value	Internal	Default	Min	Max
P046	Start Source 1	EtherNet/IP	5	Keypad	1	5
P047	Speed Reference1	EtherNet/IP	15	Drive Pot	1	16
P050	Start Source 3	Keypad	1	EtherNet/IP	1	5
P051	Speed Reference3	Drive Pot	1	EtherNet/IP	1	16
T105	Safety Open En	FaultDisable	1	FaultEnable	0	1
T106	SafetyFlt RstCfg	FltClr Reset	1	PwrCycleRset	0	1
C128	EN Addr Sel	Parameters	1	BOOTP	1	2
C129	EN IP Addr Cfg 1	10	10	0	0	255
C130	EN IP Addr Cfg 2	5	5	0	0	255
C131	EN IP Addr Cfg 3	97	97	0	0	255
C132	EN IP Addr Cfg 4	21	21	0	0	255
C133	EN Subnet Cfg 1	255	255	0	0	255
C134	EN Subnet Cfg 2	255	255	0	0	255
C135	EN Subnet Cfg 3	255	255	0	0	255

Commissioning

- Lockout the High Voltage Panel
- Un-wire the old drive and remove.
- Mount the new drive.
- Wire in the drive as shown in the Schematics.
- Apply power.
- Change the Parameters shown above to the values in the value column.
- Cycle Power Being sure to allow the drive to fully shut down.

PHOENIX INNOVATIONS INC.

Recirc Pump



#	Name	Value	Internal	Default	Min	Max
P046	Start Source 1	EtherNet/IP	5	Keypad	1	5
P047	Speed Reference1	EtherNet/IP	15	Drive Pot	1	16
P050	Start Source 3	Keypad	1	EtherNet/IP	1	5
P051	Speed Reference3	Drive Pot	1	EtherNet/IP	1	16
T105	Safety Open En	FaultDisable	1	FaultEnable	0	1
T106	SafetyFlt RstCfg	FltClr Reset	1	PwrCycleRset	0	1
C128	EN Addr Sel	Parameters	1	BOOTP	1	2
C129	EN IP Addr Cfg 1	10	10	0	0	255
C130	EN IP Addr Cfg 2	5	5	0	0	255
C131	EN IP Addr Cfg 3	97	97	0	0	255
C132	EN IP Addr Cfg 4	22	22	0	0	255
C133	EN Subnet Cfg 1	255	255	0	0	255
C134	EN Subnet Cfg 2	255	255	0	0	255
C135	EN Subnet Cfg 3	255	255	0	0	255

Commissioning

- Lockout the High Voltage Panel
- Un-wire the old drive and remove.
- Mount the new drive.
- Wire in the drive as shown in the Schematics.
- Apply power.
- Change the Parameters shown above to the values in the value column.
- Cycle Power Being sure to allow the drive to fully shut down.

**PHOENIX INNOVATIONS
INC.**

Electrical Schematics

**PHOENIX INNOVATIONS
INC.**

Mechanical Layouts



Normal Connection Line.
Ran by Phoenix Innovations

Feild Connection Line.
Ran by Others

Terminal
Jumper/Internally
connected

REFERENCE ARROWS

→ REFERENCE DEVICE:PIN
REFERENCE PAGE

WIRE LABEL

WIRE NUMBER	COLOR
CABLE DESIGNATION	
CORE OF CABLE	

=Assignment
+Location
-Device Designation


N.C. Pull Cable




Push Button



N.O. Prox Switch




N.O. Relay Contacts N.C. Relay Contacts



Relay Coil




3PH Motor



Fuse Holder / Fuse



RTD



Pressure Transducer





SANDERSON
UNION SPRINGS, AL

Repl. by	Origin	Repl. f.
Date	SN: 241039	
User	J. Callahan	
APPROVED	00 - COVER	
Standard	NOTE: UL508a	GSS PARENT # 503390

P515

5 x 15 CHILLER



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

P515
5 x 15 CHILLER

Repl. f.

=HV_PNL

+CNTPNL


01 - 480V DISTRIBUTION

NOTE:

GSS PARENT # 503390

Sheet 1 of

51 Sh.



SANDERSON
UNION SPRINGS, AL

Repl. by	Origin	Repl. f.
Date		=HV_PNL
User	J. Callahan	+CNTPNL
APPROVED		
Standard	UL508a	

P515
5 x 15 CHILLER


01 - 480V DISTRIBUTION
NOTE:

GSS PARENT # 503390

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02


Sharepoint - Document
CONTROLS



SANDERSON
UNION SPRINGS, AL

P515
5 x 15 CHILLER

Repl. by	Origin	Repl. f.
Date		
User	J. Callahan	
APPROVED		
Standard	UL508a	
	02 - 24V DISTRIBUTION NOTE:	GSS PARENT # 503390
		Sheet 3 of 51 Sh.



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

02 - 24V DISTRIBUTION

NOTE:

P515
5 x 15 CHILLER

=LV_PNL
+CNTPNL



GSS PARENT # 503390

ALL INFORMATION CONTAINED HEREIN IS PROPRIETARY, AND AS SUCH, MAY NOT BE REPRODUCED IN WHOLE OR IN PART, OR DISCLOSED TO OTHERS, WITHOUT THE PRIOR WRITTEN CONSENT OF PHOENIX INNOVATION



Project Path: C:\Users\lhelmer
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:00

CONTROLS



SANDERS
UNION SPRINGS, A

P515



5 x 15 CHILLER

Repl. by		Origin	Repl. f.	
Date				=LV_PNL
User	J. Callahan	SN: 241039		+CNPML
APPROVED		02 - 24V DISTRIBUTION		
Standard	UL508a	NOTE:		GSS PARENT # 50339

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

Sharepoint - Document
CONTROLS




SANDERSON
UNION SPRINGS, AL

Repl. by	
Date	
User	J. Callahan
APPROVED	
Standard	UL508a

P515
5 x 15 CHILLER

Origin	Repl. f.
SN: 241039	=HV_PNL +CNTPNL
02 - 24V DISTRIBUTION NOTE:	GSS PARENT # 503390
	Sheet 6 of 51 Sh.



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan

UL508a

P515
5 x 15 CHILLER

Repl. f.

=DRIVE_END

+JB1


02 - 24V DISTRIBUTION

NOTE:

GSS PARENT # 503390

Sheet 7 of

51 Sh.



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

Repl. f.

SN: 241039

=UNLOAD_END

+JB2

02 - 24V DISTRIBUTION
NOTE:


GSS PARENT # 503390

P515

5 x 15 CHILLER



KEYENCE SAFETY CONTROLLER



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan



+CNTPNL

03 - SAFETY
NOTE:

GSS PARENT # 503390

P515

5 x 15 CHILLER




SANDERSON
UNION SPRINGS, AL

Repl. by	Origin	Repl. f.
Date		
User	J. Callahan	
APPROVED		
Standard	UL508a	03 - SAFETY NOTE: +CNTPNL

P515
5 x 15 CHILLER

GSS PARENT # 503390



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan

UL508a

Repl. f.

=DRIVE_END



+MCHN

03 - SAFETY NOTE:

P515
5 x 15 CHILLER

GSS PARENT # 503390

Sheet 11 of 51 Sh.




SANDERSON
UNION SPRINGS, AL

Repl. by		Origin	Repl. f.
Date			=UNLOAD_END
User	J. Callahan		+MCHN
APPROVED			
Standard	UL508a	03 - SAFETY NOTE:	GSS PARENT # 503390

P515


5 x 15 CHILLER



SANDERSON
UNION SPRINGS, AL

Repl. by		Origin	Repl. f.
Date			=LV_PNL
User	J. Callahan		+CNTPNL
APPROVED			
Standard	UL508a	03 - SAFETY NOTE:	GSS PARENT # 503390

P515
5 x 15 CHILLER



SANDERSON
UNION SPRINGS, AL

Repl. by	Origin	Repl. f.
Date		
User	J. Callahan	=LV_PNL +CNTPNL
APPROVED		
Standard	UL508a	GSS PARENT # 503390
	NOTE:	

P515
5 x 15 CHILLER

Sheet 14 of 51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



Sharepoint - Document
CONTROLS

-TB T1:1501.A
=RMT_PB_PNL+MCHN/26.12

1501.A Blue AWG 16

1501.A Blue AWG 16

-A1401A

101778


- I-13
I-14
I-15
I-16
I-17
I-18
I-19
COM3
I-20
I-21
I-22
I-23
I-24
I-25
I-26
I-27

/14.18

REMOTE OPERATOR PNL
AUTO STOP

/14.16
-A1401ACOM2

101 WhiteBlue AWG 16



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan

04 - PLC IO

NOTE:

Repl. f.

=LV_PNL

+CNTPNL

GSS PARENT # 503390

P515

5 x 15 CHILLER

Sheet 15 of

51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document




Created by

Plot Date: 11/11/2025

Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan

04 - PLC IO

NOTE:

Repl. f.

=LV_PNL

+CNTPNL

GSS PARENT # 503390

P515


5 x 15 CHILLER

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document



CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

J. Callahan


04 - PLC IO

NOTE:

=LV_PNL
+CNTPNL

P515
5 x 15 CHILLER

GSS PARENT # 503390



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

P515
5 x 15 CHILLER

Repl. f.

=LV_PNL

+CNTPNL

05 - PLC MODULES

NOTE:

GSS PARENT # 503390

Sheet 18 of



51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

P515
5 x 15 CHILLER

SN: 241039

Repl. f.

=LV_PNL

+CNTPNL

05 - PLC MODULES

NOTE:

GSS PARENT # 503390

Sheet 19 of


51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



Sharepoint - Document
CONTROLS





SANDERSON
UNION SPRINGS, AL

Repl. by		Origin	Repl. f.
Date			=LV_PNL
User	J. Callahan		+CNTPNL
APPROVED			
Standard	UL508a	06 - RELAYS NOTE:	GSS PARENT # 503390

P515

5 x 15 CHILLER





SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

Repl. f.

SN: 241039

=HV_PNL
+CNTPNL


07 - DRIVES IO

NOTE:

GSS PARENT # 503390

P515

5 x 15 CHILLER





SANDERSON
UNION SPRINGS, AL

Repl. by		Origin	Repl. f.
Date			=HV_PNL
User	J. Callahan		+CNTPNL
APPROVED			
Standard	UL508a	07 - DRIVES IO NOTE:	GSS PARENT # 503390

P515

5 x 15 CHILLER



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

Repl. f.

=HV_PNL

+CNTPNL

SN: 241039

J. Callahan


UL508a

07 - DRIVES IO
NOTE:

GSS PARENT # 503390

P515

5 x 15 CHILLER




SANDERSON
UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by	Origin	Repl. f.
Date		=LV_PNL
User	J. Callahan	+CNTPNL
APPROVED		
Standard	UL508a	
08 - NETWORKING NOTE:		GSS PARENT # 503390
		Sheet 25 of 51 Sh.



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

SN: 241039

09 - Misc additions

P515
5 x 15 CHILLER

=RMT_PB_PNL
+MCHN

GSS PARENT # 503390

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS




Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document

CONTROLS

CONTROLS

Status	Change	Date	Name



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

Repl. f.

SN: 241039

99 - PANEL LAYOUTS
NOTE:

P515
5 x 15 CHILLER

GSS PARENT # 503390

Sheet 27 of




51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS



Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

Repl. f.

99 - PANEL LAYOUTS
NOTE:

P515
5 x 15 CHILLER



GSS PARENT # 503390

Sheet 28 of

51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Created by  Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

+JB1

99 - PANEL LAYOUTS

NOTE:

GSS PARENT # 503390

P515

5 x 15 CHILLER



Sheet 29 of

51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Created by  Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

Repl. f.

SN: 241039

+JB2

99 - PANEL LAYOUTS
NOTE:


GSS PARENT # 503390

Sheet 30 of

51 Sh.

P515

5 x 15 CHILLER



SANDERSON
UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by

Origin

Repl. f.

Date

SN: 241039

=LV_PNL

User

J. Callahan

+CNTPNL

APPROVED

99 - PANEL LAYOUTS

GSS PARENT # 503390

Standard

NOTE:

Sheet 31 of
51 Sh.


ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document

Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

Repl. f.

P515

5 x 15 CHILLER

=LV_PNL

+CNTPNL

99 - PANEL LAYOUTS
NOTE:

GSS PARENT # 503390

Sheet 32 of
51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS




Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document

Plot Date: 11/11/2025

Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

P515
5 x 15 CHILLER


=LV_PNL
+CNTPNL

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS



Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document

CONTROLS



-H2O309A
101182



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

Repl. f.

P515
5 x 15 CHILLER


=LV_PNL
+CNTPNL

99 - PANEL LAYOUTS
NOTE:

GSS PARENT # 503390

Sheet 34 of
51 Sh.

SAFETY POWER



SANDERSON
UNION SPRINGS, AL

DE15


P515
5 x 15 CHILLER

UNION SPRINGS, AL	5 x 15 CHILLER		
Repl. by	Origin	Repl. f.	
Date		=HV_PNL	
User	J. Callahan	+CNTPNL	
APPROVED			Sheet 35 of
Standard	UL508a	NOTE: 99 - PANEL LAYOUTS GSS PARENT # 503390	51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Created by 
Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

J. Callahan

UL508a

P515
5 x 15 CHILLER

=HV_PNL
+CNTPNL


99 - PANEL LAYOUTS
NOTE: GSS PARENT # 503390

Sheet 36 of
51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Created by 
Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

Repl. f.

=HV_PNL

+CNTPNL

99 - PANEL LAYOUTS
NOTE:

P515
5 x 15 CHILLER

GSS PARENT # 503390

Sheet 37 of



51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS



Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

Repl. f.

Status	Change	Date	Name

P515

5 x 15 CHILLER

=HV_PNL
+CNTPNL

99 - PANEL LAYOUTS
NOTE:


GSS PARENT # 503390

Sheet 38 of
51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\helmer\Phoenix Innovations\Phoenix Sharepoint - Document Controls
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

CONTROLS



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

Proved

Standard

Origin

SN: 241039

99 - PANEL LAYOUTS

NOTE:

P515
5 x 15 CHILLER

=HV_PNL

+CNTPNL

GSS PARENT # 503390

Sheet 39
of
51 Sh.



Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



4254 S Arkansas Ave
Russellville, AR 72802
479-219-9100

UL #: 3357337

Phoenix Innovations
Industrial Control Panel
Serial Number: **241039 -1**
Full Load Current: **33.90A**
Largest Motor: **15.0 HP**
Largest Load: **21.0A**
Voltage: **480V**
Phase and Freq: **3PH 60Hz**
SCCR: **5KA**
Enclosure Rating: **TYPE 1**
Drawing Number **241039**



SANDERSON
UNION SPRINGS, AL

Repl. by	
Date	
User	J. Callahan
APPROVED	
Standard	UL508a

Origin
SN: 241039
Repl. f.
101 - DATAPLATES
NOTE:

GSS PARENT # 503390

P515

5 x 15 CHILLER



CONTROLS



4254 S Arkansas Ave
Russellville, AR 72802
479-219-9100

UL #: 3357337

Phoenix Innovations

Industrial Control Panel

Serial Number: **241039 -2**

Full Load Current: **NA**

Largest Motor: **NA**

Largest Load: **NA**

Voltage: **24V**

Phase and Freq: **DC**

SCCR: **5KA**

Enclosure Rating: **TYPE 1**

Drawing Number

241039



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

Repl. f.

SN: 241039

J. Callahan

UL508a

P515

5 x 15 CHILLER

GSS PARENT # 503390

Sheet 41 of
51 Sh.

Device/Quantity-Bill of Material with Device Function




CONTROLS
Sharepoint - Document

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Innovations\rhelmer
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02



ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS

Amount	PART NUMBER (Component code)	GSS description		Supplier / Manufacturer
	Device designation	Placement	Function	
1	100029	POWER SUPPLY 20 AMP 24VDC		Allen-Bradley
	-PS217A	/2.17	24V Power Supply	
1	100034	PB MOMENTARY RED LED 22MM		Allen-Bradley
	-PB1016	/10.16	Safety Power Reset Push Button Actuator	
1	100099	8 BLADE RELAY SOCKET		
	-CR1610A	/16.10	Blower Run Control Relay	
2	100136	CIRCUIT BREAKER 2.5-4.0 AMP		Allen-Bradley
	-CB104B	/1.04	Auger Circuit Branch Protection	
	-CB112A	/1.12	Unload Circuit Branch Protection	
1	100143	ENCLOSURE 36X32X12		nVent HOFFMAN
	-ENC1	/27.F3		
2	100258	PROXIMITY SENSOR INDUCTIVE		
	-PRX1402A	/14.02		
	-PRX1403A	/14.03		
1	100277	MICRO800 4CH RTD IN MODULE		Rockwell_Automation
	-A1802	/18.02		
1	100278	MICRO800 4CH ANALOG IN MODULE		Rockwell Automation
	-A803	/19.02		
1	100282	MICRO850 SD CARDADAPTERMODULE		Rockwell_Automation
	-A1402	/27.B4		
1	100294	TRANSDUCER 240PSI 4-20MA NPT		
	-PRS1903A	/19.03	Air Header Pressure Sensor	
1	100317	TOUCH PANEL PV800 10IN		Rockwell_Automation
	-HMI314A	/3.14	HMI (Human Machine Interface)	
1	100331	SAFETY CONTROL CONTACTOR		Allen-Bradley
	-K1307A	/13.07	SAFETY CONTROL CONTACTOR	



SANDERSON
UNION SPRINGS, AL

Repl. by	Origin	Repl. f.
Date		
User		
APPROVED		
Standard		


P515

5 x 15 CHILLER

GSS PARENT # 503390

Sheet BOM1 of
51 Sh.

Amount	Part Number (Component code)	GSS description		Supplier / Manufacturer
		Placement	Function	
1	100645	SAFETY CONTROLLER		
	-A1001A	/9.01	KEYENCE SAFETY CONTROLLER	
3	100646	8A 24VDC SAFETY RELAY		Allen-Bradley
	-K2	/31.82		
	-K3	/31.82		
	-K4	/31.82		
3	101181	8 PIN RELAY SOCKET		
	-S1301A	/13.01	SAFETY POWER INTERPOSING RELAY	
	-S1303A	/13.03	SAFE TORQUE OFF CH1	
	-S1305A	/13.05	SAFE TORQUE OFF CH2	
1	101182	DEHUMIDIFIER		
	-H2O309A	/3.09		
5	101193	CABLE 10M M12 5PIN YLW ST		Phoenix
	-CBL20			
	-CBL21			
	-CBL22			
	-CBL23			
	-CBL24			
2	101195	ENCLOSURE 12X10X6 SS CLAMPED		nVent HOFFMAN
	-ENC5	/27.B6		
	-ENC8	/27.D6		
2	101197	DRIVE PF525 2 HP 480V		Allen-Bradley
	-DRV103A	/1.03	AUGER DRIVE	
	-DRV111A	/1.11	UNLOAD DRIVE	
2	101203	PUSH-PULL DEVICE 30MM		Allen-Bradley
	-A1002	/10.01		
	-ES1	/26.01		
1	101384	CIRCUIT BREAKER 2A 3PH		Allen Bradley
	-CB216A	/2.16	Circuit Branch Protection	
1	101385	RELAY DC 24V 8A		
	-K6	/31.64		
1	101392	ENCLOSURE 30X24X12 HIGH-SHED		nVent HOFFMAN
	-ENC3	/27.C3		



SANDERSON
UNION SPRINGS, AL

Repl. by

Origin

Repl. f.

Date

SN: 241039

User

APPROVED

Standard

P515


5 x 15 CHILLER

102 - BOM

GSS PARENT # 503390

Sheet BOM2 of
51 Sh.

Amount	Part Number (Component code)	GSS description		Supplier / Manufacturer
	Device designation	Placement	Function	
1	101657	8 Port Ethernet Switch UM		Rockwell_Automation
	-ETH2501A	/25.01		
4	101676	SWITCH NON CONTACT UC		
	-PRS1102A	/11.04	DRIVE END COVER SAFETY SWITCH	
	-PRS1108A	/11.11	DRIVE END DOOR SAFETY SWITCH	
	-PRS1202A	/12.05	UNLOAD END COVER SAFETY SWITCH	
	-PRS1208A	/12.11	UNLOAD END DOOR SAFETY SWITCH	
1	101714	14" X12" HMI COVER LATCHED		
	-ENC9	/27.B3		
2	101715	E-STOP LIFELINE 4		Rockwell_Automation
	-PC1	/10.03		
	-PC2	/10.05		
8	101731	CORD 8PIN10M SAFETY INTERLOK		
	-CBL10			
	-CBL11			
	-CBL12			
	-CBL13			
	-1			
	-2			
	-1			
	-2			
1	101778	Micro800 48 pt controller		Allen-Bradley
	-A1401A	/14.01	PLC (Programable Controller)	
1	101845	CIRCUIT BREAKER 1 P. 10A		Allen Bradley
	-CB303A	/3.04	24V Circuit Protection	
1	101959	CIRCUIT BREAKER 6.3-10.0 AMP		Allen-Bradley
	-CB203A	/2.03	Blower Motor Circuit Branch Protection	
1	102023	DRIVE PF525 15 HP 480V		Allen-Bradley
	-DRV209B	/2.09	PUMP DRIVE	
1	102024	CIRCUIT BREAKER 18-25A		Allen-Bradley
	-CB209B	/2.09	Pump Branch Circuit Protection	
1	102025	CIRCUIT BREAKER 45A 3PH		Allen-Bradley
	-CB104A	/1.04	Main Feeder Circuit Protection	



SANDERSON
UNION SPRINGS, AL

Repl. by

Origin

Repl. f.

Date

SN: 241039

User

APPROVED

Standard

102 - BOM GSS PARENT # 503390

P515

5 x 15 CHILLER

Sheet BOM3 of
51 Sh.

ALL INFORMATION CONTAINED HEREIN IS
PROPRIETARY, AND AS SUCH, MAY NOT BE
REPRODUCED IN WHOLE OR IN PART, OR
DISCLOSED TO OTHERS, WITHOUT THE PRIOR
WRITTEN CONSENT OF PHOENIX INNOVATIONS


Created by Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Sharepoint - Document Controls

Plot Date: 11/11/2025

Last Saved: 11/11/2025 08:02

CONTROLS

Amount	Part Number (Component code)	GSS description		Supplier / Manufacturer
	Device designation	Placement	Function	
2	102026	1/2" RTD 50 MM INS LNG		
	-R1808A	/18.08	Overflow RTD	
	-R1802A	/18.02	Chillerd Water RTD	
1	102164	DRIVE PF525 5HP 480V		Allen-Bradley
	-DRV202A	/2.02	BLOWER DRIVE	
1	102452	SELECTOR SW 3POS SPR RET C		
	-SS1	/26.11		
2	102665	ENLOSURE 12X10X5 GRAY CLAMPS		
	-ENC6	/29.F4		
	-ENC7	/30.F4		
1	102676	PB MOMENTARY BLUE LED 30MM		Allen-Bradley
	-PB1	/26.07		
2	500145	JBOX BACK PANEL		nVent HOFFMAN
	-ENC6	/29.F4		
	-ENC7	/30.F4		
1	501253	Low Voltage panel back plate		nVent HOFFMAN
	-ENC4	/27.C3		
1	501258	back plate for 36*30 cdsc		nVent HOFFMAN
	-ENC2	/27.F3		



SANDERSON
UNION SPRINGS, AL

Repl. by

Date

User

APPROVED

Standard

Origin

Repl. f.

SN: 241039


102 - BOM

GSS PARENT # 503390

P515

5 x 15 CHILLER

Sheet BOM4 of
51 Sh.



Creation Date: 11. Nov. 2025 08:01:50

User: r

Project name: 503390 24103

Amount	Part Number	GSS Description	Used ✓ / #	1	101392	ENCLOSURE 30X24X12 HIGH-SHED
1	100029	POWER SUPPLY 20 AMP 24VDC		1	101657	8 Port Ethernet Switch UM
1	100034	PB MOMENTARY RED LED 22MM		4	101676	SWITCH NON CONTACT UC
1	100099	8 BLADE RELAY SOCKET		1	101714	14" X12" HMI COVER LATCHED
2	100136	CIRCUIT BREAKER 2.5-4.0 AMP		2	101715	E-STOP LIFELINE 4
1	100143	ENCLOSURE 36X32X12		8	101731	CORD 8PIN10M SAFETY INTERLOK
2	100258	PROXIMITY SENSOR INDUCTIVE		1	101778	Micro800 48 pt controller
1	100277	MICRO800 4CH RTD IN MODULE		1	101845	CIRCUIT BREAKER 1 P. 10A
1	100278	MICRO800 4CH ANALOG IN MODULE		1	101959	CIRCUIT BREAKER 6.3-10.0 AMP
1	100282	MICRO850 SD CARDADAPTERMODULE		1	102023	DRIVE PF525 15 HP 480V
1	100294	TRANSDUCER 240PSI 4-20MA NPT		1	102024	CIRCUIT BREAKER 18-25A
1	100317	TOUCH PANEL PV800 10IN		1	102025	CIRCUIT BREAKER 45A 3PH
1	100331	SAFETY CONTROL CONTACTOR		2	102026	1/2" RTD 50 MM INS LNG
1	100645	SAFETY CONTROLLER		1	102164	DRIVE PF525 5HP 480V
3	100646	8A 24VDC SAFETY RELAY		1	102452	SELECTOR SW 3POS SPR RET C
3	101181	8 PIN RELAY SOCKET		2	102665	ENLOSURE 12X10X5 GRAY CLAMPS
1	101182	DEHUMIDIFIER		1	102676	PB MOMENTARY BLUE LED 30MM
5	101193	CABLE 10M M12 5PIN YLW ST		2	500145	JBOX BACK PANEL
2	101195	ENLOSURE 12X10X6 SS CLAMPED		1	501253	Low Voltage panel back plate
2	101197	DRIVE PF525 2 HP 480V		1	501258	back plate for 36*30 cdsc
2	101203	PUSH-PULL DEVICE 30MM				
1	101384	CIRCUIT BREAKER 2A 3PH				
1	101385	RELAY DC 24V 8A				

ALL INFORMATION CONTAINED HEREIN IS PROPRIETARY, AND AS SUCH, MAY NOT BE REPRODUCED IN WHOLE OR IN PART, OR DISCLOSED TO OTHERS, WITHOUT THE PRIOR WRITTEN CONSENT OF PHOENIX INNOVATIONS

roject Name: 503390 241039
Project Path: C:\Users\lhelmer
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:05

Project Path: C:\Users\lhelmer
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:00

A red graphic element located in the bottom right corner of the slide. It consists of three stylized, flame-like or wave-like shapes arranged in a triangular pattern, pointing towards the top right.



SANDERSO
UNION SPRINGS, A.

P515

5 x 15 CHILLER

Repl. by		Origin	Repl. f.	
Date		SN: 241039		
User				
APPROVED		102 - BOM		Sheet SBOM1of 51 Sh
Standard				GSS PARENT # 503390

Field Cable List with Individual Connections



Project name: 503390 241039

Creation date: 11.11.2025 08:01

Cable Designation	Article number		Source loc.	Source designation	Destination loc.	Destination designation
Core Number	Conductor Size	Sheet Location per Conductor	Wire Number	Source device	Color (field assigned if not pre-defined)	Destination device
-CBL25	14 AWG 3C wG Motor Leads		=HV_PNL +CNTPNL	-TB2	=DRIVE_END+MCHN	-M103A
1	AWG 14	/1.03	103.C	-TB2		-M103A
2	AWG 14	/1.04	104.C	-TB2		-M103A
3	AWG 14	/1.05	105.C	-TB2		-M103A
4	AWG 14	/1.06	106.A	-TB2	Green	-M103A
-CBL26	14 AWG 3C wG Motor Leads		=HV_PNL +CNTPNL	-TB2	=UNLOAD_END+MCHN	-M111A
1	AWG 14	/1.11	111.B	-TB2		-M111A
2	AWG 14	/1.12	112.B	-TB2		-M111A
3	AWG 14	/1.13	113.B	-TB2		-M111A
4	AWG 14	/1.14	114.A	-TB2	Green	-M111A
-CBL27	10 AWG 3C wG Motor Leads		=HV_PNL +CNTPNL	-TB2	=HV_PNL+MCHN	-M202A
1	AWG 10	/2.02	202.C	-TB2		-M202A
2	AWG 10	/2.03	203.C	-TB2		-M202A
3	AWG 10	/2.04	204.C	-TB2		-M202A
4	AWG 10	/2.05	205.A	-TB2	Green	-M202A
-CBL28	10 AWG VFD Cable		=HV_PNL +CNTPNL	-TB2	=HV_PNL+MCHN	-M209A
1	AWG 10	/2.09	209.B	-TB2		-M209A
2	AWG 10	/2.10	210.B	-TB2		-M209A
3	AWG 10	/2.11	211.B	-TB2		-M209A
4	AWG 10	/2.12	212.A	-TB2		-M209A
-CBL31	16 AWG 18 CONDUCTOR WITH SHIELD		=LV_PNL +CNTPNL	-TB1	=DRIVE_END+JB1	-TB4
1	AWG 16	/3.02	100	-TB1		-TB4
2	AWG 16	/10.03	1003.A	-TB1		-TB4
3	AWG 16	/4.02	101	-TB1		-TB4
4	AWG 16	/3.09	308.A	-TB1		-TB4
5	AWG 16	/9.03	903.A	-TB1		-TB4



SANDERSON
UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by	Origin	Repl. f.
Date		
User		
APPROVED		
Standard		
104 - Pull List		GSS PARENT # 503390
Sheet CON1 of		
51 Sh.		

Field Cable List with Individual Connections




Project name: 503390 241039

Creation date: 11.11.2025 08:01

 Project Name: 503390 241039
 Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Innovations
 Plot Date: 11/11/2025
 Last Saved: 11/11/2025 08:02

 ALL INFORMATION CONTAINED HEREIN IS
 PROPRIETARY, AND AS SUCH, MAY NOT BE
 REPRODUCED IN WHOLE OR IN PART, OR
 DISCLOSED TO OTHERS, WITHOUT THE PRIOR
 WRITTEN CONSENT OF PHOENIX INNOVATIONS

Cable Designation	Article number	Source loc.	Source designation	Destination loc.	Destination designation	
Core Number	Conductor Size	Sheet Location per Conductor	Wire Number	Source device	Color (field assigned if not pre-defined)	Destination device
6	AWG 16	/9.04	904.A	-TB1		-TB4
7	AWG 16	/10.04	1004.A	-TB1		-TB4
8	AWG 16	/10.05	1005.A	-TB1		-TB4
9	AWG 16	/10.06	1006.A	-TB1		-TB4
10	AWG 16	/10.07	1007.A	-TB1		-TB4
11	AWG 16	/10.08	1008.A	-TB1		-TB4
12	AWG 16	/10.09	1009.A	-TB1		-TB4
13	AWG 16	/10.10	1010.A	-TB1		-TB4
14	AWG 16	/14.02	1402.A	-TB1		-TB4
15	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
16	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
17	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
18	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
-CBL32	16 AWG 12 Conductor Shielded	=LV_PNL +CNTPNL	-TB1	=UNLOAD_END+JB2	-TB5	
1	AWG 16	/3.03	100	-TB1		-TB5
2	AWG 16	/4.03	101	-TB1		-TB5
3	AWG 16	/3.08	308.A	-TB1		-TB5
4	AWG 16	/10.11	1011.A	-TB1		-TB5
5	AWG 16	/10.12	1012.A	-TB1		-TB5
6	AWG 16	/10.13	1013.A	-TB1		-TB5
7	AWG 16	/10.14	1014.A	-TB1		-TB5
8	AWG 16	/14.03	1403.A	-TB1		-TB5
9	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
10	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
11	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
12	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
-CBL33	16 AWG 4 Conductor Shielded	=LV_PNL +CNTPNL	-TB1	=UNLOAD_END+JB2	-TB5	
1	AWG 16	/18.02	1802.A	-TB1		-TB5
2	AWG 16	/18.03	1803.A	-TB1		-TB5


SANDERSON
 UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by	Origin	Repl. f.
Date		
User		
APPROVED		
Standard		

104 - Pull List

GSS PARENT # 503390

Sheet CON2 of

51 Sh.

Field Cable List with Individual Connections



CONTROLS


Project name: 503390 241039

Creation date: 11.11.2025 08:01

 Project Name: 503390 241039
 Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Innovations\Phoenix Innovations
 Plot Date: 11/11/2025
 Last Saved: 11/11/2025 08:02

 ALL INFORMATION CONTAINED HEREIN IS
 PROPRIETARY, AND AS SUCH, MAY NOT BE
 REPRODUCED IN WHOLE OR IN PART, OR
 DISCLOSED TO OTHERS, WITHOUT THE PRIOR
 WRITTEN CONSENT OF PHOENIX INNOVATIONS

Cable Designation	Article number	Source loc.	Source designation	Destination loc.	Destination designation	
Core Number	Conductor Size	Sheet Location per Conductor	Wire Number	Source device	Color (field assigned if not pre-defined)	Destination device
3	AWG 16	/18.04	1803.A	-TB1		-TB5
4	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
-CBL34	16 AWG 4 Conductor Shielded		=LV_PNL +CNTPNL	-TB1	=DRIVE_END+JB1	-TB4
1	AWG 16	/18.08	1808.A	-TB1		-TB4
2	AWG 16	/18.09	1809.A	-TB1		-TB4
3	AWG 16	/18.10	1809.A	-TB1		-TB4
4	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
-CBL35	16 AWG 4 Conductor Shielded		=LV_PNL +CNTPNL	-TB1	=DRIVE_END+JB1	-TB4
1	AWG 16	/19.03	1903.A	-TB1		-TB4
2	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
3	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
4	AWG 16	NOT USED	NOT USED	NOT USED		NOT USED
-CBL36	16 AWG 12 Conductor Shielded		=LV_PNL +CNTPNL	-TB_T1	=RMT_PB_PNL+MCHN	-ES1
1	AWG 16	/26.01	1001	-TB_T1		-ES1
2	AWG 16	/26.02	1002	-TB_T1		-ES1
3	AWG 16	/26.03	100	-TB_B1		-ES1
4	AWG 16	/26.01	1001.A	-TB_T1		-ES1
5	AWG 16	/26.02	1002.A	-TB_T1		-ES1
6	AWG 16	/26.03	1414.A	-TB_T1		-ES1
7	AWG 16	/26.04	101	-TB_B1		-ES1
8	AWG 16	/26.07	1016.A	-TB_T1		-PB1
9	AWG 16	/26.08	1312.A	-TB_T1		-PB1
10	AWG 16	/26.11	102	-TB_B1		-SS1
11	AWG 16	/26.11	1416.A	-TB_T1		-SS1
12	AWG 16	/26.12	1501.A	-TB_T1		-SS1


SANDERSON
 UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by

Origin

Repl. f.

Date

User

APPROVED

Standard

SN: 241039

104 - Pull List

GSS PARENT # 503390

Sheet CON3 of

51 Sh.




Field Cable List without Individual Connections

CONTROLS				
Project name:	503390 241039		Creation date:	11. Nov. 2025 08:02:10
Count	Cable Type	Description		Supplier
	Device designation	From	To	
1	10 AWG 3C wG Motor Leads	Must be rated for at least 600V. Must meet environmental conditions. Must be ran in conduit.		Contractor
	-CBL27	=HV_PNL +CNTPNL -TB2	=HV_PNL +MCHN -M202A	
1	10 AWG VFD Cable	Must be ran in separate conduit from control cables. Shield Must be drained at the motor and at the drive.		Contractor
	-CBL28	=HV_PNL +CNTPNL -TB2	=HV_PNL +MCHN -M209A	
2	16 AWG 12 Conductor Shielded	Shield must be drained on the end closest to the controller		Contractor
	-CBL32	=LV_PNL +CNTPNL -TB1	=UNLOAD_END +JB2 -TB5	
	-CBL36	=LV_PNL +CNTPNL -TB_T1	=RMT_PB_PNL +MCHN -ES1	
2	14 AWG 3C wG Motor Leads	Must be rated for at least 600V. Must meet environmental conditions. Must be ran in conduit.		Contractor
	-CBL25	=HV_PNL +CNTPNL -TB2	=DRIVE-END +MCHN -M103A	
	-CBL26	=HV_PNL +CNTPNL -TB2	=UNLOAD-END +MCHN -M111A	
1	16 AWG 18 CONDUCTOR WITH SHIELD			Contractor
	-CBL31	=LV_PNL +CNTPNL -TB1	=DRIVE-END +JB1 -TB4	
3	16 AWG 4 Conductor Shielded	Shield must be drained on the end closest to the controller		Contractor
	-CBL33	=LV_PNL +CNTPNL -TB1	=UNLOAD-END +JB2 -TB5	
	-CBL34	=LV_PNL +CNTPNL -TB1	=DRIVE-END +JB1 -TB4	
	-CBL35	=LV_PNL +CNTPNL -TB1	=DRIVE-END +JB1 -TB4	

ALL INFORMATION CONTAINED HEREIN IS PROPRIETARY, AND AS SUCH, MAY NOT BE REPRODUCED IN WHOLE OR IN PART, OR DISCLOSED TO OTHERS, WITHOUT THE PRIOR WRITTEN CONSENT OF PHOENIX INNOVATIONS

Project Name: 503390 241039
Project Path: C:\Users\rhelmer\Phoenix Innovations\Phoenix Innovations\Phoenix Innovations\rhelmer\rhelmer
Plot Date: 11/11/2025
Last Saved: 11/11/2025 08:02

Created by rhelmer



SANDERSON
UNION SPRINGS, AL

P515

5 x 15 CHILLER

Repl. by	Origin	Repl. f.
Date		
User		
APPROVED		
Standard		

104 - Pull List


GSS PARENT # 503390

Sheet CBLS1 of
51 Sh.


PART NUMBER: 501635-241039

DESCRIPTION: 5FT RH Parts Chiller

JOB NUMBER:



PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
4.2	1	503065	5ft Chiller Drive Gearbox Guard
4.4	1	503067	5ft Chiller Drive Door Guard
5.9	1	503073 LHRH PARTS	
16.1	1	502994	SMALL GUARD TOP
19	2	Pull Cable AB	Pull Cable AB
21.2	1	503234	LEG BOTTOM PLATE
29.1	1	501200	4" SLIDE GATE VALVE



PHOENIX INNOVATIONS

4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802

PART NO.
501635-241039

DESCRIPTION: 5FT RH Parts Chiller


MATERIAL:

ENGINEER: esay


CREATION DATE: 5/1/2025

TOLERANCE IF NOT
OTHERWISE STATED
+/- 0.063in

SHEET 1 OF 1




PARTS LIST				PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION	ITEM	QTY	PART NUMBER	DESCRIPTION
11	1	101313	1 HP 56C SS Motor	1	1	101314	BEARING SQUARE 4 BOLT
12	1	503270	4' DRIVE MOUNT PLATE	2	1	101325	BUSHING Q1 X 1 7/8"
17	1	101316	TIMKEN LUBRICATOR MOTOR	3	1	101324	BUSHING Q1X2.5
18	1	101317	TIMKEN LUBRICATOR REFILL	4	1	102302	SPROCKET 80Q36
19	4	11581	HEX BOLT SS 5/8"-18X2"	5	2	101333	SHEAVE BK50HRM FHP
20	1	102206	SPROCKET 80Q28	6	2	101328	BUSHING H_5-8
21	1	102161	TENSIONER	8	1	501703	2.5" SHAFT SEAL BEARING
22	1	102162	Roller Tensioner	9	1	101320	GEARBOX CYCLO 1827:1
				10	1	101353	ROLLER CHAIN - 80

	PHOENIX INNOVATIONS
	4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802
PART NO.	501786 4R
DESCRIPTION:	2.5IN AUGER DRIVE
MATERIAL:	
ENGINEER:	jhill
TOLERANCE IF NOT OTHERWISE STATED	+/- 0.063in
CREATION DATE:	9/15/2023

PART NUMBER: 501785 4R

DESCRIPTION: 2IN UNLOAD DRIVE

JOB NUMBER:



PARTS LIST				PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION	ITEM	QTY	PART NUMBER	DESCRIPTION
14	1	101352	ROLLER CHAIN - 60	1	1	501782	2" UNLOAD SHAFT
17	1	101313	1 HP 56C SS Motor	2	1	501704	2" SHAFT COLLAR
18	1	501769	3" BEARING SUPPORT SHAFT	3	1	101315	BEARING SQUARE 4 BOLT
19	4	101299	3/4-16x1 1/4" BOLT FT	4	1	101333	SHEAVE BK50HRM FHP
21	1	101732	SET COLLAR SS 2" SPLIT	5	1	101339	SHEAVE BK65HRM FHP
22	1	501702	2" SHAFT SEAL BEARING	6	1	101330	SPROCKET 60P18H
23	4	101582	SKT BOLT SS 1/2"-20X2"	7	1	101331	SPROCKET 60Q36
24	1	101317	TIMKEN LUBRICATOR REFILL	8	1	101332	BUSHING P1X1.5
25	1	101316	TIMKEN LUBRICATOR MOTOR	9	1	101329	BUSHING Q1X2
26	2	504279	2in motor mount plate	10	2	101328	BUSHING H_5-8
27	1	504281	Belt Tension Flange	11	1	101319	OIL SEAL - 2"
28	1	102161	TENSIONER	12	1	501775	2" SUPPORT BUSHING
29	1	102162	Roller Tensioner	13	1	101321	GEARBOX CYCLO 165:1



PHOENIX INNOVATIONS


4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802

PART NO.	501785 4R
DESCRIPTION:	2IN UNLOAD DRIVE
MATERIAL:	
ENGINEER:	jhill
TOLERANCE IF NOT OTHERWISE STATED	+/- 0.063in
CREATION DATE:	9/15/2023


JOB NUMBER:


DESCRIPTION: 5ft UNLOADER PADDLE RH

PART NUMBER: 5FT PARTS RH UL PADDLE



PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	503173	UNLOADER TUBE CAP
2	1	503080	PADDLE MOUNT PLATE
3	4	100961	3/8"-16x1-1/4"
4	4	101007	3/8" Medium Split Lock Washer
5	1	503083	Unloader V Tube 5xRH
6	1	503081	Unloader H Tube
7	1	503087	Unloader Top Blade
8	1	503763	Paddle Support
9	1	504364	5FT RH PARTS UNLOADER BLADE




	PHOENIX INNOVATIONS
	4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802
PART NO.	5FT PARTS RH UL PADDLE
DESCRIPTION:	5ft UNLOADER PADDLE RH
MATERIAL:	
ENGINEER:	jhill
TOLERANCE IF NOT OTHERWISE STATED	+/- 0.063in
CREATION DATE:	9/15/2023


PART NUMBER: 503461

DESCRIPTION: REGEN BLOWER AIR FILTER KIT

JOB NUMBER:





PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	503456	FILTER COVER SIDE
2	1	503457	FILTER COVER TOP
3	1	503458	FILTER FLANGE
4	1	503459	FILTER MOUNT
5	2	503460	BLOWER FRAME
6	1	503464	FILTER ROD
7	4	100985	1/2"-13 Finished Hex Nut
8	1	101910	3" SANI 90
9	1	503467	PIPE ADAPTER RING
10	1	101556	5 HP BLOWER 480
11	1	504131	NIPPLE SS 2" x 12"
12	1	101550	AIR FILTER RESTRICTION GAUGE
13	1	101551	BLOWER FILTER
14	1	102669	BUNG SS 1/8" STEPPED NPT

	PHOENIX INNOVATIONS
	4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802
PART NO.	503461
DESCRIPTION:	REGEN BLOWER AIR FILTER KIT
MATERIAL:	
ENGINEER:	jhill
TOLERANCE IF NOT OTHERWISE STATED	+/- 0.063in
CREATION DATE:	4/30/2024

PART NUMBER: 503573

DESCRIPTION: Tee Brace Assembly

JOB NUMBER:






4ft Tee Brace

SCALE 1 / 5

ALL INFORMATION CONTAINED HEREIN IS PROPRIETARY, AND AS SUCH, MAY NOT BE REPRODUCED IN WHOLE OR IN PART, OR DISCLOSED TO OTHERS, WITHOUT THE PRIOR WRITTEN CONSENT OF PHOENIX INNOVATIONS

PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	2	503574	Tee Brace Bearing Mount
2	2	503575	Tee Brace Header Mount
3	2	503577	Tee Brace Support
4	1	503585	Tee Brace Vert Tube
5	1	503578	Tee Brace Top Tube
6	2	501777	2.5in Carrier Bearing
7	16	100985	1/2"-13 Finished Hex Nut
8	8	101009	1/2" Med Split Lock Washer
9	4	503273	TEE BRACE CARRIER ALLTHREAD
10	4	503274	TEE BRACE HEADER ALLTHREAD
11	4	503265	TEE BRACE SPACER



PHOENIX INNOVATIONS

4254 S. ARKANSAS AVE. RUSSELLVILLE, AR 72802

PART NO.
503573

DESCRIPTION: Tee Brace Assembly

MATERIAL:

ENGINEER: jhill

CREATION DATE: 9/13/2023

TOLERANCE IF NOT OTHERWISE STATED
+/- 0.063in

SHEET 1 OF 3