



Vilter Manufacturing Corp. VSS/VSM 5/15-Warranty™ Addendum

Your Vilter Manufacturing Corp. VSS or VSM Single Screw Compressor is now available with exclusive 5/15-Warranty coverage on new installations of VSS/M compressor units. All of the Single Screw Compressor's internal components, including the gate rotor, main rotor and Paralex™ slide valves, are covered by a 5-year warranty. All of the compressor's bearings are covered by a 15-year warranty. The remaining compressor components that are externally accessible, including the shaft seal, slide valve motors and potentiometers will continue to have a 2-year warranty, as will the components of the screw compressor package.

This warranty requires the customer to document the adherence to an itemized maintenance schedule and the use of Genuine Vilter Manufacturing Corp. parts and Vilter Manufacturing Corp. premium grade refrigeration oil. This includes the changing of oil, replacement of the oil filter and periodic free oil sample analysis. Documentation can take the form of itemized and dated maintenance logs, work-orders and/or invoices, along with the documentation of the purchase of genuine Vilter Manufacturing Corp. parts used on the unit.

Non-compliance with the warranty conditions will result in the standard warranty of 3-years on all internal rotating components and 2-years on the remainder of the screw compressor package.

SERVICE INTERVAL REQUIREMENTS FOR VILTER EXTENDED WARRANTY

The following service intervals are based on the usage of Vilter Manufacturing Corporation Premium Grade refrigeration oil in VSS/VSM Single Screw Compressor Units.

GROUP	INSPECTION OR MAINTENANCE ITEM	SERVICE INTERVALS (HOURS)													
		200	5,000	10,000	20,000	30,000	40,000	50,000	60,000	70,000	80,000	90,000	100,000	110,000	120,000
OIL CIRCUIT	Oil Change (1)		R		R		R		R		R		R		R
	Oil Analysis (2)		S	S	S	S	S	S	S	S	S	S	S	S	S
	Oil Filters (3)	R	R	R	R	R	R	R	R	R	R	R	R	R	R
	Oil Strainer	I	I	I	I	I	I	I	I	I	I	I	I	I	I
PACKAGE	Coalescing Element					R			R			R			R
	Suction Screen	I	I	I	I	I	I	I	I	I	I	I	I	I	I
	Liquid Line Strainers	I	I	I	I	I	I	I	I	I	I	I	I	I	I
	Coupling Alignment														
CONTROL CALIBRATION	Transducers	I	I	I	I	I	I	I	I	I	I	I	I	I	I
	RTD's	I	I	I	I	I	I	I	I	I	I	I	I	I	I
COMPRESSOR	Inspect Compressor		I		I		I		I		I		I		I
	Bearings														I

Key: I : Inspect. R : Replace. S : Sample.

- Notes: (1) The oil must be changed at these intervals, unless oil analysis results exceed the allowable limits. The frequency of changes will depend on the system cleanliness.
- (2) Oil analysis should be done at these intervals as a minimum; the frequency of analysis will depend on system cleanliness.
- (3) The oil filter(s) on a minimum must be changed at these intervals or annually if not run continuously. However, the oil filter(s) must be changed if the oil filter differential exceeds 12 psi or if oil analysis results require it.