Fire-system pumping starts with the required pressure and flow.

Evaluate the pump against the selected fire-protection system's duty, approval requirements and emergency supply. A component pressure rating alone does not establish fire-suppression performance or system acceptance.

Start with the approved suppression design and the simultaneous flow and pressure required at its supply point. Include the loss through pipework and controls, emergency power and the required operating duration. The pump must fit that complete duty.

Selection basis

Match the selected configuration to the working water, pressure, flow, temperature and duty. Maximum ratings and separate curve points do not establish one simultaneous operating point. Confirm installation and supplied configuration with WaterQuest Solutions.

Technical data

Specifications and selection data

Model	Displacement	Max Pressure	Key Use Case
WaterQuest Solutions P1	0.8 to 1.0 cc/rev (0.0488 to 0.061 in³/rev)	Up to 160 Bar	Compact point protection, small suppression zones
WaterQuest Solutions P3	3.0 cc/rev (0.183 in³/rev)	Up to 160 Bar	Small systems, cabinet and server room protection
WaterQuest Solutions P6	6.0 cc/rev (0.366 in³/rev)	Up to 160 Bar	Medium systems, light industrial fire suppression
WaterQuest Solutions P15	15.0 cc/rev (0.915 in³/rev)	Up to 160 Bar	Commercial buildings, hospitals, transit systems
WaterQuest Solutions P60	60.0 cc/rev (3.66 in³/rev)	Up to 160 Bar	Industrial plants, offshore platforms, large structures
WaterQuest Solutions P180	180.0 cc/rev (11 in³/rev)	Up to 160 Bar	Major infrastructure, multi-building campuses