Job Number: 2020580 Model Number: VTV-1-60x3/15V/5ST-480-3-1800-120

Project Name: Lakewood Country Club Salesperson: Mike Green

Order Date: 10/26/2020 Ship Date: 12/29/2020 Apps Engineer: Chandler Blaschka

Station Type: Vertical Turbine Site Voltage: 460VAC/3Phase/60hz

Configuration: N/A Power Configuration: WYE 3PH 4 Wire

Prime System: N/A SCCR Rating: 35 kA

Dynamic Inlet PSI : N/A FCC Type : N/A

Feet of Lift: N/A Station Location: Inside - Weather Resistant Building

Discharge PSI: 120 Site Elevation: 720

Total Flow: 1800 Regulatory Compliance: UL Listed - Industrial Control Panel

Station Color: WT Green Wet Well Depth: See CSO

Elec. Encl. Location: On Skid Flow Meter Location: On Skid

Sold To

Customer PO: 2008110728Q002 City: Mt. Pleasant
Company Name: Thielen Turf & Irrigation State: Michigan
Address 1: 600 Industrial Ave Zip: 48858

Address 2 : Country : United States

Sold To Contact

First Name : Doug Phone Number :
Last Name : Thielen Fax Number :
Mobile Number : (989) 506-6037 Email Address :

**Invoice Price Information** 

Invoice Price: \$148,917 Refer to WT Change Order:

Muiltiplier: Term of Sale: 50% Down

Corrected Price : Special Terms Approved by :

Ship To

Company Name : Lakewood Country Club City : Westlake Address 1 : 2613 Bradley Road State : Ohio

Address 2 : Zip : 44145

Country: United States

Ship To Contact

First Name : Aaron Phone Number :
Last Name : Archambauh Fax Number :
Mobile Number : (603) 502-7438 Email Address :

**Shipment Details** 

24 Hour Advance Notice : Yes Notification of Shipment : All

Carrier: FOB Hartland - WT Selects Carrier Other:

Services Included in Total Price: Full Installation Arrival Confirmation Notes:

Installation Service Type: None Station Weight:

Comments

Mechanical Engineer: Andy Casper Controls Engineer: Cory Wolgast Electrical Engineer: Sandy McElhinny

Job Number: 2020580 Model Number: VTV-1-60x3/15V/5ST-460-3-1800-120

Project Name: Lakewood Country Club Salesperson: Mike Green

# **Electrical Spec**

Pump ID	HP	RPM	GPM	HTR	XL	VFD	SS	EBV	Temp SW	Pump Temp Sensor
Sustain	5	3600	46	No	Yes	None	No	No	No	No
Jockey (#1)	15	1800	125	Yes	Yes	1	No	Yes	No	No
Main (#2)	60	1800	600	Yes	Yes	1	No	Yes	No	No
Main (#3)	60	1800	600	Yes	Yes	1	No	Yes	No	No
Main (#4)	60	1800	600	Yes	Yes	1	No	Yes	No	No

### Mechanical Reference

Inlet Pressure : N/A Inlet Pressure Transducer : N/A

Discharge Flow: 1800 Flow Meter Type: Mag Meter (Growsmart)

Discharge Pressure: 120 Discharge Size: 8IN

### Options

Control System : Sigma w/ Touchscreen Disconnect Type : Fused

Display: 7" Color Panel Location: On Skid
Surge Protection: Standard Dead Front: No
Opto Coupler: Yes NEMA Rating: 3R
Opto Isolator: Yes Station Heating: No
Lighted HOAs: Yes Panel Leg Height: Not Set

ETMs on Panel : No Window Kit : No Panel Lighting : Interior Only VFD Viewing Window : Yes

Power Phase Monitor Protection: Yes Enclosure Cooling: Heat Exchanger Left

Individual Motor Disconnects : No Chemical Treatment Relay : Yes

Accessory Junction Box : No Remote Disable Relay : Yes

Fertigation Run Relay: Yes Electrical Enclosure Size: 75X72X16

### **Option Comments**

Power Phase Monitor Protection, Remote Disable Relay, Fertigation Run Relay

#### Station Enclosure - None

Level Controls - None

Level Sensing Method: Level Float (normally closed) & Transducer Location: Wet Well

Number of Set Points: 1

Fill SourceTypeHOAPond 1ContactNoPond 2ContactNo

**Level Control Comments** 

## Fertigation - None

## Auxiliary Power - None

# Power Conditioning - None

Mechanical Engineer: Andy Casper Controls Engineer: Cory Wolgast Electrical Engineer: Sandy McElhinny

Job Number: 2020580 Model Number: VTV-1-60x3/15V/5ST-460-3-1800-120

Project Name: Lakewood Country Club Salesperson: Mike Green

Telemetry

Type: WV Cloud Provider: 4G Verizon Software and Version: 5 Year Standard

Lattitude : 41 26'56.42" N Longitude : 81 57'26..06" W

**WYE Strainer** 

WYE Strainer Manufacturer : Metraflex Type Size : Autoflush WYE (LPD) - 10"

## Sequence of Operations

ALARMS: Low pressure, high pressure, low wet well level, phase/voltage and VFD fault (when applicable) are standard alarms. Please list additional alarms below:

**Sequence of Operations Comments** 

Standard (pressure drop start / flow drop retire)

**Additional Items Comments** 

Mechanical Engineer: Andy Casper Controls Engineer: Cory Wolgast Electrical Engineer: Sandy McElhinny