PREVIEW PROVISIONAL SIMULATED

Wheeling Energy Allocation Schedule

IPP 2 • to Eskom

Sep 2026

Prepared for IPP 2

138.3 MWh was allocated to 2 off-taker accounts in Sep 2026; losses 8,830 kWh against 1,970.6 MWh generated. The schedule conserves.

ALLOCATED	LOSSES	GENERATED	UNALLOCATED
138.3 MWh	8,830 kWh	1,970.6 MWh	1,823.4 MWh
	Average loss factor 6.00%		

Allocation by off-taker account

OFF-TAKER ACCOUNT	GENERATOR	PEAK	STANDARD	OFF-PEAK	TOTAL
OffTaker A Rosebank Mall	IPP2 Atlantis Wind	11.7 MWh	31.5 MWh	21.9 MWh	65.1 MWh
OffTaker C Midrand DC	IPP2 Atlantis Wind	17.5 MWh	38.6 MWh	17.0 MWh	73.2 MWh

EXCEPTIONS AND NEXT STEPS

Nothing needs your attention for this period.

NOTES AND METHOD

Check passed: Generated = allocated + losses + unallocated. 138.3 MWh + 8,830 kWh + 1,823.4 MWh = 1,970.6 MWh.

Method: Each settled period of the contracts the organization sells under over Eskom's network (no municipal wheeling configuration): delivered energy by TOU per off-taker account, the losses settlement applied, and the metered supply.

Sources: WB.Wheeling.Settlement.SettlementPeriod; WB.Wheeling.OffTakerSite; WB.Tariff.EskomTlf; WB.Tariff.EskomDlf.

SIMULATED

SIMULATED DATA