FIRESAFETY ZONE

(An ISO 9001:2015 Certified Company)

Dealing In: All Type Of Personal Protective & Fire Fighting Equipments, Fire Detection System & Industrial Fire And Safety Trainings.

CERTIFICATE

REFILLING AND HYDRO-TESTING

To,
Ankur Chemfood Ltd,
Survey No.369,
Chopadava,
Bhachau - 370140

This Is To Certify That We Have Done Refilling & Hydro-Testing Of ***02 Nos. Fire Extinguishers*** *Against* ***Bill No. FSZ/24-25/0120 Dated:*** **06/09/2024** *As Per* ***Is 2190:2010.***

Sr. no.	Item Description	Capacity	Qty	BODY STATUS	PRESSURE STATUS	CYLINDER STATUS / REMARKS
LIST OF FIRE EXTINGUISHER SUCCESSFULLY REFILLED & HYDRO-TESTED						
1.	CO2 Type (S.R.No.609369 & 609370)	4.5 KG	02 NOS	OK	OK	PASS (NEXT DUE SEP 2029)

Above Cylinders Are Refilled & Hydro-Tested As Per The Capacity
All Above **CO2 Type Fire Extinguishers** are Hydraulically Pressure Tested At 250 Kg/Cm2 as per **IS 5844-1997** & Found No Sign of Any Critical Leakage or Permanent Stretch While Testing .

DATE OF REFILLING: **06/09/2024**
NEXT DUE DATE : **05/09/2025**

Thanks & Regard's

FIRESAFETY ZONE Gandhidham

Vicky K. Paryani
Firesafety Zone
Gandhidham – Kutch
M. 97222 22181