



Rajkiya Engineering College Ambedkar Nagar (U.P.) - 224122
Department of Civil Engineering

TEST REPORT

Departmental Consultancy No.: CE/2620

Sample: Cement Concrete Cube

Source of Sample: Project Engineer, U.P.R.N.S.S. Ltd., Construction Division- Sultanpur,

District-Sultanpur (U.P.)

Name of Work: जनपद अमेठी में अनावासीय कलेक्ट्रेट भवन के अवशेष का नवीन कार्यों का निर्माण कार्य।

Reference: 491 / यूपी०आर०एन०एस०एस० / परि०अभि० / सुल्ता० / 2025-26 Dated: 20/09/2025.

Tested for: Compressive Strength

Tested as per: IS 456:2000, IS 516:1959


No. of Sample: Two sets Only


TEST RESULTS

Specimen No.	Age (Days)	Crushing Load (kN)	Area (mm ²)	Compressive Strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1.	07	360	22500	16.00	17.26
2.	07	380	22500	16.89	
3.	07	425	22500	18.89	
4.	28	545	22500	24.22	25.70
5.	28	625	22500	27.78	
6.	28	565	22500	25.11	

Conditions:

- 1) Results given above refer only to the sample(s) supplied. Since the representative sample has not been taken in our presence, we don't take any responsibility regarding the quality of bulk material from which the sample was sent for testing in the laboratory.
- 2) The report in full or in any part should not be published, advertised, photocopied or used for any legal action unless prior permission has been obtained from the Director, REC, Ambedkar Nagar.
- 3) This report is being issued on the specific understanding that REC, Ambedkar Nagar will in no way be involved in any action following the interpretation of the above results.


(Anupam Kumar Verma)
Lab. Staff


(Anmt Kumar Rai)
Co-Principal Investigator


(Avaneesh Kr. Yadav)
Principal Investigator