



Rajkiya Engineering College Ambedkar Nagar (U.P.) - 224122
Department of Civil Engineering

TEST REPORT

Departmental Consultancy No.: CE/2477

Sample: Cement Concrete Cube

Source of Sample: Project Engineer, U.P.R.N.S.S. Ltd., Construction Division- Sultanpur, District-Sultanpur (U.P.).

Name of Work: प्रखण्ड सुल्तानपुर के अन्तर्गत उपनिबन्धक कार्यालय लम्बुआ का निर्माण कार्य।

Reference: 315 / परि०अभि० / यूपीआरएनएसएस / सुल्ता० / 2025-26 **Dated:** 23/07/2025.

Tested for: Compressive Strength

Tested as per: IS 456:2000, IS 516:1959


No. of Sample: One set only.

TEST RESULTS


Specimen No.	Age (days)	Crushing Load (kN)	Area (mm ²)	Compressive Strength	Average Compressive
1.	28	580	22500	25.78	24.81
2.	28	515	22500	22.89	
3.	28	580	22500	25.78	

Conditions:

- 1) Results given above refer only to the sample(s) supplied. Since the representative sample has not been taken in presence, we don't take any responsibility regarding the quality of bulk material from which the sample was sent for testing in the laboratory.
- 2) The report in full or in any part should not be published, advertised, photocopied or used for any legal action unless permission has been obtained from the Director, REC, Ambedkar Nagar.
- 3) This report is being issued on the specific understanding that REC, Ambedkar Nagar will in no way be involved in any action following the interpretation of the above results.


(Pooja Pathak)
Lab. Staff


(Amit Kumar Rai)
Co-Principal Investigator


(Avaneesh Kr. Yadav)
Principal Investigator