

**Rajkiya Engineering College Ambedkar Nagar (U.P.) - 224122**  
**Department of Civil Engineering**

**TEST REPORT**

**Departmental Consultancy No.- CE/327**

**Sample:** Portland Pozzolana Cement

**Source of Sample:** Superintending Engineer, U.P.R.N.S.S. Ltd. Gonda -II, Gonda (U.P.).

**Name of Work** जनपद श्रावस्ती के न्यायालय परिसर में फैमिली कोर्ट का निर्माण कार्य

**Reference:** 361/बह0/यू0पी0आर0एन0एस0एस0/2021-2022 Dated: 13.01.2022

**Tested for:** Physical Properties

**Tested as per:** IS 4031, IS 456

**No. of Sample:** One no. only


**Identification Mark:** BIRLA Cement

**TEST RESULTS**

| S. No. | Property/Name of Test                            | Result |
|--------|--------------------------------------------------|--------|
| 1.     | Standard Consistency (%)                         | 31     |
| 2.     | Initial Setting Time (minutes)                   | 137    |
| 3.     | Final Setting Time (minutes)                     | 298    |
| 4.     | Fineness (Specific Surface) (m <sup>2</sup> /kg) | 315.2  |
| 5.     | Compressive Strength (MPa)                       |        |
|        | (i) 03 days                                      | 20.9   |
|        | (ii) 07 days                                     | 32.7   |

**Conditions:**

- 1) Results given above refer only to the sample(s) supplied. Since the representative sample has not been taken in our presence, we don't take any responsibility regarding the quality of bulk material from which the sample was sent for testing in the laboratory.
- 2) The report in full or in any part should not be published, advertised, photocopied or used for any legal action unless prior permission has been obtained from the Director, REC, Ambedkar Nagar.
- 3) This report is being issued on the specific understanding that REC, Ambedkar Nagar will in no way be involved in any action following the interpretation of the above results.

  
(Rajesh Kr. Yadav)  
Lab. Staff

  
(Armit Kumar Rai)  
Co-Principal Investigator

  
(Avaneesh Kr. Yadav)  
Principal Investigator