

Rajkiya Engineering College Ambedkar Nagar (U.P.) - 224122
Department of Civil Engineering

TEST REPORT

Departmental Consultancy No.- CE/327

Sample: Coarse Aggregate (Stone Grit & Stone Ballast)

Source of Sample: Superintending Engineer, U.P.R.N.S.S. Ltd. Gonda -II, Gonda (U.P.).

Name of Work जनपद श्रावस्ती के न्यायालय परिसर में फैमिली कोर्ट का निर्माण कार्य

Reference: 361/बह0/यू0पी0आर0एन0एस0एस0/2021-2022 Dated: 13.01.2022

Tested for: Sieve Analysis & Fineness Modulus

Tested as per: IS 1077:1992, IS 3495:1992, IS 5454:1976

No. of Sample: Two nos. of Coarse Aggregate

Identification Mark: N/A

TEST RESULTS

(A) Coarse Aggregate (Stone Ballast 40 mm nominal size)


S. No.	I.S. Sieve Designation	% Passing by Weight
1.	40 mm	91.2
	20 mm	52.6
	10 mm	21.9
	4.75 mm	2.1
2.	Fineness Modulus = 7.32	


(B) Coarse Aggregate (Stone Grit 20 mm nominal size)

S. No.	I.S. Sieve Designation	% Passing by Weight
1.	40 mm	100
	20 mm	97.1
	10 mm	52.6
	4.75 mm	6.5
2.	Fineness Modulus = 6.44	

Conditions:

- 1) Results given above refer only to the sample(s) supplied. Since the representative sample has not been taken in our presence, we don't take any responsibility regarding the quality of bulk material from which the sample was sent for testing in the laboratory.
- 2) The report in full or in any part should not be published, advertised, photocopied or used for any legal action unless prior permission has been obtained from the Director, REC, Ambedkar Nagar.
- 3) This report is being issued on the specific understanding that REC, Ambedkar Nagar will in no way be involved in any action following the interpretation of the above results.


(Rajesh Kr. Yadav)
Lab. Staff


(Anil Kumar Rai)
Co-Principal Investigator


(Avaneesh Kr. Yadav)
Principal Investigator