



STRUCTURAL ENGINEERING LABORATORY

Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi – 221005

Websites : www.iitbhu.ac.in



Ref. No. Civil/Struct./926(i)/2024-25/ **4183**

Dated: 27.03.2025

TEST REPORTS

Tested for : Executive Engineer
U.P. Rajya Nirman Sahakari Sangh Ltd.
UPRNSS, Prakhand- Baharaich
Srodaya Hospital Shivnagar, Gonda Road, Bahraich

Ref. : 325 / बहो/यू०पी०आर०एन०एस०एस०/2024-25/ dated 24.01.2025


Details of Sample : Bricks " R.B.F. " Mark
& Test Required Compressive Strength

Sub : Testing of Materials for Construction of Family Court at District Shrawasti Judiciary campus.

Sl. No.	Size of Bricks (cm)	Load in (kN)	Compressive Strength (N/mm ²)	Water Absorption (%)	Efflorescence Test
1.	23.0 x 11.0 x 7.0	398	15.7	12.4	Slight
2.	23.0 x 11.0 x 7.0	394	15.6	12.5	Slight
3.	22.9 x 10.9 x 6.9	386	15.5	12.6	Slight
4.	23.0 x 11.0 x 7.0	399	15.8	12.3	Slight
5.	22.9 x 10.9 x 6.9	391	15.7	12.4	Slight

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi.


Technical Superintendent
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005


Teacher In-charge
Testing


Professor-In-Charge
Laboratory
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005