



# STRUCTURAL ENGINEERING LABORATORY


Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi – 221005

Websites : [www.iitbhu.ac.in](http://www.iitbhu.ac.in)



Ref. No. Civil/Struct./926(iii)/2024-25/ 4985

Dated: 27.03.2025

## TEST REPORTS

Tested for : Executive Engineer  
U.P. Rajya Nirman Sahakari Sangh Ltd.  
UPRNSS, Prakhand- Baharaich  
Srvodaya Hospital Shivnagar, Gonda Road, Bahraich

Ref. : 325 / बहो/यूपीआरएनएस/2024-25/ dated 24.01.2025

Details of Sample : Stone Grit 20mm  
Test Required As Under.

Sub : Testing of Materials for Construction of Family Court at District Shrawasti Judiciary campus.

## REPORT

| S. No. | TESTS          | RESULTS          |
|--------|----------------|------------------|
|        |                | Stone Grit 20 mm |
| 1      | Crushing Value | 18.0 %           |

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi

  
Technical Superintendent  
Structural Engineering Laboratory  
Department of Civil Engineering  
Indian Institute of Technology, (B.H.U.)  
Varanasi-221005

  
Teacher In-charge  
Testing

  
Professor-In-Charge  
Laboratory  
Structural Engineering Laboratory  
Department of Civil Engineering  
Indian Institute of Technology, (B.H.U.)  
Varanasi-221005