



J.P.P.W.D. DISTRICT LABORATORY, HARDOI

To, The... कांस्टेबल कमिशनर
पु.मि.आर.एन.एस.एस.
सिमाई 5005 लोहा-22

No... 157/606 PDDWD/15-26

Date 04/8/15

Laboratory Sample No. 157

Name of Material Concrete cube

Sample Submitted By मल्ल कमिशनर

Vide Letter No. 4157/नि.उ.स.ए.ए./2015-26 दिनांक 01/07/25

Location to be used अनपद हट्टाई में बनाई गई छड़ों में कम्प्रेसिव स्ट्रेंथ का परीक्षण

Examined for छिन्नोत्थन में गतिमान दृष्टिकोण का परीक्षण कार्य
compressive strength

Date of Casting

Duration days of soaking

Date of Testing 04/8/15

Mix (As per Information) (उपरोक्त परीक्षण परीक्षण उपकरण का उपयोग करके गठित करने पर)

Bond No. आधारित है

Sl. No.	IDENTIFICATION MARK	TOTAL CRUSHING LOAD IN N/Kg	CROSS SECTIONAL AREA IN MM ²	COMPRESSIVE STRENGTH IN N/ MM ²
1.		540.0 KN.	22500.0 mm ²	24.04 N/mm ²
2.		555.0 KN.	22500.0 mm ²	24.66 N/mm ²
3.		535.0 KN.	22500.0 mm ²	23.77 N/mm ²
AVERAGE 24.14 N/mm ²				

- Note : 1- The result only pertains to the particular sample submitted for the test.
 2- The samples submitted are Destroyed during the test.
 3- The laboratory will not be responsible regarding the interpretation of the results.

Tested By [Signature]

Lab Asst.
 District Lab

Office in Charge
 District Lab
 P.W.D. Hardoi



Date 04/08/25.....

Bond No.

Note : 1- The result only pertains to the particular sample submitted for the test.
2- The samples submitted are Destroyed during the test.
3- The laboratory will not be responsible regarding the interpretation of the results.

OFFICE IN CHARGE
DISTT. LAB P.W.D. HARDOI