Agrawal Associates

Building Planners, Valuer, Surveyor, Structural Designers, Soils & Material Testing etc.

AN ISO 9001 & NABL CERTIFIED CO.

Diwan Bazar (New Colony)
Gorakhpur (U.P.) - 273001
Mobile : 9935436083
email : arjun.agarwal1964@gmail.com
www : soilsurveying.com

Our Clients : GDA, Railway, BSNL, U.P.P.C.L., Jal Nigam, L&T, UPRNN, UPRNSS

Ref. No. ..... Date.....

Dept.	Executive Engineer U.P.R.N.S.S Construction Division Gorakhpur-I	Report No.	AA/720C/2024
		Date of Sample Receiving	19.01.2024
		Date of Test Started	19.01.2024
		Date of Completion	24.01.2024
		Date of Reporting	25.01.2024
		Sample Condition	Good
		Test Performed At	Material Testing Lab
		Discipline	Mechanical
		Group	Building Material
Description	Brick Marka-DKS		
Nos of sample	05 nos		
W.O. No.	1495 / सा0परी0 / 2023–24 / **Dated- 19.01.2024**		
Name of Project	राजकीय प्रशिक्षण संस्थान चारगावा गोरखपुर संस्थान मे 50 सीटर कान्फ्रेन्स हाल का निर्माण कार्य।		

TEST REPORT

S. No.	Test Parameter	Unit	Result	Standard Specification	Test Method
01	Compressive Strength	N/mm²		10.50N/mm² 1st CLASS) & 7.50N/mm² 2nd CLASS	IS: 3495(Part 1):2019
1st			14.80		
2nd			15.20		
3rd			14.90		
			15.30		
			14.90		
	Average		*15.02*		

**End of Report*

AGRAWAL ASSOCIATE DIWAN BAZAR NEW COLONY GORAKHPUR

Note: 1.The results indicated only refer to the tested samples and listed parameters and do not endorse any product
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory
4. The received samples shall be destroyed after 30 days from the date of issue of the test certificate unless specified otherwise.
5. *Calibration (C.T.M) -01/ACS/CTM/2000T-04 is O.K.& all test conducted in presence client.*

Agrawal Associates

Building Planners, Valuer, Surveyor, Structural Designers, Soils & Material Testing etc.

AN ISO 9001 & NABL CERTIFIED CO.

Diwan Bazar (New Colony)
Gorakhpur (U.P.) - 273001
Mobile : 9935436083
email : arjun.agarwal1964@gmail.com
www : soilsurveying.com

Our Clients : GDA, Railway, BSNL, U.P.P.C.L., Jal Nigam, L&T, UPRNN, UPRNSS

Ref. No. .....

Date.....

S. No.	Test Parameter	Unit	Result	Standard Specification	Test Method
2	Water Absorption	%		Max 15% 1st CLASS) & Max 20% 2nd CLASS	IS 3495(Part 2):2019
1st			10.10		
2nd			9.80		
3rd			10.70		
			11.20		
			10.40		
	Average		*10.44*		

Er.S.S.L.Gupta
Director
Ex .Principal
M.P.Polytechnic,GKP

AGRAWAL ASSOCIATES DIWAN BAZAR NEW COLONY GORAKHPUR

Note: 1.The results indicated only refer to the tested samples and listed parameters and do not endorse any product.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory
4. The received samples shall be destroyed after 30 days from the date of issue of the test certificate unless specified otherwise
5. *Calibration (C.T.M) -01/ACS/CTM/2000T-04 is O.K.& all test conducted in pres*

Agrawal Associates

Building Planners, Valuer, Surveyor, Structural Designers, Soils & Material Testing etc.

AN ISO 9001 & NABL CERTIFIED CO.

Diwan Bazar (New Colony)
Gorakhpur (U.P.) - 273001
Mobile : 9935436083
email : arjun.agarwal1964@gmail.com
www : soilsurveying.com

Our Clients : GDA, Railway, BSNL, U.P.P.C.L., Jal Nigam, L&T, UPRNN, UPRNSS

Ref. No. .....

Date.....

Dept.	**Executive Engineer U.P.R.N.S.S Construction Division Gorakhpur-I**	**Report No.**	**AA/720D/2024**
		Date of Sample Receiving	**19.01.2024**
		Date of Test Started	**19.01.2024**
		Date of Completion	**26.01.2024**
		Date of Reporting	**27.01.2024**
		Sample Condition	**Good**
		Test Performed At	**Material Testing Lab**
		Discipline	**Mechanical**
		Group	**Building Material**
Description	**Cement Brand-Prism**		
Nos of sample	01 Bag		
W.O. No.	1495 / सा0परी0 / 2023–24 / **Dated- 19.01.2024**		
Name of Project	राजकीय प्रशिक्षण संस्थान चारगावा गोरखपुर संस्थान मे 50 सीटर कान्फ्रेन्स हाल का निर्माण कार्य।		

S. No.	Test Parameter	Unit	Average Result	Standard Specification	Test Method
				Cement, Grade 43 as per IS 8112: 1989	
1.	Fineness	%	5.00	Max. 10	IS 4031(Part-1):1996
2.	Initial Setting Time	Minutes	59	Min. 30	IS 4031(Part-5):1988
3.	Final Setting Time	Hours	4.50	Max. 10	IS 4031(Part-5):1988
4.	Compressive Strength (After 7 days)	N/mm^2	35.10	Min. 33MPa	IS 4031(Part-15):1991

End of Report

S.S.L. Gupta

Er.S.S.L.Gupta
Director
Ex .Principal
M.P.Polytechnic,GKP

AGRAWAL ASSOCIATES DIWAN BAZAR NEW COLONY GORAKHPUR

Note: 1.The results indicated only refer to the tested samples and listed parameters and do not endorse any product
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory
4. The received samples shall be destroyed after 30 days from the date of issue of the test certificate unless specified otherwise.
5. *Calibration (C.T.M) -01/ACS/CTM/2000T-04 is O.K.& all test conducted in presence client.*

Agrawal Associates

Building Planners, Valuer, Surveyor, Structural Designers, Soils & Material Testing etc.

AN ISO 9001 & NABL CERTIFIED CO.

Diwan Bazar (New Colony)
Gorakhpur (U.P.) - 273001
Mobile : 9935436083
email : arjun.agarwal1964@gmail.com
www : soilsurveying.com

Our Clients : GDA, Railway, BSNL, U.P.P.C.L., Jal Nigam, L&T, UPRNN, UPRNSS

Ref. No. .....

Date.....

Dept.	Executive Engineer U.P.R.N.S.S Construction Division Gorakhpur-I	Report No.	AA/720B/2024
		Date of Sample Receiving	19.01.2024
		Date of Test Started	19.01.2024
		Date of Completion	23.01.2024
		Date of Reporting	24.01.2024
		Sample Condition	Good
		Test Performed At	Material Testing Lab
		Discipline	Mechanical
		Group	Building Material
Description	Coarse Sand		
Quantity of Sample	50kg		
W.O. No.	1495 / सा0परी0 / 2023–24 / **Dated- 19.01.2024**		
Name of Project	राजकीय प्रशिक्षण संस्थान चारगावा गोरखपुर संस्थान मे 50 सीटर कान्फ्रेन्स हाल का निर्माण कार्य।		

S. No.	Test Parameters		Test Method	Requirement As per IS:383-2016	Test Result
1.	Sieve Analysis, materials passing through IS:Sieve, % Passing		IS 2386 (Part-1):1963	Zone-III % Passing	Zone-III % Passing
	a.	10mm		100	100.00
	b.	4.75mm		90-100	100.00
	c.	2.36mm		85-100	86.95
	d.	1.18mm		75-100	77.30
	e.	600micron		60-79	64.68
	f.	300micron		12-40	19.32
	g.	150micron		0-10	4.25
2.	Specific Gravity		IS 2386 (Part-3):1963	---	2.57
3.	Material Finer Than 75micron IS Sieve,%		IS 2386 (Part-1):1963	3.0 Max.	1.28
4.	Water Absorption, % of dry weight		IS 2386 (Part-3):1963	---	0.97

**End of Report*

S.S.L. Gupta

Er.S.S.L.Gupta
Director
Ex. Principal
M.P.Polytechnic,GKP

AGRAWAL ASSOCIATES DIWAN BAZAR NEW COLONY GORAKHPUR

Note: 1.The results indicated only refer to the tested samples and listed parameters and do not endorse any product
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory
4. The received samples shall be destroyed after 30 days from the date of issue of the test certificate unless specified otherwise.
5. *Calibration (C.T.M) -01/ACS/CTM/2000T-04 is O.K.& all test conducted in presence client.*

Agrawal Associates

Building Planners, Valuer, Surveyor, Structural Designers, Soils & Material Testing etc.

AN ISO 9001 & NABL CERTIFIED CO.

Diwan Bazar (New Colony)
Gorakhpur (U.P.) - 273001
Mobile : 9935436083
email : arjun.agarwal1964@gmail.com
www : soilsurveying.com

Our Clients : GDA, Railway, BSNL, U.P.P.C.L., Jal Nigam, L&T, UPRNN, UPRNSS

Ref. No. .....

Date.....

TEST REPORT

Dept.	Executive Engineer U.P.R.N.S.S Construction Division Gorakhpur-I	Report No.	AA/720A/2023
		Date of Sample Receiving	19.01.2024
		Date of Test Started	19.01.2024
		Date of Completion	19.01.2024
		Date of Reporting	20.01.2024
		Sample Condition	Good
		Test Performed At	Material Testing Lab
		Discipline	Mechanical
		Group	Building Material
W.O. No.	1495 / सा०परी० / 2023–24 / **Dated- 19.01.2024**		
Quantity of Sample	03Nos		
Description	Cement Concrete Cube (**M-20**)		
Date of casting	21.12.2023		
Size of cube	150mm x150mm x 150mm		
Name of Project	राजकीय प्रशिक्षण संस्थान चारगावा गोरखपुर संस्थान मे 50 सीटर कान्फ्रेन्स हाल का निर्माण कार्य।		

TEST RESULTS as I.S. Code 516 (Part-1/Sec-1)2021

S. No.	Wt. of Cube in (kg)	Load in KN	Area mm²	Compressive Strength in N/mm²	Average Compressive strength after 28days in N/mm²
1.	8.166	589	22500	26.17	26.17N/mm²
2.	8.172	588	22500	26.13	
3.	8.168	590	22500	26.22	

**End of Report*

S.S.L. Gupta

Er.S.S.L.Gupta
Director
Ex .Principal
M.P.Polytechnic,GKP

AGRAWAL ASSOCIATES DIWAN BAZAR NEW COLONY GORAKHPUR

Note: 1.The results indicated only refer to the tested samples and listed parameters and do not endorse any product
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory
4. The received samples shall be destroyed after 30 days from the date of issue of the test certificate unless specified otherwise.
5. *Calibration (C.T.M) -01/ACS/CTM/2000T-04 is O.K.& all test conducted in presence client.*