



Rajkiya Engineering College, Ambekar Nagar (U.P.) - 224122
Department of Civil Engineering

Ref. No.: REC/CED/300724/18

Date: 30/07/2024

To,

**Executive Engineer,
U.P.R.N.S.S. Ltd.,
Division - Basti (U.P.).**

Subject: Regarding test reports of brick samples.

Dear Sir,

Please find enclosed herewith the test reports of brick samples provided by your representative vide office letter no.: 156/प्रखण्ड-बस्ती/सामग्री परीक्षण/2024-25 Dated: 14/06/2024. The result is only for the samples supplied to the laboratory for testing work.

Enclosure- Test reports as stated above.

Regards

(Avaneesh Kumar Yadav)
P.I. & Assistant Professor
Civil Engineering Department

Copy to following for information and necessary action-

(1) HoD (Civil Engineering)

(Avaneesh Kumar Yadav)
P.I. & Assistant Professor
Civil Engineering Department



Rajkiya Engineering College Ambedkar Nagar (U.P.) - 224122
Department of Civil Engineering

Ref. No.: REC/CED/300724/17

Date: 30/07- /2024

TEST REPORT

Departmental Consultancy No.- CE/1616

Sample: Burnt Clay Brick

Source of Sample: Executive Engineer, U.P.R.N.S.S. Ltd., Division -Basti (U.P.)

Name of Work: जनपद- बस्ती के स्पोर्ट्स स्टेडियम में निर्मित खेल अवस्थापनाओं के जीर्णोद्धार का निर्माण कार्य।

Reference: 156 / प्रखण्ड-बस्ती / सामग्री परीक्षण / 2024-25 Dated: 14/06/2024

Tested for: Physical Properties

Tested as per: IS 1077:1992, IS 3495:1992, IS 5454:1976

No. of Sample: One set only.

Identification Mark: रिठिया


TEST RESULTS


Sr. No.	Frog Mark	Examination of General Quality	Average Compressive Strength (N/mm ²)
1.	रिठिया	The bricks are free from cracks & flaws, have smooth rectangular faces with sharp corners, are uniform in colour.	15.32

Conditions:

- 1) Results given above refer only to the sample(s) supplied. Since the representative sample has not been taken in our presence, we don't take any responsibility regarding the quality of bulk material from which the sample was sent for testing in the laboratory.
- 2) The report in full or in any part should not be published, advertised, photocopied or used for any legal action unless prior permission has been obtained from the Director, REC, Ambedkar Nagar.
- 3) This report is being issued on the specific understanding that REC, Ambedkar Nagar will in no way be involved in any action following the interpretation of the above results.


(Pooja Pathak)
Lab. Staff


(Amit Kumar Rai)
Co-Principal Investigator


(Avaneesh Kr. Yadav)
Principal Investigator