



STRUCTURAL ENGINEERING LABORATORY


Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi – 221005

Websites : www.iitbhu.ac.in



Ref. No. Civil/Struct./927(i)/2024-25/4987

Dated: 27.03.2025

TEST REPORTS

Tested for : Executive Engineer
U.P. Rajya Nirman Sahakari Sangh Ltd.
UPRNSS, Prakhanda- Baharaich
Srvodaya Hospital Shivanagar, Gonda Road, Bahraich

Ref. : 324 / बहो/यूपीआरएनएस/2024-25/ dated 24.01.2025

Details of Sample : Bricks " R.B.F. " Mark
& Test Required Compressive Strength

Sub : Testing of Materials for Construction of 144 Nos. Advocate chambers at District Shrawasti Judiciary campus.

Sl. No.	Size of Bricks (cm)	Load in (kN)	Compressive Strength (N/mm ²)	Water Absorption (%)	Efflorescence Test
1.	22.9 x 10.9 x 6.9	394	15.8	12.4	Slight
2.	23.0 x 11.0 x 7.0	397	15.7	12.5	Slight
3.	22.9 x 10.9 x 6.9	396	15.9	12.1	Slight
4.	23.0 x 11.0 x 7.0	399	15.8	12.2	Slight
5.	22.9 x 10.9 x 6.9	389	15.6	12.7	Slight

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi.


Technical Superintendent
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005


Teacher In-charge
Testing


Professor-In-Charge
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005