



STRUCTURAL ENGINEERING LABORATORY


Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi – 221005

Websites : www.iitbhu.ac.in



Ref. No. Civil/Struct./927(ii)/2024-25/ 4988

Dated: 27.03.2025

TEST REPORTS

Tested for : Executive Engineer
U.P. Rajya Nirman Sahakari Sangh Ltd.
UPRNSS, Prakhanda- Baharaich
Srvodaya Hospital Shivnagar, Gonda Road, Bahraich


Ref. : 324 / बहो/यूपीआरएनएस/2024-25/ dated 24.01.2025


Details of Sample : CC Cube : 150mm x 150mm x 150 mm size
and Test Required Compressive Strength.

Sub : Testing of Materials for Construction of 144 Nos. Advocate chambers at District Shrawasti Judiciary campus.

Sl. No.	Date of Casting and details of sample	Date of Test	Load in (kN)	Compressive Strength (N/mm ²)	Average Compressive Strength in (N/mm ²)
1.	10.02.2025 M-25 Grade		728	32.4	
	-do-	10.03.2025	722	32.1	32.2
	-do-		724	32.2	

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi.


Technical Superintendent
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005


Teacher In-charge
Testing


Professor-In-Charge
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005