



STRUCTURAL ENGINEERING LABORATORY

Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi - 221005

Websites : www.iitbhu.ac.in



Ref. No. Civil/Struct./927(iii)/2024-25/ 4989

Dated: 27.03.2025

TEST REPORTS

Tested for : Executive Engineer
U.P. Rajya Nirman Sahakari Sangh Ltd.
UPRNSS, Prakhand- Baharaich
Srvidaya Hospital Shivanagar, Gonda Road, Bahraich

Ref. : 324 / बहो/यूपीआरएनएस/2024-25/ dated 24.01.2025

Details of Sample : Stone Grit 20mm
Test Required As Under.


Sub : Testing of Materials for Construction of 144 Nos. Advocate chambers at District Shrawasti Judiciary campus.


REPORT

S. No.	TESTS	RESULTS
		Stone Grit 20 mm
1	Crushing Value	17.0 %

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi


Technical Superintendent
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005


Teacher In-charge
Testing


Professor-In-Charge
Laboratory
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005