



STRUCTURAL ENGINEERING LABORATORY


Department of Civil Engineering

Indian Institute of Technology

(Banaras Hindu University)

Varanasi – 221005

Websites : www.iitbhu.ac.in



Ref. No. Civil/Struct./927(iv)/2024-25/ 4990

Dated: 27.03.2025

TEST REPORTS

Tested for : Executive Engineer
U.P. Rajya Nirman Sahakari Sangh Ltd.
UPRNSS, Prakhanda- Baharaich
Srvodaya Hospital Shivanagar, Gonda Road, Bahraich

Ref. : 324 / बहो/यूपीआरनएसएस/2024-25/ dated 24.01.2025

Details of Sample : Fine Aggregate (Coarse Sand)
Test Required As Under


Sub : Testing of Materials for Construction of 144 Nos. Advocate chambers at District Shrawasti
Judiciary campus.

REPORT

S. No.	TESTS	RESULTS
		Fine Aggregate (Coarse Sand)
1.	Sieve Analysis	Cumulative
	I.S. Sieve No.	%
		Retained
	4.75mm	3.4
	2.36 mm	16.2
	1.18 mm	41.4
	600 micron	68.8
2.	Fineness Modulus	3.218
3.	Silt Content	0.2%

Note: The test results are produced here on the basis of the test performed on the samples provided by the client to our Structural Engineering Laboratory, Department of Civil Engineering, IIT (BHU), Varanasi


Technical Superintendent
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005


Teacher In-charge
Testing


Professor-In-Charge
Structural Engineering Laboratory
Department of Civil Engineering
Indian Institute of Technology, (B.H.U.)
Varanasi-221005