Distt. LAB C.D.-1 P.W.D
MORADABAD

To

सहायक अभियन्ता,
उ0प्र0 राज्य निर्माण सहकारी संघ लि0,
निर्माण प्रखण्ड, मुरादाबाद।

No 2907R /Distt. Lab P.W.D/MBD. Dated 25-10-2016

Laboratory Sample No:- प्रपत्र नं 1 (109)

Name of Material :- Gradation (20 mm gmt)

Submitted By :- सहा० अभि० उ०प्र० रा० नि० सह० संघ लि० मुरादाबाद

Vide Letter No. 477/[illegible]/2016-17 dt 17-10-2016

Location used or to be used :- राजकीय महिला शरणालय जनपद मुरादाबाद के भवन निर्माण कार्य

Examination for :- Gradation

RESULTS :- wt. of Sample = 10 kg

S.No.	Sieve Size	Weight Retained (gm) (kg)	Cumulative Retained Weight (kg)	Weight passed (gm) (kg)	Percentage Passing %	J.M.F. Result	Specifle Limit %
	20 mm gmt.						
1	22.4mm	00	00	10 kg	100	ok	100
2	20mm	0.3 kg	0.3 kg	9.7 kg	97	3% [illegible]	100
3	16 mm	9.7 kg	10 kg	00 kg	00	ok	00
			Result - 3.0% [illegible]				
		Note - Allow = 5.0%					

REMARKS :-

(vii) The results pertain to submitted samples only.
(viii) The sample shall be destroyed after Testing or some simple one month form the date of dispatch of the report.
(ix) The sample have consumed during testing.

25/10/2016
Lab Assistent
Dist.-Lab C.D. 1
P.W.D. Moradabad

Assistent Engineer (Lab)
C.D. 1 P.W.D.
Moradabad

Scanned with OKEN Scanner