

TEST REPORT

Date: 13.04.2025

Ref. No: 758-1/NIEL/UPRNSS/2025

Client's Name : Executive Engineer, U.P.R.N.S.S., Nirman Prakhand, Prayagraj

Client's Address : Office of the Executive Engineer, U.P.R.N.S.S., Nirman Prakhand, Prayagraj

Client's Ref. No. : Letter No. 23(1)/EE/N.P.P./F-2025-26, Dated: 04.04.2025

Site/ Work : Construction Work of Sadhan Sahkari Samiti Limited Godam 100 Metric Ton Saraimamrej in District Prayagraj

Material/ Sample : Burnt Clay Bricks

Sample Received On : 05.04.2025

Date of Start of Test : 06.04.2025

Date of Completion of Test : 12.04.2025

TEST RESULT OF BURNT CLAY BRICKS

1. Compressive Strength Test of Burnt Clay Bricks:

Serial No.	Identification Marks on the Specimen	Dimension of the Specimen			C.S. Area of the Specimen (mm ²)	Max. Load Applied (kN)	Compressive Strength (N/mm ²)	Avg. Compressive Strength (N/mm ²)
		Length (mm)	Width (mm)	Height (mm)				
1	AKP	230	111	70	25530.00	400.3	15.68	15.7
2	AKP	228	109	68	24852.00	379.5	15.27	
3	AKP	230	109	70	25070.00	397.1	15.84	
4	AKP	229	108	69	24732.00	410.9	16.61	
5	AKP	230	110	71	25300.00	386.6	15.28	

Test Reference:- IS: 3495 (Part 1) - 2019

Remarks: (i) Samples were submitted by Client in sealed/packed condition. (ii) Tests conducted on supplied samples only.

Checked By:

(Dinesh Kumar Soni)

Lab In-Charge

Notes:

- The results listed refer only to the tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
- The maximum liability of the lab is limited to the total amount charged-expenditure on the project.
- The test samples will be disposed after one month from the date of completion of test unless otherwise specified.
- This report should not be used wholly or in parts for techno-legal purposes and in any advertising media.
- The Company shall not be responsible for giving any legal defense/opinion for appearing in a court of law in connection with the report/test results submitted.
- All disputes subject to Prayagraj Jurisdiction only.

End of Report

Page- 01 of 01

Issued/Approved By:
(Utkarsh Tiwari)
(Authorized Signatory)
Director