



North India Engineers' Lab & Consultants

Shed No.62, Industrial Estate, M.N.N.I.T. Allahabad, Prayagraj (U.P.)
(NABL Accredited Laboratory as per ISO: 17025-2017 & an ISO: 9001-2015 Company)

TEST REPORT

Ref. No: 749/NIEL/UPRNSS/2025

Date: 06.04.2025

Client's Name : Executive Engineer, U.P.R.N.S.S., Nirman Prakhand, Prayagraj

Client's Address : Office of the Executive Engineer, U.P.R.N.S.S., Nirman Prakhand, Prayagraj

Client's Ref. No. : Letter No. 23(1)/EE/N.P.P./F-2025-26, Dated: 04.04.2025

Site/ Work : Construction Work of Sadhan Sahkari Samiti Limited Godam 100 Metric Ton Saraimamrej
in Disriect Prayagraj

Material/ Sample : Hardened Concrete Cube

Date of Casting : 09.03.2025

Date of Receiving : 06.04.2025

Date of Testing : 06.04.2025

TEST RESULT OF HARDENED CONCRETE CUBES

Compressive Strength Test of Hardened Concrete Cubes @ 28 days:


Compressive Test of Hardened Concrete Cubes @ 28 days:							
Serial No.	Identification Mark on the CC Cubes	Weight of Specimen (Kg.)	Dimension of Concrete Cube Specimen (L x B x H) (mm)	C.S. Area of the Specimen (mm ²)	Max. Load Applied (kN)	Compressive Strength (N/mm ²)	Avg. Compressive Strength (MPa)
1	Mark-1	8.149	150.4 x 150.2 x 149.8	22590.08	564.8	25.0	25.5
2	Mark-2	8.067	149.6 x 150.0 x 150.0	22440.00	585.1	26.1	
3	Mark-3	8.201	150.2 x 150.6 x 149.8	22620.12	576.5	25.5	
Type of Machine : Digital/Automatic			Capacity : 2000kN		Date of Calibration : 15.06.2024		

Curing Condition: Field

Appearance of Fractured Faces of Concrete & Type of Fracture: Satisfactory

Test Reference:- IS: 516 (Part I/Sec 1:2021)

Remarks: (i) Cube Specimens were brought in the lab at 28 days in wet condition (ii) Details of Specimens & site were provided by the Client/Contractor.

Checked By: 
(Dinesh Kumar Soni)


Lab In-Charge

Notes:

1. The results listed refer only to the tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
2. The maximum liability of the lab is limited to the total amount charged-expenditure on the project.
3. This report should not be used wholly or in parts for techno-legal purposes and in any advertising media.
4. The Company shall not be responsible for giving any legal defense/opinion for appearing in a court of law in connection with the report/test results submitted.
5. All disputes subject to Prayagraj Jurisdiction only.

End of Report

Page- 01 of 01

Issued/Approved By: 
(Er. Utkarsh Tiwari)
(Authorized Signatory)
Director