



## Department of Civil Engineering

ख्वाजा मुईनुद्दीन चिश्ती भाषा विश्वविद्यालय, लखनऊ, उत्तर प्रदेश (भारत)  
Khwaja Moynuddin Chishti Language University, Lucknow, U.P. (India)  
U.P. STATE GOVERNMENT UNIVERSITY,  
(Recognised Under Section 2(f) & 12(B) of the UGC Act, 1956 & B.Tech. Approved by (AICTE))

Ref. No : 38/FOET/CE/Test/2024-25

Date: 30 /03/2025

To,


Executive Engineer  
UPRNSS LKO-III  
Lucknow (UP)

**Subject : Material Testing Report**

Sir,

As per your letter No- Memo/UPRNSS NPL-III /2024-25 Date -24/02/2025 regarding material testing for construction of Dormitory at District Jail Hardoi. Testing results are as follows:

- 1. Test on 150mm CC cube**  
Average Compressive strength – 25.55 N/mm<sup>2</sup>
- 2. Testing on Bricks**  
Average Compressive strength – 16.15 N/mm<sup>2</sup>
- 3. Mortar**  
Ratio – 1 : 58

  
Mr. Shakeel Ali  
LI/ Lab Incharge

  
Er. K. K. Shah  
HOD/ Subject Incharge  
Department Of Civil Engineering