

District Lab
Provincial Division, P.W.D., Shahjahanpur

Compressive Strength of Bricks

Name of Work :- जनपद शाह-के ग्राम शाबिलिया में पशु पाली-मिलन की स्थापना कार्य-

Name of Contractor :- मे. बलराम शर्मा

Name of J.E :- श्री शुभम मिश्रा

Bond No. :- UPRMSD/अधी. अभिलेख/2023-24/829-3 दि. 28-02-2024

Name of A.E :- श्री राजेंद्र प्रसाद


Material :- श्वेटा ईट - 5 नं०

Tender Cost :-

Date :- 02-08-2023

Test Result

S.No.	Dimension of Brick in Cm	Mark of Brick	Area of Brick (Cm ²)	Load (KN)	Compressive Strength Kg/Cm ²	Average Compressive Strength Kg/Cm ²	Limit As Per IS 1077
1	2	3	4	5	6	7	8
1	23X10X6.5	VERMA	230	348	151.30	-	-
2	23X10X6.5	VERMA	230	346	150.43	-	-
3	23X10X6.5	VERMA	230	345	150.00	-	-
4	23X10X6.5	VERMA	230	347	150.86	-	-
5	23X10X6.5	VERMA	230	346	150.43	150.60	-


Lab Assistant

PD,PWD,Shahjahanpur


Junior Engineer

PD,PWD,Shahjahanpur


Assistant Engineer

PD,PWD,Shahjahanpur