

District Lab
Provincial Division, P.W.D., Shahjahanpur

Compressive Strength of Bricks

Name of Work :- जनपद शाहू के ग्राम सार्वेश में पशु पोलीक्लीनिक की स्थापना कार्य

Name of Contractor :- श्री बलराम रामी

Order No. :- 00PRNSD/अधी-अभिलेख/2023-24/829-डा/दि.28-02-24

Material :- सेंटर 22-5-न

Name of J.E श्री सुभाष सिन्हा

Name of A.E श्री राजेन्द्र प्रसाद

Tender Cost :-

Date :- 02-08-2025

Test Result

S.No.	Dimension of Brick in Cm	Mark of Brick	Area of Brick (Cm ²)	Load (KN)	Compressive Strength Kg/Cm ²	Average Compressive Strength Kg/Cm ²	Limit As Per IS 1077
1	2	3	4	5	6	7	8
1	23X10X6.5	R * K	230	347	150.86	-	-
2	23X10X6.5	R * K	230	345	150.00	-	-
3	23X10X6.5	R * K	230	351	152.60	-	-
4	23X10X6.5	R * K	230	349	151.73	-	-
5	23X10X6.5	R * K	230	346	150.43	151.12	-


Lab Assistant

PD,PWD,Shahjahanpur


Junior Engineer

PD,PWD,Shahjahanpur


Assistant Engineer

PD,PWD,Shahjahanpur