



Ref: Consultancy/Material-Testing/2023-24/ 01-82'A'

Date: 19/01/2024

To,
Executive Engineer,
UPRNS, Construction Division -III
Lucknow


Subject: - Material Testing Report


Sir,

As per your Letter No. 1117/यू पी.आर.एन.एस.सि.न.ल.-III/2023-24 Dated 25.10.2023 regarding material testing for construction of Type II (6 Nos.) residences at District Jail Hardoi U.P.

The test results are as follows: -

S. No.	Materials	Tests	Result
1.	Brick	Average Compressive Strength	15.20 N/mm ²
2.	C.C Cube	Average Compressive Strength	27.60 N/mm ²


Er. Kumar Vanshaj
(Assistant Professor
M. Tech. Structures)
M. KUMAR VANSHAJ
Assistant Professor (M. Tech Structure)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow


Er. Ekta
(Assistant Professor,
M. Tech. Structures)
Er. EKTA
Assistant Professor (M. Tech Structure)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow