

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1138/Civil Engg/2025-26 Date 25/05/2025

NAME OF DEPARTMENT कार्यालय सांख्यिकी इन्जिनियरिंग यू.पी. सरकार, गोरखपुर
मिनिस्ट्री प्रखंड - गाजियाबाद

NAME OF THE TEST Compressive strength of M-150 Ist.
class bricks (गगन गार्डी)

REF. NO. Memo/यू.पी. सरकार, गोरखपुर/गाजियाबाद/2025-26/दिनांक-11/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 class bricks	Comp. strength	150.90 kg/cm ²	जिला कारागार गाजियाबाद
2.	- do -	- do -	151.86 kg/cm ²	मैथिली-टिनीपट्टा-2
3.	- do -	- do -	152.68 kg/cm ²	के सिंगीन काथी
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LL
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

UR
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

La.
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 448/Civil Engg/2025-26

Date 26/05/2025

NAME OF DEPARTMENT कार्गिल इण्डिया लिमिटेड इ.पी.आर.एन.एस.एस.सी. निजी अखण्ड-गाजियाबाद

NAME OF THE TEST Compressive strength of R.C.C. (1:1:2) (Ground floor)
Concrete Cube after 14 days curing (Rat and Column upto 6th)

REF. NO. Memo/इ.पी.आर.एन.एस.एस.सी./गाजियाबाद/2025-26/दिनांक 11/05/25
Date Casting- 11/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15cm C.C. Cube	Compressive strength	189.95 kg/cm ²	जिला कारागार गाजियाबाद
2.	— do —	— do —	190.59 kg/cm ²	मे 2 डिप डिपिप हलाउ-2
3.	— do —	— do —	192.46 kg/cm ²	के निजी अखण्ड
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 444 / Civil Engg / 2025-26 Date 26/05/2025

NAME OF DEPARTMENT कार्यलय सचिवालय इन्जिनियरिंग यू.पी. सरकार, गोरखपुर, उत्तर प्रदेश

NAME OF THE TEST Fitness Modules of Course Band.

REF. NO. Memo / यू.पी. सरकार, गोरखपुर / गाजियाबाद / 2025-26 / दिनांक-11/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Course Band	Fitness Modules	2.96	जिला कारागार गाजियाबाद
2.	— do —	— do —	3.00	मे. सर्विस-ट्रिनिंग केंद्र-2
3.	— do —	— do —	3.02	के. विभाजन कारागार
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad



GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 446 / Civil Engg / 2025-26 Date. 26 / 05 / 2025

NAME OF DEPARTMENT कार्यालय इन्जिनियरी इमिग्रेशन यू.पी. सरकार, गोरखपुर, गोरखपुर

NAME OF THE TEST Impact value of 40mm Stone pit. Appropriate

REF. NO. Memo / यू.पी. सरकार, गोरखपुर / गाजियाबाद / 2025-26 / सिंग 11/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm Stone pit.	Impact value	19.00	जिला कारागार गाजियाबाद
2.	do	do	19.20	मेन्टल डिप्टी क्लब - 2
3.	do	do	19.10	डू निमिष काय
4.				
5.				
6.				

Note 1. Sample Collected by your agency.
2. Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 447/Civil Engg/2025-26

Date 26/05/2025

NAME OF DEPARTMENT कार्यालय आप्रवासी इमिग्रेशन यू.पी. थारुन एक्सप्रेस
निर्माण प्रखण्ड-गाजियाबाद

NAME OF THE TEST Impact value of 20mm stone for 10mm plate.

REF. NO. Memo/यू.पी. थारुन एक्सप्रेस/गाजियाबाद/2025-26/दिनांक 11/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm stone grit	Impact value	21.30	जिला कारागार गाजियाबाद
2.	—do—	—do—	21.35	मे. 2 इपे द्वितीय ब्लॉक - 2
3.	—do—	—do—	21.40	के निर्माण कार्य
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

