



Department of Civil Engineering
ख्वाजा मुईनुद्दीन चिश्ती भाषा विश्वविद्यालय, लखनऊ, उत्तर प्रदेश (भारत)
Khwaja MoINUDDIN CHISHTI Language University, Lucknow, U.P. (India)
U.P. STATE GOVERNMENT UNIVERSITY,
Recognized under Section 3(1) & 3(1)(b) of the U.G. Act, 1956 & R. Tech. Approved by UGC (U)

Ref: 12/FOET/CE/Test/2025-26

Date: 25/05/2025

To,
Executive Engineer,
UPRNSS, Construction Div-III
Lucknow (U.P.)


Subject: - Material Testing Report


Sir,

As per your Letter No. 151/ U.P.R.N.S.S. N.P.L.-III/2025-26 Dated 14.05.2025 regarding material testing for construction of Type- III residence at District Jail, Hardoi.

The test results are as follows: -

S. No.	Material	Tests	Result
1.	150mm CC cube	Average Compressive Strength	26.80 N/mm ²
2.	Bricks	Average Compressive Strength	15.26 pN/mm ²
3.	Mortar	Ratio	1:6


Mr. Shakeel Ali
L/L Lab Incharge


Er. K. K. Shah
HOD/ Subject Incharge
Department Of Civil Engineering



Scanned with OKEN Scanner