

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 449/Civil Engg/2025-26

Date 28/05/2025

NAME OF DEPARTMENT कार्यालय अधिशासी अभियंता यू.पी. आर.एस.एस. निगम प्रमुख गाजियाबाद

NAME OF THE TEST Compressive strength of M-20 (1:1.5:3) (Ground floor)
Cement Concrete Cube after 28 days curing (Roof & Column up to b.L.)

REF. NO. Memo/यू.पी. आर.एस.एस. निगम/गाजियाबाद/2025-26/दिनांक-28/04/25
Cube Casting date - 28/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15cm ³	Comp strength	21.89 kg/cm ²	जिला कारागार गाजियाबाद
2.	— do —	— do —	212.42 kg/cm ²	मे. ओ.एस.सी. के
3.	— do —	— do —	215.24 kg/cm ²	निर्माणा कार्य /
4.				
5.				
6.				

Note 1- Sample Collected by your agency,
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 306 / Civil Engg / 2025-26 Date 08/05/2025

NAME OF DEPARTMENT कार्यालय अधिराष्ट्रीय अभियन्ता प्रमुख, आर. एन. एस. एस. एस. विभाग, प्रखण्ड-गाजियाबाद

NAME OF THE TEST Flexure Modulus of Concrete

REF. NO. Memo/प्रखण्ड आर. एन. एस. एस. एस. / गाजियाबाद / 2025-26 दिनांक 28/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Concrete	Flexure Modulus	3.01	जिला कारागार गाजियाबाद
2.	do	do	3.02	जे. डी. ए. ए. टी. डी. डी.
3.	do	do	3.05	निगीष सड़क
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No.. 307/Civil Engg/2025-26 Date.. 08/05/2025

NAME OF DEPARTMENT काशी लक्ष्मी इंजिनियरिंग यूनिवर्सिटी, गोरखपुर
निर्माण प्रकल्प-गोमियाबाद

NAME OF THE TEST Impact value of 40mm stone grit

Appprizate

REF. NO. Memo/यू.पी.टी.ए.क.एस.एस.एस./गोमियाबाद/2025-26/दिनांक-28/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm stone grit	Impact value	18.95	जिला करगार गोमियाबाद
2.	do	do	19.00	फे. डो.एस.डी. के
3.	do	do	19.05	निर्माण कार्य /
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Sete details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad



GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 208./Civil Engg./2025-26

Date. 08./05/2025

NAME OF DEPARTMENT कार्यालय आचार्य अभियंता यू.पी.आर.एन.एस.एस. निजी प्रखण्ड गजियाबाद

NAME OF THE TEST Impact value of 20mm stone pit.

Appropriate.

REF. NO. Memo/यूपीआरएनएसएस/गजियाबाद/2025-26/दिनांक-28/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm stone pit	Impact value	21.20	जिला कारागार गजियाबाद
2.	do	do	21.30	मे. सो.ख.टी.के
3.	do	do	21.40	निजी कार्यालय
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad