



Department of Civil Engineering
ख्वाजा मुईनुद्दीन चिश्ती भाषा विश्वविद्यालय, लखनऊ, उत्तर प्रदेश (भारत)
Khwaja Moinuddin Chishti Language University, Lucknow, U.P. (India)
U.P. STATE GOVERNMENT UNIVERSITY.
(Recognised Under Section 2(f) & 12(B) of the UGC Act, 1956 & B.Tech. Approved by (AICTE))

Ref. No : 37/FOET/CE/Test/2024-25

Date: 30/03/2025

To,


Executive Engineer
UPRNSS LKO-III
Lucknow (UP)

Subject : Material Testing Report

Sir,

As per your letter No- Memo/UPRNSS NPL-III /2024-25 Date -24/02/2025 regarding material testing for construction of Administrative Block at District jail Hardoi. Testing results are as follows:

- 1. Test on 150mm CC cube**
Average Compressive strength – 25.45 N/mm²
- 2. Testing on Bricks**
Average Compressive strength – 16.35 N/mm²
- 3. Mortar**
Ratio – 1 : 6


Mr. Shakeel Ali
LI/ Lab Incharge


Er. K. K. Shah
HOD/ Subject Incharge
Department Of Civil Engineering