

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 302 / Civil Engrg / 2025-26

Date. 08 / 05 / 2025

NAME OF DEPARTMENT कार्यालय आधिकारी अभियन्ता मृत्पीछार एवं संरक्षण

NAME OF THE TEST Compressive strength of M-150 Test class bricks (क्षीरगुआरी)

REF. NO. Memo/मृत्पीछार एवं संरक्षण/गाजियाबाद/2025-26/दिनांक-02/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 class bricks	Comp. strength	150.77 Kg/cm ²	राजगीर पोखरा का रुई प्रोजेक्ट
2.	— do —	— do —	152.41 Kg/cm ²	भांडवा में बाइपास बाल
3.	— do —	— do —	153.28 Kg/cm ²	के निर्माण कार्य।
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Enng.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Enng.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC CHAZIABAD U.P.

CIVIL ENGRG. DEPT. CAMPUS ROAD, CHAZIABAD, 202002

DATE 28/2 / Civil Engrg / 2020-21

Page no. 100/2020

NAME OF DEPARTMENT *सिविल इंजीनियरिंग*

NAME OF THE TEST *Flexure Modulus of Concrete Road*

REF. NO. *Mecon / 2020 / 100/2020*

S. NO.	NAME OF TEST	NAME OF TEST	DATE	REMARKS
1.	Concrete Road	Flexure Modulus	2/9/20	राजकीय पीएमआरसी बूटि
2.	do	do	2/9/20	प्रयोगशाला के माध्यम से
3.	do	do	2/9/20	डॉ. विनीत शर्मा
4.				
5.				
6.				

1- Sample Collected by your agency.
2- All details are in your letter.

LD
LAB IN CHARGE
CIVIL ENGRG. LAB
Lecturer in Engrg.
Govt. Polytechnic
Chaziabad

LD
LAB IN CHARGE
CIVIL ENGRG. LAB
Lecturer in Engrg.
Govt. Polytechnic
Chaziabad

J. S.
LAB IN CHARGE
CIVIL ENGRG. LAB
Lecturer in Engrg.
Govt. Polytechnic
Chaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No... 304 / Civil Engg / 2025-26

Date... 08 / 05 / 2025

NAME OF DEPARTMENT राजकीय सांख्यिकी विभाग, यू.पी. सरकार, गोरखपुर, निजी प्रखण्ड गाजियाबाद

NAME OF THE TEST Impact value of 40mm stone grit

Aggregate

REF. NO. Mem / यू.पी. सरकार, गोरखपुर, / गाजियाबाद / 2025-26 / दिनांक-02/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm stone grit	Impact value	19.00	राजकीय पॉलिटेक्निक हाई
2.	do	do	19.10	प्रखण्ड माहडवा में बाउरीवाल
3.	do	do	19.20	के निजीव कार्य।
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 305.../Civil Engg/2025-26

Date 08/05/2025

NAME OF DEPARTMENT कार्यालय अधिशासी इंजिनियरिंग यू.पी. आर.ए.ए.एस.एस. निर्माण प्रखण्ड-गाजिआबाद

NAME OF THE TEST Impact value of 20mm stone grit

Aggregate

REF. NO. Memo/पू.पी.आर.ए.एस.एस.एस./गाजिआबाद/2025-26/दिनांक 02/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm stone grit	Impact value	21.00	राजकीय पॉलिटेक्निक हाथी
2.	do	do	21.20	पुद्गल भाण्डवा में बडप्पीवाल
3.	do	do	21.40	के निर्माण कार्य /
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

UR
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

J. da.
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 288 / Civil Engg / 2025-26

Date 07/05/2025

NAME OF DEPARTMENT कार्यलय अधिशासी अभियन्ता प्रौढी आरक्षण संरक्षण व निर्माण प्रमुख - गाजियाबाद

NAME OF THE TEST Compressive strength of M-20 (1:1½:3)

(Ground Floor) Cement Concrete Cube after 28 days Curing.

REF. NO. Memo / प्रौढी आरक्षण संरक्षण व निर्माण प्रमुख / गाजियाबाद / 2025-26 / दिनांक - 02/04/25

Date Casting - 02/04/25 (Raft and column upto G.L.)

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15 cm C.C. Cube	Comp. strength	212.94 Kg/cm ²	राजकीय पंचशाला कुंठ
2.	— do —	— do —	215.49 Kg/cm ²	प्रमोद भाण्डवा ने वाडणीवाल
3.	— do —	— do —	220.26 Kg/cm ²	के निर्माणा कार्य।
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

GL
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LD
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

f. la:
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 290 / Civil Engg / 2025-26

Date 07/05/2025

NAME OF DEPARTMENT कार्यालय आचाराई अभियन्ता प्र. पी. आर. एन. एस्. एस्. / निर्माण प्रकल्प गाजियाबाद

NAME OF THE TEST Compressive strength of M-20 (1:1½:3)

Cement Concrete Cube after 28 days curing (Rec Column)

REF. NO Memo / प्र. पी. आर. एन. एस्. एस्. / गाजियाबाद / 2025-26 / दिनांक 15/03/25
Date Casting 15/03/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	150x150x150mm C.C. Cube	Comp. strength	215.95 Kg/cm ²	राजकीय पापशाला हाई
2.	— do —	— do —	220.59 Kg/cm ²	प्रक्षेत्र माण्डवा में बाइपास
3.	— do —	— do —	224.36 Kg/cm ²	के निर्माण कार्य।
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 289/Civil Engg/2025-26

Date 07/05/2025

NAME OF DEPARTMENT कार्यालय आधिकारी अभियन्ता प्रौद्योगिकी आरक्षण संस्थान संरचना विभाग प्रमुख गान्धीबाद

NAME OF THE TEST Compressive strength of M-20 grade (1:1½:3)

Slab. Intest - Cement Concrete Cube after 28 days Curing.

REF. NO. Memo/प्रौद्योगिकी आरक्षण संस्थान/गान्धीबाद/2025-26/दिनांक 08/04/25
Date Casting - 08/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15cm ³ C.C. Cube	Comp. strength	218.89 Kg/cm ²	राजकीय पौधवाला झील
2.	—do—	—do—	220.52 Kg/cm ²	प्रयोगशाला में परीक्षण
3.	—do—	—do—	225.30 Kg/cm ²	के निर्माण कार्य
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No.. 317/Civil Engg/2025-26

Date.. 14/05/2025

NAME OF DEPARTMENT कार्यालय अधिष्ठात्री अभियन्ता प्र.पी. थारु सन. एस्. एस्. निगम प्रखण्ड-गाजियाबाद

NAME OF THE TEST Compressive strength of M-20 grade (1:1½:3)
(Ground Floor) Rec Top bend Cement Concrete Cube after 28 days Curing.

REF. NO. Memo / प्र.पी. थारु सन. एस्. एस्. / गाजियाबाद / दिनांक- 16/04/25
2025-26


Work testing - 16/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	150/150/150 mm C.C. Cube	Comp. strength	216.94 kg/cm ²	राजकीय पंचशाला इडि
2.	—do—	—do—	219.39 kg/cm ²	पक्षी, भावना मै वाडवनीवा
3.	—do—	—do—	223.21 kg/cm ²	के निजीय कार्य)
4.				
5.				
6.				

Note 1-Sample Collected by your agency.
2-Site details as per your letter.


LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 443 / Civil Engg / 2025-26

Date 26 / 05 / 2025

NAME OF DEPARTMENT कार्यालय अधिशासी अभियन्ता पूरणी प्रखण्ड, गजियाबाद

NAME OF THE TEST Compressive strength of M-20 grade (1:1½:3)

(Ground Floor) slab and beam. Cement concrete cube after 14 days curing


REF. NO. Memo / पूरणी प्रखण्ड, गजियाबाद / 2025-26 / दिनांक 14/05/25
Date Casting - 10/05/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15 cm C.C. Cube	Comp. strength	217.91 kg/cm ²	राजकीय पोथवाला कुंछि
2.	— do —	— do —	220.45 kg/cm ²	पुष्पा भांडवा में पोथवा
3.	— do —	— do —	224.27 kg/cm ²	सीड ह्योर डे निर्माण स्थल
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter.


LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2977/Civil Engg/2024-25

Date 21/01/2025.....

NAME OF DEPARTMENT राष्ट्रीय अद्वितीय अभिरक्षा प्रयोगशाला, पुराण-मिथिलापुराण-गौरीगंगा

NAME OF THE TEST: Impact value of 40mm stone at appropriate

REF. NO. मल०/युवकी०डा०एस०एस०एस०/गान्धिवार्ड/२०५-२६ दिनांक २६/१२/२५

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm stone port aggregate	Impact value	18.95	स्थलगत स्थल - यैराजरीय
2.	— do —	— do —	19.00	वाँकशावा/पैरा मण्डवा(सुजा)
3.	— do —	— do —	19.10	कुलनराएट डैकेरिब/डुहरीकरा जुमी
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghazlabad

Principal
Govt. Polytechnic
Ghaziabad U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2776/Civil Engrg/Deptt-25

Date 21/4/2025

NAME OF DEPARTMENT Civil Engrg. Deptt. Govt. Polytechnic Ghaziabad

NAME OF THE TEST Impact value of concrete slab

REF. NO. None/2776/Civil Engrg/Deptt-25/21/4/2025

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Concrete Slab	Impact value	21.25	Concrete Slab
2.	do	do	21.25	Concrete Slab
3.	do	do	21.25	Concrete Slab
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by agency.
2- Test details as per IS 8112

Lab Incharge
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Lab Officer
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2975/Civil Engg./2024-25

Date 21/01/2025

NAME OF DEPARTMENT कार्यलय अभियांत्रिकी विभाग प्रवीण आर. एन. एस. एस. निमोण प्रखण्ड - गाजियाबाद

NAME OF THE TEST Forenews Modulus of Concrete Road

REF. NO. Memo/प्रवीण आर. एन. एस. एस. /गाजियाबाद/2024-25 दिनांक-26.12.24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>Concrete Road</u>	<u>Forenews Modulus</u>	<u>3.01</u>	<u>परमल-सरासी-देरबली</u>
2.	<u>do</u>	<u>do</u>	<u>3.03</u>	<u>पौधाला/प्रोमबडा (दुर्गा)</u>
3.	<u>do</u>	<u>do</u>	<u>2.95</u>	<u>कुल्लुहा/डेमिरीज/सुदीनरन</u>
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-Site details as per your letter.

LR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

VR
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LR
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2974/Civil Engg./2024-25

Date 21/01/2025.....

NAME OF DEPARTMENT समिलित अभियांत्रिकी विभाग, गुप्तिया, उत्तर प्रदेश

NAME OF THE TEST Compressive strength of mixed Ratio (M-20)

1:1½:3 Coarsest Concrete Cube after 28 days Curing

REF. NO. Memo/प्रमुख अभियंता, गुप्तिया, उत्तर प्रदेश/गुप्तिया/2024-25 दिनांक 15.12.24

Date of Casting - 28/11/2024

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15 cm ³ c.c. Cube	Comp strength	214.65 kg/cm ²	सड़क-सिल्लहवा रोड से रावकीम
2.	— do —	— do —	218.51 kg/cm ²	पोपलवाला/पद्म नहर (खुर्दा)
3.	— do —	— do —	222-26 kg/cm ²	कुल-कशहल के निर्माण/इन्फ्रस्ट्रक्चर कामों में
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by your agency,
2- See details as per your letter.

GR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

W
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

J. S.
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Date... 01/01/2025...

NAME OF THE TEST Impact value of 40mm stone

Aggregate

REF. NO. Memo/2024/28/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm stone Grat Aggregate	Impact Value	18.80	रुस०स्व०रुस०सी० रोड कोयथाला / पुणे नगर
2.	—do—	—do—	18.90	बुलन्दशहर कनिमणि/
3.	—do—	—do—	19.00	कास /
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note: 1-Sample Collected by your agency.
2-Site details as per your letter.

Principal
Govt. Polytechnic
Ghaziabad U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2817.../Civil Engg/2024-25

Date. 01/01/2025

NAME OF DEPARTMENT कार्यालय वाणिज्यी विनिमय क.पी. आर.एम. एस.एस. निमोन प्रखण्ड-गाजियाबाद

NAME OF THE TEST Impact Value of 20mm Stone Joint

Aggregate

REF. NO. Memo/2000/आर.एम.एस.एस./गाजियाबाद/2024-25/दिनांक 28/1/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm Stone Joint	Impact Value	21.40	खसि इलाका एस.सी. से राजडीम
2.	— do —	— do —	21.35	फेधशाला/प्रदेश मंडला (मुन्नी)
3.	— do —	— do —	21.30	कुलनवाहर के निमोन/सुदूरमण
4.	/	/	/	कासि /
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.


LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad


PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Date... 01/01/2025

NAME OF THE TEST Fineness Modulus of coarse sand

REF. NO. १७१०/५०००-२२०२२०/गाजिमावाड/२०२४-२५/दिनांक-२६/१२/२५

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Coarse sand	Fineness modulus	3.02	रुमठ खल ०४२० सी० सौराज कीम
2.	— do —	— do —	3.04	पौषखाला / प्रथम मण्डवा (रुमठी)
3.	— do —	— do —	2.97	डुल-कुशीहर के निकट / डुलकुख
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

Principal
Govt. Polytechnic
Ghaziabad U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2815/Civil Engrg/2024-25

Date 01/01/2025

NAME OF DEPARTMENT कार्यलय अधिशासी अभियन्ता प्रयोगशाला, गुरुग्राम

NAME OF THE TEST Compressive strength of M-150 test class bricks - (सैंपली भाग)

REF. NO. Memo/प्रयोगशाला/गुरुग्राम/2024-25/दिनांक 28/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 test class bricks	Comp. strength	150.91 Kg/cm ²	प्रयोगशाला, गुरुग्राम
2.	— do —	— do —	151.46 Kg/cm ²	प्रयोगशाला, गुरुग्राम
3.	— do —	— do —	153.23 Kg/cm ²	प्रयोगशाला, गुरुग्राम
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2814.../Civil Engg/2024-25

Date. 01/01/2025

NAME OF DEPARTMENT कार्यलय अधिशासी अभियन्ता यू.पी. आर.एन.एस.एस.

NAME OF THE TEST compressive strength of mixed Ratio

1:1½:3 (M-20) Cement Concrete Cube after 28 days Casting

REF. NO. Memo/यू.पी.आर.एन.एस.एस./गाजियाबाद/2024-25/दिनांक 28/10/24

Date Casting-28/09/2024

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15 cm ³ C.C. Cube	Comp. strength	210.48 kg/cm ²	रूपकूल = यूपी. से राजकर्म फायरला/प्रक्षेत्र
2.	— do —	— do —	215.24 kg/cm ²	भरवा (खुर्चा) कुल-प्रक्षेत्र
3.	— do —	— do —	218.12 kg/cm ²	डे निर्माण/रुद्धीकरण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad