

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1727/Civil Engg/2024-25

Date 31/08/2024

NAME OF DEPARTMENT सामाजिक इंजीनियरिंग विभाग, गौरीगढ़, गौरीगढ़

NAME OF THE TEST Impact value of 40mm Stone

aggregate

REF. NO. Memo/गौरीगढ़/सामाजिक इंजीनियरिंग विभाग/गौरीगढ़/2024-25/दिनांक-27/8/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	40mm Stone	Impact value	18.95	राईप द्वीप
2.	do	do	19.16	जनपद बुलन्दाहर
3.	do	do	19.24	के निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

LAB OFFICER
CIVIL ENGG.

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1726/Civil Engg/2024-25

Date. 31/08/2024

NAME OF DEPARTMENT कार्यालय अभियंता निर्माण, प्र. पी. धारपुर, बसपुर

NAME OF THE TEST Impact value of 20mm Stone aggregate.

REF. NO. Memo/प्र. पी. धारपुर, बसपुर/गान्धिमार्ग/2024-25/दिनांक 27/

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm Stone aggregate	Impact value	21.50	राईप ब्रिज
2.	do	do	21.39	जनपद बुलन्दशहर
3.	do	do	21.42	ई निर्माण कार्य
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

LAB OFFICER
CIVIL ENGG.

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1725/Civil Engg/2024-25

Date 31/08/2024

NAME OF DEPARTMENT कार्मिल डिप्लोमा इंजिनियरिंग यू.पी. सरकार, गजियाबाद

NAME OF THE TEST Finest Modular of Coarse Sand

REF. NO. Memo/यूपी सरकार, गजियाबाद/2024-25/दिनांक 27/

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Coarse sand	Finest Modular	3.02	खुदिय द्वीप
2.	—do—	—do—	3.04	जयपुर-बुलन्दशहर
3.	—do—	—do—	2.93	दे निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-Site details are per your letter

LAB INCHARGE
CIVIL ENGG. LAB

LAB OFFICER
CIVIL ENGG.

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

Lab. Incharge Civil Engg.
Govt. Polytechnic
Ghaziabad

Lab. Officer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1723/Civil Engg/2024-25

Date 31/02/2024

NAME OF DEPARTMENT राजस्थान शासनाधीन अभियंता, ग्राम पंचायत, गौरीगंगा, जयपुर

NAME OF THE TEST Compressive strength of 17-20 grade mixed

Ratio 1:1 1/2:3 Cement concrete Cube after 14 days curing

REF. NO. Memo/राजस्थान शासनाधीन अभियंता, गौरीगंगा/2024-25/दि.गो.सं.-27/2/24

Date of Casting - 15/02/2024

S. No.	NAME OF SPEC	NAME OF TEST	RESULT	SITE DETAILS
1.	150x150x150 mm c.c. Cube	Compressive	181.95 kg/cm ²	राजस्थान शासनाधीन अभियंता, गौरीगंगा
2.	— do —	— do —	185.46 kg/cm ²	जयपुर पुलिस स्टेशन
3.	— do —	— do —	187.19 kg/cm ²	3 मिनिट्स राई
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

LAB OFFICER
CIVIL ENGG.

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1724/Civil Engg/2024-25

Date 31/08/2024

NAME OF DEPARTMENT कार्मल इंजिनियरिंग विभाग, गुणोन्धार, रायबरेली जिला, उत्तर प्रदेश

NAME OF THE TEST Compressive strength of M-150 Ist.

class bricks (MODI MARKA)

REF. NO. Memo/गुणोन्धार, रायबरेली जिला, उत्तर प्रदेश/गानिगावाड़/2024-25/दिनांक-27/8/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 Ist class bricks	Comp strength	150.98 Kg/cm ²	टाइप इलीम
2.	—do—	—do—	152.69 Kg/cm ²	नगर ब्रिक्सवाटर
3.	—do—	—do—	154.48 Kg/cm ²	के निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB

LAB OFFICER
CIVIL ENGG.

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 178/Civil Engg/2020-25

Date 21/1/25

NAME OF DEPARTMENT कार्पस प्रौद्योगिकी विभाग यू.पी. सरकार, गोरखपुर

NAME OF THE TEST Flexure Modulus of Concrete

REF. NO. 178/Civil Engg/2020-25/दिनांक-11/01/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Concrete	Flexure Modulus	8.01	प्रियदर्शन कुलकर्णी नेवाहा
2.	— do —	— do —	3.03	हालना धारा (020 बरस) के
3.	— do —	— do —	2.96	निर्मित काम
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

GR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

VR
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2901/Civil Engrg/2024-25

Date 21/04/2025

NAME OF DEPARTMENT Dept. of Civil Engineering

NAME OF THE TEST Impact value of concrete

REF. NO. Model/2024-25/2901/2024-25/21/04/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>200mm cube</u>	<u>Impact value</u>	<u>21.02</u>	<u>Site of work</u>
2.	<u>—ds—</u>	<u>—ds—</u>	<u>21.20</u>	<u>Site of work (200mm) 3</u>
3.	<u>—ds—</u>	<u>—ds—</u>	<u>21.40</u>	<u>Site of work</u>
4.				
5.				
6.				

Note 1- Sample collected by your agency.
2- Site details as per your letter.

Lab Incharge
LAB INCHARGE
CIVIL ENGG. LAB
Govt. Polytechnic
Ghaziabad

Lab Officer
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2782/Civil Engg/2024-25

Date 21/01/2025

NAME OF DEPARTMENT कॉन्सल्टेंसी विभाग, गौरीगढ़, गौरीगढ़, गौरीगढ़

NAME OF THE TEST Impact value of concrete

REF. NO. None/2782/Civil Engg/2024-25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>Concrete</u>	<u>Impact value</u>	<u>18.90</u>	<u>गौरीगढ़, गौरीगढ़, गौरीगढ़</u>
2.	<u>do</u>	<u>do</u>	<u>19.80</u>	<u>गौरीगढ़, गौरीगढ़, गौरीगढ़</u>
3.	<u>do</u>	<u>do</u>	<u>19.10</u>	<u>गौरीगढ़, गौरीगढ़, गौरीगढ़</u>
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

GR
LAB INCHARGE
CIVIL ENGG. LAB

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

VR
LAB OFFICER
CIVIL ENGG.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 1712/Civil Engg/2024-25

Date 21/1/2025

NAME OF DEPARTMENT कॉन्सल्टेंसी विभाग, पब्लिक वर्कस

NAME OF THE TEST Test value of 6 mm stone aggregate.

REF. NO. None/1712/Consultancy/2024-25/दिनांक 11-4-25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>6mm aggregate</u>	<u>Test value</u>	<u>12.90</u>	<u>मिर्जापुरा बसस्टैंड रोड-2</u>
2.	<u>do</u>	<u>do</u>	<u>19.85</u>	<u>डी.एम. रोड (बसस्टैंड) रोड</u>
3.	<u>do</u>	<u>do</u>	<u>19.10</u>	<u>डिप्टी रोड</u>
4.				
5.				
6.				

Note 1- Samples collected by your agency.
2- Site details as per your notes.

Lab Incharge
LAB INCHARGE
CIVIL ENGG. LAB

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Lab Officer
LAB OFFICER
CIVIL ENGG.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No 2721/Civil Engg./2024-25

Date 21/01/2025

NAME OF DEPARTMENT कर्मचारी अधिकाारी अभियन्ता प्रो. पी. डी. एन. सु. ए. एस. २२२०

NAME OF THE TEST Impact value of 20mm stone from Aggarwal

REF. NO. 17/2024/प्र. पी. डी. ए. एस. कर्मचारी अधिकाारी/2024-25/दिनांक 11/01/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm stone grit	Impact value	21.00	जिला कारागार कुल्लुआह 2 ईयर्स-2
2.	—do—	—do—	21.20	ई 12-ग डीवार्ड (02 ब्लॉक) ई
3.	—do—	—do—	21.40	निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-See details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 278/Civil Engg./2020-25

Date 21/01/2025

NAME OF DEPARTMENT सरकारी अभियांत्रिकी विभाग यू.पी. सरकार, गोरखपुर
निर्माण प्रकल्प गोरखपुर

NAME OF THE TEST Forensic Modulus of Concrete Road

REF. NO. Memo/यु.पी. सरकार, गोरखपुर/गोरखपुर/2020-25/दिनांक-11/01/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>Concrete Road</u>	<u>Forensic Modulus</u>	<u>8.01</u>	<u>मिलकगाँव बसस्टैंड केराण-2</u>
2.	<u>— do —</u>	<u>— do —</u>	<u>3.03</u>	<u>हौदगाँव धारा (020 लेख) के</u>
3.	<u>— do —</u>	<u>— do —</u>	<u>2.96</u>	<u>निर्माण कार्य</u>
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

VR
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

for
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Date 21/9/25

NAME OF THE TEST Composite strength of M-10 Id

REF. NO. 100000/2000-2001-2002-2003-2004-2005-2006-2007-2008-2009-2010-2011-2012

Note 1- Sample collected by your agency.
2- Not suitable for your test.

Principal
Govt. Polytechnic
Ghaziabad U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2778/Civil Engg./2024-25

Date 21/01/2025

NAME OF DEPARTMENT सयौवम अधिकाारी अधिमम प्रुकीरुता प्रुकराकरुता
मिमल प्रुकराकरुता

NAME OF THE TEST Compressive strength of Mined Ratio

1:1½:3 (M-20) Cement concrete Cube after 28 days curing

REF. NO. Memo/प्रुकीरुता प्रुकराकरुता/21/मिमल प्रुकराकरुता/2024-25 दिमि-11/01/25

Date Casting - 12/12/2024

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	150mm x 150mm x 150mm C.C. Cube	Comp. strength	215.21 kg/cm ²	मिमल प्रुकराकरुता प्रुकराकरुता मे 45+2
2.	— do —	— do —	218.5 kg/cm ²	312PI प्रुकराकरुता (प्रुकराकरुता) मे
3.	— do —	— do —	221.25 kg/cm ²	मिमल प्रुकराकरुता /
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. SEPT. CONSULTANCY DIVISION TESTING REPORT

Ref. No. 2322/Civil Engg/2024-25

Date 21/1/2025

NAME OF DEPARTMENT सिविल इंजीनियरी विभाग, गुप्तगढ़, झारखंड

NAME OF THE TEST Impact value of concrete slab

REF. NO. Memo/सुदूरपश्चिम प्रदेश/गण्डकी/2024-25/सि.इं. 11/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1	<u>Concrete Slab</u>	<u>Impact value</u>	<u>18.20</u>	<u>जिबरापुर बुद्धापुर में</u>
2	<u>—do—</u>	<u>—do—</u>	<u>19.20</u>	<u>सिन्धुवाला ब्रिज-2 के डिवाइ</u>
3	<u>—do—</u>	<u>—do—</u>	<u>19.00</u>	<u>15 मी (50 फीट) डी सिन्धुवाला</u>
4				
5				
6				

Note 1- Sample collected by your agency.
2- Site details as per your letter.

[Signature]
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

[Signature]
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

[Signature]
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No 2272/Civil Engrg/2024-25

Date 21/01/2025

NAME OF DEPARTMENT कार्यलय अभियांत्रिकी विभाग, मु. पी. पौ. ग. घा. उ. प्र.

NAME OF THE TEST Impact value of 25 mm Stone grit Aggregate.

REF. NO. NAME/पु. पी. पौ. ग. घा. उ. प्र. / नाजिमाबाद / 2024-25 / दिनांक 21/01/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	25mm Stone grit	Impact Value	21.02	निची सराई कुवकहा में
2.	—do—	—do—	21.20	निनीगाँव के पी. डे. सार
3.	—do—	—do—	21.30	125A (62वहा) के निनीगाँव में
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note: Sample Collected by your agency.
2- Give details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.

Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2974 / Civil Engrg / 2024-25

Date 21/01/2025

NAME OF DEPARTMENT *सिटीय प्रसिद्धि विभाग, दिल्ली*

NAME OF THE TEST *Progressive Modulus of Concrete*

REF. NO. *Memo. / 2024-25 / 2974 / 2024-25 / 2974*

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<i>Concrete</i>	<i>Progressive Modulus</i>	<i>2.00</i>	<i>सिटीय प्रसिद्धि विभाग, दिल्ली</i>
2.	<i>do</i>	<i>do</i>	<i>2.02</i>	<i>सिटीय प्रसिद्धि विभाग, दिल्ली</i>
3.	<i>do</i>	<i>do</i>	<i>2.92</i>	<i>सिटीय प्रसिद्धि विभाग, दिल्ली</i>
4.				
5.				
6.				

Note 1- Sample collected by your agency.
2- Give details as per your letter.

Lab
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Lab
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Lab
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 227/ Civil Engg / 2024-25

Date 21/4/2025

NAME OF DEPARTMENT सर्विस इन्फ्रस्ट्रक्चर डिवीजन, गौरीगढ़, गोरखपुर

NAME OF THE TEST Compressive Strength of M-15

Slab bridge (M-15) (B-15)

REF. NO. 11000 / कृषि एवं जल संसाधन विभाग, गौरीगढ़ / 2024-25 / दिनांक 21/4/25

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-15 Slab bridge	Compressive strength	150.77 kg/cm ²	जिला कारागार, गोरखपुर
2.	do	do	152.56 kg/cm ²	निर्माण चरण 439-2 केन्द्र
3.	do	do	154.14 kg/cm ²	12-वर्ष (वर्तमान) इतिहास
4.				
5.				
6.				

Note 1- Samples Collected by your agency,
2- Site details as per your letter.

Lab Incharge
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Lab Officer
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.
CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2969/Civil Engrg/2024-25

Date 21/01/2025

NAME OF DEPARTMENT कार्गिल इन्डिया लिमिटेड, प.पी. इन्डिया-एस्क

NAME OF THE TEST Compressive strength of M20 concrete

1:1½:3 (M20) concrete cubes after 28 days curing.

REF. NO. KPMO/पू.पी. इर-इन्डिया-एस्क/गजियाबाद/2024-25/दिनांक-26/11/24

Date of Casting 29/11/2024

S. No.	NAME OF SPEC	NAME OF TEST	RESULT	SITE DETAILS
1.	<u>15x15x15cm³</u> <u>C.E. Cube</u>	<u>Comp strength</u>	<u>211.86 kg/cm²</u>	<u>जिला कारागार, इर-इन्डिया-एस्क</u>
2.	<u>—do—</u>	<u>—do—</u>	<u>216.68 kg/cm²</u>	<u>निर्माणार्थम यज्ञ-2 केयुआर</u>
3.	<u>—do—</u>	<u>—do—</u>	<u>220.34 kg/cm²</u>	<u>12-नं. (62 ब्लॉक) के निर्माण</u>
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

Lab Incharge
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Lab Officer
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

Principal
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2065/civil Engg/2024-25

Date. 17/10/2024

NAME OF DEPARTMENT कार्मल अभियासी डिनिमला पुंणी धारणवसु

NAME OF THE TEST Compressive strength of M-150

class bricks (MODI MARKA)

REF. NO. Memo/पुंणी धारणवसु/गानिमाबाद/2024-25/दिनांक-10/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 Ist class bricks	Comp. strength	152.72 kg/cm ²	जिला कारागार कुल्लुवाह 2 में टाईप-2 के 12 फी
2.	— do —	— do —	154.12 kg/cm ²	होमगु 02 व लाक का
3.	— do —	— do —	150.94 kg/cm ²	निर्माण कार्य 1
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2061 / Civil Engg / 2024-25

Date 17/10/2024

NAME OF DEPARTMENT *सहायक अभियंता विभाग, गौरीगढ़, गौरीगढ़, गौरीगढ़*

NAME OF THE TEST *Compressive strength of M-20 grade (1:1.5:3) (Cube) concrete after 28 days curing.*

REF. NO. *Memorandum of Understanding / 2024-25 / 17/10/24*
Date of Contracting - 17/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	<i>150mm x 150mm x 150mm C.C. Cube</i>	<i>Comp. strength</i>	<i>142.96 kg/cm²</i>	<i>जिला कारखाना की जगह</i>
2.	<i>— do —</i>	<i>— do —</i>	<i>146.62 kg/cm²</i>	<i>जैयपुर - 2 नं. 12 फीट</i>
3.	<i>— do —</i>	<i>— do —</i>	<i>148.34 kg/cm²</i>	<i>डामर रोड पर का निर्माण करी</i>
4.				
5.				
6.				

Note 1- Sample collected by your agency.
2- Site details as per your letter.

[Signature]
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

[Signature]
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

[Signature]
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2062/Civil Engrg/2024-25

Date 17/10/2024

NAME OF DEPARTMENT कार्यलय अभियांत्रिकी विभाग, पृथ्वी भूखण्ड एवं सर्वेक्षण विभाग, गौज़िआबाद

NAME OF THE TEST Fineness Modulus of Coarse sand.

REF. NO. 112340/2024-25/विभाग-10/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Coarse sand	Fineness Modulus	2.96	जिला कारभार बुखंदवाहर में
2.	do	do	2.98	यदिप-2 के 12 नमूने सावस
3.	do	do	3.00	02 प्लाट का निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer in Engrg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer in Engrg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2063/Civil Engrg/2024-25

Date. 17/10/2024....

NAME OF DEPARTMENT कार्मलय सप्लायसी लिमिटेड थुप्रींक्षारं एम० एस्०

NAME OF THE TEST Impact value of 20mm Stone grit.

Aggregate

REF. NO. Memo/थुप्रींक्षारं एम० एस्० एस्०/गाजियाबाद/2024-25/दिनांक 10/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm Stone grit Aggregate	Impact value	21.00	जिला कारागार बुलंदशहर में
2.	do	do	21.20	थरिप-2 के 12 नं० डायर
3.	do	do	21.40	ब2 ब्लॉक का निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT POLYTECHNIC GHAZIABAD UP

GOVT. ENGINEERING COLLEGE, GHAZIABAD, U.P.

DATE: 12/12/2022

Page No. 1/1

NAME OF THE STUDENT: ABHIR KUMAR

NAME OF THE FATHER: SHRI. RAMESH KUMAR

ROLL NO.:

BRANCH: CIVIL ENGINEERING

STUDENT'S ADDRESS:

STUDY CENTRE:

1. ABHIR KUMAR SHRI. RAMESH KUMAR SHRI. RAMESH KUMAR
2. ABHIR KUMAR SHRI. RAMESH KUMAR SHRI. RAMESH KUMAR
3. ABHIR KUMAR SHRI. RAMESH KUMAR SHRI. RAMESH KUMAR

4.				
5.				
6.				

Signature of Student: ABHIR KUMAR

Signature of Father: SHRI. RAMESH KUMAR

Signature of Lecturer: SHRI. RAMESH KUMAR

Signature of Principal: SHRI. RAMESH KUMAR