

# GOVT. POLYTECHNIC GHAZIABAD U.P.

## CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No... 442/Civil. Engrg/2025-26

Date... 26/05/2025

NAME OF DEPARTMENT कार्यालय अधिशाही अभियन्ता यू.पी. सार-संगर संरक्षक  
संरक्षक निर्माण पुरखर गाजियाबाद

NAME OF THE TEST Compressive strength of M-20 (1:1½:3) Cement  
Concrete Cube after 14 days Curing (on floor) Raft & Column upto  
B.L.

REF. NO. Memo/यू.पी. सार-संगर संरक्षक/गाजियाबाद/2025-26/दिनांक-05/05/25

Date of Casting - 05/05/25

| S. No. | NAME OF SPEC.                        | NAME OF TEST   | RESULT                    | SITE DETAILS               |
|--------|--------------------------------------|----------------|---------------------------|----------------------------|
| 1.     | 15x15x15cm <sup>3</sup><br>C.C. Cube | Comp. strength | 171.68 Kg/cm <sup>2</sup> | जिला कारागार गाजियाबाद में |
| 2.     | — do —                               | — do —         | 195.36 Kg/cm <sup>2</sup> | द्वितीय ब्लॉक-1 के निर्माण |
| 3.     | — do —                               | — do —         | 198.00 Kg/cm <sup>2</sup> | कार्य /                    |
| 4.     |                                      |                |                           |                            |
| 5.     |                                      |                |                           |                            |
| 6.     |                                      |                |                           |                            |

Note 1-Sample Collected by your agency.  
2-site details as per your letter.

LAB INCHARGE  
CIVIL ENGG. LAB  
Lecturer Civil Engrg.  
Govt. Polytechnic  
Ghaziabad

LAB OFFICER  
CIVIL ENGG.  
Lecturer Civil Engrg.  
Govt. Polytechnic  
Ghaziabad

PRINCIPAL  
GOVT. POLYTECHNIC  
GHAZIABAD U.P.  
Principal  
Govt. Polytechnic  
Ghaziabad

# GOVT. POLYTECHNIC GHAZIABAD U.P.

## CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 441 / Civil Engg / 2025-26

Date. 26/05/2025

NAME OF DEPARTMENT कार्यालय सार्वजनिक अभियान्ता मंत्रालय, उत्तर प्रदेश - गजियाबाद

NAME OF THE TEST Impact value of 20mm Stone grit Aggregate

REF. NO. Memo / मू. पी. डी. आर. उत्तर प्रदेश / गजियाबाद / 2025-26 / दिनांक - 05/05/25

| S. No. | NAME OF SPEC.    | NAME OF TEST | RESULT | SITE DETAILS           |
|--------|------------------|--------------|--------|------------------------|
| 1.     | 20mm Stone grit. | Impact value | 21.20  | जिला कारगार गजियाबाद   |
| 2.     | —do—             | —do—         | 21.30  | मै. द्वितीय ब्लाक I डे |
| 3.     | —do—             | —do—         | 21.40  | निर्माण काम /          |
| 4.     |                  |              |        |                        |
| 5.     |                  |              |        |                        |
| 6.     |                  |              |        |                        |

Note 1- Sample Collected by your agency.  
2- Site details as per your letter.

LAB INCHARGE  
CIVIL ENGG. LAB  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

LAB OFFICER  
CIVIL ENGG.  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

PRINCIPAL  
GOVT. POLYTECHNIC  
GHAZIABAD U.P.  
Principal  
Govt. Polytechnic  
Ghaziabad



# GOVT. POLYTECHNIC GHAZIABAD U.P.

## CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No.. 3157/Civil Engg/2025-26

Date... 08/05/2025

NAME OF DEPARTMENT सूचीत अफिशरी अभियन्ता यू.पी. शहर एवं ग्राम

निर्माण प्रकल्प-गाजियाबाद

NAME OF THE TEST Finexx Modulus of concrete Road


REF. NO. Memo/यू.पी. शहर एवं ग्राम/गाजियाबाद/2025-26/दिनांक=05/05/25

| S. No. | NAME OF SPEC. | NAME OF TEST   | RESULT | SITE DETAILS          |
|--------|---------------|----------------|--------|-----------------------|
| 1.     | concrete Road | Finexx Modulus | 2.01   | बिला करगार गाजियाबाद  |
| 2.     | -do-          | -do-           | 3.03   | में द्वितीय वलाक 1 के |
| 3.     | -do-          | -do-           | 2.97   | निर्माण कार्य /       |
| 4.     |               |                |        |                       |
| 5.     |               |                |        |                       |
| 6.     |               |                |        |                       |

Note 1- Sample Collected by your agency.  
2- Site details as per your letter.

  
LAB INCHARGE  
CIVIL ENGG. LAB  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

  
LAB OFFICER  
CIVIL ENGG.  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

  
PRINCIPAL  
GOVT. POLYTECHNIC  
GHAZIABAD U.P.  
Principal  
Govt. Polytechnic  
Ghaziabad

# GOVT. POLYTECHNIC GHAZIABAD U.P.

## CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No... 216 / Civil Engg / 2025-26

Date... 08/05/2025

NAME OF DEPARTMENT कार्यालय अधिशासी अभियन्ता यू.पी. डारुन संस्था संस्था  
निर्माण प्रखण्ड-गाजियाबाद

NAME OF THE TEST Impact value of 40mm stone grit Aggregate.

REF. NO. Memo / यू.पी. डारुन संस्था संस्था / गाजियाबाद / 2025-26 / दिनांक - 05/05/25

| S. No. | NAME OF SPEC.   | NAME OF TEST | RESULT | SITE DETAILS          |
|--------|-----------------|--------------|--------|-----------------------|
| 1.     | 40mm Stone grit | Impact value | 18.80  | जिला कारगार गाजियाबाद |
| 2.     | —do—            | —do—         | 19.00  | वे. द्वितीय ब्लाक/डी  |
| 3.     | —do—            | —do—         | 19.20  | निर्माण कार्य।        |
| 4.     |                 |              |        |                       |
| 5.     |                 |              |        |                       |
| 6.     |                 |              |        |                       |

Note 1- Sample Collected by your agency.  
2- Site details as per your letter.

LAB INCHARGE  
CIVIL ENGG. LAB  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

LAB OFFICER  
CIVIL ENGG.  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

PRINCIPAL  
GOVT. POLYTECHNIC  
GHAZIABAD U.P.  
Principal  
Govt. Polytechnic  
Ghaziabad

# GOVT. POLYTECHNIC GHAZIABAD U.P.

## CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No.. 314 / Civil Engg / 2025-26

Date. 08 / 05 / 2025

NAME OF DEPARTMENT सहायक अभियंता इन्फ्रस्ट्रक्चर एवं संसाधन  
निर्माण प्रकल्प - गाजियाबाद

NAME OF THE TEST Compressive strength of M-150 Ist.  
class bricks (गणन मार्ग)


REF. NO. Memo / शुल्क धारक नं. २२०२२० / गाजियाबाद / २०२५-२६ / दिनांक ०५/०५/२५

| S. No. | NAME OF SPEC.      | NAME OF TEST   | RESULT                    | SITE DETAILS          |
|--------|--------------------|----------------|---------------------------|-----------------------|
| 1.     | M-150 class bricks | Comp. strength | 150.95 kg/cm <sup>2</sup> | बिला कारगार गाजियाबाद |
| 2.     | — do —             | — do —         | 151.75 kg/cm <sup>2</sup> | में द्वितीय ब्लाकडे   |
| 3.     | — do —             | — do —         | 153.26 kg/cm <sup>2</sup> | निर्माण कार्य         |
| 4.     |                    |                |                           |                       |
| 5.     |                    |                |                           |                       |
| 6.     |                    |                |                           |                       |

Note 1- Sample Collected by your agency.  
2- Site details as per your letter.

  
LAB INCHARGE  
CIVIL ENGG. LAB  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

  
LAB OFFICER  
CIVIL ENGG.  
Lecturer Civil Engg.  
Govt. Polytechnic  
Ghaziabad

  
PRINCIPAL  
GOVT. POLYTECHNIC  
GHAZIABAD U.P.  
Principal  
Govt. Polytechnic  
Ghaziabad