



U.P.P.W.D. DISTRICT LABORATORY, UNNAO

To

The सहायक अभियन्ता

उत्तर प्रदेश निर्माण सहायक सचिव

निर्माण प्रकल्प लेखन क्र. 5/158 विकास नगर-लखनऊ

No. 386/Lab/AE/2022-23

Date 15/11/2022

Laboratory Sample No. 37918/PL/AE/11/2022-23

Name of Material

Sample Submitted By शिव

Vide Letter No. श्री. गणेश कुमार (ए)

Location to Be used ए.पी.आर.ए.ए.ए. नि.प्र. लि. - 11/11/2022

Examined for कंक्रीट का ग्रेड का निर्माण कार्य

Bond No. कम्प्रेसिव स्ट्रेंथ

RESULTS :-

Sl. No.	Frog. Mark	Load in Kg.	Compressive Strength Kg./Cm ²
1		37600	151
2		37200	149
3	(N.B.F)	38000	154
4		38400	150
5		37400	153
Average -			151

- Note : 1. The result only pertains to the particular sample Submitted for the test.
2. The samples submitted are Rejected during the test.
3. The laboratory will not be responsible regarding the interpretation of the results.

TESTED BY

Lab Asst.
District Lab

सहायक अभियन्ता
जनप्रतिष्ठान
P.W.D. Unnao

Copy to -

OFFICE INCHARGE
DISTT. LAB P.W.D. UNNAO.

Scanned with OKEN Scanner



P.P.W.D. DISTRICT LABORATORY, UNNAO

To

The सहायक अभियन्ता
आ.प्र. राज्य निर्माण सहायक सचिव
निर्माण प्रखण्ड लखनऊ तृतीय ड/148 विकासगर-लखनऊ

Date 15/11/2022No. 386/lab/AE/2022-23Laboratory Sample No. 379/B/DL/AE/11/2022-23

Name of Material _____

Sample Submitted By श्रीक

Vide Letter No. _____

Location to Be used _____

Examined for _____

Bond No. _____

RESULTS :-

SL No.	Frog. Mark	Load in Kg.	Compressive Strength Kg./ Cm ²
1		37600	151
2		37200	149
3	(N.B.F)	38000	154
4		38400	150
5		37400	153
Average -			151

- Note : 1. The result only pertains to the particular sample Submitted for the test.
 2. The samples submitted are Rejected during the test.
 3. The laboratory will not be responsible regarding the interpretation of the results.

TESTED BY

Lab Asst.
District Lab

सहायक अभियन्ता
 आ.प्र. राज्य निर्माण सहायक सचिव
 निर्माण प्रखण्ड लखनऊ तृतीय ड/148 विकासगर-लखनऊ

Copy to -

OFFICE INCHARGE
 DISTT. LAB P.W.D. UNNAO.

Scanned with CamScanner