

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Date...17/10/2024...

NAME OF THE TEST *Compressive strength of M-20 grade*
1:1½:3 Cement Concrete Cube after 28 days curing.

REF. NO. Memo/मु.पी.डार.अ.सं.सं.०/गजियाबाद/2024-25/दिनांक-
25/07/24
Date of Casting- 25/07/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15 cm ³ C.C. Cube	Comp. strength	207.65 Kg/cm ²	इंटरमीडियट स्कूल विजिलेंस लॉ
2.	— do —	— do —	209.38 Kg/cm ²	शांतिवाड़ा में इंटरमीडियट स्कूल
3.	— do —	— do —	211.19 Kg/cm ²	भवनोत्खनन कार्य में निरीक्षण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note.....

- 1 Sample Collected by your agency.
- 2 Site details as per your letter.

Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

Principal
Govt. Polytechnic
Ghaziabad U.P.

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2074 / Civil Engg / 2024-25

Date. 17/10/2024

NAME OF DEPARTMENT कार्यालय सिविल इंजिनियरिंग विभाग, यू.पी. सरकार, गोरखपुर

NAME OF THE TEST Flexure Modulus of Concrete Road

REF. NO. Memo / यू.पी. सरकार, गोरखपुर / गोरखपुर / 2024-25 / दिनांक 25/10/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Concrete Road	Flexure Modulus	2.98	उत्तरांचल प्रदेश संयुक्त विद्यालय
2.	— do —	— do —	3.00	लौनी गाजियाबाद में इलाहाबाद
3.	— do —	— do —	3.03	भवनो संव बाइपास वल के निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2075/Civil Engg/2024-25

Date. 17/10/2024...

NAME OF DEPARTMENT कार्यालय अधिशासी अभियंता पूर्वी उत्तर प्रदेश राज्य
सिमा क्षेत्र मुख्यालय-गान्धिमार्ग

NAME OF THE TEST Impact value of 20mm stone grit.....

Aggregate

REF. NO. Memo/पूर्वी उत्तर प्रदेश राज्य/गान्धिमार्ग/2024-25/दिनांक 25/07/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	20mm stone grit aggregate	Impact value	18.90	500 मीटर से अधिक दूरी पर स्थित
2.	— do —	— do —	24.80	लोदी गान्धिमार्ग से सावली में
3.	— do —	— do —	21.40	भरतपुर से बाइपास रोड के सिमा क्षेत्र
4.				
5.				
6.				

Note 1- Sample Collected by your agency.
2- Site details as per your letter

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2076/Civil Engrg/2024-25

Date 17/10/2024

NAME OF DEPARTMENT *समीक्षित अधिकांश अभियंता यु.पी. सरकार द्वारा*

NAME OF THE TEST *Compressive strength of M-20 grade*

(1:1.5:3) (C.Slab) Compressive strength of concrete after 14 days curing.

REF. NO. *Memo. (यु.पी. सरकार द्वारा) निर्माण विभाग/2024-25/विनोद-29/09/24*

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	15x15x15cm ³ c.c. cube	Compressive strength	185.87 kg/cm ²	इ.जी.पी.आर. सुन्दर विश्वविद्यालय कैंपस
2.	— do —	— do —	182.44 kg/cm ²	गो.प.प. गौ. वि. शास्त्रीन भवन एवं सहायक भवन
3.	— do —	— do —	190.30 kg/cm ²	इ. निर्माण कार्य
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample collected by your agency.
2- Site details as per your letter.

GR
LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

12
LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

12
PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 277/Civil Engg/2024-25

Date. 17/10/2024

NAME OF DEPARTMENT कार्यालय सापेक्षारी अभियन्ता ग्रुपी आर.एस.एस.एस. निरीक्षण प्रखण्ड-गजियाबाद

NAME OF THE TEST Fineness Modulus of Coarse sand

REF. NO. Memo/ग्रुपी आर.एस.एस.एस./गजियाबाद/2024-25/दिनांक - 29/09/2024

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	Coarse sand	Fineness modulus	2.99	56 शम्भापुरा रोड, मुक्त पिपित, लखनऊ
2.	— do —	— do —	2.96	लौनी गजियाबाद में डामाही में
3.	— do —	— do —	2.97	अवनें रंग बाइलीवाल के निरीक्षण
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1- Sample Collected by your agency.
2- Site details are per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad

GOVT. POLYTECHNIC CHANZIABAD U.P.

CIVIL ENGRG. LAB. REPORT

Roll No. 2439 / Civil Engg / 2024-25

Date 27/09/2024

NAME OF DEPARTMENT *Civil Engineering*

NAME OF THE TEST *Impact value of concrete*

Page No. *1*

REF. NO. *190001 / 2024-25*

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	TEST DETAILS
1.	<i>Concrete</i>	<i>Impact value</i>	<i>21.5</i>	<i>Concrete is strong</i>
2.	<i>do</i>	<i>do</i>	<i>21.5</i>	<i>do</i>
3.	<i>do</i>	<i>do</i>	<i>21.5</i>	<i>do</i>
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

1. Sample Collected by your agency.
2. Test details as per your letter.

[Signature]
LAB IN CHARGE
CIVIL ENGRG. LAB.
GOVT. POLYTECHNIC
CHANZIABAD

[Signature]
LAB OFFICER
CIVIL ENGRG.
GOVT. POLYTECHNIC
CHANZIABAD

[Signature]
PRINCIPAL
GOVT. POLYTECHNIC
CHANZIABAD U.P.
Principal
Govt. Polytechnic
Chanziabad

GOVT. POLYTECHNIC GHAZIABAD U.P.

CIVIL ENGG. DEPTT. CONSULTANCY DIVISION TESTING REPORT

Ref No. 2079/Civil Engrg/2024-25

Date 17/10/2024

NAME OF DEPARTMENT कार्पोरेट डिवीजन, डी.पी.ओ. कार्पोरेट डिवीजन, गुरुकुल गाजियाबाद

NAME OF THE TEST Compressive strength of M-150 Ist class bricks (SRG-MARKA)

REF. NO. Memo/डी.पी.ओ. कार्पोरेट डिवीजन/गाजियाबाद/2024-25/डि.डि. 29/09/24

S. No.	NAME OF SPEC.	NAME OF TEST	RESULT	SITE DETAILS
1.	M-150 Ist class bricks	Comp strength	150.88 kg/cm ²	इंजीनियरिंग सेक्टर, सिविलियन, गुरुकुल गाजियाबाद
2.	— do —	— do —	152.43 kg/cm ²	गाजियाबाद में डी.पी.ओ.
3.	— do —	— do —	153.14 kg/cm ²	भूखण्ड सेक्टर, गुरुकुल गाजियाबाद
4.	/	/	/	/
5.	/	/	/	/
6.	/	/	/	/

Note 1-Sample collected by your agency.
2-Site details as per your letter.

LAB INCHARGE
CIVIL ENGG. LAB
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

LAB OFFICER
CIVIL ENGG.
Lecturer Civil Engrg.
Govt. Polytechnic
Ghaziabad

PRINCIPAL
GOVT. POLYTECHNIC
GHAZIABAD U.P.
Principal
Govt. Polytechnic
Ghaziabad