

Provincial Division, P.W.D., Shahjahanpur

Name of Work :- शांति विद्या प्रसार इत्यादि विद्यालय कुरियाकलां शासनापुत्र मं मयान क्लासि.....

Name of Contractor :- श्री. बाबाजी प्रकाश इंटर प्राइवेट लि.

Name of J.E :- Mr. Anil Kumar

Bond No. : UPRN/SS/अधिक.आदि नं.पहि०./२०२५-२६/१५४-५६.५८-२०-०५-२०२५

Q. Name of A.E :- Dr. Anil Kumar

Material :- सी० सी० लघुत - 3 ज० (वीम/स्टैब)

Tender Cost :-.....

Date :- ...19-11-2025.....

S.No.	Dimension of CC Cube (mm)	Area of CC Cube (mm ²)	Load (KN)	Compressive Strength (Kg/Cm ²)	Average Compressive Strength (Kg/ Cm ²)	Limit As Per IS 456
1	2	3	4	5	6	7
1	150 mm x 150 mm	22500	448	212.44	—	—
2	150 mm x 150 mm	22500	482	214.22	—	—
3	150 mm x 150 mm	22500	476	211.55	212.73	—

[Handwritten signature]

Lab Assistant
PD,PWD,Shahjahanpur

~~Junior Engineer~~

PD,PWD,Shahjahanpur

2

Assistant Engineer
PD,PWD,Shahjahanpur